

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Tue 11/30/2021				(Import) (Export)
0001		2359				SCH - PJ - NY <b>2000 MW 1150 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>07/08/2021</u>	
0456	Continuous	1600				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>NEWBRDGE_345_138_BK_1</b>					FWD	
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>01/12/2021</u>	(Import)
1807	Continuous	2359				SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_1600</b>					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY <b>1900 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_140</b>					FWD	
Tue 06/15/2021	to	Fri 07/23/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>07/19/2021</u>	(Import)
0200	Continuous	0001				SCH - HQ_CEDARS <b>140 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	190 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PORTER__-ROTTRDAM_230_30</b>					FWD	
Thu 07/08/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/04/2021</u>	(Import)
0600	Continuous	1830				<b>CENTRAL EAST - VC</b> <b>2805 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW	
					TTC with All Lines In Service 2975 MW	
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD	
Thu 07/08/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/04/2021</u>	(Import)
0600	Continuous	1300				<b>MOSES SOUTH</b> <b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW	
					TTC with All Lines In Service 3150 MW	
<b>SCH-IMO-NYISO_LIMIT_1400</b>					FWD	
Thu 07/08/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/06/2021</u>	(Import)
0600	Continuous	1300				<b>SCH - OH - NY</b> <b>1700 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1950 MW	
<b>SCH-NYISO-IMO_LIMIT_1200</b>					REV	
Thu 07/08/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/06/2021</u>	(Export)
0600	Continuous	1300				<b>SCH - OH - NY</b> <b>1500 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 1700 MW	
<b>SPRNBK_-W49TH_ST_345_M51</b>					FWD	
Sat 07/17/2021	to	Tue 07/20/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>07/19/2021</u>	(Import)
0127	Continuous	0700				<b>SPR/DUN-SOUTH</b> <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 4600 MW	
<b>DUNWODIE-SHORE_RD_345_Y50</b>					FWD	
Sat 07/17/2021	to	Mon 08/23/2021	<u>UPDATED</u>	<u>by CE</u>	<u>07/21/2021</u>	(Import)
1053	Continuous	2359				<b>CONED - LIPA</b> <b>800 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 1500 MW	
<b>SHORE_RD_345_138_BK_1</b>					FWD	
Sat 07/17/2021	to	Mon 08/23/2021	<u>UPDATED</u>	<u>by CE</u>	<u>07/21/2021</u>	(Import)
1053	Continuous	2359				<b>CONED - LIPA</b> <b>1350 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW	
					TTC with All Lines In Service 1500 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
<b>SHORE RD_345_138_BK 2</b>						(Import)	
Sat 07/17/2021	to	Mon 08/23/2021	<b>UPDATED</b>	<b>by CE</b>	<b>07/21/2021</b>		
1053	Continuous	2359				CONED - LIPA	<b>1350 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1500 MW
<b>NIAGARA 345_230_AT4</b>						(Import)	(Export)
Mon 07/19/2021	to	Fri 07/30/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>06/30/2021</b>		
0500	Continuous	1700				SCH - OH - NY	<b>1900 MW 1400 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW 300 MW
						TTC with All Lines In Service	1950 MW 1700 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						(Import)	(Export)
Mon 07/19/2021	to	Mon 07/19/2021				SCH - NPX_CSC	<b>0 MW 0 MW</b>
0600	Continuous	2300				Impacts Total Transfer Capability	330 MW 330 MW
Work scheduled by: ISONE						TTC with All Lines In Service	330 MW 330 MW
<b>BECK -PACKARD_230_BP76</b>						(Import)	(Export)
Tue 07/20/2021	to	Wed 07/21/2021	<b>FORCED</b>	<b>by IESO</b>	<b>07/22/2021</b>		
2026	Continuous	1830				SCH - OH - NY	<b>1500 MW 1150 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability	450 MW 550 MW
						TTC with All Lines In Service	1950 MW 1700 MW
<b>DUNWODIE_345KV_4</b>						(Import)	
Wed 07/21/2021	to	Fri 07/23/2021	<b>UPDATED</b>	<b>by CE</b>	<b>07/21/2021</b>		
0913	Continuous	2359				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_6</b>						(Import)	
Wed 07/21/2021	to	Fri 07/23/2021	<b>UPDATED</b>	<b>by CE</b>	<b>07/21/2021</b>		
0913	Continuous	2359				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>CEDARS -ROSEMNTB_115_2/22</b>						(Import)	(Export)
Fri 07/23/2021	to	Fri 07/23/2021	<b>CANCELLED</b>	<b>by HQ</b>	<b>07/20/2021</b>		
0700	Continuous	1900				SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Saturday, July 24, 2021 to Monday, January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>DENNISON-ROSEMNTB_115_2/22</b>						
Fri 07/23/2021	to	Fri 07/23/2021	<b>CANCELLED</b>	<b>by HQ</b>	<b>07/20/2021</b>	
0700	Continuous	1900				
Work scheduled by: HQ					SCH - HQ_CEDARS	<b>95 MW</b>
					Impacts Total Transfer Capability	95 MW
					TTC with All Lines In Service	190 MW
						40 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>						
Fri 07/23/2021	to	Fri 07/23/2021	<b>CANCELLED</b>	<b>by HQ</b>	<b>07/20/2021</b>	
0700	Continuous	1900				
Work scheduled by: HQ					SCH - HQ_CEDARS	<b>80 MW</b>
					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW
<b>FRASANX-COOPERS_345_UCC2-41</b>						
Fri 07/23/2021	to	Thu 08/26/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>07/16/2021</b>	
0700	Continuous	1530				
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2500 MW</b>
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
						ARR: 19
<b>MARCY_-FRASANX_345_UCC2-41</b>						
Fri 07/23/2021	to	Thu 08/26/2021	<b>UPDATED</b>	<b>by NYPA</b>	<b>07/16/2021</b>	
0700	Continuous	1530				
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2500 MW</b>
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
						ARR: 19
<b>MILLWOOD-EASTVIEW_345_W99</b>						
Sat 07/24/2021	to	Sat 07/24/2021				
0001	Continuous	0030				
Work scheduled by: ConEd					UPNY CONED	<b>7550 MW</b>
					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
<b>SPRNBK_345KV_RNS5</b>						
Sat 07/24/2021	to	Sat 07/24/2021				
0001	Continuous	0030				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3200 MW</b>
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK_345_W64</b>						
Sat 07/24/2021	to	Sun 07/25/2021				
0001	Continuous	1000				
Work scheduled by: ConEd					UPNY CONED	<b>4350 MW</b>
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>					FWD	
Sun 07/25/2021	to	Sun 07/25/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Import)
0000	Continuous	0200				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>					REV	
Sun 07/25/2021	to	Sun 07/25/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Export)
0000	Continuous	0200				SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	
Sun 07/25/2021	to	Sun 07/25/2021				(Import)
0000		0200				MOSES SOUTH <b>2550 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	REV
Sun 07/25/2021	to	Sun 07/25/2021				(Import) (Export)
0000		0200				SCH - HQ - NY <b>1370 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC2</b>					FWD	
Sun 07/25/2021	to	Sun 07/25/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Import)
0000	Continuous	0200				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>					REV	
Sun 07/25/2021	to	Sun 07/25/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Export)
0000	Continuous	0200				SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>					FWD	
Sun 07/25/2021	to	Sun 07/25/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Import)
0000	Continuous	0200				SCH - HQ - NY <b>1150 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Sun 07/25/2021 to Sun 07/25/2021  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE\_345\_501

Sun 07/25/2021 to Sun 07/25/2021  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_2

Sun 07/25/2021 to Sun 07/25/2021  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

MILLWOOD-EASTVIEW\_345\_W99

Sun 07/25/2021 to Sun 07/25/2021  
0930 Continuous 1000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

SPRNBRK\_\_345KV\_RNS5

Sun 07/25/2021 to Sun 07/25/2021  
0930 Continuous 1000

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

OSWEGO\_-VOLNEY\_\_345\_12

Sat 07/31/2021 to Sat 07/31/2021  
0630 Daily 1500

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

CHAT\_DC\_GC1

Sun 08/01/2021 to Sun 08/01/2021  
0000 Continuous 0200

Work scheduled by: HQ

**UPDATED by HQ 07/06/2021**

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV
Sun 08/01/2021	to	Sun 08/01/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Export)
0000	Continuous	0200				<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD
Sun 08/01/2021	to	Sun 08/01/2021				(Import)
0000		0200				<b>2550 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD REV
Sun 08/01/2021	to	Sun 08/01/2021				(Import) (Export)
0000		0200				<b>1370 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 130 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<b>CHAT_DC_GC2</b>						FWD
Sun 08/01/2021	to	Sun 08/01/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Import)
0000	Continuous	0200				<b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>						REV
Sun 08/01/2021	to	Sun 08/01/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Export)
0000	Continuous	0200				<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>						FWD
Sun 08/01/2021	to	Sun 08/01/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>07/06/2021</u>	(Import)
0000	Continuous	0200				<b>1150 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 350 MW
						TTC with All Lines In Service 1500 MW
<b>BECK -NIAGARA_345_PA302</b>						FWD REV
Mon 08/02/2021	to	Sat 08/07/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/16/2021</u>	(Import) (Export)
0400	Continuous	0030				<b>900 MW 800 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW 900 MW
						TTC with All Lines In Service 1950 MW 1700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
<b>CEDARS__-ROSEMNTB_115_2/22</b>				
Mon 08/02/2021	to	Tue 08/03/2021		
0500	Continuous	1900	SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
<b>DENNISON-ROSEMNTB_115_2/22</b>				
Mon 08/02/2021	to	Tue 08/03/2021		
0500	Continuous	1900	SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>				
Mon 08/02/2021	to	Tue 08/03/2021		
0500	Continuous	1900	SCH - HQ_CEDARS	<b>80 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	110 MW
			TTC with All Lines In Service	190 MW
<b>CEDARS__-ROSEMNTA_115_1/11</b>				
Wed 08/04/2021	to	Thu 08/05/2021		
0500	Continuous	1900	SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
<b>DENNISON-ROSEMNTA_115_1/11</b>				
Wed 08/04/2021	to	Thu 08/05/2021		
0500	Continuous	1900	SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>				
Wed 08/04/2021	to	Thu 08/05/2021		
0500	Continuous	1900	SCH - HQ_CEDARS	<b>80 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	110 MW
			TTC with All Lines In Service	190 MW
<b>KINTIGH_-STA_255_345_SH1-39</b>				
Mon 08/09/2021	to	Sun 08/15/2021		
0500	Continuous	1900	DYSINGER EAST	<b>1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1750 MW
			TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Mon 08/09/2021 to Sun 08/15/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

Mon 08/16/2021 to Sun 08/22/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Mon 08/16/2021 to Sun 08/22/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

Mon 08/16/2021 to Sun 08/22/2021  
0700 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS **80 MW**  
Impacts Total Transfer Capability 110 MW  
TTC with All Lines In Service 190 MW

**NIAGARA\_-STA\_255\_\_345\_NH2**

Mon 08/23/2021 to Fri 08/27/2021 **UPDATED by NYPA 02/19/2021**  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**FITZPTRK-EDIC\_\_345\_FE-1**

Fri 08/27/2021 to Thu 09/02/2021  
0600 Continuous 1830

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

**FITZPTRK-EDIC\_\_345\_FE-1**

Fri 08/27/2021 to Thu 09/02/2021  
0600 Continuous 1830

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FITZPTRK-EDIC 345\_FE-1 & PORTER -ROTTRDAM 230\_30**

Fri 08/27/2021 to Thu 09/02/2021  
0600 1830

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2655 MW**  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 2975 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

Mon 08/30/2021 to Sun 09/05/2021  
0700 Continuous 2300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS **80 MW**  
Impacts Total Transfer Capability 110 MW  
TTC with All Lines In Service 190 MW

**N. SCTLND-LEEDS 345\_93**

Mon 08/30/2021 to Mon 08/30/2021  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**NIAGARA -STA\_255 345\_NH2**

Wed 09/01/2021 to Tue 09/21/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**LAFAYTTE-CLRKSCRN\_345\_4-46**

Wed 09/01/2021 to Wed 09/01/2021  
0630 Daily 1400

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**SPRNBK 345KV\_RS3 & SPRNBK 345KV\_RS4**

Mon 09/06/2021 to Mon 09/06/2021  
0001 0030

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Mon 09/06/2021 to Tue 09/07/2021 **UPDATED by CONED 07/24/2021**  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4  
 Mon 09/06/2021 to Mon 09/06/2021  
 2201 to 2230

Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

ROSETON\_-ROCKTVRN\_345\_311  
 Tue 09/07/2021 to Fri 09/10/2021  
 0700 Continuous 1600

Work scheduled by: CHGE

07/15/2021

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 3415 MW  
 TTC with All Lines In Service 7815 MW

FRASANX-COOPERS\_\_345\_UCC2-41  
 Tue 09/07/2021 to Wed 09/15/2021  
 0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYISO 02/03/2021

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_-FRASANX\_345\_UCC2-41  
 Tue 09/07/2021 to Wed 09/15/2021  
 0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYISO 02/03/2021

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

DUNWODIE\_345KV\_6  
 Wed 09/08/2021 to Wed 09/08/2021  
 0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 06/17/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_8  
 Wed 09/08/2021 to Wed 09/08/2021  
 0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 06/17/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y87  
 Wed 09/08/2021 to Wed 09/08/2021  
 0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 06/17/2021

FWD  
 (Import)  
 UPNY CONED **7260 MW**  
 Impacts Total Transfer Capability 555 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLE-DUNWODIE_345_W90</b>					FWD	
Wed 09/08/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>07/14/2021</u>	(Import)
0001	Continuous	2200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Thu 09/09/2021	to	Thu 09/09/2021				(Import)
0001	Continuous	0500				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_6</b>					FWD	
Sat 09/11/2021	to	Sat 09/11/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>07/14/2021</u>	(Import)
0001	Continuous	1800				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>					FWD	
Sat 09/11/2021	to	Sat 09/11/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>07/14/2021</u>	(Import)
0001	Continuous	1800				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>					FWD	
Sat 09/11/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>07/14/2021</u>	(Import)
0001	Continuous	2200				UPNY CONED <b>7260 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 555 MW
						TTC with All Lines In Service 7815 MW
<b>PANNELL_-CLAY_345_2</b>					FWD	
Mon 09/13/2021	to	Fri 09/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/12/2021</u>	(Import)
0700	Continuous	1530				WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 2250 MW
<b>W49TH_ST_345KV_6</b>					FWD	
Wed 09/15/2021	to	Wed 10/13/2021				(Import)
0001	Continuous	0030				SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_46**

Wed 09/15/2021 to Wed 10/13/2021  
 0001 Continuous 2300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Wed 09/15/2021 to Wed 10/13/2021  
 0001 Continuous 2300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**PORTER\_-ROTTRDAM\_230\_30**

Wed 09/15/2021 to Tue 11/30/2021 **UPDATED by NGRID 05/11/2021**  
 1830 Continuous 1730  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**DUNWODIE\_345KV\_6**

Wed 09/15/2021 to Wed 09/15/2021 **UPDATED by CONED 07/14/2021**  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Wed 09/15/2021 to Wed 09/15/2021 **UPDATED by CONED 07/14/2021**  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Thu 09/16/2021 to Sat 09/18/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **800 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1500 MW

**DUNWODIE\_345KV\_4**

Thu 09/16/2021 to Sat 09/18/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

Thu 09/16/2021 to Sat 09/18/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SHORE\_RD\_345\_138\_BK\_1**

Thu 09/16/2021 to Sat 09/18/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK\_2**

Thu 09/16/2021 to Sat 09/18/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 CONED - LIPA **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**EDIC\_\_\_-N.SCTLND\_345\_14**

Thu 09/16/2021 to Sun 11/14/2021 **UPDATED by NGRID 05/11/2021**  
 0700 Continuous 1730  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_30**

Thu 09/16/2021 to Sun 11/14/2021  
 0700 1730  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **1500 MW**  
 Impacts Total Transfer Capability 1475 MW  
 TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_\_345\_303**

Thu 09/16/2021 to Sun 10/17/2021 **UPDATED by CHGE 09/22/2020**  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 3715 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE\_345KV\_3**

Sat 09/18/2021 to Sat 09/18/2021 **UPDATED by CONED 06/08/2021**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

Sat 09/18/2021 to Tue 09/28/2021  
0001 Continuous 0030

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sat 09/18/2021 to Fri 11/05/2021  
0800 Continuous 1600

UPDATED by PJM 07/23/2021

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**PANNELL\_-CLAY\_\_\_345\_1**

Mon 09/20/2021 to Fri 09/24/2021  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**CLAY\_-EDIC\_\_\_345\_2-15**

Mon 09/20/2021 to Sat 10/16/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**EFISHKIL-WOOD\_ST\_\_345\_F38**

Sat 09/25/2021 to Tue 09/28/2021  
0001 Continuous 1000

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

Sat 09/25/2021 to Tue 09/28/2021  
0001 Continuous 1000

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

UPDATED by NYPA 03/04/2021

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

FWD

Mon 09/27/2021 to Wed 09/29/2021  
0500 Continuous 0459

UPDATED by NYPA 03/04/2021

Work scheduled by: NYPA

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**FIVEMILE-STOLLERD\_345\_29**

Mon 09/27/2021 to Fri 10/08/2021  
0800 Continuous 1400

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**DUNWODIE\_345KV\_3**

FWD

Tue 09/28/2021 to Tue 09/28/2021  
0930 Continuous 1000

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

FWD

Tue 09/28/2021 to Tue 09/28/2021  
0930 Continuous 1000

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**EFISHKIL-WOOD\_ST\_\_345\_F38**

FWD

Wed 09/29/2021 to Wed 09/29/2021  
0130 Continuous 0200

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Wed 09/29/2021 to Wed 09/29/2021  
0130 Continuous 0200

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

FWD

Wed 09/29/2021 to Wed 09/29/2021  
0130 Continuous 0200

UPDATED by CONED 06/08/2021

Work scheduled by: ConEd

UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-STA\_255\_\_345\_SH1-39**

Wed 09/29/2021 to Wed 12/01/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Wed 09/29/2021 to Wed 12/01/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**W49TH\_ST\_345KV\_6**

Wed 10/13/2021 to Wed 10/13/2021  
2230 Continuous 2300

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Thu 10/14/2021 to Thu 10/14/2021  
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Thu 10/14/2021 to Sat 10/16/2021  
0001 Continuous 0100

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Thu 10/14/2021 to Sat 10/16/2021  
0001 Continuous 0100

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_\_345\_W78**

Thu 10/14/2021 to Sat 10/16/2021  
0001 Continuous 0100

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

Thu 10/14/2021 to Sat 11/20/2021  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 06/20/2021**

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**DUNWODIE\_345KV\_5**

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**DUNWODIE\_345KV\_7**

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**SPRNBRK\_-DUNWODIE\_345\_W75**

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**SPRNBRK\_\_345KV\_RNS3**

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**W49TH\_ST\_345KV\_5**

Thu 10/14/2021 to Sun 12/05/2021  
0001 Continuous 0300

Work scheduled by: ConEd

**UPDATED by CONED 06/20/2021**

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**SPRNBRK\_\_345KV\_RS3 & SPRNBRK\_\_345KV\_RS4**

Sat 10/16/2021 to Mon 10/18/2021  
0001 0200

Work scheduled by:

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Sat 10/16/2021 to Sat 10/16/2021  
 0030 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Sat 10/16/2021 to Mon 10/18/2021  
 0101 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Sat 10/16/2021 to Mon 10/18/2021  
 0101 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**LEEDS\_\_-HURLYAVE\_345\_301**

Mon 10/18/2021 to Fri 11/19/2021  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 3715 MW  
 TTC with All Lines In Service 7815 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 10/20/2021 to Thu 10/21/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Wed 10/20/2021 to Thu 10/21/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7580 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 7815 MW

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 11/01/2021 to Fri 12/10/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7680 MW**  
 Impacts Total Transfer Capability 135 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Fri 12/31/2021  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD  
(Import)  
**2050 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2300 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

Mon 11/01/2021 to Fri 12/31/2021  
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

REV  
(Export)  
**1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

**LINDN\_CG-LNDVFT\_\_\_345\_V-3022**

Tue 11/02/2021 to Fri 11/05/2021  
0800 Continuous 1500

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

**MILLWOOD\_345KV\_18**

Wed 11/03/2021 to Wed 11/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

Wed 11/03/2021 to Tue 11/09/2021  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Wed 11/03/2021 to Tue 11/09/2021  
0201 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7560 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 7815 MW

**GOETHALS\_345KV\_5**

Fri 11/12/2021 to Tue 11/16/2021  
0001 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>PORTER__-ROTTRDAM_230_30 &amp; MASSENA_-MARCY_____765_MSU1</b></p> <p>Mon 11/15/2021 to Tue 11/30/2021</p> <p style="padding-left: 40px;">0100 1730</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC <b>1500 MW</b></p> <p>Impacts Total Transfer Capability 1475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>CHATGUAY-MASSENA__765_7040</b></p> <p>Mon 11/15/2021 to Tue 11/30/2021 <b>UPDATED by NYISO 06/03/2021</b></p> <p style="padding-left: 40px;">0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>1550 MW</b></p> <p>Impacts Total Transfer Capability 1600 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>CHATGUAY-MASSENA__765_7040</b></p> <p>Mon 11/15/2021 to Tue 11/30/2021 <b>UPDATED by NYISO 06/03/2021</b></p> <p style="padding-left: 40px;">0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - HQ - NY <b>0 MW 0 MW</b></p> <p>Impacts Total Transfer Capability 1500 MW 1000 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p><b>MARCY_____765_345_AT1</b></p> <p>Mon 11/15/2021 to Tue 11/30/2021 <b>UPDATED by NYISO 06/03/2021</b></p> <p style="padding-left: 40px;">0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>1750 MW</b></p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p> <p style="text-align: center;"><b>ARR: 19</b></p>
<p><b>MARCY_____765_345_AT2</b></p> <p>Mon 11/15/2021 to Tue 11/30/2021 <b>UPDATED by NYISO 06/03/2021</b></p> <p style="padding-left: 40px;">0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p> <p style="text-align: center;"><b>ARR: 19</b></p>
<p><b>MASSENA_-MARCY_____765_MSU1</b></p> <p>Mon 11/15/2021 to Tue 11/30/2021 <b>UPDATED by NYISO 06/03/2021</b></p> <p style="padding-left: 40px;">0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC <b>1670 MW</b></p> <p>Impacts Total Transfer Capability 1305 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>MASSENA_-MARCY_____765_MSU1</b></p> <p>Mon 11/15/2021 to Tue 11/30/2021 <b>UPDATED by NYISO 06/03/2021</b></p> <p style="padding-left: 40px;">0100 Continuous 1859</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1		FWD	REV
		(Import)	(Export)
Mon 11/15/2021	to Tue 11/30/2021		
0100	Continuous 1859		
Work scheduled by: NYPA			
		SCH - HQ - NY	<b>475 MW</b>
		Impacts Total Transfer Capability	1025 MW
		TTC with All Lines In Service	1500 MW
			1000 MW
MASSENA -MARCY 765_MSU1		FWD	
		(Import)	
Mon 11/15/2021	to Tue 11/30/2021		
0100	Continuous 1859		
Work scheduled by: NYPA			
		SCH - HQ_CEDARS	<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040		FWD	
		(Import)	
Mon 11/15/2021	to Tue 11/30/2021		
0100	1859		
Work scheduled by:			
		MOSES SOUTH	<b>500 MW</b>
		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	REV
		(Import)	(Export)
Mon 11/15/2021	to Tue 11/30/2021		
0100	1859		
Work scheduled by:			
		SCH - HQ - NY	<b>850 MW</b>
		Impacts Total Transfer Capability	650 MW
		TTC with All Lines In Service	1500 MW
			1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
		(Import)	
Mon 11/15/2021	to Tue 11/30/2021		
0100	1859		
Work scheduled by:			
		SCH - HQ_CEDARS	<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1		FWD	
		(Import)	
Mon 11/15/2021	to Tue 11/30/2021		
0100	1859		
Work scheduled by:			
		SCH - HQ_CEDARS	<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2		FWD	
		(Import)	
Mon 11/15/2021	to Tue 11/30/2021		
0100	1859		
Work scheduled by:			
		SCH - HQ_CEDARS	<b>90 MW</b>
		Impacts Total Transfer Capability	109 MW
		TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Fri 11/19/2021 to Fri 11/19/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by CE 06/28/2021

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_345\_W78**

Fri 11/19/2021 to Wed 11/24/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CE 06/28/2021

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Sat 11/20/2021 to Wed 11/24/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CONED 06/07/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Sat 11/20/2021 to Wed 11/24/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CONED 06/07/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBK\_345KV\_RS3 & SPRNBK\_345KV\_RS4**

Wed 11/24/2021 to Sun 11/28/2021  
 0001 0200  
 Work scheduled by:

UPDATED by CONED 06/07/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Wed 11/24/2021 to Wed 11/24/2021  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CE 06/28/2021

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Wed 11/24/2021 to Sun 11/28/2021  
 0201 Continuous 0100  
 Work scheduled by: ConEd

UPDATED by CONED 06/07/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>				FWD	
Wed 11/24/2021	to	Sun 11/28/2021		(Import)	
0201	Continuous	0100	SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK_345KV_RNS4</b>				FWD	
Sun 11/28/2021	to	Sun 11/28/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)	
0300	Continuous	0330	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK_-W49TH_ST_345_M52</b>				FWD	
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)	
0300	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>NIAGARA_-PACKARD_230_61</b>				FWD	REV
Tue 11/30/2021	to	Mon 12/06/2021		(Import)	(Export)
0615	Continuous	1900	SCH - OH - NY	<b>1200 MW</b>	<b>1850 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	1100 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
<b>SPRNBRK_345KV_RNS4</b>				FWD	
Wed 12/01/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)	
0130	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>MOSES_-ADIRNDCK_230_MA1</b>				FWD	
Wed 12/01/2021	to	Tue 05/31/2022		(Import)	
0700	Continuous	1300	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>NIAGARA_-STA_255_345_NH2</b>				FWD	
Thu 12/02/2021	to	Thu 01/13/2022		(Import)	
0500	Continuous	1900	DYSINGER EAST	<b>1700 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD
Tue 12/07/2021	to	Fri 12/10/2021			(Import)
0201	Continuous	0200		UPNY CONED	<b>7680 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 135 MW
					TTC with All Lines In Service 7815 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD
Tue 12/07/2021	to	Fri 12/10/2021			(Import)
0201	Continuous	0200		UPNY CONED	<b>7560 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 7815 MW
<b>MILLWOOD_345KV_18</b>					FWD
Tue 12/07/2021	to	Fri 12/10/2021			(Import)
0201	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD
Sun 12/12/2021	to	Tue 12/14/2021	<b>UPDATED</b>	<b>by CE</b>	<b>07/21/2021</b>
2000	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED <b>4350 MW</b>
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD
Sun 12/12/2021	to	Tue 12/14/2021	<b>UPDATED</b>	<b>by CE</b>	<b>07/21/2021</b>
2000	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED <b>7550 MW</b>
					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW
<b>SPRNBK__345KV_RNS5</b>					FWD
Sun 12/12/2021	to	Tue 12/14/2021	<b>UPDATED</b>	<b>by CE</b>	<b>07/21/2021</b>
2000	Continuous	0200			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD
Wed 12/22/2021	to	Thu 12/23/2021			(Import)
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W79</b>				FWD
Wed 12/22/2021	to	Thu 12/23/2021		(Import)
0001	Continuous	0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
<b>FRASER__345_FRASER SVC</b>				FWD
Tue 01/04/2022	to	Mon 02/28/2022	<u>UPDATED</u> <u>by NYPA</u> <u>05/25/2021</u>	(Import)
0700	Continuous	1730	CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW
<b>NIAGARA_-PACKARD__230_61</b>				FWD REV
Mon 01/17/2022	to	Fri 01/21/2022		(Import) (Export)
0615	Continuous	1900	SCH - OH - NY	<b>1200 MW 1850 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 1100 MW 150 MW
				TTC with All Lines In Service 2300 MW 2000 MW
<b>FRASANNX-COOPERS__345_UCC2-41</b>				FWD
Mon 02/07/2022	to	Sat 02/12/2022		(Import)
0700	Continuous	1530	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
<b>ARR: 19</b>				TTC with All Lines In Service 2975 MW
<b>MARCY__-FRASANNX_345_UCC2-41</b>				FWD
Mon 02/07/2022	to	Sat 02/12/2022		(Import)
0700	Continuous	1530	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
<b>ARR: 19</b>				TTC with All Lines In Service 2975 MW
<b>ATHENS__-PLSNTVLY_345_91</b>				FWD
Sat 02/12/2022	to	Wed 02/16/2022	<u>UPDATED</u> <u>by NGRID</u> <u>05/07/2021</u>	(Import)
0600	Continuous	1900	UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>				FWD
Thu 02/17/2022	to	Sat 02/19/2022		(Import)
0001		2200	UPNY CONED	<b>3800 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday, July 24, 2021 to Monday, January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS\_\_\_-PLSNTVLY\_345\_92

Thu 02/17/2022 to Fri 03/25/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

PLSNTVLY\_345KV\_RNS5

Thu 02/17/2022 to Fri 03/25/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD\_ST\_345\_F30

Sun 02/20/2022 to Mon 02/21/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

MARCY\_\_\_-EDIC\_\_\_\_\_345\_UE1-7

Wed 02/23/2022 to Mon 02/28/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19&16

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

NIAGARA\_-STA\_255\_345\_NH2

Sat 02/26/2022 to Mon 02/28/2022  
 0500 Continuous 1900  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

PORTER\_\_\_-ROTTRDAM\_230\_31

Tue 03/01/2022 to Tue 12/31/2030  
 0600 Continuous 2359  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

FRASANX-COOPERS\_345\_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**GOETHALS\_345KV\_5**

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 03/26/2021**

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**LINDEN\_\_-GOETHALS\_230\_A2253**

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 03/26/2021**

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Mon 03/21/2022 to Wed 03/23/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sat 03/26/2022 to Mon 03/28/2022  
0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**ATHENS\_\_-PLSNTVLY\_345\_91**

Sat 03/26/2022 to Sun 05/01/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RNS4**

Sat 03/26/2022 to Sun 05/01/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

-----  
**PLSNTVLY-WOOD\_ST\_345\_F31**

Tue 03/29/2022 to Wed 03/30/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

-----  
**SPRNBK\_-TREMONT\_345\_X28**

Tue 04/05/2022 to Wed 04/06/2022  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 04/06/2022 to Wed 04/06/2022  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

-----  
**EASTVIEW-SPRNBK\_345\_W79**

Wed 04/06/2022 to Thu 04/07/2022  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

-----  
**BUCHAN\_N-EASTVIEW\_345\_W93**

Thu 04/07/2022 to Thu 04/07/2022  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

-----  
**PANNELL\_-CLAY\_345\_1**

Mon 04/11/2022 to Fri 04/15/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Saturday, July 24, 2021 to Monday, January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PORTER - ROTTRDAM_230_30</b>			FWD
Wed 04/13/2022	to	Tue 12/31/2030	(Import)
0600	Continuous	2359	CENTRAL EAST - VC <b>2805 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 170 MW
			TTC with All Lines In Service 2975 MW
<b>PANNELL - CLAY_345_2</b>			FWD
Mon 04/18/2022	to	Fri 04/22/2022	(Import)
0700	Continuous	1530	WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 950 MW
			TTC with All Lines In Service 2250 MW
<b>EDIC - FRASER_345_EF24-40</b>			FWD
Thu 04/21/2022	to	Tue 06/14/2022	(Import)
0700	Continuous	1530	CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>			FWD
Sat 04/23/2022	to	Tue 04/26/2022	(Import)
0001		2200	UPNY CONED <b>3800 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 4015 MW
			TTC with All Lines In Service 7815 MW
<b>PLSNTVLY-WOOD_ST_345_F31</b>			FWD
Wed 04/27/2022	to	Fri 04/29/2022	(Import)
0001	Continuous	2200	UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 3815 MW
			TTC with All Lines In Service 7815 MW
<b>NIAGARA_345_230_AT4</b>			REV
Fri 04/29/2022	to	Fri 04/29/2022	(Export)
0500	Continuous	1700	SCH - OH - NY <b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 250 MW
			TTC with All Lines In Service 2000 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>			FWD
Mon 05/02/2022	to	Mon 05/02/2022	(Import)
0001	Continuous	0030	UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 3465 MW
			TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBK__345_W79</b>				FWD	
Mon 05/02/2022	to	Thu 05/05/2022		(Import)	
0001	Continuous	0200	UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
<b>ROCHESTR-PANNELL__345_RP2</b>				FWD	
Mon 05/02/2022	to	Fri 05/06/2022		(Import)	
0500	Continuous	1700	DYSINGER EAST	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>N. SCTLND-ALPS____345_2</b>				FWD	
Mon 05/02/2022	to	Mon 05/09/2022		(Import)	
0600	Daily	1800	SCH - NE - NY	<b>750 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	650 MW	
			TTC with All Lines In Service	1400 MW	
<b>N. SCTLND-ALPS____345_2</b>				FWD	REV
Mon 05/02/2022	to	Mon 05/09/2022		(Import)	(Export)
0600	Daily	1800	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
<b>SPRNBK_-TREMONT__345_X28</b>				FWD	
Tue 05/03/2022	to	Mon 05/09/2022		(Import)	
0001	Continuous	0300	SPR/DUN-SOUTH	<b>4200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD	
Thu 05/05/2022	to	Thu 05/05/2022		(Import)	
0130	Continuous	0200	UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
<b>HOMRC_NY-MAINS_NY_345_47</b>					
Fri 05/20/2022	to	Fri 05/27/2022	<b>UPDATED</b>	<b>by PJM</b>	<b>11/19/2020</b>
0800	Continuous	1600	SCH - PJ - NY		
Work scheduled by: PJM			Impacts Total Transfer Capability		
			TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR\_NYW-PIERC\_NY\_345\_48

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED** **by PJM** **11/19/2020**  
 0800 Continuous 1600  
 Work scheduled by: PJM  
 SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

PANNELL\_-CLAY\_345\_1

Mon 09/12/2022 to Fri 09/16/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

FRASER\_-GILBOA\_345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

SPRNBRK\_345KV\_RNS5

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED** **by CONED** **09/17/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

SPRNBRK\_-W49TH\_ST\_345\_M51

Mon 09/19/2022 to Wed 09/21/2022 **UPDATED** **by CONED** **09/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

PANNELL\_-CLAY\_345\_2

Mon 09/19/2022 to Fri 09/23/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

SPRNBRK\_345KV\_RNS5

Wed 09/21/2022 to Wed 09/21/2022 **UPDATED** **by CONED** **09/17/2020**  
 2130 Continuous 2200  
 Work scheduled by: ConEd  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,July 24, 2021 to Monday ,January 23, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**SPRNBRK\_-W49TH\_ST\_345\_M51**

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK\_345KV\_RNS5**

Sat 10/01/2022 to Mon 10/17/2022 UPDATED by CONED 08/01/2020  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW