

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
HUDSONP_-FARRAGUT_345_B3402				FWD
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u> by <u>CONED</u> <u>05/26/2021</u>	(Import)
0001	Continuous	2359		2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 2250 MW
<hr/>				
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403				FWD REV
Mon 01/15/2018	to	Tue 11/30/2021		(Import) (Export)
0001		2359		2000 MW 1150 MW
Work scheduled by:				Impacts Total Transfer Capability 250 MW 100 MW
				TTC with All Lines In Service 2250 MW 1250 MW
<hr/>				
MARION_-FARRAGUT_345_C3403				FWD
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u> by <u>CONED</u> <u>05/26/2021</u>	(Import)
0001	Continuous	2359		2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 2250 MW
<hr/>				
STLAWRNC-MOSES____230_L33P				
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u> by <u>IESO</u> <u>07/08/2021</u>	
0456	Continuous	1600		
Work scheduled by: IESO				SCH - OH - NY
				Impacts Total Transfer Capability
				TTC with All Lines In Service
<hr/>				
NEWBRDGE_345_138_BK_1				FWD
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u> by <u>LI</u> <u>01/12/2021</u>	(Import)
1807	Continuous	2359		375 MW
Work scheduled by: LI				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
<hr/>				
SCH-IMO-NYISO_LIMIT_1600				FWD
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u> by <u>IESO</u> <u>05/03/2019</u>	(Import)
0001	Continuous	2359		1900 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 1950 MW
<hr/>				
SCH-HQ_CEDARS-NYISO_LIMIT_140				FWD
Tue 06/15/2021	to	Fri 07/23/2021	<u>EXTENDED</u> by <u>HQ</u> <u>07/19/2021</u>	(Import)
0200	Continuous	0001		140 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 190 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
PORTER__-ROTTRDAM_230_30						(Import)
Thu 07/08/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/04/2021</u>	
0600	Continuous	1830				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW TTC with All Lines In Service 2975 MW
<hr/>						FWD
MOSES__-ADIRNDCK_230_MA2						(Import)
Thu 07/08/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/04/2021</u>	
0600	Continuous	1300				MOSES SOUTH 2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW TTC with All Lines In Service 3150 MW
<hr/>						FWD
SCH-IMO-NYISO_LIMIT_1400						(Import)
Thu 07/08/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/06/2021</u>	
0600	Continuous	1300				SCH - OH - NY 1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW TTC with All Lines In Service 1950 MW
<hr/>						REV
SCH-NYISO-IMO_LIMIT_1200						(Export)
Thu 07/08/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/06/2021</u>	
0600	Continuous	1300				SCH - OH - NY 1500 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW TTC with All Lines In Service 1700 MW
<hr/>						FWD
SPRNBK_-W49TH_ST_345_M51						(Import)
Sat 07/17/2021	to	Tue 07/20/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>07/19/2021</u>	
0127	Continuous	0700				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW TTC with All Lines In Service 4600 MW
<hr/>						FWD
DUNWODIE-SHORE_RD_345_Y50						(Import)
Sat 07/17/2021	to	Mon 08/23/2021	<u>UPDATED</u>	<u>by CE</u>	<u>07/21/2021</u>	
1053	Continuous	2359				CONED - LIPA 800 MW
Work scheduled by: LI						Impacts Total Transfer Capability 700 MW TTC with All Lines In Service 1500 MW
<hr/>						FWD
SHORE_RD_345_138_BK_1						(Import)
Sat 07/17/2021	to	Mon 08/23/2021	<u>UPDATED</u>	<u>by CE</u>	<u>07/21/2021</u>	
1053	Continuous	2359				CONED - LIPA 1350 MW
Work scheduled by: LI						Impacts Total Transfer Capability 150 MW TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Status	By	Effective Date	Zone	Impact	TTC	FWD	REV
SHORE RD_345_138_BK 2	Sat 07/17/2021	Mon 08/23/2021	UPDATED	by CE	07/21/2021	CONED - LIPA	150 MW	1500 MW	(Import)	
	1053	Continuous				Impacts Total Transfer Capability				1350 MW
	Work scheduled by: LI					TTC with All Lines In Service				
NIAGARA_345_230_AT4	Mon 07/19/2021	Fri 07/30/2021	UPDATED	by NYPA	06/30/2021	SCH - OH - NY	50 MW	1950 MW	(Import)	(Export)
	0500	Continuous				Impacts Total Transfer Capability				1900 MW 1400 MW
	Work scheduled by: NYPA					TTC with All Lines In Service				1950 MW 1700 MW
BECK__-PACKARD_230_BP76	Tue 07/20/2021	Wed 07/21/2021	FORCED	by IESO	07/22/2021	SCH - OH - NY	450 MW	1950 MW	(Import)	(Export)
	2026	Continuous				Impacts Total Transfer Capability				1500 MW 1150 MW
	Work scheduled by: IESO					TTC with All Lines In Service				1950 MW 1700 MW
DUNWODIE_345KV_4	Wed 07/21/2021	Fri 07/23/2021	UPDATED	by CE	07/21/2021	SPR/DUN-SOUTH	800 MW	4600 MW	(Import)	
	0913	Continuous				Impacts Total Transfer Capability				3800 MW
	Work scheduled by: LI					TTC with All Lines In Service				
DUNWODIE_345KV_6	Wed 07/21/2021	Fri 07/23/2021	UPDATED	by CE	07/21/2021	SPR/DUN-SOUTH	800 MW	4600 MW	(Import)	
	0913	Continuous				Impacts Total Transfer Capability				3800 MW
	Work scheduled by: LI					TTC with All Lines In Service				
CEDARS__-ROSEMNTB_115_2/22	Fri 07/23/2021	Fri 07/23/2021	CANCELLED	by HQ	07/20/2021	SCH - HQ_CEDARS	95 MW	190 MW	(Import)	(Export)
	0700	Continuous				Impacts Total Transfer Capability				95 MW 40 MW
	Work scheduled by: HQ					TTC with All Lines In Service				190 MW 40 MW
DENNISON-ROSEMNTB_115_2/22	Fri 07/23/2021	Fri 07/23/2021	CANCELLED	by HQ	07/20/2021	SCH - HQ_CEDARS	95 MW	190 MW	(Import)	(Export)
	0700	Continuous				Impacts Total Transfer Capability				95 MW 40 MW
	Work scheduled by: HQ					TTC with All Lines In Service				190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_80					FWD	
Fri 07/23/2021	to	Fri 07/23/2021	CANCELLED	by HQ	07/20/2021	(Import)
0700	Continuous	1900				80 MW
Work scheduled by: HQ					SCH - HQ_CEDARS	110 MW
					Impacts Total Transfer Capability	190 MW
					TTC with All Lines In Service	190 MW
FRASANX-COOPERS_345_UCC2-41					FWD	
Fri 07/23/2021	to	Thu 08/26/2021	UPDATED	by NYPA	07/16/2021	(Import)
0700	Continuous	1530				2500 MW
Work scheduled by: NYPA					ARR: 19	CENTRAL EAST - VC
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
MARCY_-FRASANX_345_UCC2-41					FWD	
Fri 07/23/2021	to	Thu 08/26/2021	UPDATED	by NYPA	07/16/2021	(Import)
0700	Continuous	1530				2500 MW
Work scheduled by: NYPA					ARR: 19	CENTRAL EAST - VC
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Sat 07/24/2021	to	Sat 07/24/2021				(Import)
0001	Continuous	0030				7550 MW
Work scheduled by: ConEd					UPNY CONED	265 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	7815 MW
SPRNBK_345KV_RNS5					FWD	
Sat 07/24/2021	to	Sat 07/24/2021				(Import)
0001	Continuous	0030				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	1400 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK_345_W64					FWD	
Sat 07/24/2021	to	Sun 07/25/2021				(Import)
0001	Continuous	1000				4350 MW
Work scheduled by: ConEd					UPNY CONED	3465 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	7815 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD	
Sun 07/25/2021	to	Sun 07/25/2021				(Import)
0001	Continuous	2359				0 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	660 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501					FWD
Sun 07/25/2021	to	Sun 07/25/2021			(Import)
0001	Continuous	2359		SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability
					TTC with All Lines In Service
NEWBRDGE_345_138_BK_2					FWD
Sun 07/25/2021	to	Sun 07/25/2021			(Import)
0001	Continuous	2359		SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI					Impacts Total Transfer Capability
					TTC with All Lines In Service
MILLWOOD-EASTVIEW_345_W99					FWD
Sun 07/25/2021	to	Sun 07/25/2021			(Import)
0930	Continuous	1000		UPNY CONED	7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
SPRNBRK__345KV_RNS5					FWD
Sun 07/25/2021	to	Sun 07/25/2021			(Import)
0930	Continuous	1000		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
OSWEGO__VOLNEY__345_12					FWD
Sat 07/31/2021	to	Sat 07/31/2021			(Import)
0630	Daily	1500		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability
					TTC with All Lines In Service
CHAT_DC_GC1					FWD
Sun 08/01/2021	to	Sun 08/01/2021	UPDATED	by HQ	07/25/2021
0000	Continuous	0200			(Import)
Work scheduled by: HQ					MOSES SOUTH
					Impacts Total Transfer Capability
					TTC with All Lines In Service
CHAT_DC_GC1					FWD
Sun 08/01/2021	to	Sun 08/01/2021	UPDATED	by HQ	07/25/2021
0000	Continuous	0200			(Export)
Work scheduled by: HQ					SCH - HQ - NY
					Impacts Total Transfer Capability
					TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start	End	Update	By	Date	Zone	FWD (Import)	REV (Export)
CHAT_DC_GC1 & CHAT_DC_GC2	Sun 08/01/2021 0000	to Sun 08/01/2021 0200				MOSES SOUTH	2550 MW	
Work scheduled by:						Impacts Total Transfer Capability	600 MW	
Work scheduled by:						TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1 & CHAT_DC_GC2	Sun 08/01/2021 0000	to Sun 08/01/2021 0200				SCH - HQ - NY	1370 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	130 MW	1000 MW
Work scheduled by:						TTC with All Lines In Service	1500 MW	1000 MW
CHAT_DC_GC2	Sun 08/01/2021 0000	to Sun 08/01/2021 0200	<u>UPDATED</u>	<u>by HQ</u>	<u>07/25/2021</u>	MOSES SOUTH	2850 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ						TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2	Sun 08/01/2021 0000	to Sun 08/01/2021 0200	<u>UPDATED</u>	<u>by HQ</u>	<u>07/25/2021</u>	SCH - HQ - NY		500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability		500 MW
Work scheduled by: HQ						TTC with All Lines In Service		1000 MW
SCH-HQ-NYISO_LIMIT_1150	Sun 08/01/2021 0000	to Sun 08/01/2021 0200	<u>UPDATED</u>	<u>by HQ</u>	<u>07/25/2021</u>	SCH - HQ - NY	1150 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	350 MW	
Work scheduled by: HQ						TTC with All Lines In Service	1500 MW	
BECK -NIAGARA 345_PA302	Mon 08/02/2021 0400	to Sat 08/07/2021 0030	<u>UPDATED</u>	<u>by NYPA</u>	<u>07/16/2021</u>	SCH - OH - NY	900 MW	800 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW	900 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1950 MW	1700 MW
CEDARS -ROSEMNTB_115_2/22	Mon 08/02/2021 0500	to Tue 08/03/2021 1900				SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW	0 MW
Work scheduled by: HQ						TTC with All Lines In Service	190 MW	40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
DENNISON-ROSEMNTB_115_2/22				
Mon 08/02/2021	to	Tue 08/03/2021		
0500	Continuous	1900	SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80				
Mon 08/02/2021	to	Tue 08/03/2021	FWD	
0500	Continuous	1900	(Import)	
Work scheduled by: HQ			SCH - HQ_CEDARS	80 MW
			Impacts Total Transfer Capability	110 MW
			TTC with All Lines In Service	190 MW
CEDARS__-ROSEMNTA_115_1/11				
Wed 08/04/2021	to	Thu 08/05/2021	FWD	REV
0500	Continuous	1900	(Import)	(Export)
Work scheduled by: HQ			SCH - HQ_CEDARS	95 MW 40 MW
			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
DENNISON-ROSEMNTA_115_1/11				
Wed 08/04/2021	to	Thu 08/05/2021	FWD	REV
0500	Continuous	1900	(Import)	(Export)
Work scheduled by: HQ			SCH - HQ_CEDARS	95 MW 40 MW
			Impacts Total Transfer Capability	95 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80				
Wed 08/04/2021	to	Thu 08/05/2021	FWD	
0500	Continuous	1900	(Import)	
Work scheduled by: HQ			SCH - HQ_CEDARS	80 MW
			Impacts Total Transfer Capability	110 MW
			TTC with All Lines In Service	190 MW
KINTIGH_-STA_255_345_SH1-39				
Mon 08/09/2021	to	Sun 08/15/2021	FWD	
0500	Continuous	1900	(Import)	
Work scheduled by: NYPA			DYSINGER EAST	1400 MW
			Impacts Total Transfer Capability	1750 MW
			TTC with All Lines In Service	3150 MW
NIAGARA_-KINTIGH_345_NS1-38				
Mon 08/09/2021	to	Sun 08/15/2021	FWD	
0500	Continuous	1900	(Import)	
Work scheduled by: NYPA			DYSINGER EAST	1400 MW
			Impacts Total Transfer Capability	1750 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KINTIGH_-STA_255__345_SH1-39

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 08/16/2021 to Sun 08/22/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Mon 08/16/2021 to Sun 08/22/2021
0700 Continuous 2300

Work scheduled by: HQ

FWD

(Import)

SCH - HQ_CEDARS **80 MW**
Impacts Total Transfer Capability 110 MW
TTC with All Lines In Service 190 MW

NIAGARA_-STA_255__345_NH2

Mon 08/23/2021 to Fri 08/27/2021 **UPDATED by NYPA 02/19/2021**
0500 Continuous 1900

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

FITZPTRK-EDIC____345_FE-1

Fri 08/27/2021 to Thu 09/02/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

FITZPTRK-EDIC____345_FE-1

Fri 08/27/2021 to Thu 09/02/2021
0600 Continuous 1830

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT **4800 MW**
Impacts Total Transfer Capability 450 MW
TTC with All Lines In Service 5250 MW

FITZPTRK-EDIC____345_FE-1 & PORTER_-ROTTDAM_230_30

Fri 08/27/2021 to Thu 09/02/2021
0600 Continuous 1830

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **2655 MW**
Impacts Total Transfer Capability 320 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_80

Mon 08/30/2021 to Sun 09/05/2021
0700 Continuous 2300

Work scheduled by: HQ

FWD
(Import)
SCH - HQ_CEDARS **80 MW**
Impacts Total Transfer Capability 110 MW
TTC with All Lines In Service 190 MW

N. SCTLND-LEEDS_345_93

Mon 08/30/2021 to Mon 08/30/2021
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

NIAGARA_-STA_255_345_NH2

Wed 09/01/2021 to Tue 09/21/2021
0500 Continuous 1900

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1400 MW**
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

LAFAYTTE-CLRKSCRN_345_4-46

Wed 09/01/2021 to Wed 09/01/2021
0630 Daily 1400

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4

Mon 09/06/2021 to Mon 09/06/2021
0001 0030

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Mon 09/06/2021 to Tue 09/07/2021 **UPDATED by CONED 07/24/2021**
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4

Mon 09/06/2021 to Mon 09/06/2021
2201 2230

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311

Tue 09/07/2021 to Fri 09/10/2021
 0700 Continuous 1600
 Work scheduled by: CHGE

07/15/2021

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 3415 MW
 TTC with All Lines In Service 7815 MW

FRASANX-COOPERS_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYISO 02/03/2021

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANX_345_UCC2-41

Tue 09/07/2021 to Wed 09/15/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYISO 02/03/2021

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

DUNWODIE_345KV_6

Wed 09/08/2021 to Wed 09/08/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by CONED 06/17/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Wed 09/08/2021 to Wed 09/08/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by CONED 06/17/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

WOOD_ST_-PLSNTVLE_345_Y87

Wed 09/08/2021 to Wed 09/08/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by CONED 06/17/2021

FWD
 (Import)
 UPNY CONED **7260 MW**
 Impacts Total Transfer Capability 555 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLE-DUNWODIE_345_W90

Wed 09/08/2021 to Wed 09/15/2021
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CONED 07/14/2021

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45					FWD
Thu 09/09/2021	to	Thu 09/09/2021			(Import)
0001	Continuous	0500		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_6					FWD
Sat 09/11/2021	to	Sat 09/11/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>07/14/2021</u>
0001	Continuous	1800		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8					FWD
Sat 09/11/2021	to	Sat 09/11/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>07/14/2021</u>
0001	Continuous	1800		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD
Sat 09/11/2021	to	Wed 09/15/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>07/14/2021</u>
0001	Continuous	2200		UPNY CONED	7260 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 555 MW
					TTC with All Lines In Service 7815 MW
PANNELL_-CLAY____345_2					FWD
Mon 09/13/2021	to	Fri 09/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/12/2021</u>
0700	Continuous	1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW
W49TH_ST_345KV_6					FWD
Wed 09/15/2021	to	Wed 10/13/2021			(Import)
0001	Continuous	0030		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
E13THSTA-FARRAGUT_345_46					FWD
Wed 09/15/2021	to	Wed 10/13/2021			(Import)
0001	Continuous	2300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Wed 09/15/2021 to Wed 10/13/2021
 0001 Continuous 2300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PORTER_-ROTTDAM_230_30

Wed 09/15/2021 to Tue 11/30/2021 **UPDATED by NGRID 05/11/2021**
 1830 Continuous 1730
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

DUNWODIE_345KV_6

Wed 09/15/2021 to Wed 09/15/2021 **UPDATED by CONED 07/14/2021**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Wed 09/15/2021 to Wed 09/15/2021 **UPDATED by CONED 07/14/2021**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Thu 09/16/2021 to Sat 09/18/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **800 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

DUNWODIE_345KV_4

Thu 09/16/2021 to Sat 09/18/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Thu 09/16/2021 to Sat 09/18/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1				FWD
Thu 09/16/2021	to	Sat 09/18/2021		(Import)
0001	Continuous	0200	CONED - LIPA	1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2				FWD
Thu 09/16/2021	to	Sat 09/18/2021		(Import)
0001	Continuous	0200	CONED - LIPA	1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
EDIC___-N.SCTLND_345_14				FWD
Thu 09/16/2021	to	Sun 11/14/2021	<u>UPDATED</u> <u>by NGRID</u> <u>05/11/2021</u>	(Import)
0700	Continuous	1730	CENTRAL EAST - VC	1670 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 1305 MW
				TTC with All Lines In Service 2975 MW
EDIC___-N.SCTLND_345_14 & PORTER___-ROTTRDAM_230_30				FWD
Thu 09/16/2021	to	Sun 11/14/2021		(Import)
0700		1730	CENTRAL EAST - VC	1500 MW
Work scheduled by:				Impacts Total Transfer Capability 1475 MW
				TTC with All Lines In Service 2975 MW
HURLYAVE-ROSETON__345_303				FWD
Thu 09/16/2021	to	Sun 10/17/2021	<u>UPDATED</u> <u>by CHGE</u> <u>09/22/2020</u>	(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 3715 MW
				TTC with All Lines In Service 7815 MW
DUNWODIE_345KV_3				FWD
Sat 09/18/2021	to	Sat 09/18/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/08/2021</u>	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLE-DUNWODIE_345_W89				FWD
Sat 09/18/2021	to	Tue 09/28/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/08/2021</u>	(Import)
0001	Continuous	0030	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021 **UPDATED** **by PJM** **07/23/2021**
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL_-CLAY_345_1

Mon 09/20/2021 to Fri 09/24/2021
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

CLAY_-EDIC_345_2-15

Mon 09/20/2021 to Sat 10/16/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

EFISHKIL-WOOD_ST_345_F38

Sat 09/25/2021 to Tue 09/28/2021 **UPDATED** **by CONED** **06/08/2021**
 0001 Continuous 1000
 Work scheduled by: ConEd

UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

WOOD_ST_-PLSNTVLE_345_Y86

Sat 09/25/2021 to Tue 09/28/2021 **UPDATED** **by CONED** **06/08/2021**
 0001 Continuous 1000
 Work scheduled by: ConEd

UPNY CONED **7210 MW**
 Impacts Total Transfer Capability 605 MW
 TTC with All Lines In Service 7815 MW

KINTIGH_-STA_255_345_SH1-39

Mon 09/27/2021 to Wed 09/29/2021 **UPDATED** **by NYPA** **03/04/2021**
 0500 Continuous 0459
 Work scheduled by: NYPA

DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 09/27/2021 to Wed 09/29/2021 **UPDATED** **by NYPA** **03/04/2021**
 0500 Continuous 0459
 Work scheduled by: NYPA

DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Mon 09/27/2021 to Fri 10/08/2021
 0800 Continuous 1400
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

DUNWODIE_345KV_3

Tue 09/28/2021 to Tue 09/28/2021 UPDATED by CONED 06/08/2021
 0930 Continuous 1000
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Tue 09/28/2021 to Tue 09/28/2021 UPDATED by CONED 06/08/2021
 0930 Continuous 1000
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD_ST_345_F38

Wed 09/29/2021 to Wed 09/29/2021 UPDATED by CONED 06/08/2021
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLE-DUNWODIE_345_W89

Wed 09/29/2021 to Wed 09/29/2021 UPDATED by CONED 06/08/2021
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

WOOD_ST_-PLSNTVLE_345_Y86

Wed 09/29/2021 to Wed 09/29/2021 UPDATED by CONED 06/08/2021
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7210 MW**
 Impacts Total Transfer Capability 605 MW
 TTC with All Lines In Service 7815 MW

KINTIGH_-STA_255_345_SH1-39

Wed 09/29/2021 to Wed 12/01/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

Wed 09/29/2021 to Wed 12/01/2021
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1400 MW**
 Impacts Total Transfer Capability 1750 MW
 TTC with All Lines In Service 3150 MW

W49TH_ST_345KV_6

Wed 10/13/2021 to Wed 10/13/2021
 2230 Continuous 2300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MILLWOOD-EASTVIEW_345_W85

Thu 10/14/2021 to Thu 10/14/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_72

Thu 10/14/2021 to Sat 10/16/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 10/14/2021 to Sat 10/16/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK__345_W78

Thu 10/14/2021 to Sat 10/16/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_7

Thu 10/14/2021 to Sat 11/20/2021 **UPDATED by CONED 06/20/2021**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5				FWD
Thu 10/14/2021	to	Sun 11/28/2021		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_7				FWD
Thu 10/14/2021	to	Sun 11/28/2021		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_-DUNWODIE_345_W75				FWD
Thu 10/14/2021	to	Sun 11/28/2021		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK__345KV_RNS3				FWD
Thu 10/14/2021	to	Sun 11/28/2021		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_5				FWD
Thu 10/14/2021	to	Sun 12/05/2021	UPDATED by CONED 06/20/2021	(Import)
0001	Continuous	0300	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4				FWD
Sat 10/16/2021	to	Mon 10/18/2021		(Import)
0001		0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by:				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W85				FWD
Sat 10/16/2021	to	Sat 10/16/2021		(Import)
0030	Continuous	0100	UPNY CONED	7550 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 265 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71

Sat 10/16/2021 to Mon 10/18/2021
 0101 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Sat 10/16/2021 to Mon 10/18/2021
 0101 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

LEEDS__-HURLYAVE_345_301

Mon 10/18/2021 to Fri 11/19/2021
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 10/20/2021 to Thu 10/21/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

RAMAPO__-BUCHAN_N_345_Y94

Wed 10/20/2021 to Thu 10/21/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7580 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W97

Mon 11/01/2021 to Fri 12/10/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 **UPDATED by IESO 05/03/2019**
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 2300 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 100 MW
2000 MW

LINDN_CG-LNDVFT___345_V-3022

Tue 11/02/2021 to Fri 11/05/2021
0800 Continuous 1500

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJM_VFT 0 MW 0 MW
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

MILLWOOD_345KV_18

Wed 11/03/2021 to Wed 11/10/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W98

Wed 11/03/2021 to Tue 11/09/2021
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 7680 MW
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 11/03/2021 to Tue 11/09/2021
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 7560 MW
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 7815 MW

GOETHALS_345KV_5

Fri 11/12/2021 to Tue 11/16/2021
0001 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

PORTER_-ROTTDAM_230_30 & MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
0100 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC 1500 MW
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
CHATGUAY-MASSENA 765_7040							
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>		
0100	Continuous	1859				MOSES SOUTH	1550 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040							
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>		
0100	Continuous	1859				SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MARCY 765_345_AT1							
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>		
0100	Continuous	1859				MOSES SOUTH	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
							ARR: 19
MARCY 765_345_AT2							
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>		
0100	Continuous	1859				MOSES SOUTH	1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
							ARR: 19
MASSENA -MARCY 765_MSU1							
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>		
0100	Continuous	1859				CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1305 MW
						TTC with All Lines In Service	2975 MW
MASSENA -MARCY 765_MSU1							
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>		
0100	Continuous	1859				MOSES SOUTH	500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1							
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>		
0100	Continuous	1859				SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED by NYISO 06/03/2021	(Import)	
0100	Continuous	1859		SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MASSENA_-MARCY_765_MSU1 & CHATGUAY-MASSENA_765_7040				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	(Export)
0100		1859		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES_230_L33P & MASSENA_-MARCY_765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES_230_L33P & MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MILLWOOD-EASTVIEW_345_W85				FWD	
Fri 11/19/2021	to	Fri 11/19/2021	UPDATED by CE 06/28/2021	(Import)	
0001	Continuous	0030		UPNY CONED	7550 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	265 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W78					FWD	
Fri 11/19/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CE</u>	<u>06/28/2021</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
DUNWODIE-MOTTHAVN_345_72					FWD	
Sat 11/20/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/07/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Sat 11/20/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/07/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					FWD	
Wed 11/24/2021	to	Sun 11/28/2021				(Import)
0001		0200				3800 MW
Work scheduled by:					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD-EASTVIEW_345_W85					FWD	
Wed 11/24/2021	to	Wed 11/24/2021	<u>UPDATED</u>	<u>by CE</u>	<u>06/28/2021</u>	(Import)
0130	Continuous	0200				7550 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Wed 11/24/2021	to	Sun 11/28/2021				(Import)
0201	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3					FWD	
Wed 11/24/2021	to	Sun 11/28/2021				(Import)
0201	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4				FWD
Sun 11/28/2021	to	Sun 11/28/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)
0300	Continuous	0330		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_-W49TH_ST_345_M52				FWD
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)
0300	Continuous	0200		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
NIAGARA_-PACKARD__230_61				FWD REV
Tue 11/30/2021	to	Mon 12/06/2021		(Import) (Export)
0615	Continuous	1900		SCH - OH - NY 1200 MW 1850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 1100 MW 150 MW
				TTC with All Lines In Service 2300 MW 2000 MW
SPRNBRK__345KV_RNS4				FWD
Wed 12/01/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)
0130	Continuous	0200		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
MOSES__-ADIRNDCK_230_MA1				FWD
Wed 12/01/2021	to	Tue 05/31/2022		(Import)
0700	Continuous	1300		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
NIAGARA_-STA_255__345_NH2				FWD
Thu 12/02/2021	to	Thu 01/13/2022		(Import)
0500	Continuous	1900		DYSINGER EAST 1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
BUCHAN_S-MILLWOOD_345_W98				FWD
Tue 12/07/2021	to	Fri 12/10/2021		(Import)
0201	Continuous	0200		UPNY CONED 7680 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 135 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88					FWD
Tue 12/07/2021	to	Fri 12/10/2021			(Import)
0201	Continuous	0200		UPNY CONED	7560 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 7815 MW
MILLWOOD_345KV_18					FWD
Tue 12/07/2021	to	Fri 12/10/2021			(Import)
0201	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBRK__345_W64					FWD
Sun 12/12/2021	to	Tue 12/14/2021	UPDATED	by CE	07/21/2021
2000	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
MILLWOOD-EASTVIEW_345_W99					FWD
Sun 12/12/2021	to	Tue 12/14/2021	UPDATED	by CE	07/21/2021
2000	Continuous	0200			(Import)
Work scheduled by: ConEd					UPNY CONED 7550 MW
					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW
SPRNBRK__345KV_RNS5					FWD
Sun 12/12/2021	to	Tue 12/14/2021	UPDATED	by CE	07/21/2021
2000	Continuous	0200			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
BUCHAN_N-EASTVIEW_345_W93					FWD
Wed 12/22/2021	to	Thu 12/23/2021			(Import)
0001	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBRK__345_W79					FWD
Wed 12/22/2021	to	Thu 12/23/2021			(Import)
0001	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__345_FRASER SVC				FWD
Tue 01/04/2022	to	Mon 02/28/2022	UPDATED	(Import)
0700	Continuous	1730	by NYPA	05/25/2021
Work scheduled by: NYPA				CENTRAL EAST - VC 2935 MW
				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW
<hr/>				
NIAGARA -PACKARD__230_61				FWD
Mon 01/17/2022	to	Fri 01/21/2022		(Import) (Export)
0615	Continuous	1900		SCH - OH - NY 1200 MW 1850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 1100 MW 150 MW
				TTC with All Lines In Service 2300 MW 2000 MW
<hr/>				
FRASANNX-COOPERS__345_UCC2-41				FWD
Mon 02/07/2022	to	Sat 02/12/2022		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
				ARR: 19
<hr/>				
MARCY__-FRASANNX_345_UCC2-41				FWD
Mon 02/07/2022	to	Sat 02/12/2022		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
				ARR: 19
<hr/>				
ATHENS__-PLSNTVLY_345_91				FWD
Sat 02/12/2022	to	Wed 02/16/2022	UPDATED	(Import)
0600	Continuous	1900	by NGRID	05/07/2021
Work scheduled by: NGrid				UPNY CONED 3800 MW
				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
<hr/>				
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Thu 02/17/2022	to	Sat 02/19/2022		(Import)
0001		2200		UPNY CONED 3800 MW
Work scheduled by:				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
<hr/>				
LEEDS__-PLSNTVLY_345_92				FWD
Thu 02/17/2022	to	Fri 03/25/2022		(Import)
0001	Continuous	2200		UPNY CONED 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Thu 02/17/2022 to Fri 03/25/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

(Import)

UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F30

FWD

Sun 02/20/2022 to Mon 02/21/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

(Import)

UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

MARCY -EDIC 345_UE1-7

FWD

Wed 02/23/2022 to Mon 02/28/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

(Import)

OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

ARR: 19&16

NIAGARA -STA_255_345_NH2

FWD

Sat 02/26/2022 to Mon 02/28/2022
 0500 Continuous 1900
 Work scheduled by: NYPA

(Import)

DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

PORTER -ROTTRDAM_230_31

FWD

Tue 03/01/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

(Import)

CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

FRASANX-COOPERS_345_UCC2-41

FWD

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

(Import)

CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

ARR: 19

MARCY -FRASANX_345_UCC2-41

FWD

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

(Import)

CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021
 0001 Continuous 0200 STATEN ISLAND
 Impacts Total Transfer Capability
 Work scheduled by: ConEd TTC with All Lines In Service

LINDEN_-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022 UPDATED by CONED 03/26/2021
 0001 Continuous 0200 SCH - PJ - NY
 Impacts Total Transfer Capability
 Work scheduled by: ConEd TTC with All Lines In Service

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 03/17/2022 to Sun 03/20/2022
 0100 2200 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 Work scheduled by: TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F30

Mon 03/21/2022 to Wed 03/23/2022
 0001 Continuous 2200 FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 Work scheduled by: ConEd TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 03/26/2022 to Mon 03/28/2022
 0001 2200 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 Work scheduled by: TTC with All Lines In Service 7815 MW

ATHENS_-PLSNTVLY_345_91

Sat 03/26/2022 to Sun 05/01/2022
 0001 Continuous 2200 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 Work scheduled by: ConEd TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Sat 03/26/2022 to Sun 05/01/2022
 0001 Continuous 2200 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 Work scheduled by: ConEd TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F31

Tue 03/29/2022 to Wed 03/30/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_-TREMONT__345_X28

Tue 04/05/2022 to Wed 04/06/2022
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 04/06/2022 to Wed 04/06/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBRK__345_W79

Wed 04/06/2022 to Thu 04/07/2022
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_N-EASTVIEW_345_W93

Thu 04/07/2022 to Thu 04/07/2022
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

PANNELL_-CLAY__345_1

Mon 04/11/2022 to Fri 04/15/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

PORTER_-ROTTDAM_230_30

Wed 04/13/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_345_2		FWD
Mon 04/18/2022	to Fri 04/22/2022	(Import)
0700	Continuous 1530	WEST CENTRAL 1300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 950 MW
		TTC with All Lines In Service 2250 MW
EDIC_-FRASER_345_EF24-40		FWD
Thu 04/21/2022	to Tue 06/14/2022	(Import)
0700	Continuous 1530	CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 475 MW
		TTC with All Lines In Service 2975 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4		FWD
Sat 04/23/2022	to Tue 04/26/2022	(Import)
0001	2200	UPNY CONED 3800 MW
Work scheduled by:		Impacts Total Transfer Capability 4015 MW
		TTC with All Lines In Service 7815 MW
PLSNTVLY-WOOD_ST_345_F31		FWD
Wed 04/27/2022	to Fri 04/29/2022	(Import)
0001	Continuous 2200	UPNY CONED 4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 3815 MW
		TTC with All Lines In Service 7815 MW
NIAGARA_345_230_AT4		REV
Fri 04/29/2022	to Fri 04/29/2022	(Export)
0500	Continuous 1700	SCH - OH - NY 1750 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability 250 MW
		TTC with All Lines In Service 2000 MW
BUCHAN_N-EASTVIEW_345_W93		FWD
Mon 05/02/2022	to Mon 05/02/2022	(Import)
0001	Continuous 0030	UPNY CONED 4350 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 3465 MW
		TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBRK_345_W79		FWD
Mon 05/02/2022	to Thu 05/05/2022	(Import)
0001	Continuous 0200	UPNY CONED 4350 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 3465 MW
		TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2				FWD
Mon 05/02/2022	to	Fri 05/06/2022		(Import)
0500	Continuous	1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
N. SCTLND-ALPS_____345_2				FWD
Mon 05/02/2022	to	Mon 05/09/2022		(Import)
0600	Daily	1800	SCH - NE - NY	750 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 650 MW
				TTC with All Lines In Service 1400 MW
N. SCTLND-ALPS_____345_2				FWD
Mon 05/02/2022	to	Mon 05/09/2022		(Import) (Export)
0600	Daily	1800	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW
SPRNBRK_-TREMONT__345_X28				FWD
Tue 05/03/2022	to	Mon 05/09/2022		(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Thu 05/05/2022	to	Thu 05/05/2022		(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
HOMRC_NY-MAINS_NY_345_47				
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED by PJM 11/19/2020	SCH - PJ - NY
0800	Continuous	1600		Impacts Total Transfer Capability
Work scheduled by: PJM				TTC with All Lines In Service
HOMR_NYW-PIERC_NY_345_48				
Fri 05/20/2022	to	Fri 05/27/2022	UPDATED by PJM 11/19/2020	SCH - PJ - NY
0800	Continuous	1600		Impacts Total Transfer Capability
Work scheduled by: PJM				TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1				FWD
Mon 09/12/2022	to	Fri 09/16/2022		(Import)
0700	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
FRASER_-GILBOA_____345_GF5-35				FWD
Mon 09/12/2022	to	Sun 09/18/2022		(Import)
0700	Continuous	1530	CENTRAL EAST - VC	2650 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 325 MW
				TTC with All Lines In Service 2975 MW
SPRNBRK__345KV_RNS5				FWD
Mon 09/19/2022	to	Mon 09/19/2022	UPDATED by CONED 09/17/2020	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_-W49TH_ST_345_M51				FWD
Mon 09/19/2022	to	Wed 09/21/2022	UPDATED by CONED 09/17/2020	(Import)
0001	Continuous	2200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
PANNELL_-CLAY_____345_2				FWD
Mon 09/19/2022	to	Fri 09/23/2022		(Import)
0700	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
SPRNBRK__345KV_RNS5				FWD
Wed 09/21/2022	to	Wed 09/21/2022	UPDATED by CONED 09/17/2020	(Import)
2130	Continuous	2200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_-W49TH_ST_345_M51				FWD
Sat 10/01/2022	to	Mon 10/17/2022	UPDATED by CONED 08/01/2020	(Import)
0001	Continuous	0300	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,July 25, 2021 to Tuesday ,January 24, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5

FWD

Sat 10/01/2022 to Mon 10/17/2022
0001 Continuous 0300

UPDATED by CONED 08/01/2020

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW