

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Tue 11/30/2021				(Import) (Export)
0001		2359				SCH - PJ - NY <b>2000 MW 1150 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>07/08/2021</u>	
0456	Continuous	1600				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>NEWBRDGE_345_138_BK_1</b>					FWD	
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>01/12/2021</u>	(Import)
1807	Continuous	2359				SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_1600</b>					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY <b>1900 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD	
Fri 08/06/2021	to	Thu 10/07/2021	<u>UPDATED</u>	<u>by LI</u>	<u>10/07/2021</u>	(Import)
1939	Continuous	1333				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EGRDNCTY_345_138_AT2</b>						FWD
Fri 08/06/2021	to	Thu 10/07/2021	<u>UPDATED</u>	<u>by LI</u>	<u>10/07/2021</u>	(Import)
1939	Continuous	1333				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
<b>SPRNBRK_-EGRDNCTR_345_Y49</b>						FWD
Fri 08/06/2021	to	Thu 10/07/2021	<u>UPDATED</u>	<u>by LI</u>	<u>10/07/2021</u>	(Import)
1953	Continuous	1333				CONED - LIPA <b>775 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 725 MW
						TTC with All Lines In Service 1500 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>						FWD
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>						FWD
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				SCH - OH - NY <b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1950 MW
<b>SCH-NYISO-IMO_LIMIT_1200</b>						REV
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Export)
0600	Continuous	1300				SCH - OH - NY <b>1500 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1700 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>						FWD
Tue 09/07/2021	to	Fri 10/22/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/07/2021</u>	(Import)
0700	Continuous	2359				SCH - HQ_CEDARS <b>80 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 110 MW
						TTC with All Lines In Service 190 MW
<b>E13THSTA-FARRAGUT_345_46</b>						FWD
Wed 09/15/2021	to	Fri 10/08/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/03/2021</u>	(Import)
0001	Continuous	0500				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST-E13THSTA_345_M55</b>					FWD	
Wed 09/15/2021	to	Fri 10/08/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/03/2021</u>	(Import)
0001	Continuous	0500				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>PORTER__-ROTTRDAM_230_30</b>					FWD	
Wed 09/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0700	Continuous	1730				<b>2805 MW</b>
Work scheduled by: NGrid					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW
<b>EDIC___-N.SCTLND_345_14</b>					FWD	
Thu 09/16/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0600	Continuous	1830				<b>1670 MW</b>
Work scheduled by: NGrid					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	1305 MW
					TTC with All Lines In Service	2975 MW
<b>EDIC___-N.SCTLND_345_14 &amp; PORTER__-ROTTRDAM_230_30</b>					FWD	
Thu 09/16/2021	to	Sun 11/14/2021				(Import)
0600		1830				<b>1500 MW</b>
Work scheduled by:					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>						
Sat 09/18/2021	to	Fri 11/05/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/08/2021</u>	
0800	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>SCH-NYISO-NE_LIMIT_600</b>						
Sun 09/26/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/02/2021</u>	REV
0701	Daily	2300				(Export)
Work scheduled by: ISONE					SCH - NE - NY	<b>800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
<b>LEEDS___-HURLYAVE_345_301</b>					FWD	
Mon 09/27/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
0800	Continuous	0133				<b>4100 MW</b>
Work scheduled by: CHGE					UPNY CONED	
					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS ___ 345KV_R395</b>					FWD	
Thu 09/30/2021	to	Thu 10/07/2021	<u>EXTENDED</u>	<u>by NGRID</u>	<u>10/06/2021</u>	(Import)
0900	Continuous	1800				<b>UPNY CONED</b> <b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
<b>NIAGARA -STA_255__345_NH2</b>					FWD	
Sat 10/02/2021	to	Sun 10/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/02/2021</u>	(Import)
0500	Continuous	1900				<b>DYSINGER EAST</b> <b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1750 MW	
					TTC with All Lines In Service 3150 MW	
<b>SCH-NE-NYISO_LIMIT_300</b>					FWD	
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/02/2021</u>	(Import)
2301	Daily	0700				<b>SCH - NE - NY</b> <b>500 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 900 MW	
					TTC with All Lines In Service 1400 MW	
<b>SCH-NYISO-NE_LIMIT_1200</b>					REV	
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/02/2021</u>	(Export)
2301	Daily	0700				<b>SCH - NE - NY</b> <b>1400 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 1600 MW	
<b>CHAT_DC_GC1</b>					FWD	
Sun 10/03/2021	to	Tue 11/23/2021				(Import)
0500	Continuous	2000				<b>MOSES SOUTH</b> <b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	
<b>CHAT_DC_GC1</b>					REV	
Sun 10/03/2021	to	Tue 11/23/2021				(Export)
0500	Continuous	2000				<b>SCH - HQ - NY</b> <b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 1000 MW	
<b>SCH-NE-NYISO_LIMIT_600</b>					FWD	
Sun 10/03/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/02/2021</u>	(Import)
0701	Daily	2300				<b>SCH - NE - NY</b> <b>800 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 1400 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CLAY -EDIC 345_2-15</b>				FWD	
Mon 10/04/2021	to	Sat 10/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/16/2021</u>
0700	Continuous	1730			
Work scheduled by: NYPA				OSWEGO EXPORT	<b>4850 MW</b>
				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
<b>FRASER 345_FRASER SVC</b>				FWD	
Mon 10/04/2021	to	Wed 10/06/2021			
0800	Continuous	1700			
Work scheduled by: NYSEG				CENTRAL EAST - VC	<b>2935 MW</b>
				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	2975 MW
<b>ELBRIDGE-LAFAYTTE 345_17-LE</b>				FWD	
Mon 10/04/2021	to	Sat 10/09/2021	<u>EXTENDED</u>	<u>by NGRID</u>	<u>10/07/2021</u>
0800	Continuous	1630			
Work scheduled by: NGrid				OSWEGO EXPORT	<b>5250 MW</b>
				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
<b>NRTH1385-NOR HBR_138_601</b>				FWD	REV
Wed 10/06/2021	to	Thu 10/07/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/07/2021</u>
0900	Continuous	2359			
Work scheduled by: ISONE				SCH - NPX_1385	<b>100 MW 100 MW</b>
				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>				FWD	REV
Wed 10/06/2021	to	Thu 10/07/2021			
0900		2359			
Work scheduled by:				SCH - NPX_1385	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_603</b>				FWD	REV
Wed 10/06/2021	to	Thu 10/07/2021			
0900		2359			
Work scheduled by:				SCH - NPX_1385	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_602</b>				FWD	REV
Wed 10/06/2021	to	Thu 10/07/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/07/2021</u>
0900	Continuous	2359			
Work scheduled by: ISONE				SCH - NPX_1385	<b>100 MW 100 MW</b>
				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Wed 10/06/2021 to Thu 10/07/2021  
0900 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**NRTH1385-NOR HBR\_\_138\_603**

Wed 10/06/2021 to Thu 10/07/2021 **UPDATED by ISONE 10/07/2021**  
0900 Continuous 2359

Work scheduled by: ISONE

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**NRTH1385-NRTHPORT\_138\_NNC**

Wed 10/06/2021 to Thu 10/07/2021 **UPDATED by ISONE 10/07/2021**  
0900 Continuous 2359

Work scheduled by: ISONE

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**SCH-HQ-NYISO\_LIMIT\_1200**

Thu 10/07/2021 to Tue 11/23/2021  
0001 Continuous 2000

Work scheduled by: HQ

	FWD
	(Import)
SCH - HQ - NY	<b>1200 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	1500 MW

**W49TH\_ST\_345KV\_6**

Fri 10/08/2021 to Fri 10/08/2021 **UPDATED by CONED 10/03/2021**  
0430 Continuous 0500

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>300 MW</b>
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

**LEEDS\_\_345KV\_R94301**

Fri 10/08/2021 to Sun 10/10/2021 **UPDATED by CH 10/09/2021**  
1530 Continuous 0132

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>3800 MW</b>
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sat 10/09/2021 to Sun 10/10/2021  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EFISHKIL-WOOD_ST__345_F38</b>					FWD
Sat 10/09/2021	to	Sun 10/10/2021	<b>UPDATED</b>	<b>by CONED</b>	(Import)
0001	Continuous	2200			<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD
Sat 10/09/2021	to	Sun 10/10/2021	<b>UPDATED</b>	<b>by CONED</b>	(Import)
0001	Continuous	2200			<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD
Sat 10/09/2021	to	Sun 10/10/2021	<b>UPDATED</b>	<b>by CONED</b>	(Import)
0001	Continuous	2200			<b>7210 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 605 MW
					TTC with All Lines In Service 7815 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD
Sat 10/09/2021	to	Sat 10/09/2021	<b>CANCELLED</b>	<b>by NGrid</b>	(Import)
0800	Daily	0830			<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
<b>LEEDS__-PLSNTVLY_345_92</b>					FWD
Sat 10/09/2021	to	Sat 10/09/2021	<b>CANCELLED</b>	<b>by NGrid</b>	(Import)
0800	Daily	1500			<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD
Sat 10/09/2021	to	Sat 10/09/2021	<b>CANCELLED</b>	<b>by NGrid</b>	(Import)
1430	Daily	1500			<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
<b>OSWEGO__-ELBRIDGE_345_17</b>					FWD
Sat 10/09/2021	to	Sat 10/09/2021	<b>EXTENDED</b>	<b>by NGRID</b>	(Import)
1600	Continuous	1630			<b>5250 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
					ARR: 75

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_600</b>					FWD	
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/07/2021</u>	(Import)
0500	Continuous	1300				900 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service	1950 MW
<b>SCH-NYISO-IMO_LIMIT_500</b>					REV	
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/07/2021</u>	(Export)
0500	Continuous	1300				800 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service	1700 MW
<b>LEEDS___345KV_R94301</b>					FWD	
Mon 10/11/2021	to	Mon 10/11/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
0700	Continuous	0800				3800 MW
Work scheduled by: CHGE					UPNY CONED	Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service	7815 MW
<b>LEEDS___-HURLYAVE_345_301</b>					FWD	
Mon 10/11/2021	to	Fri 10/29/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
0700	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	Impacts Total Transfer Capability 3715 MW
					TTC with All Lines In Service	7815 MW
<b>EFISHKIL-WOOD_ST__345_F38</b>					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				4000 MW
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service	7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				4000 MW
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service	7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				7210 MW
Work scheduled by: ConEd					UPNY CONED	Impacts Total Transfer Capability 605 MW
					TTC with All Lines In Service	7815 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD		
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/02/2021</u>	(Import)	
0201	Continuous	0230				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
<b>EASTVIEW-SPRNBK_345_W79</b>					FWD		
Tue 10/12/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/02/2021</u>	(Import)	
0201	Continuous	2200				UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
<b>CEDARS_-ROSEMNTB_115_2/22</b>					FWD	REV	
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import)	(Export)
0500	Continuous	2359				SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW 60 MW
						TTC with All Lines In Service	190 MW 100 MW
<b>DENNISON-ROSEMNTB_115_2/22</b>					FWD	REV	
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import)	(Export)
0500	Continuous	2359				SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW 60 MW
						TTC with All Lines In Service	190 MW 100 MW
<b>SCH-NE-NYISO_LIMIT_100</b>					FWD		
Tue 10/12/2021	to	Wed 10/20/2021				(Import)	
2300	Daily	0659				SCH - NE - NY	<b>300 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	1400 MW
<b>W49TH_ST_345KV_5</b>					FWD		
Wed 10/13/2021	to	Fri 10/15/2021				(Import)	
0001	Continuous	0100				SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>					FWD		
Wed 10/13/2021	to	Fri 10/15/2021				(Import)	
0001	Continuous	0100				SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 10/13/2021 to Wed 10/13/2021  
 2130 Continuous 2200  
 Work scheduled by: ConEd

UPDATED by CE 10/02/2021

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Thu 10/14/2021 to Thu 10/14/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Thu 10/14/2021 to Sat 10/16/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

UPDATED by CONED 08/04/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Thu 10/14/2021 to Sat 10/16/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

UPDATED by CONED 08/04/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_\_345\_W78**

Thu 10/14/2021 to Sat 10/16/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE\_345KV\_5**

Thu 10/14/2021 to Sun 11/28/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_7**

Thu 10/14/2021 to Sun 11/28/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-DUNWODIE_345_W75</b>					FWD
Thu 10/14/2021	to	Sun 11/28/2021			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>SPRNBK_345KV_RNS3</b>					FWD
Thu 10/14/2021	to	Sun 11/28/2021			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>SCH-NYISO-HQ_LIMIT_300</b>					REV
Thu 10/14/2021	to	Sun 10/17/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/07/2021</u>
0600	Daily	1800		SCH - HQ - NY	<b>300 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1000 MW
<b>SCH-NYISO-HQ_LIMIT_300</b>					REV
Thu 10/14/2021	to	Wed 10/20/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>10/07/2021</u>
0600	Continuous	1800		SCH - HQ - NY	<b>300 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1000 MW
<b>OSWEGO_-VOLNEY_345_12</b>					FWD
Thu 10/14/2021	to	Thu 10/14/2021			(Import)
1100	Daily(No Weekends)	1400		OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
<b>SPRNBK_345KV_RS3 &amp; SPRNBK_345KV_RS4</b>					FWD
Sat 10/16/2021	to	Tue 10/19/2021			(Import)
0001		0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>					FWD
Sat 10/16/2021	to	Sat 10/16/2021			(Import)
0030	Continuous	0100		UPNY CONED	<b>7550 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE-MOTTHAVN_345_71</b>				FWD	
Sat 10/16/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>
0101	Continuous	0200			
Work scheduled by: ConEd			SPR/DUN-SOUTH		<b>3800 MW</b>
			Impacts Total Transfer Capability		800 MW
			TTC with All Lines In Service		4600 MW
<b>DUNWODIE_345KV_3</b>				FWD	
Sat 10/16/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>
0101	Continuous	0200			
Work scheduled by: ConEd			SPR/DUN-SOUTH		<b>3800 MW</b>
			Impacts Total Transfer Capability		800 MW
			TTC with All Lines In Service		4600 MW
<b>CLAY - INDPDNCE_345_26</b>				FWD	
Sat 10/16/2021	to	Sat 10/16/2021			
0800	Daily	1000			
Work scheduled by: NGrid			OSWEGO EXPORT		<b>5000 MW</b>
			Impacts Total Transfer Capability		250 MW
			TTC with All Lines In Service		5250 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD	
Sun 10/17/2021	to	Sun 10/17/2021			
0001		0200			
Work scheduled by:			MOSES SOUTH		<b>2550 MW</b>
			Impacts Total Transfer Capability		600 MW
			TTC with All Lines In Service		3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD	REV
Sun 10/17/2021	to	Sun 10/17/2021			
0001		0200			
Work scheduled by:			SCH - HQ - NY		<b>1370 MW 0 MW</b>
			Impacts Total Transfer Capability		130 MW 1000 MW
			TTC with All Lines In Service		1500 MW 1000 MW
<b>CHAT_DC_GC2</b>				FWD	
Sun 10/17/2021	to	Sun 10/17/2021			
0001	Continuous	0200			
Work scheduled by: HQ			MOSES SOUTH		<b>2850 MW</b>
			Impacts Total Transfer Capability		300 MW
			TTC with All Lines In Service		3150 MW
<b>CHAT_DC_GC2</b>					REV
Sun 10/17/2021	to	Sun 10/17/2021			
0001	Continuous	0200			
Work scheduled by: HQ			SCH - HQ - NY		<b>500 MW</b>
			Impacts Total Transfer Capability		500 MW
			TTC with All Lines In Service		1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULED WORK				IMPACTS	
Start Date	End Date	Time	Work	Import	Export
<b>SCH-HQ-NYISO_LIMIT_1150</b>					
Sun 10/17/2021	to	Sun 10/17/2021		FWD	
0001	Continuous	0200	Work scheduled by: HQ	(Import)	
				SCH - HQ - NY	<b>1150 MW</b>
				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	1500 MW
<b>CEDARS_-ROSEMNTA_115_1/11</b>					
Mon 10/18/2021	to	Thu 10/21/2021		FWD	REV
0500	Continuous	2359	Work scheduled by: HQ	(Import)	(Export)
				SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
				Impacts Total Transfer Capability	95 MW 60 MW
				TTC with All Lines In Service	190 MW 100 MW
<b>DENNISON-ROSEMNTA_115_1/11</b>					
Mon 10/18/2021	to	Thu 10/21/2021		FWD	REV
0500	Continuous	2359	Work scheduled by: HQ	(Import)	(Export)
				SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
				Impacts Total Transfer Capability	95 MW 60 MW
				TTC with All Lines In Service	190 MW 100 MW
<b>NIAGARA_-KINTIGH_345_NSI-38</b>					
Mon 10/18/2021	to	Sat 12/04/2021	<b>UPDATED by NYPA 08/20/2021</b>	FWD	
0500	Continuous	1900	Work scheduled by: NYPA	(Import)	
				DYSINGER EAST	<b>1400 MW</b>
				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW
<b>SCH-NE-NYISO_LIMIT_600</b>					
Mon 10/18/2021	to	Tue 10/19/2021	<b>UPDATED by ISONE 10/02/2021</b>	FWD	
2301	Daily	0700	Work scheduled by: ISONE	(Import)	
				SCH - NE - NY	<b>800 MW</b>
				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_600</b>					
Tue 10/19/2021	to	Sat 10/23/2021	<b>UPDATED by ISONE 10/02/2021</b>	FWD	
0701	Daily	2300	Work scheduled by: ISONE	(Import)	
				SCH - NE - NY	<b>800 MW</b>
				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_900</b>					
Thu 10/21/2021	to	Fri 10/29/2021		FWD	
1700	Continuous	1600	Work scheduled by: ISONE	(Import)	
				SCH - NE - NY	<b>1100 MW</b>
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_600</b>					FWD	
Sun 10/24/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/02/2021</u>	(Import)
0701	Daily	1600				<b>800 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_600</b>					REV	
Sun 10/24/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/02/2021</u>	(Export)
0701	Daily	1600				<b>800 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	1600 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 10/25/2021	to	Sun 11/21/2021				(Import) (Export)
0700	Continuous	1600				<b>0 MW 0 MW</b>
Work scheduled by: ISONE					SCH - NPX_CSC	Impacts Total Transfer Capability 330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>LEEDS___345KV_R94301</b>					FWD	
Fri 10/29/2021	to	Fri 10/29/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
1500	Continuous	1600				<b>3800 MW</b>
Work scheduled by: CHGE					UPNY CONED	Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service	7815 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Sat 10/30/2021	to	Sat 10/30/2021				(Import)
0001	Continuous	0030				<b>300 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Sat 10/30/2021	to	Sun 12/05/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0001	Continuous	0300				<b>300 MW</b>
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service	660 MW
<b>LEEDS___-ATHENS___345_95</b>					FWD	
Sat 10/30/2021	to	Sat 10/30/2021				(Import)
0800	Daily(No Weekends)	1500				<b>3800 MW</b>
Work scheduled by: NGrid					UPNY CONED	Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_345KV\_R395**

Sat 10/30/2021 to Sat 10/30/2021  
 0800 Daily(No Weekends) 1500  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 11/01/2021 to Fri 12/10/2021 UPDATED by CE 09/10/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7680 MW**  
 Impacts Total Transfer Capability 135 MW  
 TTC with All Lines In Service 7815 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 2300 MW

**SCH-NYISO-IMO\_LIMIT\_1600**

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359  
 Work scheduled by: IESO

REV  
 (Export)  
 SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 2000 MW

**W49TH\_ST\_345KV\_7**

Tue 11/02/2021 to Tue 11/02/2021  
 0200 Continuous 0230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**LINDN\_CG-LNDVFT\_\_\_345\_V-3022**

Tue 11/02/2021 to Fri 11/05/2021  
 0800 Continuous 1500  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJM\_VFT **0 MW 0 MW**  
 Impacts Total Transfer Capability 315 MW 315 MW  
 TTC with All Lines In Service 315 MW 315 MW

**MILLWOOD\_345KV\_18**

Wed 11/03/2021 to Fri 11/12/2021 UPDATED by CE 09/10/2021  
 0001 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_S-MILLWOOD\_345\_W98**

Wed 11/03/2021 to Tue 11/09/2021  
0201 Continuous 0200

**UPDATED by CE 09/10/2021**

Work scheduled by: ConEd

FWD  
(Import)  
**7680 MW**  
UPNY CONED  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Wed 11/03/2021 to Tue 11/09/2021  
0201 Continuous 0200

**UPDATED by CE 09/10/2021**

Work scheduled by: ConEd

FWD  
(Import)  
**7560 MW**  
UPNY CONED  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 7815 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 11/05/2021 to Mon 11/08/2021  
1601 Continuous 0800

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SHORE\_RD\_345\_138\_BK 1**

Mon 11/08/2021 to Wed 11/10/2021  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
**1350 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Thu 11/11/2021 to Fri 11/12/2021  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
**1350 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**GOETHALS\_345KV\_5**

Fri 11/12/2021 to Tue 11/16/2021  
0001 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

Sun 11/14/2021 to Wed 11/24/2021  
0700 Continuous 1600

Work scheduled by: ISONE

**ARR: 78**

FWD REV  
(Import) (Export)  
**1100 MW 1700 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 300 MW 0 MW  
TTC with All Lines In Service 1400 MW 1700 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393			FWD	REV
			(Import)	(Export)
Sun 11/14/2021	to	Wed 11/24/2021		
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
ARR: 78				
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Sun 11/14/2021	to	Wed 11/24/2021		
0700		1600	SCH - NE - NY	<b>1100 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	1400 MW
ARR: 78				
BERKSHIR-NORTHFLD_345_312			FWD	
			(Import)	
Sun 11/14/2021	to	Wed 11/24/2021		
0700	Continuous	1600	SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Sun 11/14/2021	to	Wed 11/24/2021		
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
SCH-NE-NYISO_LIMIT_800			FWD	
			(Import)	
Sun 11/14/2021	to	Wed 11/24/2021		
0700	Continuous	1600	SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700				REV
				(Export)
Sun 11/14/2021	to	Wed 11/24/2021		
0700	Continuous	1600	SCH - NE - NY	<b>900 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1700 MW
PORTER_-ROTTDAM_230_30 & MASSENA_-MARCY_____765_MSU1			FWD	
			(Import)	
Mon 11/15/2021	to	Tue 11/30/2021		
0100		1730	CENTRAL EAST - VC	<b>1500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	1475 MW
			TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	(Export)
0100	Continuous	1859				SCH - HQ - NY	<b>0 MW 0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MARCY__765_345_AT1</b>						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY__765_345_AT2</b>						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				CENTRAL EAST - VC	<b>1670 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1305 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	(Export)
0100	Continuous	1859				SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	
0100	Continuous	1859		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>				FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	(Export)
0100		1859		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MASSENA_-MARCY_765_MSU1</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES_230_L33P &amp; MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021		(Import)	
0100		1859		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>				FWD	
Wed 11/17/2021	to	Wed 11/17/2021	<b>UPDATED by CE 10/01/2021</b>	(Import)	
0001	Continuous	0030		UPNY CONED	<b>7550 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	265 MW
				TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE-MOTTHAVN_345_72</b>						FWD
Wed 11/17/2021	to	Sun 11/21/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/01/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>						FWD
Wed 11/17/2021	to	Sun 11/21/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/01/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W78</b>						FWD
Wed 11/17/2021	to	Sun 11/21/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
<b>W49TH_ST_345KV_7</b>						FWD
Sat 11/20/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0001	Continuous	0030				300 MW
Work scheduled by: ConEd						SCH - PJM_HTP
						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>						FWD
Sun 11/21/2021	to	Sun 11/21/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)
0130	Continuous	0200				7550 MW
Work scheduled by: ConEd						UPNY CONED
						Impacts Total Transfer Capability 265 MW
						TTC with All Lines In Service 7815 MW
<b>SPRNBK__345KV_RS3 &amp; SPRNBK__345KV_RS4</b>						FWD
Mon 11/22/2021	to	Sun 11/28/2021				(Import)
0001		0200				3800 MW
Work scheduled by:						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>						FWD
Mon 11/22/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)
0201	Continuous	0100				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>						FWD
Mon 11/22/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)
0201	Continuous	0100				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>W49TH_ST_345KV_7</b>						FWD
Thu 11/25/2021	to	Fri 12/03/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0001	Continuous	0200				300 MW
Work scheduled by: ConEd						SCH - PJM_HTP
						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
<b>SPRNBRK__345KV_RNS4</b>						FWD
Sun 11/28/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0300	Continuous	0330				3200 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<b>SPRNBRK_-W49TH_ST_345_M52</b>						FWD
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0300	Continuous	0200				3200 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				0 MW
Work scheduled by: PJM						SCH - PJM_NEPTUNE
						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				0 MW
Work scheduled by: PJM						SCH - PJM_NEPTUNE
						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				375 MW
Work scheduled by: PJM						SCH - PJM_NEPTUNE
						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	<b>1100 MW 1700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	300 MW 0 MW
			TTC with All Lines In Service	1400 MW 1700 MW
ARR: 78				
BERKSHIR-ALPS _____ 345_393			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
ARR: 78				
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700		1600	SCH - NE - NY	<b>1100 MW 1700 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	300 MW 0 MW
			TTC with All Lines In Service	1400 MW 1700 MW
ARR: 78				
BERKSHIR-NORTHFLD_345_312			FWD	
			(Import)	
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_800			FWD	
			(Import)	
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700				REV
				(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	<b>900 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HURLYAVE-ROSETON__345_303</b>				FWD	
Mon 11/29/2021	to	Sun 12/05/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/07/2021</u>
0800	Continuous	1600			
Work scheduled by: CHGE				UPNY CONED	<b>4100 MW</b>
				Impacts Total Transfer Capability	3715 MW
				TTC with All Lines In Service	7815 MW
<b>NIAGARA -PACKARD__230_61</b>				FWD	REV
Tue 11/30/2021	to	Mon 12/06/2021			
0615	Continuous	1900			
Work scheduled by: NGrid				SCH - OH - NY	<b>1200 MW 1850 MW</b>
				Impacts Total Transfer Capability	1100 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
<b>SPRNBRK__345KV_RNS4</b>				FWD	
Wed 12/01/2021	to	Wed 12/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>
0130	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	<b>3200 MW</b>
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>				FWD	
Wed 12/01/2021	to	Tue 05/31/2022			
0700	Continuous	1300			
Work scheduled by: NYPA				MOSES SOUTH	<b>2300 MW</b>
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>SPRNBRK__345KV_RNS4</b>				FWD	
Fri 12/03/2021	to	Sat 12/04/2021			
0001	Continuous	1800			
Work scheduled by: ConEd				SPR/DUN-SOUTH	<b>3200 MW</b>
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK_-W49TH_ST_345_M52</b>				FWD	
Fri 12/03/2021	to	Sat 12/18/2021			
0201	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	<b>3200 MW</b>
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>MARCY__-EDIC__345_UE1-7</b>				FWD	
Fri 12/03/2021	to	Fri 12/03/2021			
0700	Daily(No Weekends)	1000			
Work scheduled by: NGrid				OSWEGO EXPORT	<b>5250 MW</b>
				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW

ARR: 19&16

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD\_345KV\_18**

Mon 12/06/2021 to Fri 12/10/2021  
0001 Continuous 0200

**UPDATED by CE 09/10/2021**

Work scheduled by: ConEd

FWD  
(Import)  
**4350 MW**  
UPNY CONED  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**W49TH\_ST\_345KV\_5**

Mon 12/06/2021 to Sat 12/18/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**300 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**MARCY\_\_\_345KV\_CSC**

Mon 12/06/2021 to Fri 12/17/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
**2925 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

Tue 12/07/2021 to Fri 12/10/2021  
0201 Continuous 0200

**UPDATED by CE 09/10/2021**

Work scheduled by: ConEd

FWD  
(Import)  
**7680 MW**  
UPNY CONED  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

**LADENTWN-BUCHAN\_S\_345\_Y88**

Tue 12/07/2021 to Fri 12/10/2021  
0201 Continuous 0200

**UPDATED by CE 09/10/2021**

Work scheduled by: ConEd

FWD  
(Import)  
**7560 MW**  
UPNY CONED  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 7815 MW

**SPRNBRK\_\_345KV\_RNS4**

Mon 12/13/2021 to Tue 12/14/2021  
0001 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**HURLYAVE-ROSETON\_\_345\_303**

Mon 12/13/2021 to Wed 12/22/2021  
0700 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
**4100 MW**  
UPNY CONED  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS4</b>					FWD
Sat 12/18/2021	to	Sat 12/18/2021			(Import)
0130	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>FRASER__345_FRASER SVC</b>					FWD
Tue 01/04/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/25/2021</u>
0700	Continuous	1730		CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 40 MW
					TTC with All Lines In Service 2975 MW
<b>NIAGARA_-PACKARD__230_61</b>					FWD      REV
Mon 01/17/2022	to	Fri 01/21/2022			(Import) (Export)
0615	Continuous	1900		SCH - OH - NY	<b>1200 MW 1850 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 1100 MW 150 MW
					TTC with All Lines In Service 2300 MW 2000 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					
Tue 01/18/2022	to	Fri 02/04/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>09/24/2021</u>
0700	Continuous	1730		SCH - PJ - NY	
Work scheduled by: NGrid					Impacts Total Transfer Capability
					TTC with All Lines In Service
<b>NIAGARA_-STA_255__345_NH2</b>					FWD
Fri 01/21/2022	to	Fri 03/04/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>
0500	Continuous	1900		DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<b>ATHENS__-PLSNTVLY_345_91</b>					FWD
Sat 02/12/2022	to	Wed 02/16/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/07/2021</u>
0600	Continuous	1900		UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>					FWD
Thu 02/17/2022	to	Sat 02/19/2022			(Import)
0001		2200		UPNY CONED	<b>3800 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS\_\_\_-PLSNTVLY\_345\_92

Thu 02/17/2022 to Fri 03/25/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

PLSNTVLY\_345KV\_RNS5

Thu 02/17/2022 to Fri 03/25/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD\_ST\_345\_F30

Sun 02/20/2022 to Mon 02/21/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBRK\_345\_W64

Tue 02/22/2022 to Tue 02/22/2022 **UPDATED by CONED 08/31/2021**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

SPRNBRK\_345KV\_RNS5

Tue 02/22/2022 to Tue 02/22/2022 **UPDATED by CONED 08/31/2021**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW\_345\_W99

Tue 02/22/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

MARCY\_\_\_-EDIC\_\_\_\_\_345\_UE1-7

Wed 02/23/2022 to Mon 02/28/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PORTER\_\_-ROTTRDAM\_230\_31**

Tue 03/01/2022 to Tue 12/31/2030  
 0600 Continuous 2359  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**N.SCTLND-LEEDS\_\_\_\_345\_93**

Tue 03/01/2022 to Tue 03/15/2022  
 0700 Continuous 1900  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_\_\_\_-N.SCTLND\_345\_14**

Tue 03/01/2022 to Tue 04/12/2022  
 0700 Continuous 1900  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **1670 MW**  
 Impacts Total Transfer Capability 1305 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_31**

Tue 03/01/2022 to Tue 04/12/2022  
 0700 1900  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **1500 MW**  
 Impacts Total Transfer Capability 1475 MW  
 TTC with All Lines In Service 2975 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**N.SCTLND-ALPS\_\_\_\_345\_2**

Tue 03/01/2022 to Tue 05/24/2022  
 0700 Continuous 1900  
 Work scheduled by: NGrid

FWD  
 (Import)  
 SCH - NE - NY **900 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-ALPS</b> _____ <b>345_2</b>		FWD	REV
Tue 03/01/2022 to Tue 05/24/2022			(Import) (Export)
0700 Continuous 1900		SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
<b>GOETHALS_345KV_5</b>			
Sat 03/05/2022 to Mon 04/04/2022	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>03/26/2021</u></b>
0001 Continuous 0200		STATEN ISLAND	
Work scheduled by: ConEd		Impacts Total Transfer Capability	
		TTC with All Lines In Service	
<hr/>			
<b>LINDEN_-GOETHALS_230_A2253</b>			
Sat 03/05/2022 to Mon 04/04/2022	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>03/26/2021</u></b>
0001 Continuous 0200		SCH - PJ - NY	
Work scheduled by: ConEd		Impacts Total Transfer Capability	
		TTC with All Lines In Service	
<hr/>			
<b>INDPDNCE-SCRIBA</b> _____ <b>345_25</b>			FWD
Thu 03/10/2022 to Wed 03/16/2022			(Import)
0800 Continuous 1800		OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>			FWD
Thu 03/17/2022 to Sun 03/20/2022			(Import)
0100 2200		UPNY CONED	<b>3800 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	4015 MW
		TTC with All Lines In Service	7815 MW
<hr/>			
<b>PLSNTVLY-WOOD_ST</b> _____ <b>345_F30</b>			FWD
Mon 03/21/2022 to Wed 03/23/2022			(Import)
0001 Continuous 2200		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	3815 MW
		TTC with All Lines In Service	7815 MW
<hr/>			
<b>EASTVIEW-SPRBRK</b> _____ <b>345_W64</b>			FWD
Mon 03/21/2022 to Mon 03/21/2022	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>08/31/2021</u></b>
0130 Continuous 0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd		Impacts Total Transfer Capability	3465 MW
		TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>				FWD	
Mon 03/21/2022	to	Mon 03/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>
0130	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	<b>3200 MW</b>
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>				FWD	
Sat 03/26/2022	to	Mon 03/28/2022			
0001		2200			
Work scheduled by:				UPNY CONED	<b>3800 MW</b>
				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<b>ATHENS__-PLSNTVLY_345_91</b>				FWD	
Sat 03/26/2022	to	Sun 05/01/2022			
0001	Continuous	2200			
Work scheduled by: ConEd				UPNY CONED	<b>3800 MW</b>
				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<b>PLSNTVLY_345KV_RNS4</b>				FWD	
Sat 03/26/2022	to	Sun 05/01/2022			
0001	Continuous	2200			
Work scheduled by: ConEd				UPNY CONED	<b>3800 MW</b>
				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<b>PLSNTVLY-WOOD_ST__345_F31</b>				FWD	
Tue 03/29/2022	to	Wed 03/30/2022			
0001	Continuous	2200			
Work scheduled by: ConEd				UPNY CONED	<b>4000 MW</b>
				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>				FWD	REV
Sun 04/03/2022	to	Sat 04/09/2022			
1400	Continuous	1400			
Work scheduled by: PJM				SCH - PJM_VFT	<b>0 MW</b> <b>0 MW</b>
				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
<b>SPRNBK_-TREMONT__345_X28</b>				FWD	
Tue 04/05/2022	to	Wed 04/06/2022			
0201	Continuous	0300			
Work scheduled by: ConEd				SPR/DUN-SOUTH	<b>4200 MW</b>
				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Wed 04/06/2022	to	Wed 04/06/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0301	Continuous	0330				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD	
Wed 04/06/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0301	Continuous	0300				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0230	Continuous	0300				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				<b>4350 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
<b>SPRNBK__345KV_RNS5</b>					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				<b>3200 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD	
Thu 04/07/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	2200				<b>7550 MW</b>
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
<b>PANNELL_-CLAY_____345_1</b>					FWD	
Mon 04/11/2022	to	Fri 04/15/2022				(Import)
0700	Continuous	1530				<b>1300 MW</b>
Work scheduled by: NYPA					WEST CENTRAL	
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PORTER\_\_-ROTTRDAM\_230\_30**

Wed 04/13/2022 to Tue 12/31/2030  
 0600 Continuous 2359  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

**PANNELL\_-CLAY\_\_\_\_\_345\_2**

Mon 04/18/2022 to Fri 04/22/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**EDIC\_\_\_-FRASER\_\_\_345\_EF24-40**

Thu 04/21/2022 to Tue 06/14/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sat 04/23/2022 to Tue 04/26/2022  
 0001 2200  
 Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F31**

Wed 04/27/2022 to Fri 04/29/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345\_230\_AT4**

Fri 04/29/2022 to Fri 04/29/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA

REV (Export) **1750 MW**  
 SCH - OH - NY  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 2000 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Mon 05/02/2022 to Mon 05/02/2022  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBRK\_\_345\_W79**

Mon 05/02/2022 to Thu 05/05/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**ROCHESTR-PANNELL\_\_345\_RP2**

Mon 05/02/2022 to Fri 05/06/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Thu 05/05/2022 to Thu 05/05/2022  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**SPRNBRK\_-TREMONT\_\_345\_X28**

Fri 05/06/2022 to Mon 05/09/2022 **UPDATED by CONED 08/19/2021**  
 0201 Continuous 1800  
 Work scheduled by: ConEd

FWD (Import)  
 SPR/DUN-SOUTH **4200 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 4600 MW

**FRASER\_\_345\_FRASER SVC**

Mon 05/09/2022 to Fri 05/13/2022  
 0800 Continuous 1700  
 Work scheduled by: NYSEG

FWD (Import)  
 CENTRAL EAST - VC **2935 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						
Mon 05/16/2022	to	Fri 05/27/2022				
0600	Continuous	1800		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600		SCH - PJ - NY		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>HOMR_NYW-PIERC_NY_345_48</b>						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600		SCH - PJ - NY		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>NIAGARA_-PACKARD_230_62</b>						
Sat 06/18/2022	to	Sat 06/18/2022				
0500	Continuous	1700		SCH - OH - NY	700 MW	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1250 MW
					TTC with All Lines In Service	1950 MW
<b>NIAGARA_345_230_AT4</b>						
Tue 06/28/2022	to	Wed 06/29/2022				
0500	Continuous	1700		SCH - OH - NY	1900 MW	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<b>BECK_-NIAGARA_230_PA27</b>						
Tue 07/05/2022	to	Sat 07/09/2022				
0500	Continuous	2100		SCH - OH - NY		
Work scheduled by: NYPA					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>ROCHESTR-PANNELL_345_RP1</b>						
Mon 07/25/2022	to	Fri 07/29/2022				
0500	Continuous	2100		DYSINGER EAST	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**PANNELL\_-CLAY\_345\_1**

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**FRASER\_-GILBOA\_345\_GF5-35**

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**SPRNBRK\_345KV\_RNS5**

Mon 09/19/2022 to Mon 09/19/2022  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 09/17/2020**

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**SPRNBRK\_-W49TH\_ST\_345\_M51**

Mon 09/19/2022 to Wed 09/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

**UPDATED by CONED 09/17/2020**

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**PANNELL\_-CLAY\_345\_2**

Mon 09/19/2022 to Fri 09/23/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**SPRNBRK\_345KV\_RNS5**

Wed 09/21/2022 to Wed 09/21/2022  
2130 Continuous 2200

Work scheduled by: ConEd

**UPDATED by CONED 09/17/2020**

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBRK_-W49TH_ST_345_M51</b>				FWD
Sat 10/01/2022	to	Mon 10/17/2022	<b>UPDATED</b>	(Import)
0001	Continuous	0300	<b>by CONED 08/01/2020</b>	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>SPRNBRK_345KV_RNS5</b>				FWD
Sat 10/01/2022	to	Mon 10/17/2022	<b>UPDATED</b>	(Import)
0001	Continuous	0300	<b>by CONED 08/01/2020</b>	SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD
Mon 10/03/2022	to	Fri 10/21/2022		(Import) (Export)
0600	Continuous	1800		SCH - NPX_CSC <b>0 MW 0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 330 MW 330 MW
				TTC with All Lines In Service 330 MW 330 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_1</b>				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 10, 2021 to Tuesday ,April 11, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**GILBOA\_\_-N.SCTLND\_345\_GNS-1**

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

**LEEDS\_\_\_\_345KV\_R94301**

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**MARCY\_\_-N.SCTLND\_345\_18**

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

**N.SCTLND-LEEDS\_\_\_\_345\_94**

Mon 10/31/2022 to Mon 11/28/2022  
0500 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**PORTER\_\_-ROTTRDAM\_230\_30 & MARCY\_\_-N.SCTLND\_345\_18**

Mon 10/31/2022 to Mon 11/28/2022  
0500 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

**PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_-N.SCTLND\_345\_18**

Mon 10/31/2022 to Mon 11/28/2022  
0500 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW