

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: ConEd					SCH - PJ - NY	2050 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Tue 11/30/2021				(Import) (Export)
0001		2359				2000 MW 1150 MW
Work scheduled by:					SCH - PJ - NY	2000 MW 1150 MW
					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: ConEd					SCH - PJ - NY	2050 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>07/08/2021</u>	
0456	Continuous	1600				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>NEWBRDGE_345_138_BK_1</b>					FWD	
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>01/12/2021</u>	(Import)
1807	Continuous	2359				375 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	375 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_1600</b>					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	1900 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	2100 MW
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_1400</b>						FWD
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1950 MW
<b>SCH-NYISO-IMO_LIMIT_1200</b>						REV
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Export)
0600	Continuous	1300				1500 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1700 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>						FWD
Tue 09/07/2021	to	Fri 10/22/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/07/2021</u>	(Import)
0700	Continuous	2359				80 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 110 MW
						TTC with All Lines In Service 190 MW
<b>E13THSTA-FARRAGUT_345_46</b>						FWD
Wed 09/15/2021	to	Fri 10/08/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/13/2021</u>	(Import)
0001	Continuous	0500				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>W49TH_ST-E13THSTA_345_M55</b>						FWD
Wed 09/15/2021	to	Fri 10/08/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>10/13/2021</u>	(Import)
0001	Continuous	0500				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>PORTER_-ROTTRDAM_230_30</b>						FWD
Wed 09/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0700	Continuous	1730				2805 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
<b>EDIC_-N.SCTLND_345_14</b>						FWD
Thu 09/16/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0600	Continuous	1830				1670 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 1305 MW
						TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EDIC -N.SCTLND\_345\_14 & PORTER -ROTTDAM\_230\_30**

Thu 09/16/2021 to Sun 11/14/2021  
0600 1830

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sat 09/18/2021 to Fri 11/05/2021 UPDATED by PJM 10/08/2021  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SCH-NYISO-NE\_LIMIT\_600**

Sun 09/26/2021 to Sat 10/23/2021 UPDATED by ISONE 10/02/2021  
0701 Daily 2300

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1600 MW

**LEEDS -HURLYAVE\_345\_301**

Mon 09/27/2021 to Sun 10/10/2021 UPDATED by CH 10/09/2021  
0800 Continuous 0133

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

**NIAGARA -STA\_255\_345\_NH2**

Sat 10/02/2021 to Sun 10/17/2021 UPDATED by NYPA 10/02/2021  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1400 MW**  
Impacts Total Transfer Capability 1750 MW  
TTC with All Lines In Service 3150 MW

**SCH-NE-NYISO\_LIMIT\_300**

Sat 10/02/2021 to Sun 10/24/2021 UPDATED by ISONE 10/02/2021  
2301 Daily 0700

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1200**

Sat 10/02/2021 to Sun 10/24/2021 UPDATED by ISONE 10/02/2021  
2301 Daily 0700

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1400 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Sun 10/03/2021 to Tue 11/23/2021  
0500 Continuous 2000

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Sun 10/03/2021 to Tue 11/23/2021  
0500 Continuous 2000

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 10/03/2021 to Mon 10/18/2021 **UPDATED by ISONE 10/02/2021**  
0701 Daily 2300

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### CLAY -EDIC 345\_2-15

Mon 10/04/2021 to Sat 10/30/2021 **UPDATED by NYPA 08/16/2021**  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Mon 10/04/2021 to Sat 10/09/2021 **EXTENDED by NGRID 10/07/2021**  
0800 Continuous 1630

Work scheduled by: NGrid

**ARR: 75**

FWD

(Import)

OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### SCH-HQ-NYISO\_LIMIT\_1200

Thu 10/07/2021 to Tue 11/23/2021  
0001 Continuous 2000

Work scheduled by: HQ

FWD

(Import)

SCH - HQ - NY **1200 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1500 MW

### W49TH\_ST\_345KV\_6

Fri 10/08/2021 to Fri 10/08/2021 **UPDATED by CONED 10/13/2021**  
0430 Continuous 0500

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___345KV_R94301</b>					FWD
Fri 10/08/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>
1530	Continuous	0132			
Work scheduled by: CHGE					(Import)
					UPNY CONED <b>3800 MW</b>
					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD
Sat 10/09/2021	to	Sun 10/10/2021			
0001	Continuous	0200			
Work scheduled by: ConEd					(Import)
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>EFISHKIL-WOOD_ST__345_F38</b>					FWD
Sat 10/09/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED <b>4000 MW</b>
					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD
Sat 10/09/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED <b>4000 MW</b>
					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD
Sat 10/09/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED <b>7210 MW</b>
					Impacts Total Transfer Capability 605 MW
					TTC with All Lines In Service 7815 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD
Sat 10/09/2021	to	Sat 10/09/2021	<u>CANCELLED</u>	<u>by NGrid</u>	<u>10/09/2021</u>
0800	Daily	0830			
Work scheduled by: NGrid					(Import)
					UPNY CONED <b>3800 MW</b>
					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
<b>LEEDS___-PLSNTVLY_345_92</b>					FWD
Sat 10/09/2021	to	Sat 10/09/2021	<u>CANCELLED</u>	<u>by NGrid</u>	<u>10/09/2021</u>
0800	Daily	1500			
Work scheduled by: NGrid					(Import)
					UPNY CONED <b>3800 MW</b>
					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Sat 10/09/2021	to	Sat 10/09/2021	<b>CANCELLED</b>	<b>by NGrid</b>	<b>10/09/2021</b>	(Import)
1430	Daily	1500				UPNY CONED <b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
<b>OSWEGO_-ELBRIDGE_345_17</b>					FWD	
Sat 10/09/2021	to	Sat 10/09/2021	<b>EXTENDED</b>	<b>by NGRID</b>	<b>10/07/2021</b>	(Import)
1600	Continuous	1630				OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>SCH-IMO-NYISO_LIMIT_600</b>					FWD	
Mon 10/11/2021	to	Fri 10/15/2021	<b>EXTENDED</b>	<b>by IESO</b>	<b>10/12/2021</b>	(Import)
0500	Continuous	1600				SCH - OH - NY <b>900 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	1950 MW
<b>SCH-NYISO-IMO_LIMIT_500</b>					REV	
Mon 10/11/2021	to	Fri 10/15/2021	<b>EXTENDED</b>	<b>by IESO</b>	<b>10/12/2021</b>	(Export)
0500	Continuous	1600				SCH - OH - NY <b>800 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1700 MW
<b>LEEDS___345KV_R94301</b>					FWD	
Mon 10/11/2021	to	Mon 10/11/2021	<b>UPDATED</b>	<b>by CH</b>	<b>10/09/2021</b>	(Import)
0700	Continuous	0800				UPNY CONED <b>3800 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
<b>LEEDS___-HURLYAVE_345_301</b>					FWD	
Mon 10/11/2021	to	Fri 10/29/2021	<b>UPDATED</b>	<b>by CH</b>	<b>10/09/2021</b>	(Import)
0700	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW
<b>EFISHKIL-WOOD_ST__345_F38</b>					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<b>UPDATED</b>	<b>by CONED</b>	<b>09/24/2021</b>	(Import)
0130	Continuous	0200				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
<hr/>						
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				<b>7210 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 605 MW
						TTC with All Lines In Service 7815 MW
<hr/>						
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	0230				<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
<hr/>						
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD	
Tue 10/12/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	2200				<b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
<hr/>						
<b>CEDARS_-ROSEMNTB_115_2/22</b>					FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import) (Export)
0500	Continuous	2359				<b>95 MW 40 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 95 MW 60 MW
						TTC with All Lines In Service 190 MW 100 MW
<hr/>						
<b>DENNISON-ROSEMNTB_115_2/22</b>					FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import) (Export)
0500	Continuous	2359				<b>95 MW 40 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 95 MW 60 MW
						TTC with All Lines In Service 190 MW 100 MW
<hr/>						
<b>SCH-NE-NYISO_LIMIT_100</b>					FWD	
Tue 10/12/2021	to	Wed 10/20/2021				(Import)
2300	Daily	0659				<b>300 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability 1100 MW
						TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

Wed 10/13/2021 to Fri 10/15/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

**CANCELLED by ConEd 10/13/2021**

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Wed 10/13/2021 to Fri 10/15/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

**CANCELLED by ConEd 10/13/2021**

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 10/13/2021 to Wed 10/13/2021  
 2130 Continuous 2200  
 Work scheduled by: ConEd

**UPDATED by CE 10/12/2021**

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Thu 10/14/2021 to Thu 10/14/2021  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**UPDATED by CONED 08/04/2021**

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Thu 10/14/2021 to Sat 10/16/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

**UPDATED by CONED 08/04/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

Thu 10/14/2021 to Sat 10/16/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

**UPDATED by CONED 08/04/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_345\_W78**

Thu 10/14/2021 to Sat 10/16/2021  
 0001 Continuous 0100  
 Work scheduled by: ConEd

**UPDATED by CONED 08/04/2021**

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_5

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_7

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPRNBRK\_-DUNWODIE\_345\_W75

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPRNBRK\_345KV\_RNS3

Thu 10/14/2021 to Sun 11/28/2021  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SCH-NYISO-HQ\_LIMIT\_300

Thu 10/14/2021 to Sun 10/17/2021 **UPDATED by HQ 10/07/2021**  
0600 Daily 1800

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **300 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1000 MW

OSWEGO\_-VOLNEY\_345\_12

Thu 10/14/2021 to Thu 10/14/2021  
1100 Daily(No Weekends) 1400

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

ELBRIDGE-LAFAYTTE\_345\_17-LE

Fri 10/15/2021 to Fri 10/15/2021  
0830 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

ARR: 75

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**OSWEGO\_\_-ELBRIDGE\_345\_17**

Fri 10/15/2021 to Fri 10/15/2021  
0830 Daily(No Weekends) 1630

Work scheduled by: NGrid

**ARR: 75**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**SPRNRBK\_345KV\_RS3 & SPRNRBK\_345KV\_RS4**

Sat 10/16/2021 to Tue 10/19/2021  
0001 0200

Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Sat 10/16/2021 to Sat 10/16/2021  
0030 Continuous 0100

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Sat 10/16/2021 to Mon 10/18/2021  
0101 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CE 10/01/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Sat 10/16/2021 to Mon 10/18/2021  
0101 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CE 10/01/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**CLAY\_\_\_-INPDNCE\_345\_26**

Sat 10/16/2021 to Sat 10/16/2021  
0800 Daily 1000

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5000 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 5250 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sun 10/17/2021 to Sun 10/17/2021  
0001 0200

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					
Sun 10/17/2021	to	Sun 10/17/2021			
0001		0200	SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	130 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC2</b>				FWD	
Sun 10/17/2021	to	Sun 10/17/2021		(Import)	
0001	Continuous	0200	MOSES SOUTH	<b>2850 MW</b>	
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>					REV
Sun 10/17/2021	to	Sun 10/17/2021			(Export)
0001	Continuous	0200	SCH - HQ - NY		<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>				FWD	
Sun 10/17/2021	to	Sun 10/17/2021		(Import)	
0001	Continuous	0200	SCH - HQ - NY	<b>1150 MW</b>	
Work scheduled by: HQ				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	1500 MW
<b>CEDARS__-ROSEMNTA_115_1/11</b>				FWD	REV
Mon 10/18/2021	to	Thu 10/21/2021		(Import)	(Export)
0500	Continuous	2359	SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	95 MW 60 MW
				TTC with All Lines In Service	190 MW 100 MW
<b>DENNISON-ROSEMNTA_115_1/11</b>				FWD	REV
Mon 10/18/2021	to	Thu 10/21/2021		(Import)	(Export)
0500	Continuous	2359	SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	95 MW 60 MW
				TTC with All Lines In Service	190 MW 100 MW
<b>NIAGARA_-KINTIGH_345_NS1-38</b>				FWD	
Mon 10/18/2021	to	Sat 12/04/2021	<b>UPDATED by NYPA 08/20/2021</b>	(Import)	
0500	Continuous	1900	DYSINGER EAST	<b>1400 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1750 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday ,April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_600</b>					FWD	
Mon 10/18/2021	to	Tue 10/19/2021	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/02/2021</b>	(Import)
2301	Daily	0700				<b>800 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_600</b>					FWD	
Tue 10/19/2021	to	Sat 10/23/2021	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/02/2021</b>	(Import)
0701	Daily	2300				<b>800 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1400 MW
<b>ROTTDAM-EASTOVER_230_38</b>					REV	
Wed 10/20/2021	to	Wed 10/20/2021				(Export)
0730	Daily(No Weekends)	1059				<b>1400 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	1600 MW
<b>SCH-NE-NYISO_LIMIT_900</b>					FWD	
Thu 10/21/2021	to	Fri 10/29/2021				(Import)
1700	Continuous	1600				<b>1100 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_600</b>					FWD	
Sun 10/24/2021	to	Sun 10/24/2021	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/02/2021</b>	(Import)
0701	Daily	1600				<b>800 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_600</b>					REV	
Sun 10/24/2021	to	Sun 10/24/2021	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/02/2021</b>	(Export)
0701	Daily	1600				<b>800 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	1600 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 10/25/2021	to	Sun 11/21/2021				(Import) (Export)
0700	Continuous	1600				<b>0 MW 0 MW</b>
Work scheduled by: ISONE					SCH - NPX_CSC	Impacts Total Transfer Capability 330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>CEDARS__-ROSEMNTB_115_2/22</b>						
Tue 10/26/2021	to	Thu 10/28/2021				
0300	Continuous	0200			SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	95 MW 60 MW
					TTC with All Lines In Service	190 MW 100 MW
<b>DENNISON-ROSEMNTB_115_2/22</b>						
Tue 10/26/2021	to	Thu 10/28/2021				
0300	Continuous	0200			SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	95 MW 60 MW
					TTC with All Lines In Service	190 MW 100 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_140</b>						
Tue 10/26/2021	to	Thu 10/28/2021				
0300	Continuous	0200			SCH - HQ_CEDARS	<b>140 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	190 MW
<b>LEEDS___345KV_R94301</b>						
Fri 10/29/2021	to	Fri 10/29/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	
1500	Continuous	1600			UPNY CONED	<b>3800 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
<b>W49TH_ST_345KV_7</b>						
Sat 10/30/2021	to	Sat 10/30/2021				
0001	Continuous	0030			SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_5</b>						
Sat 10/30/2021	to	Sun 12/05/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	
0001	Continuous	0300			SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
<b>LEEDS___-ATHENS___345_95</b>						
Sat 10/30/2021	to	Sat 10/30/2021				
0800	Daily(No Weekends)	1500			UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___345KV_R395</b>					FWD		
Sat 10/30/2021	to	Sat 10/30/2021			(Import)		
0800	Daily(No Weekends)	1500		UPNY CONED	<b>3800 MW</b>		
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW	
					TTC with All Lines In Service	7815 MW	
<b>BUCHAN_S-MILLWOOD_345_W97</b>					FWD		
Mon 11/01/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0001	Continuous	0200				UPNY CONED	
Work scheduled by: ConEd					Impacts Total Transfer Capability	<b>7680 MW</b>	
					TTC with All Lines In Service	7815 MW	
<b>SCH-IMO-NYISO_LIMIT_1750</b>					FWD		
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)	
0001	Continuous	2359				SCH - OH - NY	
Work scheduled by: IESO					Impacts Total Transfer Capability	<b>2050 MW</b>	
					TTC with All Lines In Service	2300 MW	
<b>SCH-NYISO-IMO_LIMIT_1600</b>						REV	
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)	
0001	Continuous	2359				SCH - OH - NY	
Work scheduled by: IESO					Impacts Total Transfer Capability	<b>1900 MW</b>	
					TTC with All Lines In Service	100 MW	
						2000 MW	
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD		
Mon 11/01/2021	to	Wed 11/03/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	0200				UPNY CONED	
Work scheduled by: ConEd					Impacts Total Transfer Capability	<b>7560 MW</b>	
					TTC with All Lines In Service	255 MW	
						7815 MW	
<b>W49TH_ST_345KV_7</b>					FWD		
Tue 11/02/2021	to	Tue 11/02/2021				(Import)	
0200	Continuous	0230				SCH - PJM_HTP	
Work scheduled by: ConEd					Impacts Total Transfer Capability	<b>300 MW</b>	
					TTC with All Lines In Service	360 MW	
						660 MW	
<b>LINDN_CG-LNDVFT___345_V-3022</b>					FWD	REV	
Tue 11/02/2021	to	Fri 11/05/2021				(Import)	(Export)
0800	Continuous	1500				SCH - PJM_VFT	
Work scheduled by: PJM					Impacts Total Transfer Capability	<b>0 MW</b>	<b>0 MW</b>
					TTC with All Lines In Service	315 MW	315 MW
						315 MW	315 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD\_345KV\_18**

Wed 11/03/2021 to Fri 11/12/2021  
0001 Continuous 1800

Work scheduled by: ConEd

**UPDATED by CE 10/12/2021**

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

FWD  
(Import)

**BUCHAN\_S-MILLWOOD\_345\_W98**

Wed 11/03/2021 to Tue 11/09/2021  
0201 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CE 10/12/2021**

UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

FWD  
(Import)

**OSWEGO\_\_-VOLNEY\_\_345\_11**

Wed 11/03/2021 to Wed 11/03/2021  
1100 Daily(No Weekends) 1300

Work scheduled by: NGrid

OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

FWD  
(Import)

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 11/05/2021 to Mon 11/08/2021  
1601 Continuous 0800

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**SHORE\_RD\_345\_138\_BK 1**

Mon 11/08/2021 to Wed 11/10/2021  
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

FWD  
(Import)

**LADENTWN-BUCHAN\_S\_345\_Y88**

Wed 11/10/2021 to Tue 11/16/2021  
0201 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CE 10/12/2021**

UPNY CONED **7560 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 7815 MW

FWD  
(Import)

**SHORE\_RD\_345\_138\_BK 2**

Thu 11/11/2021 to Fri 11/12/2021  
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**GOETHALS\_345KV\_5**

Fri 11/12/2021 to Tue 11/16/2021 **UPDATED** **by CONED** **06/30/2021**

0001 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**BERKSHIR-ALPS\_345\_393**

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

**ARR: 78**

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **1100 MW 1700 MW**  
 Impacts Total Transfer Capability 300 MW 0 MW  
 TTC with All Lines In Service 1400 MW 1700 MW

-----  
**BERKSHIR-ALPS\_345\_393**

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

**ARR: 78**

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

-----  
**BERKSHIR-ALPS\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by:

**ARR: 78**

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **1100 MW 1700 MW**  
 Impacts Total Transfer Capability 300 MW 0 MW  
 TTC with All Lines In Service 1400 MW 1700 MW

-----  
**BERKSHIR-NORTHFLD\_345\_312**

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **1300 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 1400 MW

-----  
**BERKSHIR-NORTHFLD\_345\_312**

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

-----  
**SCH-NE-NYISO\_LIMIT\_800**

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

FWD  
 (Import)  
 SCH - NE - NY **1000 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 1400 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULED WORK				IMPACTS	
Start Date	End Date	Time	Work	Impact	Limit
<b>SCH-NYISO-NE_LIMIT_700</b>					
Sun 11/14/2021	to	Wed 11/24/2021			
0700		1600	Continuous	SCH - NE - NY	900 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	1700 MW
<b>PORTER -ROTTDAM_230_30 &amp; MASSENA -MARCY_765_MSU1</b>					
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1730	Continuous	CENTRAL EAST - VC	1500 MW
Work scheduled by:				Impacts Total Transfer Capability	1475 MW
				TTC with All Lines In Service	2975 MW
<b>CHATGUAY-MASSENA_765_7040</b>					
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1859	Continuous	MOSES SOUTH	1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>					
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1859	Continuous	SCH - HQ - NY	0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	1500 MW
<b>MARCY_765_345_AT1</b>					
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1859	Continuous	MOSES SOUTH	1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
<b>MARCY_765_345_AT2</b>					
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1859	Continuous	MOSES SOUTH	1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY_765_MSU1</b>					
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1859	Continuous	CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1305 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	
0100	Continuous	1859		MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY 765_MSU1</b>				FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	(Export)
0100	Continuous	1859		SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA -MARCY 765_MSU1</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	
0100	Continuous	1859		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	
0100		1859		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	(Export)
0100		1859		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	
0100		1859		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
<b>STLAWRNC-MOSES 230_L33P &amp; MASSENA -MARCY 765_MSU1</b>				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<b>UPDATED by NYISO 06/03/2021</b>	(Import)	
0100		1859		SCH - HQ_CEDARS	<b>90 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday ,April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___- MASSENA_230_MMS2					FWD (Import)
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1859			SCH - HQ_CEDARS <b>90 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 109 MW
					TTC with All Lines In Service 199 MW
MILLWOOD-EASTVIEW_345_W85					FWD (Import)
Wed 11/17/2021	to	Wed 11/17/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>10/12/2021</u>
0001	Continuous	0030			UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW
DUNWODIE-MOTTHAVN_345_72					FWD (Import)
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/12/2021</u>
0001	Continuous	0200			SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8					FWD (Import)
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/12/2021</u>
0001	Continuous	0200			SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK__345_W78					FWD (Import)
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>10/12/2021</u>
0001	Continuous	0200			UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
W49TH_ST_345KV_7					FWD (Import)
Sat 11/20/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>
0001	Continuous	0030			SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					FWD (Import)
Mon 11/22/2021	to	Sun 11/28/2021			
0001		0200			SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Mon 11/22/2021 to Mon 11/22/2021  
 0130 Continuous 0200  
 Work scheduled by: ConEd

EXTENDED by CE 10/12/2021

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 11/22/2021 to Sun 11/28/2021  
 0201 Continuous 0100  
 Work scheduled by: ConEd

UPDATED by CE 10/01/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Mon 11/22/2021 to Sun 11/28/2021  
 0201 Continuous 0100  
 Work scheduled by: ConEd

UPDATED by CE 10/01/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_7**

Thu 11/25/2021 to Fri 12/03/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**SPRNBK\_\_345KV\_RNS4**

Sun 11/28/2021 to Sun 11/28/2021  
 0300 Continuous 0330  
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBK\_-W49TH\_ST\_345\_M52**

Sun 11/28/2021 to Wed 12/01/2021  
 0300 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 11/29/2021 to Fri 12/17/2021  
 0600 Continuous 1600  
 Work scheduled by: PJM

UPDATED by PJM 09/15/2021

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE-DUFFYAVE_345_501</b>						FWD	
Mon 11/29/2021	to	Fri 12/17/2021	<b>UPDATED</b>	<b>by PJM</b>	<b>09/15/2021</b>	(Import)	
0600	Continuous	1600				SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>						FWD	
Mon 11/29/2021	to	Fri 12/17/2021	<b>UPDATED</b>	<b>by PJM</b>	<b>09/15/2021</b>	(Import)	
0600	Continuous	1600				SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	285 MW
						TTC with All Lines In Service	660 MW
<b>BERKSHIR-ALPS_345_393</b>						FWD	REV
Mon 11/29/2021	to	Sat 12/18/2021				(Import) (Export)	
0700	Continuous	1600				SCH - NE - NY	<b>1100 MW 1700 MW</b>
Work scheduled by: ISONE				<b>ARR: 78</b>		Impacts Total Transfer Capability	300 MW 0 MW
						TTC with All Lines In Service	1400 MW 1700 MW
<b>BERKSHIR-ALPS_345_393</b>						FWD	REV
Mon 11/29/2021	to	Sat 12/18/2021				(Import) (Export)	
0700	Continuous	1600				SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE				<b>ARR: 78</b>		Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS_345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 11/29/2021	to	Sat 12/18/2021				(Import) (Export)	
0700		1600				SCH - NE - NY	<b>1100 MW 1700 MW</b>
Work scheduled by:				<b>ARR: 78</b>		Impacts Total Transfer Capability	300 MW 0 MW
						TTC with All Lines In Service	1400 MW 1700 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	
Mon 11/29/2021	to	Sat 12/18/2021				(Import)	
0700	Continuous	1600				SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD	REV
Mon 11/29/2021	to	Sat 12/18/2021				(Import) (Export)	
0700	Continuous	1600				SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work Scheduled by	Impact	TTC with All Lines In Service
SCH-NE-NYISO_LIMIT_800	Mon 11/29/2021	Sat 12/18/2021	0700	Continuous	ISONE	SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>1000 MW</b> 400 MW 1400 MW
SCH-NYISO-NE_LIMIT_700	Mon 11/29/2021	Sat 12/18/2021	0700	Continuous	ISONE	SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service	REV (Export) <b>900 MW</b> 800 MW 1700 MW
HURLYAVE-ROSETON_345_303	Mon 11/29/2021	Sun 12/05/2021	0800	Continuous	CHGE	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>4100 MW</b> 3715 MW 7815 MW
NIAGARA_PACKARD_230_61	Tue 11/30/2021	Mon 12/06/2021	0615	Continuous	NGrid	SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) (Export) <b>1200 MW 1850 MW</b> 1100 MW 150 MW 2300 MW 2000 MW
SPRNBRK_345KV_RNS4	Wed 12/01/2021	Wed 12/01/2021	0130	Continuous	ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>3200 MW</b> 1400 MW 4600 MW
MOSES_ADIRNDCK_230_MA1	Wed 12/01/2021	Tue 05/31/2022	0700	Continuous	NYPA	MOSES SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>2300 MW</b> 850 MW 3150 MW
SPRNBRK_345KV_RNS4	Fri 12/03/2021	Sat 12/04/2021	0001	Continuous	ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) <b>3200 MW</b> 1400 MW 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-W49TH_ST_345_M52</b>					FWD
Fri 12/03/2021 to Sat 12/18/2021					(Import)
0201	Continuous	0200			SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>MARCY_-EDIC_345_UE1-7</b>					FWD
Fri 12/03/2021 to Fri 12/03/2021					(Import)
0700	Daily(No Weekends)	1000			OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
<b>ARR: 19&amp;16</b>					TTC with All Lines In Service 5250 MW
<b>MILLWOOD_345KV_18</b>					FWD
Mon 12/06/2021 to Fri 12/10/2021					(Import)
0001	Continuous	0200	<b>UPDATED</b>	<b>by CE</b>	<b>10/12/2021</b>
Work scheduled by: ConEd					UPNY CONED <b>4350 MW</b>
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>W49TH_ST_345KV_5</b>					FWD
Mon 12/06/2021 to Sat 12/18/2021					(Import)
0001	Continuous	0200			SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
<b>MARCY_345KV_CSC</b>					FWD
Mon 12/06/2021 to Fri 12/17/2021					(Import)
0700	Continuous	1730			CENTRAL EAST - VC <b>2925 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2975 MW
<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD
Tue 12/07/2021 to Fri 12/10/2021					(Import)
0201	Continuous	0200	<b>UPDATED</b>	<b>by CE</b>	<b>10/12/2021</b>
Work scheduled by: ConEd					UPNY CONED <b>7680 MW</b>
					Impacts Total Transfer Capability 135 MW
					TTC with All Lines In Service 7815 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD
Tue 12/07/2021 to Fri 12/10/2021					(Import)
0201	Continuous	0200	<b>UPDATED</b>	<b>by CE</b>	<b>10/12/2021</b>
Work scheduled by: ConEd					UPNY CONED <b>7560 MW</b>
					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>SPRNBK__345KV_RNS4</b>			FWD
Mon 12/13/2021	to	Tue 12/14/2021	(Import)
0001	Continuous	1800	
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	<b>3200 MW</b>
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
<b>HURLYAVE-ROSETON__345_303</b>			FWD
Mon 12/13/2021	to	Wed 12/22/2021	(Import)
0700	Continuous	1600	
Work scheduled by: CHGE			
		UPNY CONED	<b>4100 MW</b>
		Impacts Total Transfer Capability	3715 MW
		TTC with All Lines In Service	7815 MW
<hr/>			
<b>SPRNBK__345KV_RNS4</b>			FWD
Sat 12/18/2021	to	Sat 12/18/2021	(Import)
0130	Continuous	0200	
Work scheduled by: ConEd			
		SPR/DUN-SOUTH	<b>3200 MW</b>
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
<hr/>			
<b>FRASER__345_FRASER SVC</b>			FWD
Tue 01/04/2022	to	Mon 02/28/2022	(Import)
0700	Continuous	1730	
Work scheduled by: NYPA			
		<b>UPDATED</b> <b>by NYPA</b> <b>05/25/2021</b>	
		CENTRAL EAST - VC	<b>2935 MW</b>
		Impacts Total Transfer Capability	40 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
<b>NIAGARA_-PACKARD__230_61</b>			FWD      REV
Mon 01/17/2022	to	Fri 01/21/2022	(Import) (Export)
0615	Continuous	1900	
Work scheduled by: NGrid			
		SCH - OH - NY	<b>1200 MW 1850 MW</b>
		Impacts Total Transfer Capability	1100 MW 150 MW
		TTC with All Lines In Service	2300 MW 2000 MW
<hr/>			
<b>S.RIPLEY-DUNKIRK__230_68</b>			
Tue 01/18/2022	to	Fri 02/04/2022	
0700	Continuous	1730	
Work scheduled by: NGrid			
		<b>UPDATED</b> <b>by NGRID</b> <b>09/24/2021</b>	
		SCH - PJ - NY	
		Impacts Total Transfer Capability	
		TTC with All Lines In Service	
<hr/>			
<b>NIAGARA_-STA_255__345_NH2</b>			FWD
Fri 01/21/2022	to	Fri 03/04/2022	(Import)
0500	Continuous	1900	
Work scheduled by: NYPA			
		<b>UPDATED</b> <b>by NYPA</b> <b>08/20/2021</b>	
		DYSINGER EAST	<b>1700 MW</b>
		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ATHENS\_\_-PLSNTVLY\_345\_91**

Sat 02/12/2022 to Wed 02/16/2022  
0600 Continuous 1900

Work scheduled by: NGrid

**UPDATED by NGRID 05/07/2021**

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 02/17/2022 to Sat 02/19/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**LEEDS\_\_-PLSNTVLY\_345\_92**

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

Thu 02/17/2022 to Fri 03/25/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Sun 02/20/2022 to Mon 02/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Tue 02/22/2022 to Tue 02/22/2022  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

Tue 02/22/2022 to Tue 02/22/2022  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W99**

Tue 02/22/2022 to Mon 03/21/2022  
0001 Continuous 0200

UPDATED by CONED 08/31/2021

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

**MARCY -EDIC 345 UE1-7**

Wed 02/23/2022 to Mon 02/28/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19&16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**PORTER -ROTTRDAM\_230\_31**

Tue 03/01/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

**N. SCTLND-LEEDS 345\_93**

Tue 03/01/2022 to Tue 03/15/2022  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**EDIC -N. SCTLND\_345\_14**

Tue 03/01/2022 to Tue 04/12/2022  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **1670 MW**  
Impacts Total Transfer Capability 1305 MW  
TTC with All Lines In Service 2975 MW

**EDIC -N. SCTLND\_345\_14 & PORTER -ROTTRDAM\_230\_31**

Tue 03/01/2022 to Tue 04/12/2022  
0700 1900

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

**FRASANX-COOPERS 345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY -FRASANNX\_345\_UCC2-41**

Tue 03/01/2022 to Wed 04/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**N. SCTLND-ALPS 345\_2**

Tue 03/01/2022 to Tue 05/24/2022  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

**N. SCTLND-ALPS 345\_2**

Tue 03/01/2022 to Tue 05/24/2022  
0700 Continuous 1900

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

**GOETHALS\_345KV\_5**

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 03/26/2021**

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**LINDEN -GOETHALS\_230\_A2253**

Sat 03/05/2022 to Mon 04/04/2022  
0001 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 03/26/2021**

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**INDPDNCE-SCRIBA 345\_25**

Thu 03/10/2022 to Wed 03/16/2022  
0800 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY-WOOD\_ST\_\_345\_F30**

Mon 03/21/2022 to Wed 03/23/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

-----  
**EASTVIEW-SPRNBK\_\_345\_W64**

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

-----  
**SPRNBK\_\_345KV\_RNS5**

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sat 03/26/2022 to Mon 03/28/2022  
 0001 2200  
 Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

-----  
**ATHENS\_\_-PLSNTVLY\_345\_91**

Sat 03/26/2022 to Sun 05/01/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

-----  
**PLSNTVLY\_345KV\_RNS4**

Sat 03/26/2022 to Sun 05/01/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

-----  
**PLSNTVLY-WOOD\_ST\_\_345\_F31**

Tue 03/29/2022 to Wed 03/30/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Work Scheduled by	Transfer Type	Import (MW)	Export (MW)
LINDN_CG-LNDVFT 345_V-3022	Sun 04/03/2022	Sat 04/09/2022	1400 Continuous 1400	PJM	SCH - PJM_VFT	0 MW	0 MW
					Impacts Total Transfer Capability	315 MW	315 MW
					TTC with All Lines In Service	315 MW	315 MW
SPRNBRK -TREMONT 345_X28	Tue 04/05/2022	Wed 04/06/2022	0201 Continuous 0300	ConEd	SPR/DUN-SOUTH	4200 MW	
					Impacts Total Transfer Capability	400 MW	
					TTC with All Lines In Service	4600 MW	
BUCHAN_N-EASTVIEW 345_W93	Wed 04/06/2022	Wed 04/06/2022	0301 Continuous 0330	ConEd	UPNY CONED	4350 MW	
					Impacts Total Transfer Capability	3465 MW	
					TTC with All Lines In Service	7815 MW	
EASTVIEW-SPRNBRK 345_W79	Wed 04/06/2022	Thu 04/07/2022	0301 Continuous 0300	ConEd	UPNY CONED	4350 MW	
					Impacts Total Transfer Capability	3465 MW	
					TTC with All Lines In Service	7815 MW	
BUCHAN_N-EASTVIEW 345_W93	Thu 04/07/2022	Thu 04/07/2022	0230 Continuous 0300	ConEd	UPNY CONED	4350 MW	
					Impacts Total Transfer Capability	3465 MW	
					TTC with All Lines In Service	7815 MW	
EASTVIEW-SPRNBRK 345_W64	Thu 04/07/2022	Thu 04/07/2022	0301 Continuous 0330	ConEd	UPNY CONED	4350 MW	
					Impacts Total Transfer Capability	3465 MW	
					TTC with All Lines In Service	7815 MW	
SPRNBRK 345KV_RNS5	Thu 04/07/2022	Thu 04/07/2022	0301 Continuous 0330	ConEd	SPR/DUN-SOUTH	3200 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W99**

Thu 04/07/2022 to Tue 04/26/2022  
0301 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

**PANNELL -CLAY\_345\_1**

Mon 04/11/2022 to Fri 04/15/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**PORTER -ROTTRDAM\_230\_30**

Wed 04/13/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

**PANNELL -CLAY\_345\_2**

Mon 04/18/2022 to Fri 04/22/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**EDIC -FRASER\_345\_EF24-40**

Thu 04/21/2022 to Tue 06/14/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sat 04/23/2022 to Tue 04/26/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRBRK\_345\_W64**

Tue 04/26/2022 to Tue 04/26/2022  
2130 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>				FWD
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/31/2021</u>	(Import)
2130	Continuous	2200		SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>PLSNTVLY-WOOD_ST__345_F31</b>				FWD
Wed 04/27/2022	to	Fri 04/29/2022		(Import)
0001	Continuous	2200		UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW
<b>NIAGARA__345_230_AT4</b>				REV
Fri 04/29/2022	to	Fri 04/29/2022		(Export)
0500	Continuous	1700		SCH - OH - NY <b>1750 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 2000 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD
Mon 05/02/2022	to	Mon 05/02/2022		(Import)
0001	Continuous	0030		UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK__345_W79</b>				FWD
Mon 05/02/2022	to	Thu 05/05/2022		(Import)
0001	Continuous	0200		UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
<b>ROCHESTR-PANNELL__345_RP2</b>				FWD
Mon 05/02/2022	to	Fri 05/06/2022		(Import)
0500	Continuous	1700		DYSINGER EAST <b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD
Thu 05/05/2022	to	Thu 05/05/2022		(Import)
0130	Continuous	0200		UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
<b>SPRNBK_-TREMONT__345_X28</b>							FWD	
Fri 05/06/2022	to	Mon 05/09/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>		(Import)	
0201	Continuous	1800				SPR/DUN-SOUTH	<b>4200 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW	
						TTC with All Lines In Service	4600 MW	
<hr/>								
<b>FRASER__345_FRASER SVC</b>							FWD	
Mon 05/09/2022	to	Fri 05/13/2022				CENTRAL EAST - VC	<b>2935 MW</b>	
0800	Continuous	1700				Impacts Total Transfer Capability	40 MW	
Work scheduled by: NYSEG						TTC with All Lines In Service	2975 MW	
<hr/>								
<b>SHOR_NPX-SHOREHAM_138_CSC</b>							FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022				(Import)	(Export)	
0600	Continuous	1800				SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW
<hr/>								
<b>HOMRC_NY-MAINS_NY_345_47</b>								
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>			
0800	Continuous	1600				SCH - PJ - NY		
Work scheduled by: PJM						Impacts Total Transfer Capability		
						TTC with All Lines In Service		
<hr/>								
<b>HOMR_NYW-PIERC_NY_345_48</b>								
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>			
0800	Continuous	1600				SCH - PJ - NY		
Work scheduled by: PJM						Impacts Total Transfer Capability		
						TTC with All Lines In Service		
<hr/>								
<b>NIAGARA_-PACKARD__230_62</b>							FWD	REV
Sat 06/18/2022	to	Sat 06/18/2022				(Import)	(Export)	
0500	Continuous	1700				SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1250 MW	150 MW
						TTC with All Lines In Service	1950 MW	1700 MW
<hr/>								
<b>NIAGARA__345_230_AT4</b>							FWD	REV
Tue 06/28/2022	to	Wed 06/29/2022				(Import)	(Export)	
0500	Continuous	1700				SCH - OH - NY	<b>1900 MW</b>	<b>1400 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW	300 MW
						TTC with All Lines In Service	1950 MW	1700 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**BECK -NIAGARA 230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**ROCHESTR-PANNELL 345\_RP1**

Mon 07/25/2022 to Fri 07/29/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**SAND\_BAR-PLATSBRG 115\_PV20**

Mon 08/22/2022 to Fri 08/26/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**PANNELL -CLAY 345\_1**

Mon 09/12/2022 to Fri 09/16/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

-----  
**FRASER -GILBOA 345\_GF5-35**

Mon 09/12/2022 to Sun 09/18/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

-----  
**SPRNBRK 345KV\_RNS5**

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED by CONED 09/17/2020**  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**SPRNBRK -W49TH\_ST 345\_M51**

Mon 09/19/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_345_2</b>				FWD	
Mon 09/19/2022	to	Fri 09/23/2022		(Import)	
0700	Continuous	1530	WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
<b>SPRNBRK_345KV_RNS5</b>				FWD	
Wed 09/21/2022	to	Wed 09/21/2022	<u>UPDATED</u> <u>by CONED</u> <u>09/17/2020</u>	(Import)	
2130	Continuous	2200	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
<b>SPRNBRK_-W49TH_ST_345_M51</b>				FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/01/2020</u>	(Import)	
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
<b>SPRNBRK_345KV_RNS5</b>				FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/01/2020</u>	(Import)	
0001	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022		(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD	
Mon 10/10/2022	to	Fri 10/14/2022		(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	<b>0 MW</b>	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD	
Mon 10/10/2022	to	Fri 10/14/2022		(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	<b>0 MW</b>	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE_345_138_BK_1</b>			FWD
Mon 10/10/2022	to	Fri 10/14/2022	(Import)
0600	Continuous	1600	SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>			FWD
Mon 10/10/2022	to	Fri 10/14/2022	(Import)
0600	Continuous	1600	SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
<b>GILBOA__-N.SCTLND_345_GNS-1</b>			FWD
Mon 10/31/2022	to	Mon 11/28/2022	(Import)
0500	Continuous	1900	CENTRAL EAST - VC <b>2520 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 455 MW
			TTC with All Lines In Service 2975 MW
<b>LEEDS____345KV_R94301</b>			FWD
Mon 10/31/2022	to	Mon 11/28/2022	(Import)
0500	Continuous	1900	UPNY CONED <b>3800 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 4015 MW
			TTC with All Lines In Service 7815 MW
<b>MARCY__-N.SCTLND_345_18</b>			FWD
Mon 10/31/2022	to	Mon 11/28/2022	(Import)
0500	Continuous	1900	CENTRAL EAST - VC <b>1470 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 1505 MW
			TTC with All Lines In Service 2975 MW
<b>N.SCTLND-LEEDS____345_94</b>			FWD
Mon 10/31/2022	to	Mon 11/28/2022	(Import)
0500	Continuous	1900	CENTRAL EAST - VC <b>2650 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
<b>PORTER__-ROTTDAM_230_30 &amp; MARCY__-N.SCTLND_345_18</b>			FWD
Mon 10/31/2022	to	Mon 11/28/2022	(Import)
0500		1900	CENTRAL EAST - VC <b>1300 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 1675 MW
			TTC with All Lines In Service 2975 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Wednesday, October 13, 2021 to Friday, April 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_\_-N.SCTLND\_345\_18

FWD

Mon 10/31/2022 to Mon 11/28/2022  
0500 1900

(Import)

CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by: