

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 2250 MW	
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD REV	
Mon 01/15/2018	to	Tue 11/30/2021				(Import) (Export)
0001		2359				2000 MW 1150 MW
Work scheduled by:					Impacts Total Transfer Capability 250 MW 100 MW	
					TTC with All Lines In Service 2250 MW 1250 MW	
MARION_-FARRAGUT_345_C3403					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 2250 MW	
STLAWRNC-MOSES_230_L33P					FWD	
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>07/08/2021</u>	(Import)
0456	Continuous	1600				2050 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 2250 MW	
NEWBRDGE_345_138_BK_1					FWD	
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>01/12/2021</u>	(Import)
1807	Continuous	2359				375 MW
Work scheduled by: LI					Impacts Total Transfer Capability 285 MW	
					TTC with All Lines In Service 660 MW	
SCH-IMO-NYISO_LIMIT_1600					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 50 MW	
					TTC with All Lines In Service 1950 MW	
MOSES_-ADIRNDCK_230_MA2					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW	
					TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1400					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				SCH - OH - NY 1700 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1950 MW	
SCH-NYISO-IMO_LIMIT_1200					REV	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Export)
0600	Continuous	1300				SCH - OH - NY 1500 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 1700 MW	
SCH-HQ_CEDARS-NYISO_LIMIT_80					FWD	
Tue 09/07/2021	to	Fri 10/22/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/07/2021</u>	(Import)
0700	Continuous	2359				SCH - HQ_CEDARS 80 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 110 MW	
					TTC with All Lines In Service 190 MW	
PORTER__-ROTTRDAM_230_30					FWD	
Wed 09/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW	
					TTC with All Lines In Service 2975 MW	
EDIC___-N.SCTLND_345_14					FWD	
Thu 09/16/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0600	Continuous	1830				CENTRAL EAST - VC 1670 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 1305 MW	
					TTC with All Lines In Service 2975 MW	
EDIC___-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_30					FWD	
Thu 09/16/2021	to	Sun 11/14/2021				(Import)
0600		1830				CENTRAL EAST - VC 1500 MW
Work scheduled by:					Impacts Total Transfer Capability 1475 MW	
					TTC with All Lines In Service 2975 MW	
HOMRC_NY-MAINS_NY_345_47						
Sat 09/18/2021	to	Fri 11/05/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/08/2021</u>	
0800	Continuous	1600				SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					
SCH-NYISO-NE_LIMIT_600					REV
Sun 09/26/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>
0701	Daily	2300			
Work scheduled by: ISONE					(Export)
					800 MW
					800 MW
					1600 MW
<hr/>					
LEEDS -HURLYAVE_345_301					FWD
Mon 09/27/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>
0800	Continuous	0133			
Work scheduled by: CHGE					(Import)
					4100 MW
					3715 MW
					7815 MW
<hr/>					
NIAGARA -STA_255_345_NH2					FWD
Sat 10/02/2021	to	Sun 10/17/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/02/2021</u>
0500	Continuous	1900			
Work scheduled by: NYPA					(Import)
					1400 MW
					1750 MW
					3150 MW
<hr/>					
SCH-NE-NYISO_LIMIT_300					FWD
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>
2301	Daily	0700			
Work scheduled by: ISONE					(Import)
					500 MW
					900 MW
					1400 MW
<hr/>					
SCH-NYISO-NE_LIMIT_1200					REV
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>
2301	Daily	0700			
Work scheduled by: ISONE					(Export)
					1400 MW
					200 MW
					1600 MW
<hr/>					
CHAT_DC_GC1					FWD
Sun 10/03/2021	to	Tue 11/23/2021			
0500	Continuous	2000			
Work scheduled by: HQ					(Import)
					2850 MW
					300 MW
					3150 MW
<hr/>					
CHAT_DC_GC1					REV
Sun 10/03/2021	to	Tue 11/23/2021			
0500	Continuous	2000			
Work scheduled by: HQ					(Export)
					500 MW
					500 MW
					1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600					FWD	
Sun 10/03/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					SCH - NE - NY	
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
CLAY -EDIC 345 2-15					FWD	
Mon 10/04/2021	to	Sat 10/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/16/2021</u>	(Import)
0700	Continuous	1730				4850 MW
Work scheduled by: NYPA					OSWEGO EXPORT	
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Mon 10/04/2021	to	Sat 10/09/2021	<u>EXTENDED</u>	<u>by NGRID</u>	<u>10/07/2021</u>	(Import)
0800	Continuous	1630				5250 MW
Work scheduled by: NGrid					OSWEGO EXPORT	
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
SCH-HQ-NYISO_LIMIT_1200					FWD	
Thu 10/07/2021	to	Tue 11/23/2021				(Import)
0001	Continuous	2000				1200 MW
Work scheduled by: HQ					SCH - HQ - NY	
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1500 MW
LEEDS 345KV_R94301					FWD	
Fri 10/08/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
1530	Continuous	0132				3800 MW
Work scheduled by: CHGE					UPNY CONED	
					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
W49TH_ST-E13THSTA_345_M54					FWD	
Sat 10/09/2021	to	Sun 10/10/2021				(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
EFISHKIL-WOOD_ST_345_F38					FWD	
Sat 10/09/2021	to	Sun 10/10/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0001	Continuous	2200				4000 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
PLSNTVLE-DUNWODIE_345_W89						(Import)
Sat 10/09/2021	to	Sun 10/10/2021	UPDATED	by CONED	09/24/2021	
0001	Continuous	2200				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
<hr/>						FWD
WOOD_ST_-PLSNTVLE_345_Y86						(Import)
Sat 10/09/2021	to	Sun 10/10/2021	UPDATED	by CONED	09/24/2021	
0001	Continuous	2200				UPNY CONED 7210 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 605 MW
						TTC with All Lines In Service 7815 MW
<hr/>						FWD
PLSNTVLY_345KV_RNS5						(Import)
Sat 10/09/2021	to	Sat 10/09/2021	CANCELLED	by NGrid	10/09/2021	
0800	Daily	0830				UPNY CONED 3800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW
<hr/>						FWD
LEEDS___-PLSNTVLY_345_92						(Import)
Sat 10/09/2021	to	Sat 10/09/2021	CANCELLED	by NGrid	10/09/2021	
0800	Daily	1500				UPNY CONED 3800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW
<hr/>						FWD
PLSNTVLY_345KV_RNS5						(Import)
Sat 10/09/2021	to	Sat 10/09/2021	CANCELLED	by NGrid	10/09/2021	
1430	Daily	1500				UPNY CONED 3800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW
<hr/>						FWD
OSWEGO__-ELBRIDGE_345_17						(Import)
Sat 10/09/2021	to	Sat 10/09/2021	EXTENDED	by NGRID	10/07/2021	
1600	Continuous	1630				OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					ARR: 75	Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
<hr/>						FWD
SCH-IMO-NYISO_LIMIT_600						(Import)
Mon 10/11/2021	to	Fri 10/15/2021	EXTENDED	by IESO	10/12/2021	
0500	Continuous	1600				SCH - OH - NY 900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 1950 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_500						REV
Mon 10/11/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by IESO</u>	<u>10/12/2021</u>	(Export)
0500	Continuous	1600				800 MW
Work scheduled by: IESO						900 MW
						TTC with All Lines In Service 1700 MW
LEEDS_345KV_R94301						FWD
Mon 10/11/2021	to	Mon 10/11/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
0700	Continuous	0800				3800 MW
Work scheduled by: CHGE						4015 MW
						TTC with All Lines In Service 7815 MW
LEEDS_-HURLYAVE_345_301						FWD
Mon 10/11/2021	to	Fri 10/29/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
0700	Continuous	1600				4100 MW
Work scheduled by: CHGE						3715 MW
						TTC with All Lines In Service 7815 MW
EFISHKIL-WOOD_ST_345_F38						FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				4000 MW
Work scheduled by: ConEd						3815 MW
						TTC with All Lines In Service 7815 MW
PLSNTVLE-DUNWODIE_345_W89						FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				4000 MW
Work scheduled by: ConEd						3815 MW
						TTC with All Lines In Service 7815 MW
WOOD_ST_-PLSNTVLE_345_Y86						FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				7210 MW
Work scheduled by: ConEd						605 MW
						TTC with All Lines In Service 7815 MW
BUCHAN_N-EASTVIEW_345_W93						FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	0230				4350 MW
Work scheduled by: ConEd						3465 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79					FWD	
Tue 10/12/2021	to	Wed 10/13/2021	UPDATED	by CE	10/12/2021	(Import)
0201	Continuous	2200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
CEDARS__-ROSEMNTB_115_2/22					FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	EXTENDED	by HQ	10/06/2021	(Import) (Export)
0500	Continuous	2359				SCH - HQ_CEDARS 95 MW 40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 95 MW 60 MW
						TTC with All Lines In Service 190 MW 100 MW
DENNISON-ROSEMNTB_115_2/22					FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	EXTENDED	by HQ	10/06/2021	(Import) (Export)
0500	Continuous	2359				SCH - HQ_CEDARS 95 MW 40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 95 MW 60 MW
						TTC with All Lines In Service 190 MW 100 MW
SCH-NE-NYISO_LIMIT_100					FWD	
Tue 10/12/2021	to	Wed 10/20/2021				(Import)
2300	Daily	0659				SCH - NE - NY 300 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 1100 MW
						TTC with All Lines In Service 1400 MW
W49TH_ST_345KV_5					FWD	
Wed 10/13/2021	to	Fri 10/15/2021	CANCELLED	by ConEd	10/13/2021	(Import)
0001	Continuous	0100				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7					FWD	
Wed 10/13/2021	to	Fri 10/15/2021	CANCELLED	by ConEd	10/13/2021	(Import)
0001	Continuous	0100				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
BUCHAN_N-EASTVIEW_345_W93					FWD	
Wed 10/13/2021	to	Wed 10/13/2021	UPDATED	by CE	10/12/2021	(Import)
2130	Continuous	2200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Thu 10/14/2021 to Thu 10/14/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_72

Thu 10/14/2021 to Sat 10/16/2021 **UPDATED by CONED 08/04/2021**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 10/14/2021 to Sat 10/16/2021 **UPDATED by CONED 08/04/2021**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK_345_W78

Thu 10/14/2021 to Sat 10/16/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_5

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK_-DUNWODIE_345_W75

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3

FWD

Thu 10/14/2021 to Sun 11/28/2021

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

SCH-NYISO-HQ_LIMIT_300

REV

Thu 10/14/2021 to Sun 10/17/2021

(Export)

0600 Daily 1800

UPDATED by HQ 10/07/2021

SCH - HQ - NY

300 MW

Work scheduled by: HQ

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1000 MW

OSWEGO__VOLNEY__345_12

FWD

Thu 10/14/2021 to Thu 10/14/2021

(Import)

1100 Daily(No Weekends) 1400

OSWEGO EXPORT

5250 MW

Work scheduled by: NGrid

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

ELBRIDGE-LAFAYTTE_345_17-LE

FWD

Fri 10/15/2021 to Fri 10/15/2021

(Import)

0830 Daily(No Weekends) 1630

OSWEGO EXPORT

5250 MW

Work scheduled by: NGrid

ARR: 75

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

OSWEGO__ELBRIDGE_345_17

FWD

Fri 10/15/2021 to Fri 10/15/2021

(Import)

0830 Daily(No Weekends) 1630

OSWEGO EXPORT

5250 MW

Work scheduled by: NGrid

ARR: 75

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

FWD

Sat 10/16/2021 to Tue 10/19/2021

(Import)

0001 0200

SPR/DUN-SOUTH

3200 MW

Work scheduled by:

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

FWD

Sat 10/16/2021 to Sat 10/16/2021

(Import)

0030 Continuous 0100

UPNY CONED

7550 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71				FWD	
Sat 10/16/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>
0101	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3				FWD	
Sat 10/16/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>
0101	Continuous	0200			
Work scheduled by: ConEd				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
CLAY - INDPDNCE_345_26				FWD	
Sat 10/16/2021	to	Sat 10/16/2021			
0800	Daily	1000			
Work scheduled by: NGrid				OSWEGO EXPORT	5000 MW
				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	5250 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD	
Sun 10/17/2021	to	Sun 10/17/2021			
0001		0200			
Work scheduled by:				MOSES SOUTH	2550 MW
				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD	REV
Sun 10/17/2021	to	Sun 10/17/2021			
0001		0200			
Work scheduled by:				SCH - HQ - NY	1370 MW 0 MW
				Impacts Total Transfer Capability	130 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2				FWD	
Sun 10/17/2021	to	Sun 10/17/2021			
0001	Continuous	0200			
Work scheduled by: HQ				MOSES SOUTH	2850 MW
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					REV
Sun 10/17/2021	to	Sun 10/17/2021			
0001	Continuous	0200			
Work scheduled by: HQ				SCH - HQ - NY	500 MW
				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150					FWD	
Sun 10/17/2021	to	Sun 10/17/2021			(Import)	
0001	Continuous	0200		SCH - HQ - NY	1150 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW
CEDARS_-ROSEMNTA_115_1/11					FWD	REV
Mon 10/18/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/14/2021</u>	(Import) (Export)
0500	Continuous	2359				
Work scheduled by: HQ					SCH - HQ_CEDARS	95 MW 40 MW
					Impacts Total Transfer Capability	95 MW 60 MW
					TTC with All Lines In Service	190 MW 100 MW
DENNISON-ROSEMNTA_115_1/11					FWD	REV
Mon 10/18/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/14/2021</u>	(Import) (Export)
0500	Continuous	2359				
Work scheduled by: HQ					SCH - HQ_CEDARS	95 MW 40 MW
					Impacts Total Transfer Capability	95 MW 60 MW
					TTC with All Lines In Service	190 MW 100 MW
NIAGARA_-KINTIGH_345_NSI-38					FWD	
Mon 10/18/2021	to	Sat 12/04/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>	(Import)
0500	Continuous	1900				
Work scheduled by: NYPA					DYSINGER EAST	1400 MW
					Impacts Total Transfer Capability	1750 MW
					TTC with All Lines In Service	3150 MW
SCH-NYISO-NE_LIMIT_600						REV
Mon 10/18/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
0701	Daily	2300				
Work scheduled by: ISONE					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Mon 10/18/2021	to	Tue 10/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
2301	Daily	0700				
Work scheduled by: ISONE					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-IMO_LIMIT_1000						REV
Tue 10/19/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/14/2021</u>	(Export)
0400	Continuous	1600				
Work scheduled by: IESO					SCH - OH - NY	1300 MW
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600					FWD	
Tue 10/19/2021	to	Sat 10/23/2021	UPDATED	by ISONE	10/14/2021	(Import)
0701	Daily	2300				800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 1400 MW
ROTTDAM-EASTOVER_230_38						REV
Wed 10/20/2021	to	Wed 10/20/2021				(Export)
0730	Daily(No Weekends)	1059				1400 MW
Work scheduled by: NGrid				ARR: 77		Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1600 MW
SCH-NE-NYISO_LIMIT_900						FWD
Thu 10/21/2021	to	Fri 10/29/2021				(Import)
1700	Continuous	1600				1100 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 1400 MW
SCH-NE-NYISO_LIMIT_600						FWD
Sun 10/24/2021	to	Sun 10/24/2021	UPDATED	by ISONE	10/14/2021	(Import)
0701	Daily	1600				800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_600						REV
Sun 10/24/2021	to	Sun 10/24/2021	UPDATED	by ISONE	10/14/2021	(Export)
0701	Daily	1600				800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1600 MW
LADENTWN-BUCHAN_S_345_Y88						FWD
Sun 10/24/2021	to	Sat 10/30/2021				(Import)
0900	Continuous	1559				7560 MW
Work scheduled by: ORU						Impacts Total Transfer Capability 255 MW
						TTC with All Lines In Service 7815 MW
SHOR_NPX-SHOREHAM_138_CSC						FWD
Mon 10/25/2021	to	Sun 11/21/2021				(Import) (Export)
0700	Continuous	1600				0 MW 0 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 330 MW 330 MW
						TTC with All Lines In Service 330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CEDARS__-ROSEMNTB_115_2/22

Tue 10/26/2021 to Thu 10/28/2021
 0300 Continuous 0200
 Work scheduled by: HQ

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	40 MW
Impacts Total Transfer Capability	95 MW	60 MW
TTC with All Lines In Service	190 MW	100 MW

DENNISON-ROSEMNTB_115_2/22

Tue 10/26/2021 to Thu 10/28/2021
 0300 Continuous 0200
 Work scheduled by: HQ

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	40 MW
Impacts Total Transfer Capability	95 MW	60 MW
TTC with All Lines In Service	190 MW	100 MW

SCH-HQ_CEDARS-NYISO_LIMIT_140

Tue 10/26/2021 to Thu 10/28/2021
 0300 Continuous 0200
 Work scheduled by: HQ

	FWD
	(Import)
SCH - HQ_CEDARS	140 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	190 MW

LEEDS____345KV_R94301

Fri 10/29/2021 to Fri 10/29/2021 **UPDATED by CH 10/09/2021**
 1500 Continuous 1600
 Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

W49TH_ST_345KV_7

Sat 10/30/2021 to Sat 10/30/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_5

Sat 10/30/2021 to Sun 12/05/2021 **UPDATED by CONED 06/20/2021**
 0001 Continuous 0300
 Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

LEEDS____-ATHENS____345_95

Sat 10/30/2021 to Sat 10/30/2021
 0800 Daily(No Weekends) 1500
 Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R395

Sat 10/30/2021 to Sat 10/30/2021
 0800 Daily(No Weekends) 1500
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W97

Mon 11/01/2021 to Fri 12/10/2021 UPDATED by CE 10/12/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1900 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 2000 MW

BUCHAN_S-MILLWOOD_345_W98

Mon 11/01/2021 to Tue 11/09/2021 UPDATED by CE 10/12/2021
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

LADENTWN-BUCHAN_S_345_Y88

Mon 11/01/2021 to Tue 11/09/2021 UPDATED by CE 10/12/2021
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7560 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_7

Tue 11/02/2021 to Tue 11/02/2021
 0200 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Day	Work Scheduling	Transfer Type	Capacity (MW)	Impact
LINDN_CG-LNDVFT_345_V-3022	Tue 11/02/2021	Fri 11/05/2021	0800	Continuous	1500	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM							Impacts Total Transfer Capability	315 MW
							TTC with All Lines In Service	315 MW
MILLWOOD_345KV_18	Wed 11/03/2021	Fri 11/12/2021	0001	Continuous	1800	UPNY CONED	4350 MW	
Work scheduled by: ConEd							Impacts Total Transfer Capability	3465 MW
							TTC with All Lines In Service	7815 MW
OSWEGO_-VOLNEY_345_11	Wed 11/03/2021	Wed 11/03/2021	1100	Daily(No Weekends)	1300	OSWEGO EXPORT	5250 MW	
Work scheduled by: NGrid							Impacts Total Transfer Capability	0 MW
							TTC with All Lines In Service	5250 MW
HOMRC_NY-MAINS_NY_345_47	Fri 11/05/2021	Mon 11/08/2021	1601	Continuous	0800	SCH - PJ - NY		
Work scheduled by: PJM							Impacts Total Transfer Capability	
							TTC with All Lines In Service	
SHORE_RD_345_138_BK_1	Mon 11/08/2021	Wed 11/10/2021	0001	Continuous	2359	CONED - LIPA	1350 MW	
Work scheduled by: LI							Impacts Total Transfer Capability	150 MW
							TTC with All Lines In Service	1500 MW
BUCHAN_S-MILLWOOD_345_W98	Wed 11/10/2021	Tue 11/16/2021	0201	Continuous	0200	UPNY CONED	7680 MW	
Work scheduled by: ConEd							Impacts Total Transfer Capability	135 MW
							TTC with All Lines In Service	7815 MW
LADENTWN-BUCHAN_S_345_Y88	Wed 11/10/2021	Tue 11/16/2021	0201	Continuous	0200	UPNY CONED	7560 MW	
Work scheduled by: ConEd							Impacts Total Transfer Capability	255 MW
							TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2					FWD	
Thu 11/11/2021	to	Fri 11/12/2021			(Import)	
0001	Continuous	2359		CONED - LIPA	1350 MW	
Work scheduled by: LI				Impacts Total Transfer Capability	150 MW	
				TTC with All Lines In Service	1500 MW	
<hr/>						
GOETHALS_345KV_5						
Fri 11/12/2021	to	Tue 11/16/2021	UPDATED	by CONED 06/30/2021		
0001	Continuous	0300		STATEN ISLAND		
Work scheduled by: ConEd				Impacts Total Transfer Capability		
				TTC with All Lines In Service		
<hr/>						
BERKSHIR-ALPS_____345_393					FWD	REV
Sun 11/14/2021	to	Wed 11/24/2021			(Import)	(Export)
0700	Continuous	1600		SCH - NE - NY	1100 MW	1700 MW
Work scheduled by: ISONE			ARR: 78	Impacts Total Transfer Capability	300 MW	0 MW
				TTC with All Lines In Service	1400 MW	1700 MW
<hr/>						
BERKSHIR-ALPS_____345_393					FWD	REV
Sun 11/14/2021	to	Wed 11/24/2021			(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE			ARR: 78	Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW
<hr/>						
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Sun 11/14/2021	to	Wed 11/24/2021			(Import)	(Export)
0700		1600		SCH - NE - NY	1100 MW	1700 MW
Work scheduled by:			ARR: 78	Impacts Total Transfer Capability	300 MW	0 MW
				TTC with All Lines In Service	1400 MW	1700 MW
<hr/>						
BERKSHIR-NORTHFLD_345_312					FWD	
Sun 11/14/2021	to	Wed 11/24/2021			(Import)	
0700	Continuous	1600		SCH - NE - NY	1300 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW	
				TTC with All Lines In Service	1400 MW	
<hr/>						
BERKSHIR-NORTHFLD_345_312					FWD	REV
Sun 11/14/2021	to	Wed 11/24/2021			(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULING INFORMATION				IMPACTS	
Start Date	End Date	Time	Work Scheduled by	Transfer Capability	TTC with All Lines In Service
SCH-NE-NYISO_LIMIT_800					
Sun 11/14/2021	to	Wed 11/24/2021			
0700	Continuous	1600	ISONE	1000 MW	1400 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700					
Sun 11/14/2021	to	Wed 11/24/2021			
0700	Continuous	1600	ISONE	900 MW	1700 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	1700 MW
PORTER - ROTTRDAM_230_30 & MASSENA - MARCY 765_MSU1					
Mon 11/15/2021	to	Tue 11/30/2021			
0100		1730		1500 MW	2975 MW
Work scheduled by:				Impacts Total Transfer Capability	1475 MW
				TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA_765_7040					
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>
0100	Continuous	1859			
Work scheduled by: NYPA				1500 MW	3150 MW
				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>
0100	Continuous	1859			
Work scheduled by: NYPA				0 MW	1000 MW
				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	1500 MW
MARCY 765_345_AT1					
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>
0100	Continuous	1859			
Work scheduled by: NYPA				1750 MW	3150 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
				ARR: 19	
MARCY 765_345_AT2					
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>
0100	Continuous	1859			
Work scheduled by: NYPA				1700 MW	3150 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
				ARR: 19	

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1					FWD		
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1305 MW
						TTC with All Lines In Service	2975 MW
MASSENA -MARCY 765_MSU1					FWD		
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				MOSES SOUTH	500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1					FWD	REV	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import) (Export)	
0100	Continuous	1859				SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1					FWD		
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/03/2021</u>	(Import)	
0100	Continuous	1859				SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040					FWD		
Mon 11/15/2021	to	Tue 11/30/2021				(Import)	
0100		1859				MOSES SOUTH	500 MW
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2					FWD	REV	
Mon 11/15/2021	to	Tue 11/30/2021				(Import) (Export)	
0100		1859				SCH - HQ - NY	850 MW 0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2					FWD		
Mon 11/15/2021	to	Tue 11/30/2021				(Import)	
0100		1859				SCH - HQ_CEDARS	90 MW
Work scheduled by:						Impacts Total Transfer Capability	109 MW
						TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1					FWD
Mon 11/15/2021	to	Tue 11/30/2021			(Import)
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:					Impacts Total Transfer Capability
					TTC with All Lines In Service
STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2					FWD
Mon 11/15/2021	to	Tue 11/30/2021			(Import)
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:					Impacts Total Transfer Capability
					TTC with All Lines In Service
DOLSONAV-ROCKTVRN_345_DART44					FWD
Mon 11/15/2021	to	Fri 11/19/2021			(Import)
0800	Continuous	1600		CENTRAL EAST - VC	2720 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability
					TTC with All Lines In Service
MILLWOOD-EASTVIEW_345_W85					FWD
Wed 11/17/2021	to	Wed 11/17/2021	EXTENDED	by CE	10/12/2021
0001	Continuous	0030			UPNY CONED
Work scheduled by: ConEd					7550 MW
					Impacts Total Transfer Capability
					TTC with All Lines In Service
DUNWODIE-MOTTHAVN_345_72					FWD
Wed 11/17/2021	to	Mon 11/22/2021	EXTENDED	by CONED	10/12/2021
0001	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability
					TTC with All Lines In Service
DUNWODIE_345KV_8					FWD
Wed 11/17/2021	to	Mon 11/22/2021	EXTENDED	by CONED	10/12/2021
0001	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability
					TTC with All Lines In Service
EASTVIEW-SPRNBRK_345_W78					FWD
Wed 11/17/2021	to	Mon 11/22/2021	EXTENDED	by CE	10/12/2021
0001	Continuous	0200			UPNY CONED
Work scheduled by: ConEd					4350 MW
					Impacts Total Transfer Capability
					TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Sat 11/20/2021 to Sat 11/20/2021
0001 Continuous 0030

UPDATED by CONED 06/20/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

SPRNBRK_345KV_RS3 & SPRNBRK_345KV_RS4

Mon 11/22/2021 to Sun 11/28/2021
0001 0200

Work scheduled by:

FWD
(Import)
3800 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Mon 11/22/2021 to Mon 11/22/2021
0130 Continuous 0200

EXTENDED by CE 10/12/2021

Work scheduled by: ConEd

FWD
(Import)
7550 MW
UPNY CONED
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_71

Mon 11/22/2021 to Sun 11/28/2021
0201 Continuous 0100

UPDATED by CE 10/01/2021

Work scheduled by: ConEd

FWD
(Import)
3800 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Mon 11/22/2021 to Sun 11/28/2021
0201 Continuous 0100

UPDATED by CE 10/01/2021

Work scheduled by: ConEd

FWD
(Import)
3800 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_7

Thu 11/25/2021 to Fri 12/03/2021
0001 Continuous 0200

UPDATED by CONED 06/20/2021

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

SPRNBRK_345KV_RNS4

Sun 11/28/2021 to Sun 11/28/2021
0300 Continuous 0330

UPDATED by CONED 06/20/2021

Work scheduled by: ConEd

FWD
(Import)
3200 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-W49TH_ST_345_M52					FWD		
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)	
0300	Continuous	0200				3200 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	1400 MW	
					Impacts Total Transfer Capability	4600 MW	
					TTC with All Lines In Service	4600 MW	
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD		
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)	
0600	Continuous	1600				0 MW	
Work scheduled by: PJM					SCH - PJM_NEPTUNE	660 MW	
					Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501					FWD		
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)	
0600	Continuous	1600				0 MW	
Work scheduled by: PJM					SCH - PJM_NEPTUNE	660 MW	
					Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2					FWD		
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)	
0600	Continuous	1600				375 MW	
Work scheduled by: PJM					SCH - PJM_NEPTUNE	285 MW	
					Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service	660 MW	
BERKSHIR-ALPS_____345_393					FWD	REV	
Mon 11/29/2021	to	Sat 12/18/2021				(Import)	(Export)
0700	Continuous	1600				1100 MW	1700 MW
Work scheduled by: ISONE					SCH - NE - NY	300 MW	0 MW
					Impacts Total Transfer Capability	1400 MW	1700 MW
					TTC with All Lines In Service	1400 MW	1700 MW
					ARR: 78		
BERKSHIR-ALPS_____345_393					FWD	REV	
Mon 11/29/2021	to	Sat 12/18/2021				(Import)	(Export)
0700	Continuous	1600				100 MW	100 MW
Work scheduled by: ISONE					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service	200 MW	200 MW
					ARR: 78		
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV	
Mon 11/29/2021	to	Sat 12/18/2021				(Import)	(Export)
0700		1600				1100 MW	1700 MW
Work scheduled by:					SCH - NE - NY	300 MW	0 MW
					Impacts Total Transfer Capability	1400 MW	1700 MW
					TTC with All Lines In Service	1400 MW	1700 MW
					ARR: 78		

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312					FWD	
Mon 11/29/2021	to	Sat 12/18/2021			(Import)	
0700	Continuous	1600		SCH - NE - NY	1300 MW	
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Mon 11/29/2021	to	Sat 12/18/2021			(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
SCH-NE-NYISO_LIMIT_800					FWD	
Mon 11/29/2021	to	Sat 12/18/2021			(Import)	
0700	Continuous	1600		SCH - NE - NY	1000 MW	
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700						REV
Mon 11/29/2021	to	Sat 12/18/2021				(Export)
0700	Continuous	1600		SCH - NE - NY		900 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1700 MW
HURLYAVE-ROSETON__345_303					FWD	
Mon 11/29/2021	to	Fri 12/17/2021	UPDATED	by CH	10/07/2021	(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	4100 MW
					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW
NIAGARA_-PACKARD__230_61					FWD	REV
Tue 11/30/2021	to	Mon 12/06/2021			(Import)	(Export)
0615	Continuous	1900		SCH - OH - NY	1200 MW	1850 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	2300 MW
SPRNBRK__345KV_RNS4					FWD	
Wed 12/01/2021	to	Wed 12/01/2021	UPDATED	by CONED	06/20/2021	(Import)
0130	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3200 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Wed 12/01/2021 to Tue 05/31/2022
0700 Continuous 1300

Work scheduled by: NYPA

FWD
(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SPRNBRK_345KV_RNS4

Fri 12/03/2021 to Sat 12/04/2021
0001 Continuous 1800

Work scheduled by: ConEd

FWD
(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M52

Fri 12/03/2021 to Sat 12/18/2021
0201 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MARCY___-EDIC_____345_UE1-7

Fri 12/03/2021 to Fri 12/03/2021
0700 Daily(No Weekends) 1000

Work scheduled by: NGrid

ARR: 19&16

FWD
(Import)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MILLWOOD_345KV_18

Mon 12/06/2021 to Fri 12/10/2021 **UPDATED by CE 10/12/2021**
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_5

Mon 12/06/2021 to Sat 12/18/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

MARCY_____345KV_CSC

Mon 12/06/2021 to Fri 12/17/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W98					FWD		
Tue 12/07/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	0200				7680 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability 135 MW	
						TTC with All Lines In Service 7815 MW	
LADENTWN-BUCHAN_S_345_Y88					FWD		
Tue 12/07/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	0200				7560 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability 255 MW	
						TTC with All Lines In Service 7815 MW	
SPRNBRK__345KV_RNS4					FWD		
Mon 12/13/2021	to	Tue 12/14/2021				(Import)	
0001	Continuous	1800				3200 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW	
						TTC with All Lines In Service 4600 MW	
HURLYAVE-ROSETON__345_303					FWD		
Mon 12/13/2021	to	Wed 12/22/2021	<u>CANCELLED</u>	<u>by CHGE</u>	<u>10/14/2021</u>	(Import)	
0700	Continuous	1600				4100 MW	
Work scheduled by: CHGE						Impacts Total Transfer Capability 3715 MW	
						TTC with All Lines In Service 7815 MW	
SPRNBRK__345KV_RNS4					FWD		
Sat 12/18/2021	to	Sat 12/18/2021				(Import)	
0130	Continuous	0200				3200 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW	
						TTC with All Lines In Service 4600 MW	
FRASER__345_FRASER SVC					FWD		
Tue 01/04/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/25/2021</u>	(Import)	
0700	Continuous	1730				2935 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability 40 MW	
						TTC with All Lines In Service 2975 MW	
NIAGARA_-PACKARD__230_61					FWD	REV	
Mon 01/17/2022	to	Fri 01/21/2022				(Import)	(Export)
0615	Continuous	1900				1200 MW	1850 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 1100 MW	150 MW
						TTC with All Lines In Service 2300 MW	2000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK__230_68

Tue 01/18/2022 to Fri 02/04/2022 **UPDATED** by NGRID 09/24/2021
 0700 Continuous 1730
 Work scheduled by: NGrid
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NIAGARA_-STA_255_345_NH2

Fri 01/21/2022 to Fri 03/04/2022 **UPDATED** by NYPA 08/20/2021
 0500 Continuous 1900
 Work scheduled by: NYPA
 FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ATHENS_-PLSNTVLY_345_91

Sat 02/12/2022 to Wed 02/16/2022 **UPDATED** by NGRID 05/07/2021
 0600 Continuous 1900
 Work scheduled by: NGrid
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 02/17/2022 to Sat 02/19/2022
 0001 2200
 Work scheduled by:
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

LEEDS_-PLSNTVLY_345_92

Thu 02/17/2022 to Fri 03/25/2022
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Thu 02/17/2022 to Fri 03/25/2022
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F30

Sun 02/20/2022 to Mon 02/21/2022
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64

Tue 02/22/2022 to Tue 02/22/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Tue 02/22/2022 to Tue 02/22/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Tue 02/22/2022 to Mon 03/21/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

MARCY__-EDIC__345_UE1-7

Wed 02/23/2022 to Mon 02/28/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

PORTER__-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

N. SCTLND-LEEDS__345_93

Tue 03/01/2022 to Tue 03/15/2022
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

EDIC__-N. SCTLND_345_14

Tue 03/01/2022 to Tue 04/12/2022
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC___-N.SCTLND_345_14 & PORTER___-ROTTDAM_230_31

Tue 03/01/2022 to Tue 04/12/2022
0700 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **1500 MW**
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

FRASANNX-COOPERS__345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

N.SCTLND-ALPS_____345_2

Tue 03/01/2022 to Tue 05/24/2022
0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

SCH - NE - NY **900 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1400 MW

N.SCTLND-ALPS_____345_2

Tue 03/01/2022 to Tue 05/24/2022
0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
0001 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

LINDEN___-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

INDPDNCE-SCRIBA__345_25				FWD
Thu 03/10/2022	to	Wed 03/16/2022		(Import)
0800	Continuous	1800	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Thu 03/17/2022	to	Sun 03/20/2022		(Import)
0100		2200	UPNY CONED	3800 MW
Work scheduled by:				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
PLSNTVLY-WOOD_ST__345_F30				FWD
Mon 03/21/2022	to	Wed 03/23/2022		(Import)
0001	Continuous	2200	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBRK__345_W64				FWD
Mon 03/21/2022	to	Mon 03/21/2022	UPDATED by CONED 08/31/2021	(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBRK__345KV_RNS5				FWD
Mon 03/21/2022	to	Mon 03/21/2022	UPDATED by CONED 08/31/2021	(Import)
0130	Continuous	0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Sat 03/26/2022	to	Mon 03/28/2022		(Import)
0001		2200	UPNY CONED	3800 MW
Work scheduled by:				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
ATHENS__-PLSNTVLY_345_91				FWD
Sat 03/26/2022	to	Sun 05/01/2022		(Import)
0001	Continuous	2200	UPNY CONED	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

Sat 03/26/2022 to Sun 05/01/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F31

Tue 03/29/2022 to Wed 03/30/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

LINDN_CG-LNDVFT_345_V-3022

Sun 04/03/2022 to Sat 04/09/2022
 1400 Continuous 1400
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

SPRNBRK_-TREMONT_345_X28

Tue 04/05/2022 to Wed 04/06/2022
 0201 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 04/06/2022 to Wed 04/06/2022 **UPDATED by CONED 08/19/2021**
 0301 Continuous 0330
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBRK_345_W79

Wed 04/06/2022 to Thu 04/07/2022 **UPDATED by CONED 08/19/2021**
 0301 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_N-EASTVIEW_345_W93

Thu 04/07/2022 to Thu 04/07/2022 **UPDATED by CONED 08/19/2021**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RNS5					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 04/07/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	2200				UPNY CONED 7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW	TTC with All Lines In Service 7815 MW
PANNELL_-CLAY____345_1					FWD	
Mon 04/11/2022	to	Fri 04/15/2022				(Import)
0700	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW	TTC with All Lines In Service 2250 MW
PORTER__-ROTTRDAM_230_30					FWD	
Wed 04/13/2022	to	Tue 12/31/2030				(Import)
0600	Continuous	2359				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW	TTC with All Lines In Service 2975 MW
PANNELL_-CLAY____345_2					FWD	
Mon 04/18/2022	to	Fri 04/22/2022				(Import)
0700	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW	TTC with All Lines In Service 2250 MW
EDIC____-FRASER____345_EF24-40					FWD	
Thu 04/21/2022	to	Tue 06/14/2022				(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW	TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 04/23/2022 to Tue 04/26/2022
0001 2200

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK__345_W64

Tue 04/26/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021
2130 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Tue 04/26/2022 to Tue 04/26/2022 UPDATED by CONED 08/31/2021
2130 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

PLSNTVLY-WOOD_ST__345_F31

Wed 04/27/2022 to Fri 04/29/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

NIAGARA__345_230_AT4

Fri 04/29/2022 to Fri 04/29/2022
0500 Continuous 1700

Work scheduled by: NYPA

REV
(Export)
SCH - OH - NY **1750 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2000 MW

BUCHAN_N-EASTVIEW_345_W93

Mon 05/02/2022 to Mon 05/02/2022
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK__345_W79

Mon 05/02/2022 to Thu 05/05/2022
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2				FWD	
Mon 05/02/2022	to	Fri 05/06/2022		(Import)	
0500	Continuous	1700	DYSINGER EAST	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
BUCHAN_N-EASTVIEW_345_W93				FWD	
Thu 05/05/2022	to	Thu 05/05/2022		(Import)	
0130	Continuous	0200	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
SPRNBK_-TREMONT__345_X28				FWD	
Fri 05/06/2022	to	Mon 05/09/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/19/2021</u>	(Import)	
0201	Continuous	1800	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
FRASER__345_FRASER SVC				FWD	
Mon 05/09/2022	to	Fri 05/13/2022		(Import)	
0800	Continuous	1700	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022		(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
HOMRC_NY-MAINS_NY_345_47					
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u> <u>by PJM</u> <u>11/19/2020</u>		
0800	Continuous	1600	SCH - PJ - NY		
Work scheduled by: PJM			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
HOMR_NYW-PIERC_NY_345_48					
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u> <u>by PJM</u> <u>11/19/2020</u>		
0800	Continuous	1600	SCH - PJ - NY		
Work scheduled by: PJM			Impacts Total Transfer Capability		
			TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone / Line			FWD	REV
			(Import)	(Export)
NIAGARA_-PACKARD__230_62				
Sat 06/18/2022	to	Sat 06/18/2022		
0500	Continuous	1700		
Work scheduled by: NYPA			SCH - OH - NY	700 MW 1550 MW
			Impacts Total Transfer Capability	1250 MW 150 MW
			TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA_345_230_AT4				
Tue 06/28/2022	to	Wed 06/29/2022		
0500	Continuous	1700		
Work scheduled by: NYPA			SCH - OH - NY	1900 MW 1400 MW
			Impacts Total Transfer Capability	50 MW 300 MW
			TTC with All Lines In Service	1950 MW 1700 MW
BECK_-NIAGARA_230_PA27				
Tue 07/05/2022	to	Sat 07/09/2022		
0500	Continuous	2100		
Work scheduled by: NYPA			SCH - OH - NY	
			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
ROCHESTR-PANNELL_345_RP1				
Mon 07/25/2022	to	Fri 07/29/2022		
0500	Continuous	2100		
Work scheduled by: NYPA			DYSINGER EAST	2300 MW
			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
SAND_BAR-PLATSBRG_115_PV20				
Mon 08/22/2022	to	Fri 08/26/2022		
0700	Continuous	1530		
Work scheduled by: NYPA			SCH - NE - NY	
			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
PANNELL_-CLAY_345_1				
Mon 09/12/2022	to	Fri 09/16/2022		
0700	Continuous	1530		
Work scheduled by: NYPA			WEST CENTRAL	1300 MW
			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
FRASER_-GILBOA_345_GF5-35				
Mon 09/12/2022	to	Sun 09/18/2022		
0700	Continuous	1530		
Work scheduled by: NYPA			CENTRAL EAST - VC	2650 MW
			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5					FWD	
Mon 09/19/2022	to	Mon 09/19/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK_-W49TH_ST_345_M51					FWD	
Mon 09/19/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	(Import)
0001	Continuous	2200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
PANNELL_-CLAY____345_2					FWD	
Mon 09/19/2022	to	Fri 09/23/2022				(Import)
0700	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
SPRNBRK__345KV_RNS5					FWD	
Wed 09/21/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	(Import)
2130	Continuous	2200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK_-W49TH_ST_345_M51					FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/01/2020</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK__345KV_RNS5					FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/01/2020</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022				(Import) (Export)
0600	Continuous	1800				SCH - NPX_CSC 0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

LEEDS_345KV_R94301

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

MARCY_-N.SCTLND_345_18

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **1470 MW**
Impacts Total Transfer Capability 1505 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Thursday ,October 14, 2021 to Saturday ,April 15, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-LEEDS___345_94

Mon 10/31/2022 to Mon 11/28/2022
 0500 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_30 & MARCY___-N.SCTLND_345_18

Mon 10/31/2022 to Mon 11/28/2022
 0500 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_31 & MARCY___-N.SCTLND_345_18

Mon 10/31/2022 to Mon 11/28/2022
 0500 1900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW