

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY 2050 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD	REV
Mon 01/15/2018	to	Tue 11/30/2021				(Import) (Export)
0001		2359				SCH - PJ - NY 2000 MW 1150 MW
Work scheduled by:					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
MARION_-FARRAGUT_345_C3403					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY 2050 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
STLAWRNC-MOSES_230_L33P						
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>07/08/2021</u>	
0456	Continuous	1600				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
NEWBRDGE_345_138_BK_1					FWD	
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>01/12/2021</u>	(Import)
1807	Continuous	2359				SCH - PJM_NEPTUNE 375 MW
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_1600					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				SCH - OH - NY 1900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1400					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				1700 MW
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1950 MW
SCH-NYISO-IMO_LIMIT_1200					REV	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Export)
0600	Continuous	1300				1500 MW
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1700 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80					FWD	
Tue 09/07/2021	to	Fri 10/22/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/07/2021</u>	(Import)
0700	Continuous	1700				80 MW
Work scheduled by: HQ					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW
PORTER__-ROTTRDAM_230_30					FWD	
Wed 09/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0700	Continuous	1730				2805 MW
Work scheduled by: NGrid					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW
EDIC___-N.SCTLND_345_14					FWD	
Thu 09/16/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0600	Continuous	1830				1670 MW
Work scheduled by: NGrid					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	1305 MW
					TTC with All Lines In Service	2975 MW
EDIC___-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_30					FWD	
Thu 09/16/2021	to	Sun 11/14/2021				(Import)
0600		1830				1500 MW
Work scheduled by:					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW
HOMRC_NY-MAINS_NY_345_47						
Sat 09/18/2021	to	Fri 11/05/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/08/2021</u>	
0800	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_600						REV
Sun 09/26/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_300						FWD
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
2301	Daily	0700				500 MW
Work scheduled by: ISONE					SCH - NE - NY	900 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_1200						REV
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
2301	Daily	0700				1400 MW
Work scheduled by: ISONE					SCH - NE - NY	200 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	1600 MW
CHAT_DC_GC1						FWD
Sun 10/03/2021	to	Tue 11/23/2021				(Import)
0500	Continuous	2000				2850 MW
Work scheduled by: HQ					MOSES SOUTH	300 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1						REV
Sun 10/03/2021	to	Tue 11/23/2021				(Export)
0500	Continuous	2000				500 MW
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1000 MW
SCH-NE-NYISO_LIMIT_600						FWD
Sun 10/03/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					SCH - NE - NY	600 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	1400 MW
CLAY -EDIC 345_2-15						FWD
Mon 10/04/2021	to	Sat 10/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/16/2021</u>	(Import)
0700	Continuous	1730				4850 MW
Work scheduled by: NYPA					OSWEGO EXPORT	400 MW
					Impacts Total Transfer Capability	5250 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1200					FWD
Thu 10/07/2021	to	Tue 11/23/2021			(Import)
0001	Continuous	2000			SCH - HQ - NY 1200 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 1500 MW
SCH-IMO-NYISO_LIMIT_600					FWD
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/15/2021</u>
0500	Continuous	1600			SCH - OH - NY 900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 1950 MW
SCH-NYISO-IMO_LIMIT_500					REV
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/15/2021</u>
0500	Continuous	1600			SCH - OH - NY 800 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service 1700 MW
LEEDS___345KV_R94301					FWD
Mon 10/11/2021	to	Mon 10/11/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>
0700	Continuous	0800			UPNY CONED 3800 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
LEEDS___-HURLYAVE_345_301					FWD
Mon 10/11/2021	to	Fri 10/29/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>
0700	Continuous	1600			UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 3715 MW
					TTC with All Lines In Service 7815 MW
EFISHKIL-WOOD_ST_345_F38					FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>
0130	Continuous	0200			UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLE-DUNWODIE_345_W89					FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>
0130	Continuous	0200			UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y86						FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)	
0130	Continuous	0200				UPNY CONED	7210 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	605 MW
						TTC with All Lines In Service	7815 MW
BUCHAN_N-EASTVIEW_345_W93						FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	0230				UPNY CONED	4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK_345_W79						FWD	
Tue 10/12/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	2200				UPNY CONED	4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
CEDARS_-ROSEMNTB_115_2/22						FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import)	(Export)
0500	Continuous	2359				SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW 60 MW
						TTC with All Lines In Service	190 MW 100 MW
DENNISON-ROSEMNTB_115_2/22						FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import)	(Export)
0500	Continuous	2359				SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW 60 MW
						TTC with All Lines In Service	190 MW 100 MW
SCH-NE-NYISO_LIMIT_100						FWD	
Tue 10/12/2021	to	Wed 10/20/2021				(Import)	
2300	Daily	0659				SCH - NE - NY	300 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	1400 MW
W49TH_ST_345KV_5						FWD	
Wed 10/13/2021	to	Fri 10/15/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>10/13/2021</u>	(Import)	
0001	Continuous	0100				SCH - PJM_HTP	300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Wed 10/13/2021 to Fri 10/15/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

CANCELLED by ConEd 10/13/2021

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 10/13/2021 to Wed 10/13/2021
 2130 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CE 10/12/2021

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W85

Thu 10/14/2021 to Thu 10/14/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_72

Thu 10/14/2021 to Sun 10/17/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

EXTENDED by CONED 10/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 10/14/2021 to Sun 10/17/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

EXTENDED by CONED 10/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK_345_W78

Thu 10/14/2021 to Sun 10/17/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_5

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7					FWD
Thu 10/14/2021	to	Sun 11/28/2021			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SPRNBRK_-DUNWODIE_345_W75					FWD
Thu 10/14/2021	to	Sun 11/28/2021			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SPRNBRK__345KV_RNS3					FWD
Thu 10/14/2021	to	Sun 11/28/2021			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SCH-NYISO-HQ_LIMIT_300					REV
Thu 10/14/2021	to	Sun 10/17/2021	UPDATED	by HQ	(Export)
0600	Daily	1800		10/07/2021	300 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1000 MW
OSWEGO_-VOLNEY__345_12					FWD
Thu 10/14/2021	to	Thu 10/14/2021			(Import)
1100	Daily(No Weekends)	1400		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD
Fri 10/15/2021	to	Fri 10/15/2021	UPDATED	by NGRID	(Import)
0830	Daily(No Weekends)	1630		10/15/2021	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
OSWEGO_-ELBRIDGE_345_17					FWD
Fri 10/15/2021	to	Fri 10/15/2021	UPDATED	by NGRID	(Import)
0830	Daily(No Weekends)	1630		10/15/2021	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY___ - INDPDNCE_345_26				FWD
Sat 10/16/2021	to	Sat 10/16/2021	CANCELLED by NGrid 10/16/2021	(Import)
0800	Daily	1000	OSWEGO EXPORT	5000 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 5250 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD
Sun 10/17/2021	to	Sun 10/17/2021		(Import)
0001		0200	MOSES SOUTH	2550 MW
Work scheduled by:				Impacts Total Transfer Capability 600 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD
Sun 10/17/2021	to	Sun 10/17/2021		(Import) (Export)
0001		0200	SCH - HQ - NY	1370 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability 130 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
CHAT_DC_GC2				FWD
Sun 10/17/2021	to	Sun 10/17/2021		(Import)
0001	Continuous	0200	MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC2				REV
Sun 10/17/2021	to	Sun 10/17/2021		(Export)
0001	Continuous	0200	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_1150				FWD
Sun 10/17/2021	to	Sun 10/17/2021		(Import)
0001	Continuous	0200	SCH - HQ - NY	1150 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 350 MW
				TTC with All Lines In Service 1500 MW
SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4				FWD
Sun 10/17/2021	to	Wed 10/20/2021		(Import)
0001		0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by:				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Sun 10/17/2021 to Sun 10/17/2021
0030 Continuous 0100
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 7550 MW
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_71

Sun 10/17/2021 to Tue 10/19/2021 **UPDATED by CE 10/01/2021**
0101 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH 3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Sun 10/17/2021 to Tue 10/19/2021 **UPDATED by CE 10/01/2021**
0101 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH 3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

CEDARS_-ROSEMNTA_115_1/11

Mon 10/18/2021 to Wed 10/20/2021 **UPDATED by HQ 10/14/2021**
0500 Continuous 2359
Work scheduled by: HQ

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 95 MW 40 MW
Impacts Total Transfer Capability 95 MW 60 MW
TTC with All Lines In Service 190 MW 100 MW

DENNISON-ROSEMNTA_115_1/11

Mon 10/18/2021 to Wed 10/20/2021 **UPDATED by HQ 10/14/2021**
0500 Continuous 2359
Work scheduled by: HQ

FWD REV
(Import) (Export)
SCH - HQ_CEDARS 95 MW 40 MW
Impacts Total Transfer Capability 95 MW 60 MW
TTC with All Lines In Service 190 MW 100 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 10/18/2021 to Sat 12/04/2021 **UPDATED by NYPA 08/20/2021**
0500 Continuous 1900
Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST 1400 MW
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 3150 MW

SCH-NYISO-NE_LIMIT_600

Mon 10/18/2021 to Sat 10/23/2021 **UPDATED by ISONE 10/14/2021**
0701 Daily 2300
Work scheduled by: ISONE

REV
(Export)
SCH - NE - NY 800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600					FWD	
Mon 10/18/2021	to	Tue 10/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
2301	Daily	0700				800 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 1400 MW	
SCH-NYISO-IMO_LIMIT_1000					REV	
Tue 10/19/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/14/2021</u>	(Export)
0400	Continuous	1600				1300 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 400 MW	
					TTC with All Lines In Service 1700 MW	
SCH-NE-NYISO_LIMIT_600					FWD	
Tue 10/19/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 1400 MW	
HUDSONTP-W49TH_ST_345_Y56					FWD	
Wed 10/20/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/15/2021</u>	(Import)
0200	Continuous	0230				0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 660 MW	
					TTC with All Lines In Service 660 MW	
SCH-IMO-NYISO_LIMIT_700					FWD	
Wed 10/20/2021	to	Thu 10/21/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/15/2021</u>	(Import)
0500	Continuous	1900				1000 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW	
					TTC with All Lines In Service 1950 MW	
ROTTRDAM-EASTOVER_230_38					REV	
Wed 10/20/2021	to	Wed 10/20/2021				(Export)
0730	Daily(No Weekends)	1059				1400 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 200 MW	
ARR: 77					TTC with All Lines In Service 1600 MW	
SCH-NE-NYISO_LIMIT_900					FWD	
Thu 10/21/2021	to	Fri 10/29/2021				(Import)
1700	Continuous	1600				1100 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 1400 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56						FWD	
Thu 10/21/2021	to	Thu 10/21/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/15/2021</u>	(Import)	
1730	Continuous	1830				0 MW	
Work scheduled by: PJM					SCH - PJM_HTP	Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
SCH-NE-NYISO_LIMIT_600						FWD	
Sun 10/24/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)	
0701	Daily	1600				800 MW	
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_600						REV	
Sun 10/24/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)	
0701	Daily	1600				800 MW	
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1600 MW
LADENTWN-BUCHAN_S_345_Y88						FWD	
Sun 10/24/2021	to	Sat 10/30/2021				(Import)	
0900	Continuous	1559				7560 MW	
Work scheduled by: ORU					UPNY CONED	Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	7815 MW
SHOR_NPX-SHOREHAM_138_CSC						FWD	REV
Mon 10/25/2021	to	Sun 11/21/2021				(Import)	(Export)
0700	Continuous	1600				0 MW	0 MW
Work scheduled by: ISONE					SCH - NPX_CSC	Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
BECK__-PACKARD_230_BP76						FWD	REV
Mon 10/25/2021	to	Fri 10/29/2021				(Import)	(Export)
0800	Continuous	1600				1500 MW	1150 MW
Work scheduled by: IESO					SCH - OH - NY	Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	1950 MW
CEDARS__-ROSEMNTB_115_2/22						FWD	REV
Tue 10/26/2021	to	Thu 10/28/2021				(Import)	(Export)
0300	Continuous	0200				95 MW	40 MW
Work scheduled by: HQ					SCH - HQ_CEDARS	Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DENNISON-ROSEMNTB_115_2/22

Tue 10/26/2021 to Thu 10/28/2021
0300 Continuous 0200

Work scheduled by: HQ

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	40 MW
Impacts Total Transfer Capability	95 MW	60 MW
TTC with All Lines In Service	190 MW	100 MW

SCH-HQ_CEDARS-NYISO_LIMIT_140

Tue 10/26/2021 to Thu 10/28/2021
0300 Continuous 0200

Work scheduled by: HQ

	FWD
	(Import)
SCH - HQ_CEDARS	140 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	190 MW

LEEDS___345KV_R94301

Fri 10/29/2021 to Fri 10/29/2021 UPDATED by CH 10/09/2021
1500 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

W49TH_ST_345KV_7

Sat 10/30/2021 to Sat 10/30/2021
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_5

Sat 10/30/2021 to Sun 12/05/2021 UPDATED by CONED 06/20/2021
0001 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	300 MW
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

LEEDS___-ATHENS___345_95

Sat 10/30/2021 to Sat 10/30/2021
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

LEEDS___345KV_R395

Sat 10/30/2021 to Sat 10/30/2021
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W97						FWD
Mon 11/01/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0001	Continuous	0200				7680 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 135 MW
						TTC with All Lines In Service 7815 MW
SCH-IMO-NYISO_LIMIT_1750						FWD
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1600						REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
BUCHAN_S-MILLWOOD_345_W98						FWD
Mon 11/01/2021	to	Tue 11/09/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	0200				7680 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 135 MW
						TTC with All Lines In Service 7815 MW
LADENTWN-BUCHAN_S_345_Y88						FWD
Mon 11/01/2021	to	Tue 11/09/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	0200				7560 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 255 MW
						TTC with All Lines In Service 7815 MW
W49TH_ST_345KV_7						FWD
Tue 11/02/2021	to	Tue 11/02/2021				(Import)
0200	Continuous	0230				300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
LINDN_CG-LNDVFT___345_V-3022						FWD REV
Tue 11/02/2021	to	Fri 11/05/2021				(Import) (Export)
0800	Continuous	1500				0 MW 0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 315 MW 315 MW
						TTC with All Lines In Service 315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18

Wed 11/03/2021 to Fri 11/12/2021
0001 Continuous 1800

Work scheduled by: ConEd

UPDATED by CE 10/12/2021

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

OSWEGO_-VOLNEY_345_11

Wed 11/03/2021 to Wed 11/03/2021
1100 Daily(No Weekends) 1300

Work scheduled by: NGrid

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

HOMRC_NY-MAINS_NY_345_47

Fri 11/05/2021 to Mon 11/08/2021
1601 Continuous 0800

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SHORE_RD_345_138_BK 1

Mon 11/08/2021 to Wed 11/10/2021
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

FWD
(Import)

BUCHAN_S-MILLWOOD_345_W98

Wed 11/10/2021 to Tue 11/16/2021
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/12/2021

UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

LADENTWN-BUCHAN_S_345_Y88

Wed 11/10/2021 to Tue 11/16/2021
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/12/2021

UPNY CONED **7560 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

SHORE_RD_345_138_BK 2

Thu 11/11/2021 to Fri 11/12/2021
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Fri 11/12/2021 to Tue 11/16/2021 **UPDATED by CONED 06/30/2021**

0001 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

BERKSHIR-ALPS_345_393

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1100 MW	1700 MW
Impacts Total Transfer Capability	300 MW	0 MW
TTC with All Lines In Service	1400 MW	1700 MW

BERKSHIR-ALPS_345_393

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1100 MW	1700 MW
Impacts Total Transfer Capability	300 MW	0 MW
TTC with All Lines In Service	1400 MW	1700 MW

BERKSHIR-NORTHFLD_345_312

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	1300 MW
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1400 MW

BERKSHIR-NORTHFLD_345_312

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

SCH-NE-NYISO_LIMIT_800

Sun 11/14/2021 to Wed 11/24/2021

0700 Continuous 1600

Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	1000 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULED WORK				IMPACTS		
Start Date	End Date	Time	Work	Zone	Impact	TTC
SCH-NYISO-NE_LIMIT_700						
Sun 11/14/2021	to	Wed 11/24/2021				
0700		1600	Continuous	SCH - NE - NY	900 MW	1700 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	800 MW	
				TTC with All Lines In Service		
PORTER -ROTTDAM_230_30 & MASSENA -MARCY_765_MSU1						
Mon 11/15/2021	to	Tue 11/30/2021				
0100		1730	Continuous	CENTRAL EAST - VC	1500 MW	2975 MW
Work scheduled by:				Impacts Total Transfer Capability	1475 MW	
				TTC with All Lines In Service		
CHATGUAY-MASSENA_765_7040						
Mon 11/15/2021	to	Tue 11/30/2021				
0100		1859	Continuous	MOSES SOUTH	1550 MW	3150 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW	
				TTC with All Lines In Service		
CHATGUAY-MASSENA_765_7040						
Mon 11/15/2021	to	Tue 11/30/2021				
0100		1859	Continuous	SCH - HQ - NY	0 MW	1000 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW	1000 MW
				TTC with All Lines In Service	1500 MW	1000 MW
MARCY_765_345_AT1						
Mon 11/15/2021	to	Tue 11/30/2021				
0100		1859	Continuous	MOSES SOUTH	1750 MW	3150 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW	
				TTC with All Lines In Service		
				ARR: 19		
MARCY_765_345_AT2						
Mon 11/15/2021	to	Tue 11/30/2021				
0100		1859	Continuous	MOSES SOUTH	1700 MW	3150 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW	
				TTC with All Lines In Service		
				ARR: 19		
MASSENA -MARCY_765_MSU1						
Mon 11/15/2021	to	Tue 11/30/2021				
0100		1859	Continuous	CENTRAL EAST - VC	1670 MW	2975 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1305 MW	
				TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021
0100	Continuous	1859		MOSES SOUTH	500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1				FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021
0100	Continuous	1859		SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MASSENA -MARCY 765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021
0100	Continuous	1859		SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD	
Mon 11/15/2021	to	Tue 11/30/2021			(Import)
0100		1859		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021			(Import) (Export)
0100		1859		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	
Mon 11/15/2021	to	Tue 11/30/2021			(Import)
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW
STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1				FWD	
Mon 11/15/2021	to	Tue 11/30/2021			(Import)
0100		1859		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	109 MW
				TTC with All Lines In Service	199 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___-					FWD
MASSENA_230_MMS2					(Import)
Mon 11/15/2021	to	Tue 11/30/2021			SCH - HQ_CEDARS
0100		1859			90 MW
Work scheduled by:					Impacts Total Transfer Capability
					109 MW
					TTC with All Lines In Service
					199 MW
DOLSONAV-ROCKTVRN_345_DART44					FWD
					(Import)
Mon 11/15/2021	to	Fri 11/19/2021			CENTRAL EAST - VC
0800	Continuous	1600			2720 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability
					255 MW
					TTC with All Lines In Service
					2975 MW
MILLWOOD-EASTVIEW_345_W85					FWD
					(Import)
Wed 11/17/2021	to	Wed 11/17/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>10/12/2021</u>
0001	Continuous	0030			UPNY CONED
Work scheduled by: ConEd					7550 MW
					Impacts Total Transfer Capability
					265 MW
					TTC with All Lines In Service
					7815 MW
DUNWODIE-MOTTHAVN_345_72					FWD
					(Import)
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/12/2021</u>
0001	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability
					800 MW
					TTC with All Lines In Service
					4600 MW
DUNWODIE_345KV_8					FWD
					(Import)
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/12/2021</u>
0001	Continuous	0200			SPR/DUN-SOUTH
Work scheduled by: ConEd					3800 MW
					Impacts Total Transfer Capability
					800 MW
					TTC with All Lines In Service
					4600 MW
EASTVIEW-SPRNBK__345_W78					FWD
					(Import)
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>10/12/2021</u>
0001	Continuous	0200			UPNY CONED
Work scheduled by: ConEd					4350 MW
					Impacts Total Transfer Capability
					3465 MW
					TTC with All Lines In Service
					7815 MW
W49TH_ST_345KV_7					FWD
					(Import)
Sat 11/20/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>
0001	Continuous	0030			SCH - PJM_HTP
Work scheduled by: ConEd					300 MW
					Impacts Total Transfer Capability
					360 MW
					TTC with All Lines In Service
					660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					FWD
Mon 11/22/2021	to	Sun 11/28/2021			(Import)
0001		0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by:					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W85					FWD
Mon 11/22/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>10/12/2021</u>
0130	Continuous	0200		UPNY CONED	7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW
DUNWODIE-MOTTHAVN_345_71					FWD
Mon 11/22/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>
0201	Continuous	0100		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_3					FWD
Mon 11/22/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>
0201	Continuous	0100		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_7					FWD
Thu 11/25/2021	to	Fri 12/03/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>
0001	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
SPRNBK__345KV_RNS4					FWD
Sun 11/28/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>
0300	Continuous	0330		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
SPRNBK_-W49TH_ST_345_M52					FWD
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>
0300	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 11/29/2021 to Fri 12/17/2021
0600 Continuous 1600

UPDATED by PJM 09/15/2021

Work scheduled by: PJM

FWD
(Import)
0 MW
SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 11/29/2021 to Fri 12/17/2021
0600 Continuous 1600

UPDATED by PJM 09/15/2021

Work scheduled by: PJM

FWD
(Import)
0 MW
SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 11/29/2021 to Fri 12/17/2021
0600 Continuous 1600

UPDATED by PJM 09/15/2021

Work scheduled by: PJM

FWD
(Import)
375 MW
SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

BERKSHIR-ALPS_____345_393

Mon 11/29/2021 to Sat 12/18/2021
0700 Continuous 1600

ARR: 78

Work scheduled by: ISONE

FWD REV
(Import) (Export)
1100 MW 1700 MW
SCH - NE - NY
Impacts Total Transfer Capability 300 MW 0 MW
TTC with All Lines In Service 1400 MW 1700 MW

BERKSHIR-ALPS_____345_393

Mon 11/29/2021 to Sat 12/18/2021
0700 Continuous 1600

ARR: 78

Work scheduled by: ISONE

FWD REV
(Import) (Export)
100 MW 100 MW
SCH - NPX_1385
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312

Mon 11/29/2021 to Sat 12/18/2021
0700 Continuous 1600

ARR: 78

Work scheduled by:

FWD REV
(Import) (Export)
1100 MW 1700 MW
SCH - NE - NY
Impacts Total Transfer Capability 300 MW 0 MW
TTC with All Lines In Service 1400 MW 1700 MW

BERKSHIR-NORTHFLD_345_312

Mon 11/29/2021 to Sat 12/18/2021
0700 Continuous 1600

Work scheduled by: ISONE

FWD
(Import)
1300 MW
SCH - NE - NY
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BERKSHIR-NORTHFLD_345_312						
Mon 11/29/2021	to	Sat 12/18/2021				
0700	Continuous	1600			SCH - NPX_1385	100 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
SCH-NE-NYISO_LIMIT_800						
Mon 11/29/2021	to	Sat 12/18/2021				
0700	Continuous	1600			SCH - NE - NY	1000 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700						
Mon 11/29/2021	to	Sat 12/18/2021				REV
0700	Continuous	1600			SCH - NE - NY	900 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1700 MW
HURLYAVE-ROSETON__345_303						
Mon 11/29/2021	to	Fri 12/17/2021	UPDATED	by CH	10/07/2021	
0800	Continuous	1600			UPNY CONED	4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW
NIAGARA_-PACKARD__230_61						
Tue 11/30/2021	to	Mon 12/06/2021				
0615	Continuous	1900			SCH - OH - NY	1200 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	2300 MW
SPRNBRK__345KV_RNS4						
Wed 12/01/2021	to	Wed 12/01/2021	UPDATED	by CONED	06/20/2021	
0130	Continuous	0200			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
MOSES__-ADIRNDCK_230_MAL						
Wed 12/01/2021	to	Tue 05/31/2022				
0700	Continuous	1300			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4

Fri 12/03/2021 to Sat 12/04/2021
0001 Continuous 1800
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M52

Fri 12/03/2021 to Sat 12/18/2021
0201 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MARCY__-EDIC__345_UE1-7

Fri 12/03/2021 to Fri 12/03/2021
0700 Daily(No Weekends) 1000
Work scheduled by: NGrid

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MILLWOOD_345KV_18

Mon 12/06/2021 to Fri 12/10/2021 **UPDATED by CE 10/12/2021**
0001 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_5

Mon 12/06/2021 to Sat 12/18/2021
0001 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

MARCY__345KV_CSC

Mon 12/06/2021 to Fri 12/17/2021
0700 Continuous 1730
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

BUCHAN_S-MILLWOOD_345_W98

Tue 12/07/2021 to Fri 12/10/2021 **UPDATED by CE 10/12/2021**
0201 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

Tue 12/07/2021 to Fri 12/10/2021
0201 Continuous 0200

UPDATED by CE 10/12/2021

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **7560 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS4

Mon 12/13/2021 to Tue 12/14/2021
0001 Continuous 1800

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

HURLYAVE-ROSETON_345_303

Mon 12/13/2021 to Wed 12/22/2021
0700 Continuous 1600

CANCELLED by CHGE 10/14/2021

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS4

Sat 12/18/2021 to Sat 12/18/2021
0130 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

FRASER_345_FRASER SVC

Tue 01/04/2022 to Mon 02/28/2022
0700 Continuous 1730

UPDATED by NYPA 05/25/2021

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2935 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

NIAGARA_-PACKARD_230_61

Mon 01/17/2022 to Fri 01/21/2022
0615 Continuous 1900

Work scheduled by: NGrid

FWD

REV

(Import) (Export)

SCH - OH - NY **1200 MW 1850 MW**
Impacts Total Transfer Capability 1100 MW 150 MW
TTC with All Lines In Service 2300 MW 2000 MW

S.RIPLEY-DUNKIRK_230_68

Tue 01/18/2022 to Fri 02/04/2022
0700 Continuous 1730

UPDATED by NGRID 09/24/2021

Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-STA_255__345_NH2

Fri 01/21/2022 to Fri 03/04/2022
0500 Continuous 1900

UPDATED by NYPA 08/20/2021

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ATHENS_-PLSNTVLY_345_91

Sat 02/12/2022 to Wed 02/16/2022
0600 Continuous 1900

UPDATED by NGRID 05/07/2021

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 02/17/2022 to Sat 02/19/2022
0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

LEEDS_-PLSNTVLY_345_92

Thu 02/17/2022 to Fri 03/25/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Thu 02/17/2022 to Fri 03/25/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F30

Sun 02/20/2022 to Mon 02/21/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK_345_W64

Tue 02/22/2022 to Tue 02/22/2022
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SPRNBRK__345KV_RNS5			FWD
Tue 02/22/2022	to	Tue 02/22/2022	(Import)
0001	Continuous	0030	2000 MW
Work scheduled by: ConEd			3200 MW
		SPR/DUN-SOUTH	Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
MILLWOOD-EASTVIEW_345_W99			FWD
Tue 02/22/2022	to	Mon 03/21/2022	(Import)
0001	Continuous	0200	7550 MW
Work scheduled by: ConEd			7550 MW
		UPNY CONED	Impacts Total Transfer Capability 265 MW
			TTC with All Lines In Service 7815 MW
<hr/>			
MARCY__-EDIC__345_UE1-7			FWD
Wed 02/23/2022	to	Mon 02/28/2022	(Import)
0700	Continuous	1530	5250 MW
Work scheduled by: NYPA			5250 MW
		OSWEGO EXPORT	Impacts Total Transfer Capability 0 MW
			TTC with All Lines In Service 5250 MW
			ARR: 19&16
<hr/>			
PORTER__-ROTTRDAM_230_31			FWD
Tue 03/01/2022	to	Tue 12/31/2030	(Import)
0600	Continuous	2359	2805 MW
Work scheduled by: NGrid			2805 MW
		CENTRAL EAST - VC	Impacts Total Transfer Capability 170 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
N.SCTLND-LEEDS__345_93			FWD
Tue 03/01/2022	to	Tue 03/15/2022	(Import)
0700	Continuous	1900	2650 MW
Work scheduled by: NGrid			2650 MW
		CENTRAL EAST - VC	Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
EDIC__-N.SCTLND_345_14			FWD
Tue 03/01/2022	to	Tue 04/12/2022	(Import)
0700	Continuous	1900	1670 MW
Work scheduled by: NGrid			1670 MW
		CENTRAL EAST - VC	Impacts Total Transfer Capability 1305 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
EDIC__-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_31			FWD
Tue 03/01/2022	to	Tue 04/12/2022	(Import)
0700		1900	1500 MW
Work scheduled by:			1500 MW
		CENTRAL EAST - VC	Impacts Total Transfer Capability 1475 MW
			TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41				FWD
Tue 03/01/2022	to	Wed 04/20/2022		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
MARCY__-FRASANX_345_UCC2-41				FWD
Tue 03/01/2022	to	Wed 04/20/2022		(Import)
0700	Continuous	1530		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
N. SCTLND-ALPS____345_2				FWD
Tue 03/01/2022	to	Tue 05/24/2022		(Import)
0700	Continuous	1900		SCH - NE - NY 900 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1400 MW
N. SCTLND-ALPS____345_2				FWD REV
Tue 03/01/2022	to	Tue 05/24/2022		(Import) (Export)
0700	Continuous	1900		SCH - NPX_1385 100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW 100 MW
				TTC with All Lines In Service 200 MW 200 MW
GOETHALS_345KV_5				
Sat 03/05/2022	to	Mon 04/04/2022	UPDATED by CONED 03/26/2021	
0001	Continuous	0200		STATEN ISLAND
Work scheduled by: ConEd				Impacts Total Transfer Capability
				TTC with All Lines In Service
LINDEN__-GOETHALS_230_A2253				
Sat 03/05/2022	to	Mon 04/04/2022	UPDATED by CONED 03/26/2021	
0001	Continuous	0200		SCH - PJ - NY
Work scheduled by: ConEd				Impacts Total Transfer Capability
				TTC with All Lines In Service
INDPDNCE-SCRIBA____345_25				FWD
Thu 03/10/2022	to	Wed 03/16/2022		(Import)
0800	Continuous	1800		OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4
 Thu 03/17/2022 to Sun 03/20/2022
 0100 2200
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F30
 Mon 03/21/2022 to Wed 03/23/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK_345_W64
 Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

SPRNBK_345KV_RNS5
 Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4
 Sat 03/26/2022 to Mon 03/28/2022
 0001 2200
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

ATHENS_-PLSNTVLY_345_91
 Sat 03/26/2022 to Sun 05/01/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4
 Sat 03/26/2022 to Sun 05/01/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F31				FWD	
Tue 03/29/2022 to Wed 03/30/2022				(Import)	
0001	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
LINDN_CG-LNDVFT__345_V-3022				FWD	REV
Sun 04/03/2022 to Sat 04/09/2022				(Import)	(Export)
1400	Continuous	1400		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
SPRNBK_-TREMONT__345_X28				FWD	
Tue 04/05/2022 to Wed 04/06/2022				(Import)	
0201	Continuous	0300		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
BUCHAN_N-EASTVIEW_345_W93				FWD	
Wed 04/06/2022 to Wed 04/06/2022				(Import)	
0301	Continuous	0330	UPDATED by CONED 08/19/2021	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W79				FWD	
Wed 04/06/2022 to Thu 04/07/2022				(Import)	
0301	Continuous	0300	UPDATED by CONED 08/19/2021	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
BUCHAN_N-EASTVIEW_345_W93				FWD	
Thu 04/07/2022 to Thu 04/07/2022				(Import)	
0230	Continuous	0300	UPDATED by CONED 08/19/2021	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W64				FWD	
Thu 04/07/2022 to Thu 04/07/2022				(Import)	
0301	Continuous	0330	UPDATED by CONED 08/31/2021	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5

FWD

Thu 04/07/2022 to Thu 04/07/2022 **UPDATED** **by CONED** **08/31/2021**
 0301 Continuous 0330
 Work scheduled by: ConEd

(Import)

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

FWD

Thu 04/07/2022 to Tue 04/26/2022 **UPDATED** **by CONED** **08/31/2021**
 0301 Continuous 2200
 Work scheduled by: ConEd

(Import)

UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

PANNELL_-CLAY____345_1

FWD

Mon 04/11/2022 to Fri 04/15/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

(Import)

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

PORTER_-ROTTDAM_230_30

FWD

Wed 04/13/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

(Import)

CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

PANNELL_-CLAY____345_2

FWD

Mon 04/18/2022 to Fri 04/22/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

(Import)

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

EDIC_-FRASER_345_EF24-40

FWD

Thu 04/21/2022 to Tue 06/14/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

(Import)

CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

FWD

Sat 04/23/2022 to Tue 04/26/2022
 0001 2200
 Work scheduled by:

(Import)

UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64					FWD	
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
2130	Continuous	2200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
SPRNBK__345KV_RNS5					FWD	
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
2130	Continuous	2200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLY-WOOD_ST__345_F31					FWD	
Wed 04/27/2022	to	Fri 04/29/2022				(Import)
0001	Continuous	2200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
NIAGARA__345_230_AT4					REV	
Fri 04/29/2022	to	Fri 04/29/2022				(Export)
0500	Continuous	1700				SCH - OH - NY 1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	2000 MW
BUCHAN_N-EASTVIEW_345_W93					FWD	
Mon 05/02/2022	to	Mon 05/02/2022				(Import)
0001	Continuous	0030				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W79					FWD	
Mon 05/02/2022	to	Thu 05/05/2022				(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
ROCHESTR-PANNELL__345_RP2					FWD	
Mon 05/02/2022	to	Fri 05/06/2022				(Import)
0500	Continuous	1700				DYSINGER EAST 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93					FWD	
Thu 05/05/2022	to	Thu 05/05/2022			(Import)	
0130	Continuous	0200		UPNY CONED	4350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
SPRNBRK_-TREMONT_345_X28					FWD	
Fri 05/06/2022	to	Mon 05/09/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0201	Continuous	1800		SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
FRASER_345_FRASER SVC					FWD	
Mon 05/09/2022	to	Fri 05/13/2022			(Import)	
0800	Continuous	1700		CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022			(Import)	(Export)
0600	Continuous	1800		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
HOMRC_NY-MAINS_NY_345_47						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600		SCH - PJ - NY		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
HOMR_NYW-PIERC_NY_345_48						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600		SCH - PJ - NY		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
NIAGARA_-PACKARD_230_62					FWD	REV
Sat 06/18/2022	to	Sat 06/18/2022			(Import)	(Export)
0500	Continuous	1700		SCH - OH - NY	700 MW	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1250 MW
					TTC with All Lines In Service	1950 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Tue 06/28/2022 to Wed 06/29/2022
 0500 Continuous 1700
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

BECK__-NIAGARA_230_PA27

Tue 07/05/2022 to Sat 07/09/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

SCH - OH - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

ROCHESTR-PANNELL__345_RP1

Mon 07/25/2022 to Fri 07/29/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

PANNELL_-CLAY__345_1

Mon 09/12/2022 to Fri 09/16/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

FRASER_-GILBOA__345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

SPRNBRK__345KV_RNS5

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED by CONED 09/17/2020**
 0001 Continuous 0030
 Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-W49TH_ST_345_M51					FWD	
Mon 09/19/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	(Import)
0001	Continuous	2200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
PANNELL_-CLAY_345_2					FWD	
Mon 09/19/2022	to	Fri 09/23/2022				(Import)
0700	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
SPRNBK_345KV_RNS5					FWD	
Wed 09/21/2022	to	Wed 09/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/17/2020</u>	(Import)
2130	Continuous	2200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBK_-W49TH_ST_345_M51					FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/01/2020</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBK_345KV_RNS5					FWD	
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/01/2020</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022				(Import) (Export)
0600	Continuous	1800				SCH - NPX_CSC 0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD	
Mon 10/10/2022	to	Fri 10/14/2022				(Import)
0600	Continuous	1600				SCH - PJM_NEPTUNE 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

GILBOA__-N.SCTLND_345_GNS-1

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

LEEDS___345KV_R94301

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

MARCY___-N.SCTLND_345_18

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **1470 MW**
Impacts Total Transfer Capability 1505 MW
TTC with All Lines In Service 2975 MW

N.SCTLND-LEEDS___345_94

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 16, 2021 to Monday ,April 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

 PORTER__-ROTTRDAM_230_30 & MARCY__-N.SCTLND_345_18

FWD

Mon 10/31/2022 to Mon 11/28/2022
 0500 1900

(Import)

CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW

Work scheduled by:

 PORTER__-ROTTRDAM_230_31 & MARCY__-N.SCTLND_345_18

FWD

Mon 10/31/2022 to Mon 11/28/2022
 0500 1900

(Import)

CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW

Work scheduled by: