

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: ConEd					SCH - PJ - NY	2050 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD	REV
Mon 01/15/2018	to	Tue 11/30/2021				(Import) (Export)
0001		2359				2000 MW 1150 MW
Work scheduled by:					SCH - PJ - NY	2000 MW 1150 MW
					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
MARION_-FARRAGUT_345_C3403					FWD	
Mon 01/15/2018	to	Tue 11/30/2021	<u>EXT FORCE</u>	<u>by CONED</u>	<u>05/26/2021</u>	(Import)
0001	Continuous	2359				2050 MW
Work scheduled by: ConEd					SCH - PJ - NY	2050 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
STLAWRNC-MOSES_230_L33P						
Mon 04/30/2018	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>07/08/2021</u>	
0456	Continuous	1600				
Work scheduled by: IESO					SCH - OH - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
NEWRDGE_345_138_BK_1					FWD	
Wed 09/02/2020	to	Tue 02/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>01/12/2021</u>	(Import)
1807	Continuous	2359				375 MW
Work scheduled by: LI					SCH - PJM_NEPTUNE	375 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_1600					FWD	
Sat 05/01/2021	to	Sun 10/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>	(Import)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO					SCH - OH - NY	1900 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	2100 MW
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1400					FWD	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Import)
0600	Continuous	1300				1700 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1950 MW	
SCH-NYISO-IMO_LIMIT_1200					REV	
Tue 09/07/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/01/2021</u>	(Export)
0600	Continuous	1300				1500 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 1700 MW	
SCH-HQ_CEDARS-NYISO_LIMIT_80					FWD	
Tue 09/07/2021	to	Fri 10/22/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/07/2021</u>	(Import)
0700	Continuous	1700				80 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 110 MW	
					TTC with All Lines In Service 190 MW	
PORTER__-ROTTRDAM_230_30					FWD	
Wed 09/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0700	Continuous	1730				2805 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW	
					TTC with All Lines In Service 2975 MW	
EDIC___-N.SCTLND_345_14					FWD	
Thu 09/16/2021	to	Sun 11/14/2021	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/31/2021</u>	(Import)
0600	Continuous	1830				1670 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 1305 MW	
					TTC with All Lines In Service 2975 MW	
EDIC___-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_30					FWD	
Thu 09/16/2021	to	Sun 11/14/2021				(Import)
0600		1830				1500 MW
Work scheduled by:					Impacts Total Transfer Capability 1475 MW	
					TTC with All Lines In Service 2975 MW	
HOMRC_NY-MAINS_NY_345_47						
Sat 09/18/2021	to	Fri 11/05/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/08/2021</u>	
0800	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_600						REV
Sun 09/26/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
SCH-NYISO-NE_LIMIT_1200						REV
Sat 10/02/2021	to	Sat 10/16/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
2301	Daily	0700				1400 MW
Work scheduled by: ISONE					SCH - NE - NY	1400 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_300						FWD
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
2301	Daily	0700				500 MW
Work scheduled by: ISONE					SCH - NE - NY	500 MW
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW
CHAT_DC_GC1						FWD
Sun 10/03/2021	to	Tue 11/23/2021				(Import)
0500	Continuous	2000				2850 MW
Work scheduled by: HQ					MOSES SOUTH	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1						REV
Sun 10/03/2021	to	Tue 11/23/2021				(Export)
0500	Continuous	2000				500 MW
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
SCH-NE-NYISO_LIMIT_600						FWD
Sun 10/03/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
CLAY -EDIC 345_2-15						FWD
Mon 10/04/2021	to	Sat 10/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/16/2021</u>	(Import)
0700	Continuous	1730				4850 MW
Work scheduled by: NYPA					OSWEGO EXPORT	4850 MW
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1200						FWD
Thu 10/07/2021	to	Tue 11/23/2021				(Import)
0001	Continuous	2000				SCH - HQ - NY 1200 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 1500 MW
SCH-IMO-NYISO_LIMIT_600						FWD
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/15/2021</u>	(Import)
0500	Continuous	1600				SCH - OH - NY 900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 1950 MW
SCH-NYISO-IMO_LIMIT_500						REV
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/15/2021</u>	(Export)
0500	Continuous	1600				SCH - OH - NY 800 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 1700 MW
LEEDS__-HURLYAVE_345_301						FWD
Mon 10/11/2021	to	Fri 10/29/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)
0700	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 3715 MW
						TTC with All Lines In Service 7815 MW
EFISHKIL-WOOD_ST_345_F38						FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
PLSNTVLE-DUNWODIE_345_W89						FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
WOOD_ST_-PLSNTVLE_345_Y86						FWD
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>09/24/2021</u>	(Import)
0130	Continuous	0200				UPNY CONED 7210 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 605 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93					FWD	
Tue 10/12/2021	to	Tue 10/12/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	0230				4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	
					TTC with All Lines In Service 7815 MW	
EASTVIEW-SPRNBK_345_W79					FWD	
Tue 10/12/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	2200				4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	
					TTC with All Lines In Service 7815 MW	
CEDARS_-ROSEMNTB_115_2/22					FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import) (Export)
0500	Continuous	2359				95 MW 40 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 95 MW 60 MW	
					TTC with All Lines In Service 190 MW 100 MW	
DENNISON-ROSEMNTB_115_2/22					FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import) (Export)
0500	Continuous	2359				95 MW 40 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 95 MW 60 MW	
					TTC with All Lines In Service 190 MW 100 MW	
SCH-NE-NYISO_LIMIT_100					FWD	
Tue 10/12/2021	to	Wed 10/20/2021				(Import)
2300	Daily	0659				300 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 1100 MW	
					TTC with All Lines In Service 1400 MW	
W49TH_ST_345KV_5					FWD	
Wed 10/13/2021	to	Fri 10/15/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>10/13/2021</u>	(Import)
0001	Continuous	0100				300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
W49TH_ST_345KV_7					FWD	
Wed 10/13/2021	to	Fri 10/15/2021	<u>CANCELLED</u>	<u>by ConEd</u>	<u>10/13/2021</u>	(Import)
0001	Continuous	0100				300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

Wed 10/13/2021 to Wed 10/13/2021
 2130 Continuous 2200
 Work scheduled by: ConEd

UPDATED by CE 10/12/2021

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W85

Thu 10/14/2021 to Thu 10/14/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_72

Thu 10/14/2021 to Sun 10/17/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

EXTENDED by CONED 10/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 10/14/2021 to Sun 10/17/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

EXTENDED by CONED 10/15/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W78

Thu 10/14/2021 to Sun 10/17/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_5

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-DUNWODIE_345_W75					FWD
Thu 10/14/2021	to	Sun 11/28/2021			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SPRNBRK_345KV_RNS3					FWD
Thu 10/14/2021	to	Sun 11/28/2021			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
SCH-NYISO-HQ_LIMIT_300					REV
Thu 10/14/2021	to	Sun 10/17/2021	UPDATED	by HQ	10/07/2021
0600	Daily	1800			(Export)
Work scheduled by: HQ					SCH - HQ - NY 300 MW
					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1000 MW
OSWEGO_-VOLNEY_345_12					FWD
Thu 10/14/2021	to	Thu 10/14/2021			(Import)
1100	Daily(No Weekends)	1400		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD
Fri 10/15/2021	to	Fri 10/15/2021	UPDATED	by NGRID	10/15/2021
0830	Daily(No Weekends)	1630			(Import)
Work scheduled by: NGrid					OSWEGO EXPORT 5250 MW
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
OSWEGO_-ELBRIDGE_345_17					FWD
Fri 10/15/2021	to	Fri 10/15/2021	UPDATED	by NGRID	10/15/2021
0830	Daily(No Weekends)	1630			(Import)
Work scheduled by: NGrid					OSWEGO EXPORT 5250 MW
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
CLAY_-INDPDCE_345_26					FWD
Sat 10/16/2021	to	Sat 10/16/2021	CANCELLED	by NGrid	10/16/2021
0800	Daily	1000			(Import)
Work scheduled by: NGrid					OSWEGO EXPORT 5000 MW
					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
CHAT_DC_GC2						(Import)
Sun 10/17/2021	to	Sun 10/17/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>10/17/2021</u>	
0001	Continuous	0200				2850 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
CHAT_DC_GC2						REV
						(Export)
Sun 10/17/2021	to	Sun 10/17/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>10/17/2021</u>	
0001	Continuous	0200				500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<hr/>						
SCH-HQ-NYISO_LIMIT_1150						FWD
						(Import)
Sun 10/17/2021	to	Sun 10/17/2021	<u>CANCELLED</u>	<u>by HQ</u>	<u>10/17/2021</u>	
0001	Continuous	0200				1150 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 350 MW
						TTC with All Lines In Service 1500 MW
<hr/>						
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4						FWD
						(Import)
Sun 10/17/2021	to	Wed 10/20/2021				
0001		0200				3200 MW
Work scheduled by:						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
DUNWODIE-MOTTHAVN_345_71						FWD
						(Import)
Sun 10/17/2021	to	Tue 10/19/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	
0101	Continuous	0200				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
DUNWODIE_345KV_3						FWD
						(Import)
Sun 10/17/2021	to	Tue 10/19/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	
0101	Continuous	0200				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
SCH-NYISO-NE_LIMIT_1200						REV
						(Export)
Sun 10/17/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	
2301	Daily	0700				1400 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
CEDARS__-ROSEMNTA_115_1/11							
Mon 10/18/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/14/2021</u>		
0500	Continuous	2359				SCH - HQ_CEDARS	95 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	60 MW
						TTC with All Lines In Service	100 MW
DENNISON-ROSEMNTA_115_1/11							
Mon 10/18/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/14/2021</u>		
0500	Continuous	2359				SCH - HQ_CEDARS	95 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	60 MW
						TTC with All Lines In Service	100 MW
NIAGARA_-KINTIGH_345_NS1-38							
Mon 10/18/2021	to	Sat 12/04/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>		
0500	Continuous	1900				DYSINGER EAST	1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
SCH-NYISO-NE_LIMIT_600							REV
Mon 10/18/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>		(Export)
0701	Daily	2300				SCH - NE - NY	800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_600							FWD
Mon 10/18/2021	to	Tue 10/19/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>		(Import)
2301	Daily	0700				SCH - NE - NY	800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	1400 MW
SCH-NYISO-IMO_LIMIT_1000							REV
Tue 10/19/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/14/2021</u>		(Export)
0400	Continuous	1600				SCH - OH - NY	1300 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	1700 MW
SCH-NE-NYISO_LIMIT_600							FWD
Tue 10/19/2021	to	Sat 10/23/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>		(Import)
0701	Daily	2300				SCH - NE - NY	800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56					FWD	
Wed 10/20/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/15/2021</u>	(Import)
0200	Continuous	0230				0 MW
Work scheduled by: PJM					SCH - PJM_HTP	Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_700					FWD	
Wed 10/20/2021	to	Thu 10/21/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/15/2021</u>	(Import)
0500	Continuous	1900				1000 MW
Work scheduled by: NYPA					SCH - OH - NY	Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service	1950 MW
ROTTDAM-EASTOVER_230_38					REV	
Wed 10/20/2021	to	Wed 10/20/2021				(Export)
0730	Daily(No Weekends)	1059				1400 MW
Work scheduled by: NGrid				ARR: 77		Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_900					FWD	
Thu 10/21/2021	to	Tue 11/02/2021	<u>EXTENDED</u>	<u>by ISONE</u>	<u>10/17/2021</u>	(Import)
1700	Continuous	1600				1100 MW
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service	1400 MW
HUDSONTP-W49TH_ST_345_Y56					FWD	
Thu 10/21/2021	to	Thu 10/21/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>10/15/2021</u>	(Import)
1730	Continuous	1830				0 MW
Work scheduled by: PJM					SCH - PJM_HTP	Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service	660 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Sun 10/24/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
0701	Daily	1600				800 MW
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_600					REV	
Sun 10/24/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
0701	Daily	1600				800 MW
Work scheduled by: ISONE					SCH - NE - NY	Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88				FWD	
Sun 10/24/2021	to	Sat 10/30/2021		(Import)	
0900	Continuous	1559	UPNY CONED	7560 MW	
Work scheduled by: ORU			Impacts Total Transfer Capability	255 MW	
			TTC with All Lines In Service	7815 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 10/25/2021	to	Sun 11/21/2021		(Import)	(Export)
0700	Continuous	1600	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
BECK__-PACKARD_230_BP76				FWD	REV
Mon 10/25/2021	to	Fri 10/29/2021		(Import)	(Export)
0800	Continuous	1600	SCH - OH - NY	1500 MW	1150 MW
Work scheduled by: IESO			Impacts Total Transfer Capability	450 MW	550 MW
			TTC with All Lines In Service	1950 MW	1700 MW
CEDARS__-ROSEMNTB_115_2/22				FWD	REV
Tue 10/26/2021	to	Thu 10/28/2021		(Import)	(Export)
0300	Continuous	0200	SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	95 MW	60 MW
			TTC with All Lines In Service	190 MW	100 MW
DENNISON-ROSEMNTB_115_2/22				FWD	REV
Tue 10/26/2021	to	Thu 10/28/2021		(Import)	(Export)
0300	Continuous	0200	SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	95 MW	60 MW
			TTC with All Lines In Service	190 MW	100 MW
SCH-HQ_CEDARS-NYISO_LIMIT_140				FWD	
Tue 10/26/2021	to	Thu 10/28/2021		(Import)	
0300	Continuous	0200	SCH - HQ_CEDARS	140 MW	
Work scheduled by: HQ			Impacts Total Transfer Capability	50 MW	
			TTC with All Lines In Service	190 MW	
LEEDS__345KV_R94301				FWD	
Fri 10/29/2021	to	Fri 10/29/2021	UPDATED	(Import)	
1500	Continuous	1600	by CH		
Work scheduled by: CHGE			10/09/2021	UPNY CONED	3800 MW
				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7					FWD
Sat 10/30/2021	to	Sat 10/30/2021			(Import)
0001	Continuous	0030		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
					660 MW
W49TH_ST_345KV_5					FWD
Sat 10/30/2021	to	Sun 12/05/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>
0001	Continuous	0300		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
					660 MW
LEEDS___-ATHENS___345_95					FWD
Sat 10/30/2021	to	Sat 10/30/2021			(Import)
0800	Daily(No Weekends)	1500		UPNY CONED	3800 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability
					TTC with All Lines In Service
					7815 MW
LEEDS___345KV_R395					FWD
Sat 10/30/2021	to	Sat 10/30/2021			(Import)
0800	Daily(No Weekends)	1500		UPNY CONED	3800 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability
					TTC with All Lines In Service
					7815 MW
BUCHAN_S-MILLWOOD_345_W97					FWD
Mon 11/01/2021	to	Fri 12/10/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>
0001	Continuous	0200		UPNY CONED	7680 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability
					TTC with All Lines In Service
					7815 MW
SCH-IMO-NYISO_LIMIT_1750					FWD
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359		SCH - OH - NY	2050 MW
Work scheduled by: IESO					Impacts Total Transfer Capability
					TTC with All Lines In Service
					2300 MW
SCH-NYISO-IMO_LIMIT_1600					REV
Mon 11/01/2021	to	Fri 12/31/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>05/03/2019</u>
0001	Continuous	2359		SCH - OH - NY	1900 MW
Work scheduled by: IESO					Impacts Total Transfer Capability
					TTC with All Lines In Service
					2000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W98					FWD	
Mon 11/01/2021	to	Tue 11/09/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	0200				UPNY CONED 7680 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	7815 MW
LADENTWN-BUCHAN_S_345_Y88					FWD	
Mon 11/01/2021	to	Tue 11/09/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0201	Continuous	0200				UPNY CONED 7560 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_7					FWD	
Tue 11/02/2021	to	Tue 11/02/2021				(Import)
0200	Continuous	0230				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
LINDN_CG-LNDVFT___345_V-3022					FWD	REV
Tue 11/02/2021	to	Fri 11/05/2021				(Import) (Export)
0800	Continuous	1500				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
MILLWOOD_345KV_18					FWD	
Wed 11/03/2021	to	Fri 11/12/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0001	Continuous	1800				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
OSWEGO__ -VOLNEY___345_11					FWD	
Wed 11/03/2021	to	Wed 11/03/2021				(Import)
1100	Daily(No Weekends)	1300				OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
HOMRC_NY-MAINS_NY_345_47						
Fri 11/05/2021	to	Mon 11/08/2021				
1601	Continuous	0800				SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1

Mon 11/08/2021 to Wed 11/10/2021
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

BUCHAN_S-MILLWOOD_345_W98

Wed 11/10/2021 to Tue 11/16/2021
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/12/2021

FWD
(Import)
UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 11/10/2021 to Tue 11/16/2021
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/12/2021

FWD
(Import)
UPNY CONED **7560 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 7815 MW

SHORE_RD_345_138_BK 2

Thu 11/11/2021 to Fri 11/12/2021
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

GOETHALS_345KV_5

Fri 11/12/2021 to Tue 11/16/2021
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 06/30/2021

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

BERKSHIR-ALPS 345_393

Sun 11/14/2021 to Wed 11/24/2021
0700 Continuous 1600

Work scheduled by: ISONE

ARR: 78

FWD REV
(Import) (Export)
SCH - NE - NY **1100 MW 1700 MW**
Impacts Total Transfer Capability 300 MW 0 MW
TTC with All Lines In Service 1400 MW 1700 MW

BERKSHIR-ALPS 345_393

Sun 11/14/2021 to Wed 11/24/2021
0700 Continuous 1600

Work scheduled by: ISONE

ARR: 78

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312		FWD	REV
Sun 11/14/2021 to Wed 11/24/2021		(Import) (Export)	
0700 1600		SCH - NE - NY	1100 MW 1700 MW
Work scheduled by:	ARR: 78	Impacts Total Transfer Capability	300 MW 0 MW
		TTC with All Lines In Service	1400 MW 1700 MW
<hr/>			
BERKSHIR-NORTHFLD_345_312		FWD	
Sun 11/14/2021 to Wed 11/24/2021		(Import)	
0700 Continuous 1600		SCH - NE - NY	1300 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	1400 MW
<hr/>			
BERKSHIR-NORTHFLD_345_312		FWD	REV
Sun 11/14/2021 to Wed 11/24/2021		(Import) (Export)	
0700 Continuous 1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
SCH-NE-NYISO_LIMIT_800		FWD	
Sun 11/14/2021 to Wed 11/24/2021		(Import)	
0700 Continuous 1600		SCH - NE - NY	1000 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	1400 MW
<hr/>			
SCH-NYISO-NE_LIMIT_700			REV
Sun 11/14/2021 to Wed 11/24/2021			(Export)
0700 Continuous 1600		SCH - NE - NY	900 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	1700 MW
<hr/>			
PORTER_-ROTTDAM_230_30 & MASSENA_-MARCY_____765_MSU1		FWD	
Mon 11/15/2021 to Tue 11/30/2021		(Import)	
0100 1730		CENTRAL EAST - VC	1500 MW
Work scheduled by:		Impacts Total Transfer Capability	1475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
CHATGUAY-MASSENA_765_7040		FWD	
Mon 11/15/2021 to Tue 11/30/2021		(Import)	
0100 Continuous 1859	UPDATED by NYISO 06/03/2021	MOSES SOUTH	1550 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						
CHATGUAY-MASSENA__765_7040					FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021	(Import) (Export)
0100	Continuous	1859				0 MW 0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1500 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<hr/>						
MARCY__765_345_AT1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021	(Import)
0100	Continuous	1859				1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MARCY__765_345_AT2					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021	(Import)
0100	Continuous	1859				1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021	(Import)
0100	Continuous	1859				1670 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1305 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021	(Import)
0100	Continuous	1859				500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW
						TTC with All Lines In Service 3150 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021	(Import) (Export)
0100	Continuous	1859				475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<hr/>						
MASSENA_-MARCY__765_MSU1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	UPDATED	by NYISO	06/03/2021	(Import)
0100	Continuous	1859				90 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 109 MW
						TTC with All Lines In Service 199 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
0100 1859

Work scheduled by:

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 109 MW
TTC with All Lines In Service 199 MW

DOLSONAV-ROCKTVRN 345_DART44

Mon 11/15/2021 to Fri 11/19/2021
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

MILLWOOD-EASTVIEW 345_W85

Wed 11/17/2021 to Wed 11/17/2021 **EXTENDED by CE 10/12/2021**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7550 MW**
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_72					FWD	
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/12/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CONED</u>	<u>10/12/2021</u>	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
EASTVIEW-SPRNBK__345_W78					FWD	
Wed 11/17/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_7					FWD	
Sat 11/20/2021	to	Sat 11/20/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0001	Continuous	0030				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					FWD	
Mon 11/22/2021	to	Sun 11/28/2021				(Import)
0001		0200				3800 MW
Work scheduled by:					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD-EASTVIEW_345_W85					FWD	
Mon 11/22/2021	to	Mon 11/22/2021	<u>EXTENDED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)
0130	Continuous	0200				7550 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
Mon 11/22/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)
0201	Continuous	0100				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3						FWD
Mon 11/22/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)
0201	Continuous	0100				3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_7						FWD
Thu 11/25/2021	to	Fri 12/03/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0001	Continuous	0200				300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
SPRNBRK__345KV_RNS4						FWD
Sun 11/28/2021	to	Sun 11/28/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0300	Continuous	0330				3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
SPRNBRK_-W49TH_ST_345_M52						FWD
Sun 11/28/2021	to	Wed 12/01/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/20/2021</u>	(Import)
0300	Continuous	0200				3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE_345_501						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2						FWD
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u>	<u>by PJM</u>	<u>09/15/2021</u>	(Import)
0600	Continuous	1600				375 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	1100 MW 1700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	300 MW 0 MW
ARR: 78			TTC with All Lines In Service	1400 MW 1700 MW
BERKSHIR-ALPS _____ 345_393			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
ARR: 78			TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700		1600	SCH - NE - NY	1100 MW 1700 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW 0 MW
ARR: 78			TTC with All Lines In Service	1400 MW 1700 MW
BERKSHIR-NORTHFLD_345_312			FWD	
			(Import)	
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	1300 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312			FWD	REV
			(Import)	(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_800			FWD	
			(Import)	
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	1000 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700				REV
				(Export)
Mon 11/29/2021	to	Sat 12/18/2021		
0700	Continuous	1600	SCH - NE - NY	900 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303				FWD	
Mon 11/29/2021	to	Fri 12/17/2021	<u>UPDATED</u> <u>by CH</u> <u>10/07/2021</u>	(Import)	
0800	Continuous	1600		UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability	3715 MW
				TTC with All Lines In Service	7815 MW
NIAGARA -PACKARD__230_61				FWD	REV
Tue 11/30/2021	to	Mon 12/06/2021		(Import)	(Export)
0615	Continuous	1900		SCH - OH - NY	1200 MW 1850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1100 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
SPRNBRK__345KV_RNS4				FWD	
Wed 12/01/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
MOSES__-ADIRNDCK_230_MA1				FWD	
Wed 12/01/2021	to	Tue 05/31/2022		(Import)	
0700	Continuous	1300		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
SPRNBRK__345KV_RNS4				FWD	
Fri 12/03/2021	to	Sat 12/04/2021		(Import)	
0001	Continuous	1800		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
SPRNBRK_-W49TH_ST_345_M52				FWD	
Fri 12/03/2021	to	Sat 12/18/2021		(Import)	
0201	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
MARCY__-EDIC__345_UE1-7				FWD	
Fri 12/03/2021	to	Fri 12/03/2021		(Import)	
0700	Daily(No Weekends)	1000		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18

Mon 12/06/2021 to Fri 12/10/2021
0001 Continuous 0200

UPDATED by CE 10/12/2021

Work scheduled by: ConEd

FWD
(Import)
4350 MW
UPNY CONED
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_5

Mon 12/06/2021 to Sat 12/18/2021
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
300 MW
SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

MARCY___345KV_CSC

Mon 12/06/2021 to Fri 12/17/2021
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
2925 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

BUCHAN_S-MILLWOOD_345_W98

Tue 12/07/2021 to Fri 12/10/2021
0201 Continuous 0200

UPDATED by CE 10/12/2021

Work scheduled by: ConEd

FWD
(Import)
7680 MW
UPNY CONED
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

LADENTWN-BUCHAN_S_345_Y88

Tue 12/07/2021 to Fri 12/10/2021
0201 Continuous 0200

UPDATED by CE 10/12/2021

Work scheduled by: ConEd

FWD
(Import)
7560 MW
UPNY CONED
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 7815 MW

SPRNBRK__345KV_RNS4

Mon 12/13/2021 to Tue 12/14/2021
0001 Continuous 1800

Work scheduled by: ConEd

FWD
(Import)
3200 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

HURLYAVE-ROSETON__345_303

Mon 12/13/2021 to Wed 12/22/2021
0700 Continuous 1600

CANCELLED by CHGE 10/14/2021

Work scheduled by: CHGE

FWD
(Import)
4100 MW
UPNY CONED
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS4					FWD	
Sat 12/18/2021	to	Sat 12/18/2021			(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
FRASER__345_FRASER SVC					FWD	
Tue 01/04/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/25/2021</u>	(Import)
0700	Continuous	1730		CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
NIAGARA_-PACKARD__230_61					FWD	REV
Mon 01/17/2022	to	Fri 01/21/2022			(Import)	(Export)
0615	Continuous	1900		SCH - OH - NY	1200 MW	1850 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	1100 MW 150 MW
					TTC with All Lines In Service	2300 MW 2000 MW
S.RIPLEY-DUNKIRK__230_68						
Tue 01/18/2022	to	Fri 02/04/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>09/24/2021</u>	
0700	Continuous	1730		SCH - PJ - NY		
Work scheduled by: NGrid					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
NIAGARA_-STA_255__345_NH2					FWD	
Fri 01/21/2022	to	Fri 03/04/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/20/2021</u>	(Import)
0500	Continuous	1900		DYSINGER EAST	1700 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
ATHENS__-PLSNTVLY_345_91					FWD	
Sat 02/12/2022	to	Wed 02/16/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/07/2021</u>	(Import)
0600	Continuous	1900		UPNY CONED	3800 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD	
Thu 02/17/2022	to	Sat 02/19/2022			(Import)	
0001		2200		UPNY CONED	3800 MW	
Work scheduled by:					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-PLSNTVLY_345_92

Thu 02/17/2022 to Fri 03/25/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Thu 02/17/2022 to Fri 03/25/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST__345_F30

Sun 02/20/2022 to Mon 02/21/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBRK__345_W64

Tue 02/22/2022 to Tue 02/22/2022 **UPDATED by CONED 08/31/2021**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK__345KV_RNS5

Tue 02/22/2022 to Tue 02/22/2022 **UPDATED by CONED 08/31/2021**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Tue 02/22/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

MARCY___-EDIC_____345_UE1-7

Wed 02/23/2022 to Mon 02/28/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

N.SCTLND-LEEDS____345_93

Tue 03/01/2022 to Tue 03/15/2022
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

EDIC____-N.SCTLND_345_14

Tue 03/01/2022 to Tue 04/12/2022
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

EDIC____-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 04/12/2022
 0700 1900
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

FRASANNX-COOPERS__345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY____-FRASANNX_345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

N.SCTLND-ALPS____345_2

Tue 03/01/2022 to Tue 05/24/2022
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work by	Notes	FWD	REV
N. SCTLND-ALPS_345_2	Tue 03/01/2022	Tue 05/24/2022	0700 Continuous 1900	NGrid	SCH - NPX_1385	(Import)	(Export)
					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
GOETHALS_345KV_5	Sat 03/05/2022	Mon 04/04/2022	0001 Continuous 0200	ConEd	STATEN ISLAND		
					Impacts Total Transfer Capability		
					TTC with All Lines In Service		
LINDEN_-GOETHALS_230_A2253	Sat 03/05/2022	Mon 04/04/2022	0001 Continuous 0200	ConEd	SCH - PJ - NY		
					Impacts Total Transfer Capability		
					TTC with All Lines In Service		
INDPDNCE-SCRIBA_345_25	Thu 03/10/2022	Wed 03/16/2022	0800 Continuous 1800	NGrid	OSWEGO EXPORT	(Import)	
					Impacts Total Transfer Capability	5250 MW	
					TTC with All Lines In Service	5250 MW	
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4	Thu 03/17/2022	Sun 03/20/2022	0100 Continuous 2200		UPNY CONED	(Import)	
					Impacts Total Transfer Capability	3800 MW	
					TTC with All Lines In Service	4015 MW	7815 MW
PLSNTVLY-WOOD_ST_345_F30	Mon 03/21/2022	Wed 03/23/2022	0001 Continuous 2200	ConEd	UPNY CONED	(Import)	
					Impacts Total Transfer Capability	4000 MW	
					TTC with All Lines In Service	3815 MW	7815 MW
EASTVIEW-SPRNBK_345_W64	Mon 03/21/2022	Mon 03/21/2022	0130 Continuous 0200	ConEd	UPNY CONED	(Import)	
					Impacts Total Transfer Capability	4350 MW	
					TTC with All Lines In Service	3465 MW	7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5				FWD	
Mon 03/21/2022	to	Mon 03/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>
0130	Continuous	0200			
Work scheduled by: ConEd			SPR/DUN-SOUTH		3200 MW
			Impacts Total Transfer Capability		1400 MW
			TTC with All Lines In Service		4600 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD	
Sat 03/26/2022	to	Mon 03/28/2022			
0001		2200			
Work scheduled by:			UPNY CONED		3800 MW
			Impacts Total Transfer Capability		4015 MW
			TTC with All Lines In Service		7815 MW
ATHENS__-PLSNTVLY_345_91				FWD	
Sat 03/26/2022	to	Sun 05/01/2022			
0001	Continuous	2200			
Work scheduled by: ConEd			UPNY CONED		3800 MW
			Impacts Total Transfer Capability		4015 MW
			TTC with All Lines In Service		7815 MW
PLSNTVLY_345KV_RNS4				FWD	
Sat 03/26/2022	to	Sun 05/01/2022			
0001	Continuous	2200			
Work scheduled by: ConEd			UPNY CONED		3800 MW
			Impacts Total Transfer Capability		4015 MW
			TTC with All Lines In Service		7815 MW
PLSNTVLY-WOOD_ST__345_F31				FWD	
Tue 03/29/2022	to	Wed 03/30/2022			
0001	Continuous	2200			
Work scheduled by: ConEd			UPNY CONED		4000 MW
			Impacts Total Transfer Capability		3815 MW
			TTC with All Lines In Service		7815 MW
LINDN_CG-LNDVFT__345_V-3022				FWD	REV
Sun 04/03/2022	to	Sat 04/09/2022			
1400	Continuous	1400			
Work scheduled by: PJM			SCH - PJM_VFT	0 MW	0 MW
			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
SPRNBK_-TREMONT__345_X28				FWD	
Tue 04/05/2022	to	Wed 04/06/2022			
0201	Continuous	0300			
Work scheduled by: ConEd			SPR/DUN-SOUTH		4200 MW
			Impacts Total Transfer Capability		400 MW
			TTC with All Lines In Service		4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93					FWD	
Wed 04/06/2022	to	Wed 04/06/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0301	Continuous	0330				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W79					FWD	
Wed 04/06/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0301	Continuous	0300				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
BUCHAN_N-EASTVIEW_345_W93					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0230	Continuous	0300				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W64					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				4350 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
SPRNBK__345KV_RNS5					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 04/07/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	2200				7550 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
PANNELL_-CLAY_____345_1					FWD	
Mon 04/11/2022	to	Fri 04/15/2022				(Import)
0700	Continuous	1530				1300 MW
Work scheduled by: NYPA					WEST CENTRAL	
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30

Wed 04/13/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

PANNELL_-CLAY_____345_2

Mon 04/18/2022 to Fri 04/22/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

EDIC___-FRASER___345_EF24-40

Thu 04/21/2022 to Tue 06/14/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 04/23/2022 to Tue 04/26/2022
 0001 2200
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK__345_W64

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLY-WOOD_ST__345_F31

Wed 04/27/2022 to Fri 04/29/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4				REV
Fri 04/29/2022	to	Fri 04/29/2022		(Export)
0500	Continuous	1700	SCH - OH - NY	1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 2000 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Mon 05/02/2022	to	Mon 05/02/2022		(Import)
0001	Continuous	0030	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBRK__345_W79				FWD
Mon 05/02/2022	to	Thu 05/05/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
ROCHESTR-PANNELL__345_RP2				FWD
Mon 05/02/2022	to	Fri 05/06/2022		(Import)
0500	Continuous	1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Thu 05/05/2022	to	Thu 05/05/2022		(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBRK_-TREMONT__345_X28				FWD
Fri 05/06/2022	to	Mon 05/09/2022	UPDATED by CONED 08/19/2021	(Import)
0201	Continuous	1800	SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW
FRASER__345_FRASER SVC				FWD
Mon 05/09/2022	to	Fri 05/13/2022		(Import)
0800	Continuous	1700	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC						
Mon 05/16/2022	to	Fri 05/27/2022				
0600	Continuous	1800		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
HOMRC_NY-MAINS_NY_345_47						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600		SCH - PJ - NY		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
HOMR_NYW-PIERC_NY_345_48						
Fri 05/20/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by PJM</u>	<u>11/19/2020</u>	
0800	Continuous	1600		SCH - PJ - NY		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
NIAGARA_-PACKARD_230_62						
Sat 06/18/2022	to	Sat 06/18/2022				
0500	Continuous	1700		SCH - OH - NY	700 MW	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1250 MW
					TTC with All Lines In Service	1950 MW
NIAGARA_345_230_AT4						
Tue 06/28/2022	to	Wed 06/29/2022				
0500	Continuous	1700		SCH - OH - NY	1900 MW	1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1950 MW
BECK_-NIAGARA_230_PA27						
Tue 07/05/2022	to	Sat 07/09/2022				
0500	Continuous	2100		SCH - OH - NY		
Work scheduled by: NYPA					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
ROCHESTR-PANNELL_345_RP1						
Mon 07/25/2022	to	Fri 07/29/2022				
0500	Continuous	2100		DYSINGER EAST	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL -CLAY 345_1

Mon 09/12/2022 to Fri 09/16/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FRASER -GILBOA 345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

SPRNBRK 345KV_RNS5

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED by CONED 09/17/2020**
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK -W49TH_ST_345_M51

Mon 09/19/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

PANNELL -CLAY 345_2

Mon 09/19/2022 to Fri 09/23/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

SPRNBRK 345KV_RNS5

Wed 09/21/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**
2130 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-W49TH_ST_345_M51				FWD
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/01/2020</u>	(Import)
0001	Continuous	0300		3200 MW
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBRK_345KV_RNS5				FWD
Sat 10/01/2022	to	Mon 10/17/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/01/2020</u>	(Import)
0001	Continuous	0300		3200 MW
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD
Mon 10/03/2022	to	Fri 10/21/2022		(Import) (Export)
0600	Continuous	1800		0 MW 0 MW
Work scheduled by: LI				SCH - NPX_CSC
				Impacts Total Transfer Capability 330 MW 330 MW
				TTC with All Lines In Service 330 MW 330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		0 MW
Work scheduled by: LI				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE_345_501				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		0 MW
Work scheduled by: LI				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_1				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		375 MW
Work scheduled by: LI				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2				FWD
Mon 10/10/2022	to	Fri 10/14/2022		(Import)
0600	Continuous	1600		375 MW
Work scheduled by: LI				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,October 17, 2021 to Tuesday ,April 18, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-N.SCTLND_345_GNS-1

Mon 10/31/2022 to Mon 11/28/2022
 0500 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

LEEDS____345KV_R94301

Mon 10/31/2022 to Mon 11/28/2022
 0500 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

MARCY__-N.SCTLND_345_18

Mon 10/31/2022 to Mon 11/28/2022
 0500 Continuous 1900
 Work scheduled by: NGrid

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **1470 MW**
 Impacts Total Transfer Capability 1505 MW
 TTC with All Lines In Service 2975 MW

N.SCTLND-LEEDS____345_94

Mon 10/31/2022 to Mon 11/28/2022
 0500 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_30 & MARCY__-N.SCTLND_345_18

Mon 10/31/2022 to Mon 11/28/2022
 0500 1900
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_31 & MARCY__-N.SCTLND_345_18

Mon 10/31/2022 to Mon 11/28/2022
 0500 1900
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW