

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 11/30/2021
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCE by CONED 05/26/2021

FWD
(Import)
SCH - PJ - NY **2050 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 2250 MW

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Tue 11/30/2021
0001 2359

Work scheduled by:

FWD REV
(Import) (Export)
SCH - PJ - NY **2000 MW 1150 MW**
Impacts Total Transfer Capability 250 MW 100 MW
TTC with All Lines In Service 2250 MW 1250 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Tue 11/30/2021
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCE by CONED 05/26/2021

FWD
(Import)
SCH - PJ - NY **2050 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 2250 MW

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Mon 10/31/2022
0456 Continuous 1600

Work scheduled by: IESO

EXT FORCE by IESO 07/08/2021

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Tue 02/01/2022
1807 Continuous 2359

Work scheduled by: LI

EXT FORCE by LI 01/12/2021

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1600

Sat 05/01/2021 to Sun 10/31/2021
0001 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 05/03/2019

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1950 MW

MOSES_-ADIRNDCK_230_MA2

Tue 09/07/2021 to Sun 11/14/2021
0600 Continuous 1300

Work scheduled by: NYPA

UPDATED by NYPA 09/01/2021

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1400

FWD

Tue 09/07/2021 to Sun 11/14/2021 **UPDATED** **by NYPA** **09/01/2021**
 0600 Continuous 1300

Work scheduled by: IESO

SCH - OH - NY **1700 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1950 MW

SCH-NYISO-IMO_LIMIT_1200

REV

Tue 09/07/2021 to Sun 11/14/2021 **UPDATED** **by NYPA** **09/01/2021**
 0600 Continuous 1300

Work scheduled by: IESO

SCH - OH - NY **1500 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1700 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

FWD

Tue 09/07/2021 to Fri 10/22/2021 **UPDATED** **by HQ** **10/07/2021**
 0700 Continuous 1700

Work scheduled by: HQ

SCH - HQ_CEDARS **80 MW**
 Impacts Total Transfer Capability 110 MW
 TTC with All Lines In Service 190 MW

PORTER__-ROTTRDAM_230_30

FWD

Wed 09/15/2021 to Tue 11/30/2021 **UPDATED** **by NGRID** **08/31/2021**
 0700 Continuous 1730

Work scheduled by: NGrid

CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

EDIC___-N.SCTLND_345_14

FWD

Thu 09/16/2021 to Sun 11/14/2021 **UPDATED** **by NGRID** **08/31/2021**
 0600 Continuous 1830

Work scheduled by: NGrid

CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

EDIC___-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_30

FWD

Thu 09/16/2021 to Sun 11/14/2021
 0600 1830

Work scheduled by:

CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

HOMRC_NY-MAINS_NY_345_47

Sat 09/18/2021 to Fri 11/05/2021 **UPDATED** **by PJM** **10/08/2021**
 0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_600					REV	
Sun 09/26/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
SCH-NYISO-NE_LIMIT_1200					REV	
Sat 10/02/2021	to	Sat 10/16/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)
2301	Daily	0700				1400 MW
Work scheduled by: ISONE					SCH - NE - NY	1400 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_300					FWD	
Sat 10/02/2021	to	Sun 10/24/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
2301	Daily	0700				500 MW
Work scheduled by: ISONE					SCH - NE - NY	500 MW
					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1400 MW
CHAT_DC_GC1					FWD	
Sun 10/03/2021	to	Tue 11/23/2021				(Import)
0500	Continuous	2000				2850 MW
Work scheduled by: HQ					MOSES SOUTH	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV	
Sun 10/03/2021	to	Tue 11/23/2021				(Export)
0500	Continuous	2000				500 MW
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Sun 10/03/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Import)
0701	Daily	2300				800 MW
Work scheduled by: ISONE					SCH - NE - NY	800 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
CLAY -EDIC 345_2-15					FWD	
Mon 10/04/2021	to	Sat 10/30/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/16/2021</u>	(Import)
0700	Continuous	1730				4850 MW
Work scheduled by: NYPA					OSWEGO EXPORT	4850 MW
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1200						FWD	
Thu 10/07/2021	to	Tue 11/23/2021				(Import)	
0001	Continuous	2000			SCH - HQ - NY	1200 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1500 MW
SCH-IMO-NYISO_LIMIT_600						FWD	
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/18/2021</u>	(Import)	
0500	Continuous	1600			SCH - OH - NY	900 MW	
Work scheduled by: IESO						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	1950 MW
SCH-NYISO-IMO_LIMIT_500							REV
Mon 10/11/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by IESO</u>	<u>10/18/2021</u>		(Export)
0500	Continuous	1600			SCH - OH - NY	800 MW	
Work scheduled by: IESO						Impacts Total Transfer Capability	900 MW
						TTC with All Lines In Service	1700 MW
LEEDS__-HURLYAVE_345_301						FWD	
Mon 10/11/2021	to	Fri 10/29/2021	<u>UPDATED</u>	<u>by CH</u>	<u>10/09/2021</u>	(Import)	
0700	Continuous	1600			UPNY CONED	4100 MW	
Work scheduled by: CHGE						Impacts Total Transfer Capability	3715 MW
						TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W79						FWD	
Tue 10/12/2021	to	Wed 10/13/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	2200			UPNY CONED	4350 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3465 MW
						TTC with All Lines In Service	7815 MW
CEDARS__-ROSEMNTB_115_2/22						FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import)	(Export)
0500	Continuous	2359			SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW
DENNISON-ROSEMNTB_115_2/22						FWD	REV
Tue 10/12/2021	to	Fri 10/15/2021	<u>EXTENDED</u>	<u>by HQ</u>	<u>10/06/2021</u>	(Import)	(Export)
0500	Continuous	2359			SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_100

Tue 10/12/2021 to Wed 10/20/2021
 2300 Daily 0659
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **300 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 1400 MW

W49TH_ST_345KV_5

Wed 10/13/2021 to Fri 10/15/2021 **CANCELLED by ConEd 10/13/2021**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Wed 10/13/2021 to Fri 10/15/2021 **CANCELLED by ConEd 10/13/2021**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 10/13/2021 to Wed 10/13/2021 **UPDATED by CE 10/12/2021**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W85

Thu 10/14/2021 to Thu 10/14/2021
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_72

Thu 10/14/2021 to Sun 10/17/2021 **EXTENDED by CONED 10/15/2021**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 10/14/2021 to Sun 10/17/2021 **EXTENDED by CONED 10/15/2021**
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W78

Thu 10/14/2021 to Sun 10/17/2021
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_5

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK_-DUNWODIE_345_W75

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK__345KV_RNS3

Thu 10/14/2021 to Sun 11/28/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SCH-NYISO-HQ_LIMIT_300

Thu 10/14/2021 to Sun 10/17/2021 **UPDATED by HQ 10/07/2021**
 0600 Daily 1800
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **300 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1000 MW

OSWEGO_-VOLNEY__345_12

Thu 10/14/2021 to Thu 10/14/2021
 1100 Daily(No Weekends) 1400
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ELBRIDGE-LAFAYTTE_345_17-LE					FWD
Fri 10/15/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by</u> <u>NGROD</u> <u>10/15/2021</u>	(Import)
0830	Daily(No Weekends)	1630			OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
OSWEGO_-ELBRIDGE_345_17					FWD
Fri 10/15/2021	to	Fri 10/15/2021	<u>UPDATED</u>	<u>by</u> <u>NGROD</u> <u>10/15/2021</u>	(Import)
0830	Daily(No Weekends)	1630			OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
CLAY_-INDPDNCE_345_26					FWD
Sat 10/16/2021	to	Sat 10/16/2021	<u>CANCELLED</u>	<u>by</u> <u>NGrid</u> <u>10/16/2021</u>	(Import)
0800	Daily	1000			OSWEGO EXPORT 5000 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 5250 MW
CHAT_DC_GC2					FWD
Sun 10/17/2021	to	Sun 10/17/2021	<u>CANCELLED</u>	<u>by</u> <u>HQ</u> <u>10/17/2021</u>	(Import)
0001	Continuous	0200			MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW
CHAT_DC_GC2					REV
Sun 10/17/2021	to	Sun 10/17/2021	<u>CANCELLED</u>	<u>by</u> <u>HQ</u> <u>10/17/2021</u>	(Export)
0001	Continuous	0200			SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_1150					FWD
Sun 10/17/2021	to	Sun 10/17/2021	<u>CANCELLED</u>	<u>by</u> <u>HQ</u> <u>10/17/2021</u>	(Import)
0001	Continuous	0200			SCH - HQ - NY 1150 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 350 MW
					TTC with All Lines In Service 1500 MW
SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4					FWD
Sun 10/17/2021	to	Wed 10/20/2021			(Import)
0001		0200			SPR/DUN-SOUTH 3200 MW
Work scheduled by:					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71						FWD	
Sun 10/17/2021	to	Tue 10/19/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)	
0101	Continuous	0200				3800 MW	
Work scheduled by: ConEd						SPR/DUN-SOUTH	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3						FWD	
Sun 10/17/2021	to	Tue 10/19/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/01/2021</u>	(Import)	
0101	Continuous	0200				3800 MW	
Work scheduled by: ConEd						SPR/DUN-SOUTH	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
SCH-NYISO-NE_LIMIT_1200							REV
Sun 10/17/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)	
2301	Daily	0700				1400 MW	
Work scheduled by: ISONE						SCH - NE - NY	
						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	1600 MW
CEDARS__-ROSEMNTA_115_1/11						FWD	REV
Mon 10/18/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/14/2021</u>	(Import)	(Export)
0500	Continuous	2359				95 MW	40 MW
Work scheduled by: HQ						SCH - HQ_CEDARS	
						Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW
DENNISON-ROSEMNTA_115_1/11						FWD	REV
Mon 10/18/2021	to	Wed 10/20/2021	<u>UPDATED</u>	<u>by HQ</u>	<u>10/14/2021</u>	(Import)	(Export)
0500	Continuous	2359				95 MW	40 MW
Work scheduled by: HQ						SCH - HQ_CEDARS	
						Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW
NIAGARA_-KINTIGH_345_NS1-38						FWD	
Mon 10/18/2021	to	Sat 12/04/2021	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/18/2021</u>	(Import)	
0500	Continuous	1900				1400 MW	
Work scheduled by: NYPA						DYSINGER EAST	
						Impacts Total Transfer Capability	1750 MW
						TTC with All Lines In Service	3150 MW
SCH-NYISO-NE_LIMIT_600							REV
Mon 10/18/2021	to	Mon 10/18/2021	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/14/2021</u>	(Export)	
0701	Daily	2300				800 MW	
Work scheduled by: ISONE						SCH - NE - NY	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600						FWD
Mon 10/18/2021	to	Tue 10/19/2021	UPDATED	by ISONE	10/14/2021	(Import)
2301	Daily	0700				800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 1400 MW
SCH-NYISO-IMO_LIMIT_1000						REV
Tue 10/19/2021	to	Sat 10/23/2021	UPDATED	by IESO	10/14/2021	(Export)
0400	Continuous	1600				1300 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 1700 MW
SCH-NE-NYISO_LIMIT_600						FWD
Tue 10/19/2021	to	Tue 10/19/2021	UPDATED	by ISONE	10/14/2021	(Import)
0701	Daily	2300				800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 1400 MW
HUDSONTP-W49TH_ST_345_Y56						FWD
Wed 10/20/2021	to	Wed 10/20/2021	UPDATED	by PJM	10/15/2021	(Import)
0200	Continuous	0230				0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
SCH-IMO-NYISO_LIMIT_700						FWD
Wed 10/20/2021	to	Thu 10/21/2021	UPDATED	by NYPA	10/15/2021	(Import)
0500	Continuous	1900				1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 1950 MW
HURLYAVE-ROSETON_345_303						FWD
Wed 10/20/2021	to	Fri 10/22/2021		by CH	10/18/2021	(Import)
0700	Continuous	1600				4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 3715 MW
						TTC with All Lines In Service 7815 MW
SCH-NYISO-NE_LIMIT_1000						REV
Wed 10/20/2021	to	Sat 10/23/2021	UPDATED	by ISONE	10/14/2021	(Export)
0701	Daily	2300				1200 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROTTRDAM-EASTOVER_230_38					REV	
Wed 10/20/2021	to	Wed 10/20/2021			(Export)	
0730	Daily(No Weekends)	1059		SCH - NE - NY	1400 MW	
Work scheduled by: NGrid			ARR: 77	Impacts Total Transfer Capability	200 MW	
					TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Thu 10/21/2021	to	Sat 10/23/2021	UPDATED	by ISONE	10/14/2021	
0701	Daily	2300		SCH - NE - NY	800 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	600 MW	
					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_900					FWD	
Thu 10/21/2021	to	Tue 11/02/2021	EXTENDED	by ISONE	10/17/2021	
1700	Continuous	1600		SCH - NE - NY	1100 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	1400 MW
HUDSONTP-W49TH_ST_345_Y56					FWD	
Thu 10/21/2021	to	Thu 10/21/2021	UPDATED	by PJM	10/15/2021	
1730	Continuous	1830		SCH - PJM_HTP	0 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service	660 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Sun 10/24/2021	to	Sun 10/24/2021	UPDATED	by ISONE	10/14/2021	
0701	Daily	1600		SCH - NE - NY	800 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	600 MW	
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_1000					REV	
Sun 10/24/2021	to	Sun 10/24/2021	UPDATED	by ISONE	10/14/2021	
0701	Daily	1600		SCH - NE - NY	1200 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW	
					TTC with All Lines In Service	1600 MW
LADENTWN-BUCHAN_S_345_Y88					FWD	
Sun 10/24/2021	to	Sat 10/30/2021	UPDATED	by CONED	10/18/2021	
0900	Continuous	1559		UPNY CONED	7560 MW	
Work scheduled by: ORU				Impacts Total Transfer Capability	255 MW	
					TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC					
Mon 10/25/2021	to	Sun 11/21/2021			
0700	Continuous	1600	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW
BECK-PACKARD_230_BP76					
Mon 10/25/2021	to	Fri 10/29/2021			
0800	Continuous	1600	SCH - OH - NY	1500 MW	1150 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	450 MW 550 MW
				TTC with All Lines In Service	1950 MW 1700 MW
CEDARS-ROSEMNTB_115_2/22					
Tue 10/26/2021	to	Thu 10/28/2021			
0300	Continuous	0200	SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	95 MW 60 MW
				TTC with All Lines In Service	190 MW 100 MW
DENNISON-ROSEMNTB_115_2/22					
Tue 10/26/2021	to	Thu 10/28/2021			
0300	Continuous	0200	SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	95 MW 60 MW
				TTC with All Lines In Service	190 MW 100 MW
SCH-HQ_CEDARS-NYISO_LIMIT_140					
Tue 10/26/2021	to	Thu 10/28/2021			
0300	Continuous	0200	SCH - HQ_CEDARS	140 MW	
Work scheduled by: HQ				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	190 MW
LEEDS_345KV_R94301					
Fri 10/29/2021	to	Fri 10/29/2021	UPDATED by CH 10/09/2021		
1500	Continuous	1600	UPNY CONED	3800 MW	
Work scheduled by: CHGE				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
W49TH_ST_345KV_7					
Sat 10/30/2021	to	Sat 10/30/2021			
0001	Continuous	0030	SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Sat 10/30/2021 to Sun 12/05/2021
0001 Continuous 0300

UPDATED by CONED 06/20/2021

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

LEEDS__-ATHENS__345_95

Sat 10/30/2021 to Sat 10/30/2021
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

LEEDS__345KV_R395

Sat 10/30/2021 to Sat 10/30/2021
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W97

Mon 11/01/2021 to Fri 12/10/2021
0001 Continuous 0200

UPDATED by CE 10/12/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Fri 12/31/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **2050 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1600

Mon 11/01/2021 to Fri 12/31/2021
0001 Continuous 2359

UPDATED by IESO 05/03/2019

Work scheduled by: IESO

REV
(Export)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

BUCHAN_S-MILLWOOD_345_W98

Mon 11/01/2021 to Tue 11/09/2021
0201 Continuous 0200

UPDATED by CE 10/12/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

Mon 11/01/2021 to Tue 11/09/2021
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 10/12/2021

UPNY CONED **7560 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

W49TH_ST_345KV_7

Tue 11/02/2021 to Tue 11/02/2021
0200 Continuous 0230

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

FWD
(Import)

LINDN_CG-LNDVFT__345_V-3022

Tue 11/02/2021 to Fri 11/05/2021
0800 Continuous 1500

Work scheduled by: PJM

SCH - PJM_VFT **0 MW** **0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

FWD REV
(Import) (Export)

MILLWOOD_345KV_18

Wed 11/03/2021 to Fri 11/12/2021
0001 Continuous 1800

Work scheduled by: ConEd

UPDATED by CE 10/12/2021

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

OSWEGO__VOLNEY__345_11

Wed 11/03/2021 to Wed 11/03/2021
1100 Daily(No Weekends) 1300

Work scheduled by: NGrid

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

HOMRC_NY-MAINS_NY_345_47

Fri 11/05/2021 to Mon 11/08/2021
1601 Continuous 0800

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SHORE_RD_345_138_BK_1

Mon 11/08/2021 to Wed 11/10/2021
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W98					FWD		
Wed 11/10/2021	to	Tue 11/16/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	0200				7680 MW	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	135 MW	
					TTC with All Lines In Service	7815 MW	
LADENTWN-BUCHAN_S_345_Y88					FWD		
Wed 11/10/2021	to	Tue 11/16/2021	<u>UPDATED</u>	<u>by CE</u>	<u>10/12/2021</u>	(Import)	
0201	Continuous	0200				7560 MW	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	255 MW	
					TTC with All Lines In Service	7815 MW	
SHORE_RD_345_138_BK 2					FWD		
Thu 11/11/2021	to	Fri 11/12/2021				(Import)	
0001	Continuous	2359				1350 MW	
Work scheduled by: LI					CONED - LIPA		
					Impacts Total Transfer Capability	150 MW	
					TTC with All Lines In Service	1500 MW	
GOETHALS_345KV_5							
Fri 11/12/2021	to	Tue 11/16/2021	<u>UPDATED</u>	<u>by CONED</u>	<u>06/30/2021</u>		
0001	Continuous	0300					
Work scheduled by: ConEd					STATEN ISLAND		
					Impacts Total Transfer Capability		
					TTC with All Lines In Service		
BERKSHIR-ALPS_____345_393					FWD	REV	
Sun 11/14/2021	to	Wed 11/24/2021				(Import)	(Export)
0700	Continuous	1600				1100 MW	1700 MW
Work scheduled by: ISONE							
					SCH - NE - NY		
					Impacts Total Transfer Capability	300 MW	0 MW
					TTC with All Lines In Service	1400 MW	1700 MW
					ARR: 78		
BERKSHIR-ALPS_____345_393					FWD	REV	
Sun 11/14/2021	to	Wed 11/24/2021				(Import)	(Export)
0700	Continuous	1600				100 MW	100 MW
Work scheduled by: ISONE							
					SCH - NPX_1385		
					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
					ARR: 78		
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV	
Sun 11/14/2021	to	Wed 11/24/2021				(Import)	(Export)
0700		1600				1100 MW	1700 MW
Work scheduled by:					SCH - NE - NY		
					Impacts Total Transfer Capability	300 MW	0 MW
					TTC with All Lines In Service	1400 MW	1700 MW
					ARR: 78		

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312

Sun 11/14/2021 to Wed 11/24/2021
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **1300 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 1400 MW

BERKSHIR-NORTHFLD_345_312

Sun 11/14/2021 to Wed 11/24/2021
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

SCH-NE-NYISO_LIMIT_800

Sun 11/14/2021 to Wed 11/24/2021
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **1000 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_700

Sun 11/14/2021 to Wed 11/24/2021
 0700 Continuous 1600
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1700 MW

PORTER__-ROTTRDAM_230_30 & MASSENA_-MARCY___765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

CHATGUAY-MASSENA_765_7040

Mon 11/15/2021 to Tue 11/30/2021 **UPDATED by NYISO 06/03/2021**
 0100 Continuous 1859
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Mon 11/15/2021 to Tue 11/30/2021 **UPDATED by NYISO 06/03/2021**
 0100 Continuous 1859
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u> <u>06/03/2021</u>	(Import)	
0100	Continuous	1859			MOSES SOUTH	1750 MW
Work scheduled by: NYPA					ARR: 19	
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u> <u>06/03/2021</u>	(Import)	
0100	Continuous	1859			MOSES SOUTH	1700 MW
Work scheduled by: NYPA					ARR: 19	
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u> <u>06/03/2021</u>	(Import)	
0100	Continuous	1859			CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA						
					Impacts Total Transfer Capability	1305 MW
					TTC with All Lines In Service	2975 MW
MASSENA_-MARCY___765_MSU1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u> <u>06/03/2021</u>	(Import)	
0100	Continuous	1859			MOSES SOUTH	500 MW
Work scheduled by: NYPA						
					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1					FWD	REV
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u> <u>06/03/2021</u>	(Import)	(Export)
0100	Continuous	1859			SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA						
					Impacts Total Transfer Capability	1025 MW 0 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1					FWD	
Mon 11/15/2021	to	Tue 11/30/2021	<u>UPDATED</u>	<u>by NYISO</u> <u>06/03/2021</u>	(Import)	
0100	Continuous	1859			SCH - HQ_CEDARS	90 MW
Work scheduled by: NYPA						
					Impacts Total Transfer Capability	109 MW
					TTC with All Lines In Service	199 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040					FWD	
Mon 11/15/2021	to	Tue 11/30/2021			(Import)	
0100		1859			MOSES SOUTH	500 MW
Work scheduled by:						
					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230_L33P & MASSENA -MARCY 765_MSU1

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

STLAWRNC-MOSES 230_L33P & MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Mon 11/15/2021 to Tue 11/30/2021
 0100 1859

Work scheduled by:

	FWD	
	(Import)	
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	109 MW	
TTC with All Lines In Service	199 MW	

DOLSONAV-ROCKTVRN_345_DART44

Mon 11/15/2021 to Fri 11/19/2021
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD	
	(Import)	
CENTRAL EAST - VC	2720 MW	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	2975 MW	

MILLWOOD-EASTVIEW_345_W85

Wed 11/17/2021 to Wed 11/17/2021 **EXTENDED by CE 10/12/2021**
 0001 Continuous 0030

Work scheduled by: ConEd

	FWD	
	(Import)	
UPNY CONED	7550 MW	
Impacts Total Transfer Capability	265 MW	
TTC with All Lines In Service	7815 MW	

DUNWODIE-MOTTHAVN_345_72

Wed 11/17/2021 to Mon 11/22/2021 **EXTENDED by CONED 10/12/2021**
 0001 Continuous 0200

Work scheduled by: ConEd

	FWD	
	(Import)	
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8

Wed 11/17/2021 to Mon 11/22/2021
0001 Continuous 0200

EXTENDED by CONED 10/12/2021

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK_345_W78

Wed 11/17/2021 to Mon 11/22/2021
0001 Continuous 0200

EXTENDED by CE 10/12/2021

Work scheduled by: ConEd

FWD (Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_7

Sat 11/20/2021 to Sat 11/20/2021
0001 Continuous 0030

UPDATED by CONED 06/20/2021

Work scheduled by: ConEd

FWD (Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4

Mon 11/22/2021 to Sun 11/28/2021
0001 0200

Work scheduled by:

FWD (Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W85

Mon 11/22/2021 to Mon 11/22/2021
0130 Continuous 0200

EXTENDED by CE 10/12/2021

Work scheduled by: ConEd

FWD (Import)
UPNY CONED **7550 MW**
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

DUNWODIE-MOTTHAVN_345_71

Mon 11/22/2021 to Sun 11/28/2021
0201 Continuous 0100

UPDATED by CE 10/01/2021

Work scheduled by: ConEd

FWD (Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Mon 11/22/2021 to Sun 11/28/2021
0201 Continuous 0100

UPDATED by CE 10/01/2021

Work scheduled by: ConEd

FWD (Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Thu 11/25/2021 to Fri 12/03/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SPRNBRK_345KV_RNS4

Sun 11/28/2021 to Sun 11/28/2021
 0300 Continuous 0330
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M52

Sun 11/28/2021 to Wed 12/01/2021
 0300 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 06/20/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 11/29/2021 to Fri 12/17/2021
 0600 Continuous 1600
 Work scheduled by: PJM

UPDATED by PJM 09/15/2021

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 11/29/2021 to Fri 12/17/2021
 0600 Continuous 1600
 Work scheduled by: PJM

UPDATED by PJM 09/15/2021

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 11/29/2021 to Fri 12/17/2021
 0600 Continuous 1600
 Work scheduled by: PJM

UPDATED by PJM 09/15/2021

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

BERKSHIR-ALPS_345_393

Mon 11/29/2021 to Sat 12/18/2021
 0700 Continuous 1600
 Work scheduled by: ISONE

ARR: 78

FWD REV
 (Import) (Export)
 SCH - NE - NY **1100 MW 1700 MW**
 Impacts Total Transfer Capability 300 MW 0 MW
 TTC with All Lines In Service 1400 MW 1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393		FWD	REV
		(Import)	(Export)
Mon 11/29/2021	to Sat 12/18/2021		
0700	Continuous 1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE	ARR: 78	Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312		FWD	REV
		(Import)	(Export)
Mon 11/29/2021	to Sat 12/18/2021		
0700	1600	SCH - NE - NY	1100 MW 1700 MW
Work scheduled by:	ARR: 78	Impacts Total Transfer Capability	300 MW 0 MW
		TTC with All Lines In Service	1400 MW 1700 MW
BERKSHIR-NORTHFLD_345_312		FWD	
		(Import)	
Mon 11/29/2021	to Sat 12/18/2021		
0700	Continuous 1600	SCH - NE - NY	1300 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312		FWD	REV
		(Import)	(Export)
Mon 11/29/2021	to Sat 12/18/2021		
0700	Continuous 1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_800		FWD	
		(Import)	
Mon 11/29/2021	to Sat 12/18/2021		
0700	Continuous 1600	SCH - NE - NY	1000 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700			REV
			(Export)
Mon 11/29/2021	to Sat 12/18/2021		
0700	Continuous 1600	SCH - NE - NY	900 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	1700 MW
HURLYAVE-ROSETON__345_303		FWD	
		(Import)	
Mon 11/29/2021	to Fri 12/17/2021		
0800	Continuous 1600	UPDATED by CH 10/07/2021	
Work scheduled by: CHGE		UPNY CONED	4100 MW
		Impacts Total Transfer Capability	3715 MW
		TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_-PACKARD__230_61					
Tue 11/30/2021	to	Mon 12/06/2021			
0615	Continuous	1900	SCH - OH - NY	1200 MW	1850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1100 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
SPRNBRK__345KV_RNS4					
Wed 12/01/2021	to	Wed 12/01/2021	<u>UPDATED</u> <u>by CONED</u> <u>06/20/2021</u>	FWD	
0130	Continuous	0200		(Import)	
Work scheduled by: ConEd				SPR/DUN-SOUTH	3200 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
MOSES__-ADIRNDCK_230_MAL					
Wed 12/01/2021	to	Tue 05/31/2022		FWD	
0700	Continuous	1300		(Import)	
Work scheduled by: NYPA				MOSES SOUTH	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
SPRNBRK__345KV_RNS4					
Fri 12/03/2021	to	Sat 12/04/2021		FWD	
0001	Continuous	1800		(Import)	
Work scheduled by: ConEd				SPR/DUN-SOUTH	3200 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
SPRNBRK_-W49TH_ST_345_M52					
Fri 12/03/2021	to	Sat 12/18/2021		FWD	
0201	Continuous	0200		(Import)	
Work scheduled by: ConEd				SPR/DUN-SOUTH	3200 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
MARCY__-EDIC__345_UE1-7					
Fri 12/03/2021	to	Fri 12/03/2021		FWD	
0700	Daily(No Weekends)	1000		(Import)	
Work scheduled by: NGrid				OSWEGO EXPORT	5250 MW
				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
MILLWOOD_345KV_18					
Mon 12/06/2021	to	Fri 12/10/2021	<u>UPDATED</u> <u>by CE</u> <u>10/12/2021</u>	FWD	
0001	Continuous	0200		(Import)	
Work scheduled by: ConEd				UPNY CONED	4350 MW
				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Mon 12/06/2021 to Sat 12/18/2021
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

MARCY_345KV_CSC

Mon 12/06/2021 to Fri 12/17/2021
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

BUCHAN_S-MILLWOOD_345_W98

Tue 12/07/2021 to Fri 12/10/2021 **UPDATED by CE 10/12/2021**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

LADENTWN-BUCHAN_S_345_Y88

Tue 12/07/2021 to Fri 12/10/2021 **UPDATED by CE 10/12/2021**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7560 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS4

Mon 12/13/2021 to Tue 12/14/2021
 0001 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

HURLYAVE-ROSETON_345_303

Mon 12/13/2021 to Wed 12/22/2021 **CANCELLED by CHGE 10/14/2021**
 0700 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS4

Sat 12/18/2021 to Sat 12/18/2021
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__345_FRASER SVC					FWD	
Tue 01/04/2022	to	Mon 02/28/2022	UPDATED	by NYPA	05/25/2021	(Import)
0700	Continuous	1730				CENTRAL EAST - VC 2935 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 40 MW
						TTC with All Lines In Service 2975 MW
NIAGARA -PACKARD__230_61					FWD	REV
Mon 01/17/2022	to	Fri 01/21/2022				(Import) (Export)
0615	Continuous	1900				SCH - OH - NY 1200 MW 1850 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 1100 MW 150 MW
						TTC with All Lines In Service 2300 MW 2000 MW
S.RIPLEY-DUNKIRK__230_68						
Tue 01/18/2022	to	Fri 02/04/2022	UPDATED	by NGRID	09/24/2021	
0700	Continuous	1730				SCH - PJ - NY
Work scheduled by: NGrid						Impacts Total Transfer Capability
						TTC with All Lines In Service
NIAGARA -STA_255__345_NH2					FWD	
Fri 01/21/2022	to	Fri 03/04/2022	UPDATED	by NYPA	08/20/2021	(Import)
0500	Continuous	1900				DYSINGER EAST 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
ATHENS__-PLSNTVLY_345_91					FWD	
Sat 02/12/2022	to	Wed 02/16/2022	UPDATED	by NGRID	05/07/2021	(Import)
0600	Continuous	1900				UPNY CONED 3800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD	
Thu 02/17/2022	to	Sat 02/19/2022				(Import)
0001		2200				UPNY CONED 3800 MW
Work scheduled by:						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW
LEEDS__-PLSNTVLY_345_92					FWD	
Thu 02/17/2022	to	Fri 03/25/2022				(Import)
0001	Continuous	2200				UPNY CONED 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Thu 02/17/2022 to Fri 03/25/2022

(Import)

0001 Continuous 2200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

PLSNTVLY-WOOD_ST_345_F30

FWD

Sun 02/20/2022 to Mon 02/21/2022

(Import)

0001 Continuous 2200

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK_345_W64

FWD

Tue 02/22/2022 to Tue 02/22/2022

(Import)

0001 Continuous 0030

UPDATED by CONED 08/31/2021

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

SPRNBK_345KV_RNS5

FWD

Tue 02/22/2022 to Tue 02/22/2022

(Import)

0001 Continuous 0030

UPDATED by CONED 08/31/2021

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW_345_W99

FWD

Tue 02/22/2022 to Mon 03/21/2022

(Import)

0001 Continuous 0200

UPDATED by CONED 08/31/2021

UPNY CONED

7550 MW

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

MARCY-EDIC_345_UE1-7

FWD

Wed 02/23/2022 to Mon 02/28/2022

(Import)

0700 Continuous 1530

ARR: 19&16

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

PORTER-ROTTDAM_230_31

FWD

Tue 03/01/2022 to Tue 12/31/2030

(Import)

0600 Continuous 2359

CENTRAL EAST - VC

2805 MW

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-LEEDS ___ 345_93			FWD	
Tue 03/01/2022	to	Tue 03/15/2022	(Import)	
0700	Continuous	1900	CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW
EDIC ___ -N. SCTLND_345_14			FWD	
Tue 03/01/2022	to	Tue 04/12/2022	(Import)	
0700	Continuous	1900	CENTRAL EAST - VC	1670 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	1305 MW
			TTC with All Lines In Service	2975 MW
EDIC ___ -N. SCTLND_345_14 & PORTER ___ -ROTTRDAM_230_31			FWD	
Tue 03/01/2022	to	Tue 04/12/2022	(Import)	
0700		1900	CENTRAL EAST - VC	1500 MW
Work scheduled by:			Impacts Total Transfer Capability	1475 MW
			TTC with All Lines In Service	2975 MW
FRASANX-COOPERS ___ 345_UCC2-41			FWD	
Tue 03/01/2022	to	Wed 04/20/2022	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
				ARR: 19
MARCY ___ -FRASANX_345_UCC2-41			FWD	
Tue 03/01/2022	to	Wed 04/20/2022	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
				ARR: 19
N. SCTLND-ALPS ___ 345_2			FWD	
Tue 03/01/2022	to	Tue 05/24/2022	(Import)	
0700	Continuous	1900	SCH - NE - NY	900 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1400 MW
N. SCTLND-ALPS ___ 345_2			FWD	REV
Tue 03/01/2022	to	Tue 05/24/2022	(Import)	(Export)
0700	Continuous	1900	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED** by CONED 03/26/2021
 0001 Continuous 0200 STATEN ISLAND
 Impacts Total Transfer Capability
 Work scheduled by: ConEd TTC with All Lines In Service

LINDEN_-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED** by CONED 03/26/2021
 0001 Continuous 0200 SCH - PJ - NY
 Impacts Total Transfer Capability
 Work scheduled by: ConEd TTC with All Lines In Service

INDPDNCE-SCRIBA__345_25

Thu 03/10/2022 to Wed 03/16/2022
 0800 Continuous 1800 FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 Work scheduled by: NGrid TTC with All Lines In Service 5250 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 03/17/2022 to Sun 03/20/2022 FWD
 (Import)
 0100 2200 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 Work scheduled by: TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST__345_F30

Mon 03/21/2022 to Wed 03/23/2022 FWD
 (Import)
 0001 Continuous 2200 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 Work scheduled by: ConEd TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK__345_W64

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED** by CONED 08/31/2021 FWD
 (Import)
 0130 Continuous 0200 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 Work scheduled by: ConEd TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED** by CONED 08/31/2021 FWD
 (Import)
 0130 Continuous 0200 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 Work scheduled by: ConEd TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 03/26/2022 to Mon 03/28/2022
0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

ATHENS_-PLSNTVLY_345_91

Sat 03/26/2022 to Sun 05/01/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Sat 03/26/2022 to Sun 05/01/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F31

Tue 03/29/2022 to Wed 03/30/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

LINDN_CG-LNDVFT_345_V-3022

Sun 04/03/2022 to Sat 04/09/2022
1400 Continuous 1400

Work scheduled by: PJM

FWD

(Import) (Export)

SCH - PJM_VFT **0 MW 0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

SPRNBK_-TREMONT_345_X28

Tue 04/05/2022 to Wed 04/06/2022
0201 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 04/06/2022 to Wed 04/06/2022 **UPDATED by CONED 08/19/2021**
0301 Continuous 0330

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79					FWD	
Wed 04/06/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0301	Continuous	0300				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	TTC with All Lines In Service 7815 MW
BUCHAN_N-EASTVIEW_345_W93					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0230	Continuous	0300				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK__345_W64					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RNS5					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	0330				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 04/07/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>	(Import)
0301	Continuous	2200				UPNY CONED 7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW	TTC with All Lines In Service 7815 MW
PANNELL_-CLAY____345_1					FWD	
Mon 04/11/2022	to	Fri 04/15/2022				(Import)
0700	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW	TTC with All Lines In Service 2250 MW
PORTER_-ROTTDAM_230_30					FWD	
Wed 04/13/2022	to	Tue 12/31/2030				(Import)
0600	Continuous	2359				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 170 MW	TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_ 345_2				FWD
Mon 04/18/2022	to	Fri 04/22/2022		(Import)
0700	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 2250 MW
EDIC_-FRASER_ 345_EF24-40				FWD
Thu 04/21/2022	to	Tue 06/14/2022		(Import)
0700	Continuous	1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Sat 04/23/2022	to	Tue 04/26/2022		(Import)
0001		2200	UPNY CONED	3800 MW
Work scheduled by:				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBRK_ 345_W64				FWD
Tue 04/26/2022	to	Tue 04/26/2022	UPDATED by CONED 08/31/2021	(Import)
2130	Continuous	2200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBRK_ 345KV_RNS5				FWD
Tue 04/26/2022	to	Tue 04/26/2022	UPDATED by CONED 08/31/2021	(Import)
2130	Continuous	2200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLY-WOOD_ST_ 345_F31				FWD
Wed 04/27/2022	to	Fri 04/29/2022		(Import)
0001	Continuous	2200	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW
NIAGARA_ 345_230_AT4				REV
Fri 04/29/2022	to	Fri 04/29/2022		(Export)
0500	Continuous	1700	SCH - OH - NY	1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93				FWD	
Mon 05/02/2022	to	Mon 05/02/2022		(Import)	
0001	Continuous	0030	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
EASTVIEW-SPRNBK__345_W79				FWD	
Mon 05/02/2022	to	Thu 05/05/2022		(Import)	
0001	Continuous	0200	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
ROCHESTR-PANNELL__345_RP2				FWD	
Mon 05/02/2022	to	Fri 05/06/2022		(Import)	
0500	Continuous	1700	DYSINGER EAST	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
BUCHAN_N-EASTVIEW_345_W93				FWD	
Thu 05/05/2022	to	Thu 05/05/2022		(Import)	
0130	Continuous	0200	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
SPRNBK_-TREMONT__345_X28				FWD	
Fri 05/06/2022	to	Mon 05/09/2022	UPDATED by CONED 08/19/2021	(Import)	
0201	Continuous	1800	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
FRASER__345_FRASER SVC				FWD	
Mon 05/09/2022	to	Fri 05/13/2022		(Import)	
0800	Continuous	1700	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022		(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED** **by PJM** **11/19/2020**
 0800 Continuous 1600
 Work scheduled by: PJM
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED** **by PJM** **11/19/2020**
 0800 Continuous 1600
 Work scheduled by: PJM
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NIAGARA_-PACKARD_230_62

Sat 06/18/2022 to Sat 06/18/2022
 0500 Continuous 1700
 Work scheduled by: NYPA
 SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	700 MW	1550 MW
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

NIAGARA_345_230_AT4

Tue 06/28/2022 to Wed 06/29/2022
 0500 Continuous 1700
 Work scheduled by: NYPA
 SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

BECK_-NIAGARA_230_PA27

Tue 07/05/2022 to Sat 07/09/2022
 0500 Continuous 2100
 Work scheduled by: NYPA
 SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROCHESTR-PANNELL_345_RP1

Mon 07/25/2022 to Fri 07/29/2022
 0500 Continuous 2100
 Work scheduled by: NYPA
 DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD
	(Import)
DYSINGER EAST	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
 0700 Continuous 1530
 Work scheduled by: NYPA
 SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1

Mon 09/12/2022 to Fri 09/16/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FRASER_-GILBOA_____345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

SPRNBRK__345KV_RNS5

Mon 09/19/2022 to Mon 09/19/2022 **UPDATED by CONED 09/17/2020**
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51

Mon 09/19/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**
0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_____345_2

Mon 09/19/2022 to Fri 09/23/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

SPRNBRK__345KV_RNS5

Wed 09/21/2022 to Wed 09/21/2022 **UPDATED by CONED 09/17/2020**
2130 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51

Sat 10/01/2022 to Mon 10/17/2022 **UPDATED by CONED 08/01/2020**
0001 Continuous 0300

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5

Sat 10/01/2022 to Mon 10/17/2022
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 08/01/2020

SPR/DUN-SOUTH

FWD

(Import)

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/03/2022 to Fri 10/21/2022
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX_CSC

FWD

(Import)

0 MW

REV

(Export)

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD

(Import)

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD

(Import)

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD

(Import)

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/10/2022 to Fri 10/14/2022
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD

(Import)

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD

(Import)

2520 MW

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 18, 2021 to Wednesday, April 19, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R94301

FWD

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

MARCY___-N.SCTLND_345_18

FWD

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

(Import)

Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC **1470 MW**
Impacts Total Transfer Capability 1505 MW
TTC with All Lines In Service 2975 MW

N.SCTLND-LEEDS___345_94

FWD

Mon 10/31/2022 to Mon 11/28/2022
0500 Continuous 1900

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

PORTER___-ROTTRDAM_230_30 & MARCY___-N.SCTLND_345_18

FWD

Mon 10/31/2022 to Mon 11/28/2022
0500 1900

(Import)

Work scheduled by:

CENTRAL EAST - VC **1300 MW**
Impacts Total Transfer Capability 1675 MW
TTC with All Lines In Service 2975 MW

PORTER___-ROTTRDAM_230_31 & MARCY___-N.SCTLND_345_18

FWD

Mon 10/31/2022 to Mon 11/28/2022
0500 1900

(Import)

Work scheduled by:

CENTRAL EAST - VC **1300 MW**
Impacts Total Transfer Capability 1675 MW
TTC with All Lines In Service 2975 MW