

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Sun 07/31/2022  
 0001 2359  
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022  
 0001 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**STLAWRNC-MOSES\_230\_L33P**

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021  
 0456 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NEWBRDGE\_345\_138\_BK\_1**

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021  
 1807 Continuous 2359  
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

Mon 10/18/2021 to Sat 12/31/2022 UPDATED by NYPA 01/08/2022  
 0500 Continuous 2359  
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**SCH-IMO-NYISO\_LIMIT\_1750**

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019  
 0001 Continuous 2359  
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	<b>2050 MW</b>
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	2300 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							
<b>SCH-NYISO-IMO_LIMIT_1600</b>							REV
Mon 11/01/2021	to	Sat 04/30/2022	<b>UPDATED</b>	<b>by IESO</b>	<b>05/03/2019</b>		(Export)
0001	Continuous	2359				SCH - OH - NY	<b>1900 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	2000 MW
<hr/>							
<b>KINTIGH_STA_255_345_SH1-39</b>							FWD
Wed 12/08/2021	to	Sat 12/31/2022	<b>UPDATED</b>	<b>by RGE</b>	<b>01/08/2022</b>		(Import)
2000	Continuous	2359				DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
<b>DYSINGER-KINTIGH_345_39 &amp; DYSINGER-STA_255_345_DH1</b>							FWD
Tue 12/14/2021	to	Mon 01/10/2022					(Import)
1129		1600				DYSINGER EAST	<b>2650 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
<b>DYSINGER-STA_255_345_DH1</b>							FWD
Tue 12/14/2021	to	Mon 01/10/2022	<b>FORCED</b>	<b>by NYISO</b>	<b>01/08/2022</b>		(Import)
1129	Continuous	1600				DYSINGER EAST	<b>2550 MW</b>
Work scheduled by: NYISO						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
<b>MOSES-ADIRNDCK_230_MAI</b>							FWD
Mon 01/03/2022	to	Mon 01/10/2022	<b>UPDATED</b>	<b>by NYPA</b>	<b>01/07/2022</b>		(Import)
0700	Continuous	1600				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
<b>SCH-IMO-NYISO_LIMIT_1550</b>							FWD
Mon 01/03/2022	to	Sat 04/30/2022					(Import)
0700	Continuous	2359				SCH - OH - NY	<b>1850 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	2300 MW
<hr/>							
<b>SCH-NYISO-IMO_LIMIT_1400</b>							REV
Mon 01/03/2022	to	Sat 04/30/2022					(Export)
0700	Continuous	2359				SCH - OH - NY	<b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	2000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

Tue 01/04/2022 to Tue 01/04/2022  
 0001 Continuous 0300  
 Work scheduled by: ConEd

**CANCELLED by ConEd 01/04/2022**

FWD  
 (Import)  
**300 MW**  
 SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Tue 01/04/2022 to Tue 01/04/2022  
 0001 Continuous 0300  
 Work scheduled by: ConEd

**CANCELLED by ConEd 01/04/2022**

FWD  
 (Import)  
**300 MW**  
 SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**SAND\_BAR-PLATSBURG\_115\_PV20**

Tue 01/04/2022 to Fri 01/07/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**by NYPA 01/08/2022**

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SCH-NE-NYISO\_LIMIT\_700**

Tue 01/04/2022 to Thu 01/06/2022  
 2300 Continuous 0659  
 Work scheduled by: NGrid

**UPDATED by ISONE 12/31/2021**

FWD  
 (Import)  
**900 MW**  
 SCH - NE - NY  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1300**

Tue 01/04/2022 to Thu 01/06/2022  
 2300 Continuous 0659  
 Work scheduled by: NGrid

**UPDATED by ISONE 12/31/2021**

REV  
 (Export)  
**1500 MW**  
 SCH - NE - NY  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 1800 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

Wed 01/05/2022 to Wed 01/05/2022  
 0800 Continuous 1700  
 Work scheduled by: HQ

FWD  
 (Import)  
**80 MW**  
 SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability 199 MW  
 TTC with All Lines In Service 279 MW

**HOPATCON-RAMAPO\_500\_5018**

Thu 01/06/2022 to Mon 01/10/2022  
 0200 Continuous 1900  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
**1650 MW 1200 MW**  
 SCH - PJ - NY  
 Impacts Total Transfer Capability 1200 MW 1000 MW  
 TTC with All Lines In Service 2850 MW 2200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HOPATCON-RAMAPO__500_5018</b>			FWD	
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	
0200	Continuous	1900	UPNY CONED	<b>7480 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
<b>RAMAPO__345_345_PAR3500</b>			FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	(Export)
0200	Continuous	1900	SCH - PJ - NY	<b>2500 MW 1250 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
<b>RAMAPO__345_345_PAR4500</b>			FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	(Export)
0200	Continuous	1900	SCH - PJ - NY	<b>2500 MW 1250 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
<b>RAMAPO__500_345_BK 1500</b>			FWD	REV
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	(Export)
0200	Continuous	1900	SCH - PJ - NY	<b>1650 MW 1200 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	1200 MW 1000 MW
			TTC with All Lines In Service	2850 MW 2200 MW
<b>RAMAPO__500_345_BK 1500</b>			FWD	
Thu 01/06/2022	to	Mon 01/10/2022	(Import)	
0200	Continuous	1900	UPNY CONED	<b>7480 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
<b>W49TH_ST_345KV_5</b>			FWD	
Fri 01/07/2022	to	Fri 01/07/2022	(Import)	
0001	Continuous	0030	<b>CANCELLED by ConEd 01/06/2022</b>	
Work scheduled by: ConEd			SCH - PJM_HTP	<b>300 MW</b>
			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_7</b>			FWD	
Fri 01/07/2022	to	Fri 01/07/2022	(Import)	
0001	Continuous	0030	<b>CANCELLED by ConEd 01/06/2022</b>	
Work scheduled by: ConEd			SCH - PJM_HTP	<b>300 MW</b>
			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

Fri 01/07/2022 to Fri 01/07/2022  
 2230 Continuous 2300  
 Work scheduled by: ConEd

**CANCELLED** **by ConEd** **01/06/2022**

FWD  
 (Import)  
**300 MW**  
 SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Fri 01/07/2022 to Fri 01/07/2022  
 2230 Continuous 2300  
 Work scheduled by: ConEd

**CANCELLED** **by ConEd** **01/06/2022**

FWD  
 (Import)  
**300 MW**  
 SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**NIAGARA\_-ROBNSNRD\_230\_64**

Mon 01/10/2022 to Mon 01/10/2022  
 0600 Continuous 0700  
 Work scheduled by: NYSEG

**UPDATED** **by NYSEG** **01/07/2022**

REV  
 (Export)  
**1900 MW**  
 SCH - OH - NY  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 2000 MW

**NIAGARA\_-ROBNSNRD\_230\_64**

Wed 01/12/2022 to Wed 01/12/2022  
 0500 Daily 0600  
 Work scheduled by: NYSEG

**UPDATED** **by NYSEG** **01/06/2022**

REV  
 (Export)  
**1900 MW**  
 SCH - OH - NY  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 2000 MW

**HURLYAVE-ROSETON\_\_345\_303**

Wed 01/12/2022 to Sat 01/22/2022  
 0600 Continuous 1600  
 Work scheduled by: CHGE

**UPDATED** **by NYISO** **01/06/2022**

FWD  
 (Import)  
**4100 MW**  
 UPNY CONED  
 Impacts Total Transfer Capability 3715 MW  
 TTC with All Lines In Service 7815 MW

**NIAGARA\_-ROBNSNRD\_230\_64**

Wed 01/12/2022 to Wed 01/12/2022  
 1500 Daily 1600  
 Work scheduled by: NYSEG

**UPDATED** **by NYSEG** **01/06/2022**

REV  
 (Export)  
**1900 MW**  
 SCH - OH - NY  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 2000 MW

**SCH-IMO-NYISO\_LIMIT\_1000**

Thu 01/13/2022 to Tue 01/18/2022  
 0600 Daily 2000  
 Work scheduled by: NYISO

FWD  
 (Import)  
**1300 MW**  
 SCH - OH - NY  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 2300 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_500						REV
Thu 01/13/2022	to	Thu 01/13/2022				(Export)
0700	Continuous	1900				500 MW
Work scheduled by: HQ						500 MW
						TTC with All Lines In Service 1000 MW
CHATGUAY-MASSENA_765_7040						FWD
Thu 01/13/2022	to	Sun 01/16/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/06/2022</u>	(Import)
0700	Continuous	1530				1550 MW
Work scheduled by: NYPA						1600 MW
						TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA_765_7040						FWD
Thu 01/13/2022	to	Sun 01/16/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/06/2022</u>	(Import) (Export)
0700	Continuous	1530				0 MW 0 MW
Work scheduled by: NYPA						1500 MW 1000 MW
						TTC with All Lines In Service 1500 MW 1000 MW
MOSES_-ADIRNDCK_230_MA1						FWD
Thu 01/13/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/07/2022</u>	(Import)
0700	Continuous	1600				2300 MW
Work scheduled by: NYPA						850 MW
						TTC with All Lines In Service 3150 MW
W49TH_ST_345KV_5						FWD
Sun 01/16/2022	to	Sun 01/16/2022	<u>CANCELLED</u>	<u>by ConEd</u>	<u>01/06/2022</u>	(Import)
0001	Continuous	0030				300 MW
Work scheduled by: ConEd						360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7						FWD
Sun 01/16/2022	to	Sun 01/16/2022	<u>CANCELLED</u>	<u>by ConEd</u>	<u>01/06/2022</u>	(Import)
0001	Continuous	0030				300 MW
Work scheduled by: ConEd						360 MW
						TTC with All Lines In Service 660 MW
DYSINGER-KINTIGH_345_38						FWD
Mon 01/17/2022	to	Thu 01/20/2022				(Import)
0500	Continuous	1900				2500 MW
Work scheduled by: NYSEG						650 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NIAGARA\_-DYSINGER\_345\_ND1**

FWD

Mon 01/17/2022 to Thu 01/20/2022  
 0500 Continuous 1900

(Import)

DYSINGER EAST **2650 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

-----  
**S.RIPLEY-DUNKIRK\_230\_68**

Tue 01/18/2022 to Fri 02/04/2022  
 0700 Continuous 1730

**CANCELLED by NGRID 09/24/2021**

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

-----  
**SCH-IMO-NYISO\_LIMIT\_1000**

FWD

Wed 01/19/2022 to Wed 01/19/2022  
 0600 Daily 1900

(Import)

SCH - OH - NY **1300 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: NYISO

-----  
**W49TH\_ST\_345KV\_5**

FWD

Wed 01/19/2022 to Thu 01/20/2022  
 2300 Continuous 0200

**CANCELLED by ConEd 01/04/2022**

(Import)

SCH - PJM\_HTP **300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

-----  
**W49TH\_ST\_345KV\_7**

FWD

Wed 01/19/2022 to Thu 01/20/2022  
 2300 Continuous 0200

**CANCELLED by ConEd 01/04/2022**

(Import)

SCH - PJM\_HTP **300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

-----  
**W49TH\_ST\_345KV\_5**

FWD

Fri 01/21/2022 to Fri 01/21/2022  
 0130 Continuous 0200

**CANCELLED by ConEd 01/06/2022**

(Import)

SCH - PJM\_HTP **300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

-----  
**W49TH\_ST\_345KV\_7**

FWD

Fri 01/21/2022 to Fri 01/21/2022  
 0130 Continuous 0200

**CANCELLED by ConEd 01/06/2022**

(Import)

SCH - PJM\_HTP **300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-STA\_255\_\_345\_NH2**

FWD

Fri 01/21/2022 to Fri 03/04/2022 **UPDATED by NYPA 08/20/2021**  
 0500 Continuous 1900

(Import)

Work scheduled by: NYPA

DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**NIAGARA\_-STA\_255\_\_345\_NH2 & KINTIGH\_-STA\_255\_\_345\_SH1-39**

FWD

Fri 01/21/2022 to Fri 03/04/2022  
 0500 Continuous 1900

(Import)

Work scheduled by:

DYSINGER EAST **1250 MW**  
 Impacts Total Transfer Capability 1900 MW  
 TTC with All Lines In Service 3150 MW

**FIVEMILE-STOLLERD\_345\_29**

Mon 01/24/2022 to Sun 01/30/2022  
 0500 Continuous 1900

Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**OAKDALE\_-FRASER\_\_345\_32**

FWD

Tue 01/25/2022 to Wed 01/26/2022  
 0700 Continuous 1600

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**E13THSTA-FARRAGUT\_345\_45**

FWD

Thu 01/27/2022 to Fri 01/28/2022  
 0001 Continuous 0100

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**PLSNTVLY-WOOD\_ST\_\_345\_F30**

FWD

Sat 01/29/2022 to Sat 01/29/2022  
 0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

FWD

Sat 01/29/2022 to Sat 01/29/2022  
 0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLY-WOOD_ST__345_F30</b>				FWD	
Wed 02/02/2022	to	Wed 02/02/2022		(Import)	
1930	Continuous	2000	UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
<b>PLSNTVLY_345KV_RNS5</b>				FWD	
Wed 02/02/2022	to	Wed 02/02/2022		(Import)	
1930	Continuous	2000	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
<b>NIAGARA_-PACKARD__230_61</b>				FWD	REV
Thu 02/03/2022	to	Sat 02/12/2022	<b>UPDATED</b>	(Import)	(Export)
0615	Continuous	1900	<b>by NGRID</b>	SCH - OH - NY	<b>1400 MW 1850 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	900 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
<b>MARCY_-N.SCTLND_345_18</b>				FWD	
Tue 02/08/2022	to	Wed 02/09/2022		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	<b>1470 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	1505 MW
				TTC with All Lines In Service	2975 MW
<b>PLSNTVLY_345KV_RNS4</b>				FWD	
Sat 02/12/2022	to	Sat 02/12/2022	<b>UPDATED</b>	(Import)	
0600	Continuous	0630	<b>by CONED</b>	UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<b>ATHENS_-PLSNTVLY_345_91</b>				FWD	
Sat 02/12/2022	to	Wed 02/16/2022	<b>UPDATED</b>	(Import)	
0600	Continuous	1900	<b>by CONED</b>	UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>				FWD	
Sun 02/13/2022	to	Mon 02/14/2022		(Import)	
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Sun 02/13/2022 to Mon 02/14/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7580 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 7815 MW

**MILLWOOD\_345KV\_18**

Mon 02/14/2022 to Tue 02/15/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**EDIC\_\_-FRASER\_\_345\_EF24-40**

Mon 02/14/2022 to Tue 02/22/2022 **UPDATED by NYSEG 01/04/2022**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**EASTVIEW-SPRNBK\_\_345\_W78**

Tue 02/15/2022 to Wed 02/16/2022 **UPDATED by CE 01/07/2022**  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Tue 02/15/2022 to Wed 02/16/2022 **UPDATED by CE 01/07/2022**  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS3**

Tue 02/15/2022 to Wed 02/16/2022 **UPDATED by CE 01/07/2022**  
 0201 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**PLSNTVLY\_345KV\_RNS4**

Wed 02/16/2022 to Wed 02/16/2022 **UPDATED by CONED 11/12/2021**  
 1830 Continuous 1900  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 02/17/2022 to Sat 02/19/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

LEEDS\_\_-PLSNTVLY\_345\_92

Thu 02/17/2022 to Fri 03/25/2022 **UPDATED by NYISO 11/15/2021**  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

PLSNTVLY\_345KV\_RNS5

Thu 02/17/2022 to Fri 03/25/2022 **UPDATED by NYISO 11/15/2021**  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD\_ST\_\_345\_F30

Sun 02/20/2022 to Mon 02/21/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK\_\_345\_W64

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW\_345\_W99

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

SPRNBK\_\_345KV\_RNS5

Sun 02/20/2022 to Mon 02/21/2022  
2000 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

Tue 02/22/2022 to Tue 02/22/2022  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

Tue 02/22/2022 to Tue 02/22/2022  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Tue 02/22/2022 to Mon 03/21/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**MARCY\_\_-EDIC\_\_345\_UE1-7**

Wed 02/23/2022 to Mon 02/28/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sun 02/27/2022 to Wed 03/02/2022  
 0201 Continuous 2230  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**FIVEMILE-STOLLERD\_345\_29**

Tue 03/01/2022 to Tue 04/12/2022  
 0500 Continuous 1900  
 Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**PORTER\_\_-ROTTRDAM\_230\_31**

Tue 03/01/2022 to Tue 12/31/2030  
 0600 Continuous 2359  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2805 MW**  
 Impacts Total Transfer Capability 170 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-LEEDS</b> ___ 345_93					FWD	
Tue 03/01/2022	to	Mon 03/28/2022	<b>UPDATED</b>	<b>by NGRID</b>	<b>11/15/2021</b>	(Import)
0700	Continuous	1900				CENTRAL EAST - VC <b>2650 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 325 MW
						TTC with All Lines In Service 2975 MW
<b>EDIC</b> ___-N.SCTLND_345_14					FWD	
Tue 03/01/2022	to	Tue 04/12/2022	<b>UPDATED</b>	<b>by NGRID</b>	<b>11/15/2021</b>	(Import)
0700	Continuous	1900				CENTRAL EAST - VC <b>1670 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 1305 MW
						TTC with All Lines In Service 2975 MW
<b>EDIC</b> ___-N.SCTLND_345_14 & <b>PORTER</b> ___-ROTTDAM_230_31					FWD	
Tue 03/01/2022	to	Tue 04/12/2022				(Import)
0700		1900				CENTRAL EAST - VC <b>1500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 1475 MW
						TTC with All Lines In Service 2975 MW
<b>FRASANX-COOPERS</b> ___ 345_UCC2-41					FWD	
Tue 03/01/2022	to	Wed 04/20/2022				(Import)
0700	Continuous	1530				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA					<b>ARR: 19</b>	Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
<b>MARCY</b> ___-FRASANX_345_UCC2-41					FWD	
Tue 03/01/2022	to	Wed 04/20/2022				(Import)
0700	Continuous	1530				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA					<b>ARR: 19</b>	Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
<b>N. SCTLND-ALPS</b> ___ 345_2					FWD	
Tue 03/01/2022	to	Fri 06/24/2022	<b>UPDATED</b>	<b>by NGRID</b>	<b>11/15/2021</b>	(Import)
0700	Continuous	1900				SCH - NE - NY <b>900 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1400 MW
<b>N. SCTLND-ALPS</b> ___ 345_2					FWD	REV
Tue 03/01/2022	to	Fri 06/24/2022	<b>UPDATED</b>	<b>by NGRID</b>	<b>11/15/2021</b>	(Import) (Export)
0700	Continuous	1900				SCH - NPX_1385 <b>100 MW 100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**GOETHALS\_345KV\_5**

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED** by CONED 03/26/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**LINDEN\_\_-GOETHALS\_230\_A2253**

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED** by CONED 03/26/2021  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402**

Sat 03/05/2022 to Mon 04/04/2022  
 0001 0200

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

Work scheduled by:

**LINDEN\_\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403**

Sat 03/05/2022 to Mon 04/04/2022  
 0001 0200

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

Work scheduled by:

**LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403**

Sat 03/05/2022 to Mon 04/04/2022  
 0001 0200

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

Work scheduled by:

**INDPDNCE-SCRIBA\_\_345\_25**

Thu 03/10/2022 to Wed 03/16/2022  
 0800 Continuous 1800  
 Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**NIAGARA\_-DYSINGER\_345\_ND1**

Fri 03/11/2022 to Fri 03/11/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2650 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Thu 03/17/2022 to Sun 03/20/2022  
0100 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD\_ST\_345\_F30

Mon 03/21/2022 to Wed 03/23/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK\_345\_W64

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

SPRNBK\_345KV\_RNS5

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 08/31/2021**  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 03/26/2022 to Mon 03/28/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

ATHENS\_-PLSNTVLY\_345\_91

Sat 03/26/2022 to Sun 05/01/2022 **UPDATED by CE 01/03/2022**  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

PLSNTVLY\_345KV\_RNS4

Sat 03/26/2022 to Sun 05/01/2022 **UPDATED by CE 01/03/2022**  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLY-WOOD_ST__345_F31</b>			FWD	
Tue 03/29/2022	to	Wed 03/30/2022	(Import)	
0001	Continuous	2200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
<b>DUNWODIE_345KV_6</b>			FWD	
Thu 03/31/2022	to	Sat 04/02/2022	(Import)	
2100	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>			FWD	
Thu 03/31/2022	to	Sat 04/02/2022	(Import)	
2100	Continuous	0300	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>			FWD	
Thu 03/31/2022	to	Tue 04/05/2022	(Import)	
2100	Continuous	2200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>			FWD	
Thu 03/31/2022	to	Tue 04/05/2022	(Import)	
2100	Continuous	2200	UPNY CONED	<b>7260 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	555 MW
			TTC with All Lines In Service	7815 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>			FWD	REV
Sun 04/03/2022	to	Sat 04/09/2022	(Import)	(Export)
1400	Continuous	1400	SCH - PJM_VFT	<b>0 MW 0 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW 315 MW
			TTC with All Lines In Service	315 MW 315 MW
<b>SPRNBK_-TREMONT__345_X28</b>			FWD	
Tue 04/05/2022	to	Wed 04/06/2022	(Import)	
0201	Continuous	0300	SPR/DUN-SOUTH	<b>4200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	4600 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_6</b>					FWD
Tue 04/05/2022	to	Tue 04/05/2022			(Import)
2130	Continuous	2200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>					FWD
Tue 04/05/2022	to	Tue 04/05/2022			(Import)
2130	Continuous	2200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD
Wed 04/06/2022	to	Wed 04/06/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>08/19/2021</b>
0301	Continuous	0330		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD
Wed 04/06/2022	to	Thu 04/07/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>08/19/2021</b>
0301	Continuous	0300		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD
Thu 04/07/2022	to	Thu 04/07/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>08/19/2021</b>
0230	Continuous	0300		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD
Thu 04/07/2022	to	Thu 04/07/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>08/31/2021</b>
0301	Continuous	0330		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
<b>SPRNBK__345KV_RNS5</b>					FWD
Thu 04/07/2022	to	Thu 04/07/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>08/31/2021</b>
0301	Continuous	0330		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W99**

Thu 04/07/2022 to Tue 04/26/2022  
0301 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

UPNY CONED

Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

FWD  
(Import)

**MOTTHAVN-RAINEY\_345\_Q12**

Mon 04/11/2022 to Thu 04/28/2022  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**PANNELL -CLAY\_345\_1**

Mon 04/11/2022 to Fri 04/15/2022  
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD  
(Import)

**GOETHALS\_345KV\_5**

Wed 04/13/2022 to Fri 05/13/2022  
0001 Continuous 0259

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD  
(Import)

**PORTER\_-ROTTRDAM\_230\_30**

Wed 04/13/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

**PANNELL -CLAY\_345\_2**

Mon 04/18/2022 to Fri 04/22/2022  
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD  
(Import)

**SCH-NE-NYISO\_LIMIT\_700**

Tue 04/19/2022 to Fri 04/22/2022  
0601 Continuous 0759

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EDIC -FRASER 345\_EF24-40**

Thu 04/21/2022 to Tue 06/14/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MARCY 345KV\_CSC**

Fri 04/22/2022 to Sat 04/23/2022  
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**SCH-NE-NYISO\_LIMIT\_700**

Fri 04/22/2022 to Sun 04/24/2022  
1601 Continuous 1800

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sat 04/23/2022 to Tue 04/26/2022  
0001 2200

Work scheduled by:

FWD

(Import)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**ROCHESTR-PANNELL\_345\_RP1**

Mon 04/25/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 04/25/2022 to Fri 04/29/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**EASTVIEW-SPRNBK\_345\_W64**

Tue 04/26/2022 to Tue 04/26/2022  
2130 Continuous 2200

Work scheduled by: ConEd

**UPDATED by CONED 08/31/2021**

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
SPRNBK__345KV_RNS5					(Import)
Tue 04/26/2022	to	Tue 04/26/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>08/31/2021</b>
2130	Continuous	2200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
PLSNTVLY-WOOD_ST__345_F31					FWD
					(Import)
Wed 04/27/2022	to	Fri 04/29/2022		UPNY CONED	<b>4000 MW</b>
0001	Continuous	2200		Impacts Total Transfer Capability	3815 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
<hr/>					
NIAGARA__345_230_AT4					REV
					(Export)
Fri 04/29/2022	to	Fri 04/29/2022		SCH - OH - NY	<b>1750 MW</b>
0500	Continuous	1700		Impacts Total Transfer Capability	250 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2000 MW
<hr/>					
BUCHAN_N-EASTVIEW_345_W93					FWD
					(Import)
Mon 05/02/2022	to	Mon 05/02/2022		UPNY CONED	<b>4350 MW</b>
0001	Continuous	0030		Impacts Total Transfer Capability	3465 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
<hr/>					
EASTVIEW-SPRNBK__345_W79					FWD
					(Import)
Mon 05/02/2022	to	Thu 05/05/2022		UPNY CONED	<b>4350 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	3465 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
<hr/>					
ROCHESTR-PANNELL__345_RP2					FWD
					(Import)
Mon 05/02/2022	to	Fri 05/06/2022		DYSINGER EAST	<b>2300 MW</b>
0500	Continuous	1700		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
<hr/>					
BUCHAN_N-EASTVIEW_345_W93					FWD
					(Import)
Thu 05/05/2022	to	Thu 05/05/2022		UPNY CONED	<b>4350 MW</b>
0130	Continuous	0200		Impacts Total Transfer Capability	3465 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-TREMONT__345_X28</b>				FWD	
Fri 05/06/2022	to	Mon 05/09/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/19/2021</u>	(Import)	
0201	Continuous	1800		SPR/DUN-SOUTH	<b>4200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	4600 MW
<b>FRASER__345_FRASER SVC</b>				FWD	
Mon 05/09/2022	to	Fri 05/13/2022		(Import)	
0800	Continuous	1700		CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	2975 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0200	Continuous	0230		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
<b>EFISHKIL-WOOD_ST__345_F38</b>				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0200	Continuous	0430		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0200	Continuous	0430		UPNY CONED	<b>7210 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	605 MW
				TTC with All Lines In Service	7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0400	Continuous	0430		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022		(Import)	(Export)
0600	Continuous	1800		SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-MOTTHAVN\_345\_71**

Thu 05/19/2022 to Fri 05/20/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Thu 05/19/2022 to Fri 05/20/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Thu 05/19/2022 to Fri 05/20/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED by PJM 11/19/2020**  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**HOMR\_NYW-PIERC\_NY\_345\_48**

Fri 05/20/2022 to Fri 05/27/2022 **UPDATED by PJM 11/19/2020**  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**MARCY -EDIC 345\_UE1-7**

Sat 05/21/2022 to Sat 05/21/2022  
 0700 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**PORTER -ROTTDAM\_230\_30 & VOLNEY -MARCY 345\_19**

Sat 05/21/2022 to Sat 05/21/2022  
 0700 1730  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2655 MW**  
 Impacts Total Transfer Capability 320 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_31 & VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2655 MW**  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sat 05/21/2022  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

MOSES\_\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Tue 11/29/2022  
0700 Continuous 1800

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_-DYSINGER\_345\_ND1

Mon 06/13/2022 to Fri 06/17/2022  
0500 Continuous 2100

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2650 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_-PACKARD\_230\_62

Sat 06/18/2022 to Sat 06/18/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **700 MW 1550 MW**  
Impacts Total Transfer Capability 1250 MW 150 MW  
TTC with All Lines In Service 1950 MW 1700 MW

NIAGARA\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1400 MW**  
Impacts Total Transfer Capability 50 MW 300 MW  
TTC with All Lines In Service 1950 MW 1700 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**BECK -NIAGARA 230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

-----  
**NIAGARA -DYSINGER 345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2650 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3150 MW

-----  
**ROCHESTR-PANNELL 345\_RP1**

Mon 07/25/2022 to Fri 07/29/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY -EDIC 345\_UE1-7**

Sat 08/06/2022 to Sat 08/06/2022  
 0500 Continuous 1830  
 Work scheduled by: NYPA

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

-----  
**PORTER -ROTTRDAM 230\_30 & VOLNEY -MARCY 345\_19**

Sat 08/06/2022 to Sat 08/06/2022  
 0500 1830  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2655 MW**  
 Impacts Total Transfer Capability 320 MW  
 TTC with All Lines In Service 2975 MW

-----  
**PORTER -ROTTRDAM 230\_31 & VOLNEY -MARCY 345\_19**

Sat 08/06/2022 to Sat 08/06/2022  
 0500 1830  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2655 MW**  
 Impacts Total Transfer Capability 320 MW  
 TTC with All Lines In Service 2975 MW

-----  
**VOLNEY -MARCY 345\_19**

Sat 08/06/2022 to Sat 08/06/2022  
 0500 Continuous 1830  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2825 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**VOLNEY -MARCY 345\_19**

Sat 08/06/2022 to Sat 08/06/2022  
0500 Continuous 1830

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**ROSETON -ROCKTVRN\_345\_311**

Mon 08/29/2022 to Fri 09/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

**MOTTHAVN-RAINEY 345\_Q12**

Thu 09/01/2022 to Mon 09/05/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**PANNELL -CLAY 345\_1**

Mon 09/12/2022 to Fri 09/16/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**FRASER -GILBOA 345\_GF5-35**

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**PANNELL -CLAY 345\_2**

Mon 09/19/2022 to Fri 09/23/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY -EDIC 345 UE1-7</b>					FWD	
Mon 09/19/2022	to	Sat 10/08/2022			(Import)	
0700	Continuous	1530		OSWEGO EXPORT		<b>5250 MW</b>
Work scheduled by: NYPA			<b>ARR: 19&amp;16</b>	Impacts Total Transfer Capability		0 MW
					TTC with All Lines In Service	5250 MW
<b>NIAGARA -DYSINGER 345 ND1</b>					FWD	
Mon 09/26/2022	to	Fri 09/30/2022			(Import)	
0500	Continuous	1700		DYSINGER EAST		<b>2650 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability		500 MW
					TTC with All Lines In Service	3150 MW
<b>SHOR NPX-SHOREHAM 138 CSC</b>					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022	<b>UPDATED by LI 01/07/2022</b>		(Import)	(Export)
1000	Continuous	1500		SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW	330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>NEPTUNE -DUFFYAVE 345 NEPTUNE</b>					FWD	
Mon 10/10/2022	to	Fri 10/14/2022			(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE		<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability		660 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE 345 501</b>					FWD	
Mon 10/10/2022	to	Fri 10/14/2022			(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE		<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability		660 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE 345 138 BK 1</b>					FWD	
Mon 10/10/2022	to	Fri 10/14/2022			(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE		<b>375 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability		285 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE 345 138 BK 2</b>					FWD	
Mon 10/10/2022	to	Fri 10/14/2022			(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE		<b>375 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability		285 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EDIC -N.SCTLND_345_14</b>				FWD
Mon 10/10/2022	to	Mon 10/31/2022		(Import)
0700	Continuous	1530	CENTRAL EAST - VC	<b>1670 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1305 MW
				TTC with All Lines In Service 2975 MW
<b>EDIC -N.SCTLND_345_14 &amp; PORTER -ROTTRDAM_230_30</b>				FWD
Mon 10/10/2022	to	Mon 10/31/2022		(Import)
0700		1530	CENTRAL EAST - VC	<b>1500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 1475 MW
				TTC with All Lines In Service 2975 MW
<b>EDIC -N.SCTLND_345_14 &amp; PORTER -ROTTRDAM_230_31</b>				FWD
Mon 10/10/2022	to	Mon 10/31/2022		(Import)
0700		1530	CENTRAL EAST - VC	<b>1500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 1475 MW
				TTC with All Lines In Service 2975 MW
<b>GILBOA -N.SCTLND_345_GNS-1</b>				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<b>UPDATED</b>	(Import)
0500	Continuous	1900	<b>by NGRID</b>	<b>12/29/2021</b>
Work scheduled by: NGrid				CENTRAL EAST - VC
				<b>2520 MW</b>
				Impacts Total Transfer Capability 455 MW
				TTC with All Lines In Service 2975 MW
<b>LEEDS 345KV_R94301</b>				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<b>UPDATED</b>	(Import)
0500	Continuous	1900	<b>by NGRID</b>	<b>12/29/2021</b>
Work scheduled by: NGrid				UPNY CONED
				<b>3800 MW</b>
				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
<b>MARCY -N.SCTLND_345_18</b>				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<b>UPDATED</b>	(Import)
0500	Continuous	1900	<b>by NGRID</b>	<b>12/29/2021</b>
Work scheduled by: NGrid				CENTRAL EAST - VC
				<b>1470 MW</b>
				Impacts Total Transfer Capability 1505 MW
				TTC with All Lines In Service 2975 MW
<b>N.SCTLND-LEEDS 345_94</b>				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<b>UPDATED</b>	(Import)
0500	Continuous	1900	<b>by NGRID</b>	<b>12/29/2021</b>
Work scheduled by: NGrid				CENTRAL EAST - VC
				<b>2650 MW</b>
				Impacts Total Transfer Capability 325 MW
				TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,January 08, 2022 to Monday ,July 10, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PORTER\_\_-ROTTRDAM\_230\_30 & MARCY\_\_-N.SCTLND\_345\_18**

Tue 11/01/2022 to Tue 12/06/2022  
 0500 1900

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **1300 MW**  
 Impacts Total Transfer Capability 1675 MW  
 TTC with All Lines In Service 2975 MW

-----  
**PORTER\_\_-ROTTRDAM\_230\_31 & MARCY\_\_-N.SCTLND\_345\_18**

Tue 11/01/2022 to Tue 12/06/2022  
 0500 1900

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **1300 MW**  
 Impacts Total Transfer Capability 1675 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MOSES\_\_-ADIRNDCK\_230\_MAL**

Wed 11/30/2022 to Wed 03/01/2023  
 0700 Continuous 1100

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**FRASER\_\_345\_FRASER SVC**

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2935 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW

-----  
**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 05/01/2023 to Fri 05/05/2023  
 0600 Continuous 1800

Work scheduled by: LI

FWD REV  
 (Import) (Export)  
 SCH - NPX\_CSC **0 MW 0 MW**  
 Impacts Total Transfer Capability 330 MW 330 MW  
 TTC with All Lines In Service 330 MW 330 MW