

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 07/31/2022 **EXT FORCE** **by CONED** **01/04/2022**

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 07/31/2022

0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 07/31/2022 **EXT FORCE** **by CONED** **01/04/2022**

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Tue 05/31/2022 **EXT FORCE** **by IESO** **11/04/2021**

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Mon 08/01/2022 **EXT FORCE** **by LI** **12/10/2021**

1807 Continuous 2359

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 10/18/2021 to Sat 12/31/2022 **UPDATED** **by NYPA** **01/08/2022**

0500 Continuous 2359

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Sat 04/30/2022 **UPDATED** **by IESO** **05/03/2019**

0001 Continuous 2359

Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	2300 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1600						REV
Mon 11/01/2021	to	Sat 04/30/2022	UPDATED	by IESO	05/03/2019	(Export)
0001	Continuous	2359				1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW
KINTIGH_STA_255_345_SH1-39						FWD
Wed 12/08/2021	to	Sat 12/31/2022	UPDATED	by RGE	01/08/2022	(Import)
2000	Continuous	2359				1700 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
DYSINGER-KINTIGH_345_39 & DYSINGER-STA_255_345_DH1						FWD
Tue 12/14/2021	to	Mon 01/10/2022				(Import)
1129		1600				2650 MW
Work scheduled by:						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 3150 MW
DYSINGER-STA_255_345_DH1						FWD
Tue 12/14/2021	to	Mon 01/10/2022	FORCED	by NYISO	01/08/2022	(Import)
1129	Continuous	1600				2550 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 3150 MW
MOSES_ADIRNDCK_230_MAI						FWD
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by NYPA	01/07/2022	(Import)
0700	Continuous	1600				2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_1550						FWD
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by IESO	01/10/2022	(Import)
0700	Continuous	1600				1850 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1400						REV
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by IESO	01/10/2022	(Export)
0700	Continuous	1600				1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 2000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Tue 01/04/2022 to Fri 01/07/2022
0700 Continuous 1530

by NYPA 01/08/2022

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOPATCON-RAMAPO__500_5018

Thu 01/06/2022 to Sat 01/08/2022
0200 Continuous 1900

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1650 MW	1200 MW
Impacts Total Transfer Capability	1200 MW	1000 MW
TTC with All Lines In Service	2850 MW	2200 MW

HOPATCON-RAMAPO__500_5018

Thu 01/06/2022 to Sat 01/08/2022
0200 Continuous 1900

Work scheduled by: PJM

	FWD
	(Import)
UPNY CONED	7480 MW
Impacts Total Transfer Capability	335 MW
TTC with All Lines In Service	7815 MW

RAMAPO__345_345_PAR3500

Thu 01/06/2022 to Sat 01/08/2022
0200 Continuous 1900

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2500 MW	1250 MW
Impacts Total Transfer Capability	350 MW	950 MW
TTC with All Lines In Service	2850 MW	2200 MW

RAMAPO__345_345_PAR4500

Thu 01/06/2022 to Sat 01/08/2022
0200 Continuous 1900

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2500 MW	1250 MW
Impacts Total Transfer Capability	350 MW	950 MW
TTC with All Lines In Service	2850 MW	2200 MW

RAMAPO__500_345_BK 1500

Thu 01/06/2022 to Sat 01/08/2022
0200 Continuous 1900

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1650 MW	1200 MW
Impacts Total Transfer Capability	1200 MW	1000 MW
TTC with All Lines In Service	2850 MW	2200 MW

RAMAPO__500_345_BK 1500

Thu 01/06/2022 to Sat 01/08/2022
0200 Continuous 1900

Work scheduled by: PJM

	FWD
	(Import)
UPNY CONED	7480 MW
Impacts Total Transfer Capability	335 MW
TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					REV
NIAGARA_-ROBNSNRD_230_64					(Export)
Mon 01/10/2022	to	Mon 01/10/2022	UPDATED	by NYSEG	01/07/2022
0600	Continuous	0700			
Work scheduled by: NYSEG					SCH - OH - NY 1900 MW
					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
<hr/>					
SPRNBRK_-W49TH_ST_345_M51					FWD
Mon 01/10/2022	to	Thu 01/13/2022			(Import)
1553	Continuous	2359			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
DUNWODIE-SHORE_RD_345_Y50					FWD
Tue 01/11/2022	to	Sat 01/15/2022			(Import)
1838	Continuous	2359			
Work scheduled by: ConEd					CONED - LIPA 800 MW
					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK 1					FWD
Tue 01/11/2022	to	Sat 01/15/2022			(Import)
1838	Continuous	2359			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK 2					FWD
Tue 01/11/2022	to	Sat 01/15/2022			(Import)
1839	Continuous	2359			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
NIAGARA_-ROBNSNRD_230_64					REV
Wed 01/12/2022	to	Wed 01/12/2022	UPDATED	by NYSEG	01/06/2022
0500	Daily	0600			
Work scheduled by: NYSEG					SCH - OH - NY 1900 MW
					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
<hr/>					
HURLYAVE-ROSETON__345_303					FWD
Wed 01/12/2022	to	Sat 01/22/2022	CANCELLED	by CHGE	01/12/2022
1300	Continuous	1600			
Work scheduled by: CHGE					UPNY CONED 4100 MW
					Impacts Total Transfer Capability 3715 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROBNSNRD_230_64				REV	
Wed 01/12/2022	to	Wed 01/12/2022	<u>UPDATED</u> <u>by NYSEG</u> <u>01/06/2022</u>	(Export)	
1500	Daily	1600		SCH - OH - NY	1900 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	2000 MW
SCH-IMO-NYISO_LIMIT_1000				FWD	
Thu 01/13/2022	to	Tue 01/18/2022		(Import)	
0600	Daily	2000		SCH - OH - NY	1300 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	2300 MW
MOSES_-ADIRNDCK_230_MA1 & MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	
Thu 01/13/2022	to	Thu 01/13/2022		(Import)	
0700		1200		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	189 MW
				TTC with All Lines In Service	279 MW
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	REV
Thu 01/13/2022	to	Thu 01/13/2022		(Import)	(Export)
0700		1200		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	
Thu 01/13/2022	to	Thu 01/13/2022		(Import)	
0700		1200		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	189 MW
				TTC with All Lines In Service	279 MW
STLAWRNC-MOSES_230_L33P & MOSES_-ADIRNDCK_230_MA1 & MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	
Thu 01/13/2022	to	Thu 01/13/2022		(Import)	
0700		1200		SCH - HQ_CEDARS	90 MW
Work scheduled by:				Impacts Total Transfer Capability	189 MW
				TTC with All Lines In Service	279 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L33P & MOSES___-MASSENA_230_MMS1 & MOSES___- MASSENA_230_MMS2					FWD (Import)
Thu 01/13/2022	to	Thu 01/13/2022			
0700		1200			SCH - HQ_CEDARS 90 MW
Work scheduled by:					Impacts Total Transfer Capability 189 MW
SCH-NYISO-HQ_LIMIT_500					REV (Export)
Thu 01/13/2022	to	Thu 01/13/2022			
0700	Continuous	1900			SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW
MOSES___-ADIRNDCK_230_MAI					FWD (Import)
Thu 01/13/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/07/2022</u>
0700	Continuous	1600			
Work scheduled by: NYPA					MOSES SOUTH 2300 MW
					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_1550					FWD (Import)
Thu 01/13/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>01/10/2022</u>
0700	Continuous	1600			
Work scheduled by: IESO					SCH - OH - NY 1850 MW
					Impacts Total Transfer Capability 450 MW
					TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1400					REV (Export)
Thu 01/13/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>01/10/2022</u>
0700	Continuous	1600			
Work scheduled by: IESO					SCH - OH - NY 1700 MW
					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 2000 MW
W49TH_ST_345KV_5					FWD (Import)
Fri 01/14/2022	to	Fri 01/14/2022			
0001	Continuous	0030			
Work scheduled by: ConEd					SCH - PJM_HTP 300 MW
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7					FWD (Import)
Fri 01/14/2022	to	Fri 01/14/2022			
0001	Continuous	0030			
Work scheduled by: ConEd					SCH - PJM_HTP 300 MW
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5					FWD
Sat 01/15/2022	to	Sat 01/15/2022			(Import)
0130	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7					FWD
Sat 01/15/2022	to	Sat 01/15/2022			(Import)
0130	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
CHATGUAY-MASSENA__765_7040					FWD
Mon 01/17/2022	to	Thu 01/20/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/11/2022</u>
0700	Continuous	1530			
Work scheduled by: NYPA					(Import)
					MOSES SOUTH 1550 MW
					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA__765_7040					FWD
Mon 01/17/2022	to	Thu 01/20/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/11/2022</u>
0700	Continuous	1530			
Work scheduled by: NYPA					(Import) (Export)
					SCH - HQ - NY 0 MW 0 MW
					Impacts Total Transfer Capability 1500 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW
S.RIPLEY-DUNKIRK__230_68					
Tue 01/18/2022	to	Fri 02/04/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>09/24/2021</u>
0700	Continuous	1730			
Work scheduled by: NGrid					SCH - PJ - NY
					Impacts Total Transfer Capability
					TTC with All Lines In Service
BECK__-NIAGARA__345_PA301					FWD
Tue 01/18/2022	to	Fri 06/17/2022			(Import) (Export)
0700	Continuous	1700			
Work scheduled by: IESO					SCH - OH - NY 1100 MW 950 MW
					Impacts Total Transfer Capability 1200 MW 1050 MW
					TTC with All Lines In Service 2300 MW 2000 MW
SCH-IMO-NYISO_LIMIT_1000					FWD
Wed 01/19/2022	to	Wed 01/19/2022			(Import)
0600	Daily	1900			
Work scheduled by: NYISO					SCH - OH - NY 1300 MW
					Impacts Total Transfer Capability 1000 MW
					TTC with All Lines In Service 2300 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Sun 01/23/2022 to Sun 01/23/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
SCH - PJM_HTP 300 MW
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sun 01/23/2022 to Sun 01/23/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
SCH - PJM_HTP 300 MW
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FIVEMILE-STOLLERD_345_29

Mon 01/24/2022 to Sun 01/30/2022
 0500 Continuous 1900
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

DYSINGER-KINTIGH_345_38

Tue 01/25/2022 to Fri 01/28/2022 **UPDATED** **by NYPA** **01/11/2022**
 0500 Continuous 1900
 Work scheduled by: NYSEG

FWD
 (Import)
DYSINGER EAST 2500 MW
 Impacts Total Transfer Capability 650 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-DYSINGER_345_ND1

Tue 01/25/2022 to Fri 01/28/2022 **UPDATED** **by NYPA** **01/11/2022**
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 2650 MW
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3150 MW

OAKDALE_-FRASER_345_32

Tue 01/25/2022 to Wed 01/26/2022
 0700 Continuous 1600
 Work scheduled by: NYSEG

FWD
 (Import)
CENTRAL EAST - VC 2650 MW
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

E13THSTA-FARRAGUT_345_45

Thu 01/27/2022 to Fri 01/28/2022
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
SPR/DUN-SOUTH 3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Fri 01/28/2022 to Fri 01/28/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Fri 01/28/2022 to Fri 01/28/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

PLSNTVLY-WOOD_ST_345_F30

Sat 01/29/2022 to Sat 01/29/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Sat 01/29/2022 to Sat 01/29/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NIAGARA_-STA_255_345_NH2

Sat 01/29/2022 to Sat 03/12/2022 **EXTENDED by NYPA 01/10/2022**
 0500 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NIAGARA_-STA_255_345_NH2 & KINTIGH_-STA_255_345_SH1-39

Sat 01/29/2022 to Sat 03/12/2022
 0500 Continuous 1900
 Work scheduled by:

FWD
 (Import)
 DYSINGER EAST **1250 MW**
 Impacts Total Transfer Capability 1900 MW
 TTC with All Lines In Service 3150 MW

PLSNTVLY-WOOD_ST_345_F30

Wed 02/02/2022 to Wed 02/02/2022
 1930 Continuous 2000
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Wed 02/02/2022 to Wed 02/02/2022
 1930 Continuous 2000
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NIAGARA -PACKARD_230_61

Thu 02/03/2022 to Sat 02/12/2022 **UPDATED by NGRID 12/03/2021**
 0615 Continuous 1900
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - OH - NY **1400 MW 1850 MW**
 Impacts Total Transfer Capability 900 MW 150 MW
 TTC with All Lines In Service 2300 MW 2000 MW

MARCY -N.SCTLND_345_18

Tue 02/08/2022 to Wed 02/09/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **1470 MW**
 Impacts Total Transfer Capability 1505 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLY_345KV_RNS4

Sat 02/12/2022 to Sat 02/12/2022 **UPDATED by CONED 11/12/2021**
 0600 Continuous 0630
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

ATHENS -PLSNTVLY_345_91

Sat 02/12/2022 to Wed 02/16/2022 **UPDATED by CONED 11/12/2021**
 0600 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_N-EASTVIEW_345_W93

Sun 02/13/2022 to Mon 02/14/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

RAMAPO -BUCHAN_N_345_Y94

Sun 02/13/2022 to Mon 02/14/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7580 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18

Mon 02/14/2022 to Tue 02/15/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

EDIC -FRASER 345 EF24-40

Mon 02/14/2022 to Tue 02/22/2022 **UPDATED by NYSEG 01/04/2022**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

EASTVIEW-SPRNBK 345 W78

Tue 02/15/2022 to Wed 02/16/2022 **UPDATED by CE 01/07/2022**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW 345 W85

Tue 02/15/2022 to Wed 02/16/2022 **UPDATED by CE 01/07/2022**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBK 345KV_RNS3

Tue 02/15/2022 to Wed 02/16/2022 **UPDATED by CE 01/07/2022**
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLY 345KV_RNS4

Wed 02/16/2022 to Wed 02/16/2022 **UPDATED by CONED 11/12/2021**
 1830 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY 345KV_RN5 & PLSNTVLY 345KV_RN4

Thu 02/17/2022 to Sat 02/19/2022
 0001 2200
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-PLSNTVLY_345_92					FWD
Thu 02/17/2022	to	Fri 03/25/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/15/2021</u>
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED 3800 MW
					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS5					FWD
Thu 02/17/2022	to	Fri 03/25/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/15/2021</u>
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED 3800 MW
					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLY-WOOD_ST_345_F30					FWD
Sun 02/20/2022	to	Mon 02/21/2022			
0001	Continuous	2200			
Work scheduled by: ConEd					(Import)
					UPNY CONED 4000 MW
					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK_345_W64					FWD
Sun 02/20/2022	to	Mon 02/21/2022			
2000	Continuous	2359			
Work scheduled by: ConEd					(Import)
					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
MILLWOOD-EASTVIEW_345_W99					FWD
Sun 02/20/2022	to	Mon 02/21/2022			
2000	Continuous	2359			
Work scheduled by: ConEd					(Import)
					UPNY CONED 7550 MW
					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW
SPRNBK_345KV_RNS5					FWD
Sun 02/20/2022	to	Mon 02/21/2022			
2000	Continuous	2359			
Work scheduled by: ConEd					(Import)
					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK_345_W64					FWD
Tue 02/22/2022	to	Tue 02/22/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>
0001	Continuous	0030			
Work scheduled by: ConEd					(Import)
					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5

Tue 02/22/2022 to Tue 02/22/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Tue 02/22/2022 to Mon 03/21/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 08/31/2021

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

MARCY__-EDIC__345_UE1-7

Wed 02/23/2022 to Mon 02/28/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

W49TH_ST-E13THSTA_345_M54

Sun 02/27/2022 to Wed 03/02/2022
 0201 Continuous 2230
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FIVEMILE-STOLLERD_345_29

Tue 03/01/2022 to Tue 04/12/2022
 0500 Continuous 1900
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PORTER__-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

N.SCTLND-LEEDS__345_93

Tue 03/01/2022 to Mon 03/28/2022
 0700 Continuous 1900
 Work scheduled by: NGrid

UPDATED by NGRID 11/15/2021

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
EDIC _____ -N.SCTLND_345_14			FWD
Tue 03/01/2022	to	Tue 04/12/2022	(Import)
0700	Continuous	1900	1670 MW
Work scheduled by: NGrid			
		CENTRAL EAST - VC	1670 MW
		Impacts Total Transfer Capability	1305 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
EDIC _____ -N.SCTLND_345_14 & PORTER _____ -ROTTDAM_230_31			
FWD			
Tue 03/01/2022	to	Tue 04/12/2022	(Import)
0700		1900	1500 MW
Work scheduled by:			
		CENTRAL EAST - VC	1500 MW
		Impacts Total Transfer Capability	1475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
FRASANX-COOPERS _____ 345_UCC2-41			
FWD			
Tue 03/01/2022	to	Wed 04/20/2022	(Import)
0700	Continuous	1530	2500 MW
Work scheduled by: NYPA			
		CENTRAL EAST - VC	2500 MW
		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
MARCY _____ -FRASANX_345_UCC2-41			
FWD			
Tue 03/01/2022	to	Wed 04/20/2022	(Import)
0700	Continuous	1530	2500 MW
Work scheduled by: NYPA			
		CENTRAL EAST - VC	2500 MW
		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
N.SCTLND-ALPS _____ 345_2			
FWD			
Tue 03/01/2022	to	Fri 06/24/2022	(Import)
0700	Continuous	1900	900 MW
Work scheduled by: NGrid			
		SCH - NE - NY	900 MW
		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	1400 MW
<hr/>			
N.SCTLND-ALPS _____ 345_2			
FWD			
Tue 03/01/2022	to	Fri 06/24/2022	(Import) (Export)
0700	Continuous	1900	100 MW 100 MW
Work scheduled by: NGrid			
		SCH - NPX_1385	100 MW 100 MW
		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
GOETHALS_345KV_5			
FWD			
Sat 03/05/2022	to	Mon 04/04/2022	
0001	Continuous	0200	
Work scheduled by: ConEd			
		STATEN ISLAND	
		Impacts Total Transfer Capability	
		TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253

Sat 03/05/2022 to Mon 04/04/2022 **UPDATED by CONED 03/26/2021**
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Sat 03/05/2022 to Mon 04/04/2022
 0001 0200
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Sat 03/05/2022 to Mon 04/04/2022
 0001 0200
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

LINDEN__-GOETHALS_230_A2253 & MARION_-FARRAGUT_345_C3403

Sat 03/05/2022 to Mon 04/04/2022
 0001 0200
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

INDPDNCE-SCRIBA__345_25

Thu 03/10/2022 to Wed 03/16/2022
 0800 Continuous 1800
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

NIAGARA_-DYSINGER_345_ND1

Fri 03/11/2022 to Fri 03/11/2022
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2650 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3150 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 03/17/2022 to Sun 03/20/2022
 0100 2200
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30					FWD
Mon 03/21/2022	to	Wed 03/23/2022			(Import)
0001	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK__345_W64					FWD
Mon 03/21/2022	to	Mon 03/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>
0130	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RNS5					FWD
Mon 03/21/2022	to	Mon 03/21/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/31/2021</u>
0130	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD
Sat 03/26/2022	to	Mon 03/28/2022			(Import)
0001		2200		UPNY CONED	3800 MW
Work scheduled by:					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
ATHENS__-PLSNTVLY_345_91					FWD
Sat 03/26/2022	to	Sun 05/01/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/03/2022</u>
0001	Continuous	2200		UPNY CONED	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS4					FWD
Sat 03/26/2022	to	Sun 05/01/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/03/2022</u>
0001	Continuous	2200		UPNY CONED	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLY-WOOD_ST__345_F31					FWD
Tue 03/29/2022	to	Wed 03/30/2022			(Import)
0001	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6				FWD	
Thu 03/31/2022	to	Sat 04/02/2022		(Import)	
2100	Continuous	0300	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8				FWD	
Thu 03/31/2022	to	Sat 04/02/2022		(Import)	
2100	Continuous	0300	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W90				FWD	
Thu 03/31/2022	to	Tue 04/05/2022		(Import)	
2100	Continuous	2200	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
WOOD_ST_-PLSNTVLE_345_Y87				FWD	
Thu 03/31/2022	to	Tue 04/05/2022		(Import)	
2100	Continuous	2200	UPNY CONED	7260 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	555 MW	
			TTC with All Lines In Service	7815 MW	
LINDN_CG-LNDVFT__345_V-3022				FWD	REV
Sun 04/03/2022	to	Sat 04/09/2022		(Import)	(Export)
1400	Continuous	1400	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
SPRNBK_-TREMONT__345_X28				FWD	
Tue 04/05/2022	to	Wed 04/06/2022	UPDATED	(Import)	
0201	Continuous	0300	by CE		
Work scheduled by: ConEd			01/12/2022		
			SPR/DUN-SOUTH	4200 MW	
			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_6				FWD	
Tue 04/05/2022	to	Tue 04/05/2022		(Import)	
2130	Continuous	2200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
DUNWODIE_345KV_8					(Import)
Tue 04/05/2022	to	Tue 04/05/2022			SPR/DUN-SOUTH 3800 MW
2130	Continuous	2200			Impacts Total Transfer Capability 800 MW
Work scheduled by: ConEd					TTC with All Lines In Service 4600 MW
<hr/>					FWD
BUCHAN_N-EASTVIEW_345_W93					(Import)
Wed 04/06/2022	to	Wed 04/06/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/19/2021</u>	UPNY CONED 4350 MW
0301	Continuous	0330			Impacts Total Transfer Capability 3465 MW
Work scheduled by: ConEd					TTC with All Lines In Service 7815 MW
<hr/>					FWD
EASTVIEW-SPRNBK__345_W79					(Import)
Wed 04/06/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/19/2021</u>	UPNY CONED 4350 MW
0301	Continuous	0300			Impacts Total Transfer Capability 3465 MW
Work scheduled by: ConEd					TTC with All Lines In Service 7815 MW
<hr/>					FWD
BUCHAN_N-EASTVIEW_345_W93					(Import)
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/19/2021</u>	UPNY CONED 4350 MW
0230	Continuous	0300			Impacts Total Transfer Capability 3465 MW
Work scheduled by: ConEd					TTC with All Lines In Service 7815 MW
<hr/>					FWD
EASTVIEW-SPRNBK__345_W64					(Import)
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/31/2021</u>	UPNY CONED 4350 MW
0301	Continuous	0330			Impacts Total Transfer Capability 3465 MW
Work scheduled by: ConEd					TTC with All Lines In Service 7815 MW
<hr/>					FWD
SPRNBK__345KV_RNS5					(Import)
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/31/2021</u>	SPR/DUN-SOUTH 3200 MW
0301	Continuous	0330			Impacts Total Transfer Capability 1400 MW
Work scheduled by: ConEd					TTC with All Lines In Service 4600 MW
<hr/>					FWD
MILLWOOD-EASTVIEW_345_W99					(Import)
Thu 04/07/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u> <u>08/31/2021</u>	UPNY CONED 7550 MW
0301	Continuous	2200			Impacts Total Transfer Capability 265 MW
Work scheduled by: ConEd					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q12

Mon 04/11/2022 to Thu 04/28/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_____345_1

Mon 04/11/2022 to Fri 04/15/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

GOETHALS_345KV_5

Wed 04/13/2022 to Fri 05/13/2022
 0001 Continuous 0259
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PORTER_-ROTTDAM_230_30

Wed 04/13/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

PANNELL_-CLAY_____345_2

Mon 04/18/2022 to Fri 04/22/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

SCH-NE-NYISO_LIMIT_700

Tue 04/19/2022 to Fri 04/22/2022
 0601 Continuous 0759
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

EDIC_-FRASER_____345_EF24-40

Thu 04/21/2022 to Tue 06/14/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Fri 04/22/2022 to Sat 04/23/2022
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

SCH-NE-NYISO_LIMIT_700

Fri 04/22/2022 to Sun 04/24/2022
1601 Continuous 1800

Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY **900 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1400 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 04/23/2022 to Tue 04/26/2022
0001 2200

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

ROCHESTR-PANNELL__345_RP1

Mon 04/25/2022 to Fri 04/29/2022
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 04/25/2022 to Fri 04/29/2022
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

EASTVIEW-SPRNBK__345_W64

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**
2130 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Tue 04/26/2022 to Tue 04/26/2022 **UPDATED by CONED 08/31/2021**
2130 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST_345_F31				FWD
Wed 04/27/2022	to	Fri 04/29/2022		(Import)
0001	Continuous	2200	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW
NIAGARA_345_230_AT4				REV
Fri 04/29/2022	to	Fri 04/29/2022		(Export)
0500	Continuous	1700	SCH - OH - NY	1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 2000 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Mon 05/02/2022	to	Mon 05/02/2022		(Import)
0001	Continuous	0030	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK_345_W79				FWD
Mon 05/02/2022	to	Thu 05/05/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
ROCHESTR-PANNELL_345_RP2				FWD
Mon 05/02/2022	to	Fri 05/06/2022		(Import)
0500	Continuous	1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Thu 05/05/2022	to	Thu 05/05/2022		(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBK_-TREMONT_345_X28				FWD
Fri 05/06/2022	to	Mon 05/09/2022	UPDATED by CONED 08/19/2021	(Import)
0201	Continuous	1800	SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__345_FRASER SVC				FWD	
Mon 05/09/2022	to	Fri 05/13/2022		(Import)	
0800	Continuous	1700	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
HURLYAVE-ROSETON__345_303				FWD	
Mon 05/09/2022	to	Fri 06/10/2022	CANCELLED by CHGE 01/11/2022	(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	3715 MW	
			TTC with All Lines In Service	7815 MW	
PLSNTVLE-DUNWODIE_345_W89				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0200	Continuous	0230	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
EFISHKIL-WOOD_ST__345_F38				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0200	Continuous	0430	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
WOOD_ST_-PLSNTVLE_345_Y86				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0200	Continuous	0430	UPNY CONED	7210 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	605 MW	
			TTC with All Lines In Service	7815 MW	
PLSNTVLE-DUNWODIE_345_W89				FWD	
Fri 05/13/2022	to	Fri 05/13/2022		(Import)	
0400	Continuous	0430	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022		(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71

Thu 05/19/2022 to Fri 05/20/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Thu 05/19/2022 to Fri 05/20/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Thu 05/19/2022 to Fri 05/20/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MARCY -EDIC 345 UE1-7

Sat 05/21/2022 to Sat 05/21/2022
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

PORTER -ROTTRDAM_230_30 & VOLNEY -MARCY 345_19

Sat 05/21/2022 to Sat 05/21/2022
 0700 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2655 MW**
 Impacts Total Transfer Capability 320 MW
 TTC with All Lines In Service 2975 MW

PORTER -ROTTRDAM_230_31 & VOLNEY -MARCY 345_19

Sat 05/21/2022 to Sat 05/21/2022
 0700 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2655 MW**
 Impacts Total Transfer Capability 320 MW
 TTC with All Lines In Service 2975 MW

VOLNEY -MARCY 345_19

Sat 05/21/2022 to Sat 05/21/2022
 0700 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -MARCY 345_19			FWD	
Sat 05/21/2022	to	Sat 05/21/2022	(Import)	
0700	Continuous	1730	OSWEGO EXPORT	4900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW
			TTC with All Lines In Service	5250 MW
ARR: 19				
MOSES -ADIRNDCK 230_MA2			FWD	
Wed 06/01/2022	to	Tue 11/29/2022	(Import)	
0700	Continuous	1800	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
NIAGARA -DYSINGER 345_ND1			FWD	
Mon 06/13/2022	to	Fri 06/17/2022	(Import)	
0500	Continuous	2100	DYSINGER EAST	2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	3150 MW
NIAGARA -PACKARD 230_62			FWD	REV
Sat 06/18/2022	to	Sat 06/18/2022	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	700 MW 1550 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1250 MW 150 MW
			TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA 345_230_AT4			FWD	REV
Tue 06/28/2022	to	Wed 06/29/2022	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	1900 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW 300 MW
			TTC with All Lines In Service	1950 MW 1700 MW
BECK -NIAGARA 230_PA27				
Tue 07/05/2022	to	Sat 07/09/2022		
0500	Continuous	2100	SCH - OH - NY	
Work scheduled by: NYPA			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
NIAGARA -DYSINGER 345_ND1			FWD	
Mon 07/11/2022	to	Fri 07/15/2022	(Import)	
0500	Continuous	1700	DYSINGER EAST	2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1

Mon 07/25/2022 to Fri 07/29/2022
0500 Continuous 2100

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY__-EDIC__345_UE1-7

Sat 08/06/2022 to Sat 08/06/2022
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PORTER__-ROTTRDAM_230_30 & VOLNEY__-MARCY__345_19

Sat 08/06/2022 to Sat 08/06/2022
0500 1830

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2655 MW**
Impacts Total Transfer Capability 320 MW
TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_31 & VOLNEY__-MARCY__345_19

Sat 08/06/2022 to Sat 08/06/2022
0500 1830

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2655 MW**
Impacts Total Transfer Capability 320 MW
TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY__345_19

Sat 08/06/2022 to Sat 08/06/2022
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY__345_19

Sat 08/06/2022 to Sat 08/06/2022
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311

Mon 08/29/2022 to Fri 09/09/2022
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 3415 MW
TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY_345_Q12

Thu 09/01/2022 to Mon 09/05/2022
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_345_1

Mon 09/12/2022 to Fri 09/16/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FRASER_-GILBOA_345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

PANNELL_-CLAY_345_2

Mon 09/19/2022 to Fri 09/23/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY_-EDIC_345_UE1-7

Mon 09/19/2022 to Sat 10/08/2022
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NIAGARA_-DYSINGER_345_ND1

Mon 09/26/2022 to Fri 09/30/2022
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2650 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC							
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>		
1000	Continuous	1500				SCH - NPX_CSC	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE						FWD	
Mon 10/10/2022	to	Fri 10/14/2022				(Import)	
0600	Continuous	1600				SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501						FWD	
Mon 10/10/2022	to	Fri 10/14/2022				(Import)	
0600	Continuous	1600				SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1						FWD	
Mon 10/10/2022	to	Fri 10/14/2022				(Import)	
0600	Continuous	1600				SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI						Impacts Total Transfer Capability	285 MW
						TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2						FWD	
Mon 10/10/2022	to	Fri 10/14/2022				(Import)	
0600	Continuous	1600				SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI						Impacts Total Transfer Capability	285 MW
						TTC with All Lines In Service	660 MW
EDIC_-N.SCTLND_345_14						FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1305 MW
						TTC with All Lines In Service	2975 MW
EDIC_-N.SCTLND_345_14 & PORTER_-ROTTDAM_230_30						FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)	
0700		1530				CENTRAL EAST - VC	1500 MW
Work scheduled by:						Impacts Total Transfer Capability	1475 MW
						TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC ___-N.SCTLND_345_14 & PORTER ___-ROTTDAM_230_31				FWD
Mon 10/10/2022	to	Mon 10/31/2022		(Import)
0700		1530	CENTRAL EAST - VC	1500 MW
Work scheduled by:				Impacts Total Transfer Capability 1475 MW
				TTC with All Lines In Service 2975 MW
GILBOA ___-N.SCTLND_345_GNS-1				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u> by NGRID <u>12/29/2021</u>	(Import)
0500	Continuous	1900		CENTRAL EAST - VC 2520 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 455 MW
				TTC with All Lines In Service 2975 MW
LEEDS ___345KV_R94301				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u> by NGRID <u>12/29/2021</u>	(Import)
0500	Continuous	1900		UPNY CONED 3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
MARCY ___-N.SCTLND_345_18				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u> by NGRID <u>12/29/2021</u>	(Import)
0500	Continuous	1900		CENTRAL EAST - VC 1470 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 1505 MW
				TTC with All Lines In Service 2975 MW
N.SCTLND-LEEDS ___345_94				FWD
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u> by NGRID <u>12/29/2021</u>	(Import)
0500	Continuous	1900		CENTRAL EAST - VC 2650 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 325 MW
				TTC with All Lines In Service 2975 MW
PORTER ___-ROTTDAM_230_30 & MARCY ___-N.SCTLND_345_18				FWD
Tue 11/01/2022	to	Tue 12/06/2022		(Import)
0500		1900		CENTRAL EAST - VC 1300 MW
Work scheduled by:				Impacts Total Transfer Capability 1675 MW
				TTC with All Lines In Service 2975 MW
PORTER ___-ROTTDAM_230_31 & MARCY ___-N.SCTLND_345_18				FWD
Tue 11/01/2022	to	Tue 12/06/2022		(Import)
0500		1900		CENTRAL EAST - VC 1300 MW
Work scheduled by:				Impacts Total Transfer Capability 1675 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, January 12, 2022 to Friday, July 14, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Wed 11/30/2022 to Wed 03/01/2023
 0700 Continuous 1100

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER 345_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**
 0700 Continuous 1730

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/01/2023 to Fri 05/05/2023
 0600 Continuous 1800

Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW