

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 07/31/2022
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 10/18/2021 to Sat 12/31/2022 UPDATED by NYPA 01/08/2022
 0500 Continuous 2359
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	2300 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							
SCH-NYISO-IMO_LIMIT_1600							REV
Mon 11/01/2021	to	Sat 04/30/2022	UPDATED	by IESO	05/03/2019		(Export)
0001	Continuous	2359				SCH - OH - NY	1900 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	2000 MW
<hr/>							
KINTIGH_STA_255_345_SH1-39							FWD
Wed 12/08/2021	to	Sat 12/31/2022	UPDATED	by RGE	01/08/2022		(Import)
2000	Continuous	2359				DYSINGER EAST	1700 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
DYSINGER-KINTIGH_345_39 & DYSINGER-STA_255_345_DH1							FWD
Tue 12/14/2021	to	Mon 01/10/2022					(Import)
1129		1600				DYSINGER EAST	2650 MW
Work scheduled by:						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
DYSINGER-STA_255_345_DH1							FWD
Tue 12/14/2021	to	Mon 01/10/2022	FORCED	by NYISO	01/08/2022		(Import)
1129	Continuous	1600				DYSINGER EAST	2550 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
MOSES_ADIRNDCK_230_MAI							FWD
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by NYPA	01/07/2022		(Import)
0700	Continuous	1600				MOSES SOUTH	2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
SCH-IMO-NYISO_LIMIT_1550							FWD
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by IESO	01/10/2022		(Import)
0700	Continuous	1600				SCH - OH - NY	1850 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	2300 MW
<hr/>							
SCH-NYISO-IMO_LIMIT_1400							REV
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by IESO	01/10/2022		(Export)
0700	Continuous	1600				SCH - OH - NY	1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	2000 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					REV
NIAGARA_-ROBNSNRD_230_64					(Export)
Mon 01/10/2022	to	Mon 01/10/2022	<u>UPDATED</u>	<u>by NYSEG</u>	<u>01/07/2022</u>
0600	Continuous	0700			
Work scheduled by: NYSEG					SCH - OH - NY 1900 MW
					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
<hr/>					
SPRNBRK_-W49TH_ST_345_M51					FWD
Mon 01/10/2022	to	Thu 01/13/2022			(Import)
1553	Continuous	2359			
Work scheduled by: ConEd					SPR/DUN-SOUTH 3200 MW
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
DUNWODIE-SHORE_RD_345_Y50					FWD
Tue 01/11/2022	to	Sat 01/15/2022			(Import)
1838	Continuous	2359			
Work scheduled by: ConEd					CONED - LIPA 800 MW
					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK 1					FWD
Tue 01/11/2022	to	Sat 01/15/2022			(Import)
1838	Continuous	2359			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK 2					FWD
Tue 01/11/2022	to	Sat 01/15/2022			(Import)
1839	Continuous	2359			
Work scheduled by: ConEd					CONED - LIPA 1350 MW
					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
HURLYAVE-ROSETON_345_303					FWD
Wed 01/12/2022	to	Sat 01/22/2022	<u>CANCELLED</u>	<u>by CHGE</u>	<u>01/12/2022</u>
1300	Continuous	1600			
Work scheduled by: CHGE					UPNY CONED 4100 MW
					Impacts Total Transfer Capability 3715 MW
					TTC with All Lines In Service 7815 MW
<hr/>					
SCH-IMO-NYISO_LIMIT_1000					FWD
Thu 01/13/2022	to	Tue 01/18/2022			(Import)
0600	Daily	2000			
Work scheduled by: NYISO					SCH - OH - NY 1300 MW
					Impacts Total Transfer Capability 1000 MW
					TTC with All Lines In Service 2300 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_500						REV
Thu 01/13/2022	to	Thu 01/13/2022				(Export)
0700	Continuous	1900			SCH - HQ - NY	500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
MOSES -ADIRNDCK_230_MAI						FWD
Thu 01/13/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/07/2022</u>	(Import)
0700	Continuous	1600			MOSES SOUTH	2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_1550						FWD
Thu 01/13/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>01/10/2022</u>	(Import)
0700	Continuous	1600			SCH - OH - NY	1850 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 2300 MW
SCH-NYISO-IMO_LIMIT_1400						REV
Thu 01/13/2022	to	Mon 02/28/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>01/10/2022</u>	(Export)
0700	Continuous	1600			SCH - OH - NY	1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 2000 MW
W49TH_ST_345KV_5						FWD
Fri 01/14/2022	to	Fri 01/14/2022				(Import)
0001	Continuous	0030			SCH - PJM_HTP	300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7						FWD
Fri 01/14/2022	to	Fri 01/14/2022				(Import)
0001	Continuous	0030			SCH - PJM_HTP	300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_5						FWD
Sat 01/15/2022	to	Sat 01/15/2022				(Import)
0130	Continuous	0200			SCH - PJM_HTP	300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Sat 01/15/2022 to Sat 01/15/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1300

Sun 01/16/2022 to Mon 01/17/2022 **UPDATED by IESO 01/13/2022**
 0700 Continuous 1700
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1600 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1300

Sun 01/16/2022 to Mon 01/17/2022 **UPDATED by IESO 01/13/2022**
 0700 Continuous 1700
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1600 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 2000 MW

CHATGUAY-MASSENA_765_7040

Mon 01/17/2022 to Thu 01/20/2022 **CANCELLED by NYPA 01/13/2022**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Mon 01/17/2022 to Thu 01/20/2022 **CANCELLED by NYPA 01/13/2022**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

FIVEMILE-STOLLERD_345_29

Mon 01/17/2022 to Fri 01/21/2022
 0700 Continuous 1800
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

S.RIPLEY-DUNKIRK_230_68

Tue 01/18/2022 to Fri 02/04/2022 **CANCELLED by NGrid 01/14/2022**
 0700 Continuous 1730
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK	-NIAGARA	345_PA301		FWD	REV
Tue 01/18/2022	to	Fri 06/17/2022		(Import)	(Export)
0700	Continuous	1700		SCH - OH - NY	1100 MW 950 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	1200 MW 1050 MW
				TTC with All Lines In Service	2300 MW 2000 MW
<hr/>					
SCH-IMO-NYISO_LIMIT	1000			FWD	
Wed 01/19/2022	to	Wed 01/19/2022		(Import)	
0600	Daily	1900		SCH - OH - NY	1300 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	2300 MW
<hr/>					
EDIC	-N.SCTLND	345_14		FWD	
Wed 01/19/2022	to	Wed 01/19/2022		(Import)	
0630	Daily	1700		CENTRAL EAST - VC	1670 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1305 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
E13THSTA-FARRAGUT	345_45			FWD	
Sat 01/22/2022	to	Mon 01/24/2022	UPDATED	(Import)	
0001	Continuous	0200	by CONED	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			01/14/2022	Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
W49TH_ST_345KV	5			FWD	
Sun 01/23/2022	to	Sun 01/23/2022		(Import)	
0001	Continuous	0030		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
<hr/>					
W49TH_ST_345KV	7			FWD	
Sun 01/23/2022	to	Sun 01/23/2022		(Import)	
0001	Continuous	0030		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW
				TTC with All Lines In Service	660 MW
<hr/>					
FIVEMILE-STOLLERD	345_29				
Mon 01/24/2022	to	Sun 01/30/2022		SCH - PJ - NY	
0500	Continuous	1900		Impacts Total Transfer Capability	
Work scheduled by: PJM				TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-KINTIGH__345_38					FWD	
Tue 01/25/2022	to	Fri 01/28/2022	UPDATED	by NYPA	01/11/2022	(Import)
0500	Continuous	1900				DYSINGER EAST 2500 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 650 MW	
					TTC with All Lines In Service 3150 MW	
NIAGARA_-DYSINGER_345_ND1					FWD	
Tue 01/25/2022	to	Fri 01/28/2022	UPDATED	by NYPA	01/11/2022	(Import)
0500	Continuous	1900				DYSINGER EAST 2650 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 3150 MW	
OAKDALE_-FRASER__345_32					FWD	
Tue 01/25/2022	to	Wed 01/26/2022				(Import)
0700	Continuous	1600				CENTRAL EAST - VC 2650 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 325 MW	
					TTC with All Lines In Service 2975 MW	
W49TH_ST_345KV_5					FWD	
Fri 01/28/2022	to	Fri 01/28/2022				(Import)
0130	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
W49TH_ST_345KV_7					FWD	
Fri 01/28/2022	to	Fri 01/28/2022				(Import)
0130	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW	
					TTC with All Lines In Service 660 MW	
PLSNTVLY-WOOD_ST__345_F30					FWD	
Sat 01/29/2022	to	Sat 01/29/2022	CANCELLED	by ConEd	01/13/2022	(Import)
0001	Continuous	0030				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLY_345KV_RNS5					FWD	
Sat 01/29/2022	to	Sat 01/29/2022	CANCELLED	by ConEd	01/13/2022	(Import)
0001	Continuous	0030				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-STA_255__345_NH2					FWD	
Sat 01/29/2022	to	Sat 03/12/2022	EXTENDED	by NYPA	01/10/2022	(Import)
0500	Continuous	1900				DYSINGER EAST 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
NIAGARA_-STA_255__345_NH2 & KINTIGH_-STA_255__345_SH1-39					FWD	
Sat 01/29/2022	to	Sat 03/12/2022				(Import)
0500		1900				DYSINGER EAST 1250 MW
Work scheduled by:						Impacts Total Transfer Capability 1900 MW
						TTC with All Lines In Service 3150 MW
PLSNTVLY-WOOD_ST__345_F30					FWD	
Wed 02/02/2022	to	Wed 02/02/2022	CANCELLED	by ConEd	01/13/2022	(Import)
1930	Continuous	2000				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS5					FWD	
Wed 02/02/2022	to	Wed 02/02/2022	CANCELLED	by ConEd	01/13/2022	(Import)
1930	Continuous	2000				UPNY CONED 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW
NIAGARA_-PACKARD__230_61					FWD	REV
Thu 02/03/2022	to	Sat 02/12/2022	UPDATED	by NGRID	12/03/2021	(Import) (Export)
0615	Continuous	1900				SCH - OH - NY 1400 MW 1850 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 900 MW 150 MW
						TTC with All Lines In Service 2300 MW 2000 MW
MARCY__-N.SCTLND_345_18					FWD	
Tue 02/08/2022	to	Wed 02/09/2022				(Import)
0700	Continuous	1530				CENTRAL EAST - VC 1470 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1505 MW
						TTC with All Lines In Service 2975 MW
PLSNTVLY_345KV_RNS4					FWD	
Sat 02/12/2022	to	Sat 02/12/2022	UPDATED	by CONED	11/12/2021	(Import)
0600	Continuous	0630				UPNY CONED 3800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ATHENS__-PLSNTVLY_345_91

Sat 02/12/2022 to Wed 02/16/2022
0600 Continuous 1900

Work scheduled by: NGrid

UPDATED by CONED 11/12/2021

UPNY CONED

FWD
(Import)

3800 MW
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

BUCHAN_N-EASTVIEW_345_W93

Sun 02/13/2022 to Mon 02/14/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD
(Import)

4350 MW
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

RAMAPO__-BUCHAN_N_345_Y94

Sun 02/13/2022 to Mon 02/14/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD
(Import)

7580 MW
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 7815 MW

MILLWOOD_345KV_18

Mon 02/14/2022 to Tue 02/15/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD
(Import)

4350 MW
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

EDIC__-FRASER_345_EF24-40

Mon 02/14/2022 to Tue 02/22/2022
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYSEG 01/04/2022

CENTRAL EAST - VC

FWD
(Import)

2500 MW
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

EASTVIEW-SPRNBRK_345_W78

Tue 02/15/2022 to Wed 02/16/2022
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 01/07/2022

UPNY CONED

FWD
(Import)

4350 MW
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W85

Tue 02/15/2022 to Wed 02/16/2022
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 01/07/2022

UPNY CONED

FWD
(Import)

7550 MW
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3					FWD	
Tue 02/15/2022	to	Wed 02/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/07/2022</u>	(Import)
0201	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
PLSNTVLY_345KV_RNS4					FWD	
Wed 02/16/2022	to	Wed 02/16/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>11/12/2021</u>	(Import)
1830	Continuous	1900				UPNY CONED 3800 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD	
Thu 02/17/2022	to	Sat 02/19/2022				(Import)
0001		2200				UPNY CONED 3800 MW
Work scheduled by:					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
LEEDS__-PLSNTVLY_345_92					FWD	
Thu 02/17/2022	to	Fri 03/25/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/15/2021</u>	(Import)
0001	Continuous	2200				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLY_345KV_RNS5					FWD	
Thu 02/17/2022	to	Fri 03/25/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/15/2021</u>	(Import)
0001	Continuous	2200				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLY-WOOD_ST_345_F30					FWD	
Sun 02/20/2022	to	Mon 02/21/2022				(Import)
0001	Continuous	2200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	
EASTVIEW-SPRNBK__345_W64					FWD	
Sun 02/20/2022	to	Mon 02/21/2022				(Import)
2000	Continuous	2359				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	
					TTC with All Lines In Service 7815 MW	

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Sun 02/20/2022 to Mon 02/21/2022
 2000 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS5

Sun 02/20/2022 to Mon 02/21/2022
 2000 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK_345_W64

Tue 02/22/2022 to Wed 02/23/2022 **UPDATED by CONED 01/13/2022**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS5

Tue 02/22/2022 to Wed 02/23/2022 **UPDATED by CONED 01/13/2022**
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Tue 02/22/2022 to Mon 03/21/2022 **UPDATED by CONED 01/13/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

MARCY-EDIC_345_UE1-7

Wed 02/23/2022 to Mon 02/28/2022
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19&16**

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

W49TH_ST-E13THSTA_345_M54

Sun 02/27/2022 to Wed 03/02/2022
 0201 Continuous 2230
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Tue 03/01/2022 to Tue 04/12/2022
 0500 Continuous 1900
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PORTER_-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

N.SCTLND-LEEDS_345_93

Tue 03/01/2022 to Mon 03/28/2022 **UPDATED by NGRID 11/15/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14

Tue 03/01/2022 to Tue 04/12/2022 **UPDATED by NGRID 11/15/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14 & PORTER_-ROTTRDAM_230_31

Tue 03/01/2022 to Tue 04/12/2022
 0700 1900
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

FRASANX-COOPERS_345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANX_345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2					FWD	
Tue 03/01/2022	to	Fri 06/24/2022	UPDATED	by NGRID	11/15/2021	(Import)
0700	Continuous	1900				900 MW
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service	1400 MW
N. SCTLND-ALPS_____345_2					FWD	REV
Tue 03/01/2022	to	Fri 06/24/2022	UPDATED	by NGRID	11/15/2021	(Import) (Export)
0700	Continuous	1900				100 MW 100 MW
Work scheduled by: NGrid					SCH - NPX_1385	Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
W49TH_ST_345KV_5					FWD	
Fri 03/04/2022	to	Fri 03/04/2022				(Import)
0001	Continuous	0031				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service	660 MW
SPRNBRK__345KV_RNS4					FWD	
Fri 03/04/2022	to	Sat 03/05/2022				(Import)
0001	Continuous	1800				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK_-W49TH_ST_345_M52					FWD	
Fri 03/04/2022	to	Sat 03/19/2022				(Import)
0001	Continuous	0200				3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service	4600 MW
GOETHALS_345KV_5						
Sat 03/05/2022	to	Mon 04/04/2022	UPDATED	by CONED	03/26/2021	
0001	Continuous	0200				
Work scheduled by: ConEd					STATEN ISLAND	Impacts Total Transfer Capability
					TTC with All Lines In Service	
LINDEN__-GOETHALS_230_A2253						
Sat 03/05/2022	to	Mon 04/04/2022	UPDATED	by CONED	03/26/2021	
0001	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	Impacts Total Transfer Capability
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402			FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022	(Import)	(Export)
0001		0200	SCH - PJ - NY	2550 MW 1900 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW 300 MW
			TTC with All Lines In Service	2850 MW 2200 MW
LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403			FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022	(Import)	(Export)
0001		0200	SCH - PJ - NY	2550 MW 1900 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW 300 MW
			TTC with All Lines In Service	2850 MW 2200 MW
LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403			FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022	(Import)	(Export)
0001		0200	SCH - PJ - NY	2550 MW 1900 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW 300 MW
			TTC with All Lines In Service	2850 MW 2200 MW
W49TH_ST_345KV_5			FWD	
Mon 03/07/2022	to	Sat 03/19/2022	(Import)	
0001	Continuous	0200	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
SPRNBRK__345KV_RNS4			FWD	
Thu 03/10/2022	to	Tue 03/15/2022	(Import)	
0001	Continuous	1800	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
INDPDNCE-SCRIBA__345_25			FWD	
Thu 03/10/2022	to	Wed 03/16/2022	(Import)	
0800	Continuous	1800	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
NIAGARA_-DYSINGER_345_ND1			FWD	
Fri 03/11/2022	to	Fri 03/11/2022	(Import)	
0500	Continuous	1700	CANCELLED by NYPA 01/13/2022	2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 03/17/2022 to Sun 03/20/2022
 0100 2200

Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST__345_F30

Mon 03/21/2022 to Wed 03/23/2022
 0001 Continuous 2200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

EGRDNCTY_345_138_AT1

Mon 03/21/2022 to Sat 03/26/2022
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Mon 03/21/2022 to Sat 03/26/2022
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

SPRNBK_-EGRDNCTR_345_Y49

Mon 03/21/2022 to Sat 03/26/2022
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **775 MW**
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

EASTVIEW-SPRNBK__345_W64

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 01/13/2022**
 0130 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 01/13/2022**
 0130 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD
Sat 03/26/2022	to	Mon 03/28/2022			(Import)
0001		2200		UPNY CONED	3800 MW
Work scheduled by:					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
ATHENS_-PLSNTVLY_345_91					FWD
Sat 03/26/2022	to	Sun 05/01/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/03/2022</u>
0001	Continuous	2200		UPNY CONED	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS4					FWD
Sat 03/26/2022	to	Sun 05/01/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/03/2022</u>
0001	Continuous	2200		UPNY CONED	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLY-WOOD_ST_345_F31					FWD
Tue 03/29/2022	to	Wed 03/30/2022			(Import)
0001	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
DUNWODIE_345KV_6					FWD
Thu 03/31/2022	to	Sat 04/02/2022			(Import)
2100	Continuous	0300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8					FWD
Thu 03/31/2022	to	Sat 04/02/2022			(Import)
2100	Continuous	0300		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
PLSNTVLE-DUNWODIE_345_W90					FWD
Thu 03/31/2022	to	Tue 04/05/2022			(Import)
2100	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

Thu 03/31/2022 to Tue 04/05/2022
 2100 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7260 MW**
 Impacts Total Transfer Capability 555 MW
 TTC with All Lines In Service 7815 MW

LINDN_CG-LNDVFT___345_V-3022

Sun 04/03/2022 to Sat 04/09/2022
 1400 Continuous 1400
 Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

SPRNBK_-TREMONT__345_X28

Tue 04/05/2022 to Wed 04/06/2022 **UPDATED by CE 01/12/2022**
 0201 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **4200 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Tue 04/05/2022 to Tue 04/05/2022
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Tue 04/05/2022 to Tue 04/05/2022
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

BUCHAN_N-EASTVIEW_345_W93

Wed 04/06/2022 to Wed 04/06/2022 **UPDATED by CONED 08/19/2021**
 0301 Continuous 0330
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK__345_W79

Wed 04/06/2022 to Thu 04/07/2022 **UPDATED by CONED 08/19/2021**
 0301 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/19/2021</u>	(Import)
0230	Continuous	0300				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W64					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>01/13/2022</u>	(Import)
0301	Continuous	0330				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
SPRNBK__345KV_RNS5					FWD	
Thu 04/07/2022	to	Thu 04/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>01/13/2022</u>	(Import)
0301	Continuous	0330				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
MILLWOOD-EASTVIEW_345_W99					FWD	
Thu 04/07/2022	to	Tue 04/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>01/13/2022</u>	(Import)
0301	Continuous	2200				UPNY CONED 7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
MOTTHAVN-RAINEY__345_Q12					FWD	
Mon 04/11/2022	to	Thu 04/28/2022				(Import)
0001	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PANNELL_-CLAY____345_1					FWD	
Mon 04/11/2022	to	Fri 04/15/2022				(Import)
0700	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
GOETHALS_345KV_5					FWD	
Wed 04/13/2022	to	Fri 05/13/2022				(Import)
0001	Continuous	0259				STATEN ISLAND
Work scheduled by: ConEd					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30

Wed 04/13/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
CENTRAL EAST - VC 2805 MW
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

PANNELL_-CLAY_____345_2

Mon 04/18/2022 to Fri 04/22/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
WEST CENTRAL 1300 MW
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

SCH-NE-NYISO_LIMIT_700

Tue 04/19/2022 to Fri 04/22/2022
 0601 Continuous 0759
 Work scheduled by: ISONE

FWD
 (Import)
SCH - NE - NY 900 MW
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

EDIC_____-FRASER_____345_EF24-40

Thu 04/21/2022 to Tue 06/14/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2500 MW
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY____345KV_CSC

Fri 04/22/2022 to Sat 04/23/2022
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2925 MW
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

SCH-NE-NYISO_LIMIT_700

Fri 04/22/2022 to Sun 04/24/2022
 1601 Continuous 1800
 Work scheduled by: ISONE

FWD
 (Import)
SCH - NE - NY 900 MW
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 04/23/2022 to Tue 04/26/2022
 0001 2200
 Work scheduled by:

FWD
 (Import)
UPNY CONED 3800 MW
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1

FWD

Mon 04/25/2022 to Fri 04/29/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

SAND_BAR-PLATSBRG_115_PV20

Mon 04/25/2022 to Fri 04/29/2022

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

EASTVIEW-SPRNBRK__345_W64

FWD

Tue 04/26/2022 to Tue 04/26/2022

(Import)

2130 Continuous 2200

UPDATED by CONED 01/13/2022

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

SPRNBRK__345KV_RNS5

FWD

Tue 04/26/2022 to Tue 04/26/2022

(Import)

2130 Continuous 2200

UPDATED by CONED 01/13/2022

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

PLSNTVLY-WOOD_ST__345_F31

FWD

Wed 04/27/2022 to Fri 04/29/2022

(Import)

0001 Continuous 2200

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

NIAGARA__345_230_AT4

REV

Fri 04/29/2022 to Fri 04/29/2022

(Export)

0500 Continuous 1700

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

BUCHAN_N-EASTVIEW_345_W93

FWD

Mon 05/02/2022 to Mon 05/02/2022

(Import)

0001 Continuous 0030

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79				FWD
Mon 05/02/2022	to	Thu 05/05/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
ROCHESTR-PANNELL__345_RP2				FWD
Mon 05/02/2022	to	Fri 05/06/2022		(Import)
0500	Continuous	1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Thu 05/05/2022	to	Thu 05/05/2022		(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBK_-TREMONT__345_X28				FWD
Fri 05/06/2022	to	Mon 05/09/2022	UPDATED by CONED 08/19/2021	(Import)
0201	Continuous	1800	SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW
FRASER__345_FRASER SVC				FWD
Mon 05/09/2022	to	Fri 05/13/2022		(Import)
0800	Continuous	1700	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW
HURLYAVE-ROSETON__345_303				FWD
Mon 05/09/2022	to	Fri 06/10/2022	CANCELLED by CHGE 01/11/2022	(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 3715 MW
				TTC with All Lines In Service 7815 MW
PLSNTVLE-DUNWODIE_345_W89				FWD
Fri 05/13/2022	to	Fri 05/13/2022		(Import)
0200	Continuous	0230	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F38			FWD	
Fri 05/13/2022	to	Fri 05/13/2022	(Import)	
0200	Continuous	0430	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
WOOD_ST_-PLSNTVLE_345_Y86			FWD	
Fri 05/13/2022	to	Fri 05/13/2022	(Import)	
0200	Continuous	0430	UPNY CONED	7210 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	605 MW
			TTC with All Lines In Service	7815 MW
PLSNTVLE-DUNWODIE_345_W89			FWD	
Fri 05/13/2022	to	Fri 05/13/2022	(Import)	
0400	Continuous	0430	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
SHOR_NPX-SHOREHAM_138_CSC			FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022	(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
DUNWODIE-MOTTHAVN_345_71			FWD	
Thu 05/19/2022	to	Fri 05/20/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3			FWD	
Thu 05/19/2022	to	Fri 05/20/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5			FWD	
Thu 05/19/2022	to	Fri 05/20/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MARCY -EDIC 345 UE1-7</p> <p>Sat 05/21/2022 to Sat 05/21/2022 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) OSWEGO EXPORT 5250 MW Impacts Total Transfer Capability 0 MW TTC with All Lines In Service 5250 MW</p>
<p>ARR: 19&16</p>	
<p>PORTER -ROTTRDAM 230_30 & VOLNEY -MARCY 345_19</p> <p>Sat 05/21/2022 to Sat 05/21/2022 0700 1730</p> <p>Work scheduled by:</p>	<p>FWD (Import) CENTRAL EAST - VC 2655 MW Impacts Total Transfer Capability 320 MW TTC with All Lines In Service 2975 MW</p>
<p>PORTER -ROTTRDAM 230_31 & VOLNEY -MARCY 345_19</p> <p>Sat 05/21/2022 to Sat 05/21/2022 0700 1730</p> <p>Work scheduled by:</p>	<p>FWD (Import) CENTRAL EAST - VC 2655 MW Impacts Total Transfer Capability 320 MW TTC with All Lines In Service 2975 MW</p>
<p>VOLNEY -MARCY 345_19</p> <p>Sat 05/21/2022 to Sat 05/21/2022 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) CENTRAL EAST - VC 2825 MW Impacts Total Transfer Capability 150 MW TTC with All Lines In Service 2975 MW</p>
<p>ARR: 19</p>	
<p>VOLNEY -MARCY 345_19</p> <p>Sat 05/21/2022 to Sat 05/21/2022 0700 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) OSWEGO EXPORT 4900 MW Impacts Total Transfer Capability 350 MW TTC with All Lines In Service 5250 MW</p>
<p>ARR: 19</p>	
<p>MOSES -ADIRNDCK 230_MA2</p> <p>Wed 06/01/2022 to Tue 11/29/2022 0700 Continuous 1800</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) MOSES SOUTH 2100 MW Impacts Total Transfer Capability 1050 MW TTC with All Lines In Service 3150 MW</p>
<p>NIAGARA -DYSINGER 345_ND1</p> <p>Mon 06/13/2022 to Fri 06/17/2022 0500 Continuous 2100</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import) DYSINGER EAST 2650 MW Impacts Total Transfer Capability 500 MW TTC with All Lines In Service 3150 MW</p>

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-PACKARD__230_62

Sat 06/18/2022 to Sat 06/18/2022
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	700 MW	1550 MW
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

NIAGARA__345_230_AT4

Tue 06/28/2022 to Wed 06/29/2022
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

BECK___-NIAGARA__230_PA27

Tue 07/05/2022 to Sat 07/09/2022
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

NIAGARA_-DYSINGER_345_ND1

Mon 07/11/2022 to Fri 07/15/2022
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	
	(Import)	
DYSINGER EAST	2650 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3150 MW	

ROCHESTR-PANNELL__345_RP1

Mon 07/25/2022 to Fri 07/29/2022
0500 Continuous 2100

Work scheduled by: NYPA

	FWD	
	(Import)	
DYSINGER EAST	2300 MW	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

MARCY___-EDIC____345_UE1-7

Sat 08/06/2022 to Sat 08/06/2022
0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19&16

	FWD	
	(Import)	
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

PORTER__-ROTTDAM_230_30 & VOLNEY__-MARCY____345_19

Sat 08/06/2022 to Sat 08/06/2022
0500 Continuous 1830

Work scheduled by:

	FWD	
	(Import)	
CENTRAL EAST - VC	2655 MW	
Impacts Total Transfer Capability	320 MW	
TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_31 & VOLNEY__-MARCY_____345_19

Sat 08/06/2022 to Sat 08/06/2022
 0500 1830

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2655 MW**
 Impacts Total Transfer Capability 320 MW
 TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY_____345_19

Sat 08/06/2022 to Sat 08/06/2022
 0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY_____345_19

Sat 08/06/2022 to Sat 08/06/2022
 0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
 0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROSETON_-ROCKTVRN_345_311

Mon 08/29/2022 to Fri 09/09/2022
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 3415 MW
 TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY_____345_Q12

Thu 09/01/2022 to Mon 09/05/2022
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_____345_1

Mon 09/12/2022 to Fri 09/16/2022
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

PANNELL -CLAY 345_2

Mon 09/19/2022 to Fri 09/23/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY -EDIC 345_UE1-7

Mon 09/19/2022 to Sat 10/08/2022
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19&16

FWD

(Import)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NIAGARA -DYSINGER 345_ND1

Mon 09/26/2022 to Fri 09/30/2022
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2650 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3150 MW

EGRDNCTY 345_138_AT1

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359

Work scheduled by: LI

FWD

(Import)

CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

EGRDNCTY 345_138_AT2

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359

Work scheduled by: LI

FWD

(Import)

CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SPRNBK -EGRDNCTR 345_Y49

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359

Work scheduled by: LI

FWD

(Import)

CONED - LIPA **775 MW**
Impacts Total Transfer Capability 725 MW
TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC						
Mon 10/03/2022	to	Fri 10/21/2022	UPDATED	by LI	01/07/2022	
1000	Continuous	1500				
Work scheduled by: LI					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	0 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	0 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	375 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	375 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
EDIC_-N.SCTLND_345_14						
Mon 10/10/2022	to	Mon 10/31/2022				
0700	Continuous	1530				
Work scheduled by: NYPA					CENTRAL EAST - VC	1670 MW
					Impacts Total Transfer Capability	1305 MW
					TTC with All Lines In Service	2975 MW
EDIC_-N.SCTLND_345_14 & PORTER_-ROTTDAM_230_30						
Mon 10/10/2022	to	Mon 10/31/2022				
0700		1530				
Work scheduled by:					CENTRAL EAST - VC	1500 MW
					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC ___ -N.SCTLND_345_14 & PORTER ___ -ROTTDAM_230_31				FWD (Import) CENTRAL EAST - VC 1500 MW Impacts Total Transfer Capability 1475 MW TTC with All Lines In Service 2975 MW
Mon 10/10/2022	to	Mon 10/31/2022		
0700		1530		
Work scheduled by:				
GILBOA ___ -N.SCTLND_345_GNS-1				FWD (Import) CENTRAL EAST - VC 2520 MW Impacts Total Transfer Capability 455 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID <u>12/29/2021</u>
0500	Continuous	1900		
Work scheduled by: NGrid				
LEEDS ___ 345KV_R94301				FWD (Import) UPNY CONED 3800 MW Impacts Total Transfer Capability 4015 MW TTC with All Lines In Service 7815 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID <u>12/29/2021</u>
0500	Continuous	1900		
Work scheduled by: NGrid				
MARCY ___ -N.SCTLND_345_18				FWD (Import) CENTRAL EAST - VC 1470 MW Impacts Total Transfer Capability 1505 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID <u>12/29/2021</u>
0500	Continuous	1900		
Work scheduled by: NGrid				ARR: 19
N.SCTLND-LEEDS ___ 345_94				FWD (Import) CENTRAL EAST - VC 2650 MW Impacts Total Transfer Capability 325 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID <u>12/29/2021</u>
0500	Continuous	1900		
Work scheduled by: NGrid				
PORTER ___ -ROTTDAM_230_30 & MARCY ___ -N.SCTLND_345_18				FWD (Import) CENTRAL EAST - VC 1300 MW Impacts Total Transfer Capability 1675 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022		
0500		1900		
Work scheduled by:				
PORTER ___ -ROTTDAM_230_31 & MARCY ___ -N.SCTLND_345_18				FWD (Import) CENTRAL EAST - VC 1300 MW Impacts Total Transfer Capability 1675 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022		
0500		1900		
Work scheduled by:				

NYISO TRANSFER LIMITATIONS

Friday ,January 14, 2022 to Sunday ,July 16, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Wed 11/30/2022 to Wed 03/01/2023
 0700 Continuous 1100

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER 345_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**
 0700 Continuous 1730

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/01/2023 to Fri 05/05/2023
 0600 Continuous 1800

Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW