

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 07/31/2022
 0001 2359
 Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2550 MW	1900 MW
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022
 0001 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

STLAWRNC-MOSES_230_L33P

Mon 04/30/2018 to Tue 05/31/2022 EXT FORCE by IESO 11/04/2021
 0456 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NEWBRDGE_345_138_BK_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021
 1807 Continuous 2359
 Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NIAGARA_-KINTIGH_345_NS1-38

Mon 10/18/2021 to Sat 12/31/2022 UPDATED by NYPA 01/08/2022
 0500 Continuous 2359
 Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

SCH-IMO-NYISO_LIMIT_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019
 0001 Continuous 2359
 Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	2050 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	2300 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							REV
SCH-NYISO-IMO_LIMIT_1600							(Export)
Mon 11/01/2021	to	Sat 04/30/2022	UPDATED	by IESO	05/03/2019	SCH - OH - NY	1900 MW
0001	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: IESO						TTC with All Lines In Service	2000 MW
<hr/>							
KINTIGH_STA_255_345_SH1-39							FWD
Wed 12/08/2021	to	Sat 12/31/2022	UPDATED	by RGE	01/08/2022		(Import)
2000	Continuous	2359				DYSINGER EAST	1700 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
DYSINGER-KINTIGH_345_39 & DYSINGER-STA_255_345_DH1							FWD
Tue 12/14/2021	to	Mon 01/10/2022				DYSINGER EAST	2650 MW
1129		1600				Impacts Total Transfer Capability	500 MW
Work scheduled by:						TTC with All Lines In Service	3150 MW
<hr/>							
DYSINGER-STA_255_345_DH1							FWD
Tue 12/14/2021	to	Mon 01/10/2022	FORCED	by NYISO	01/08/2022		(Import)
1129	Continuous	1600				DYSINGER EAST	2550 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
MOSES_ADIRNDCK_230_MAI							FWD
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by NYPA	01/07/2022		(Import)
0700	Continuous	1600				MOSES SOUTH	2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
SCH-IMO-NYISO_LIMIT_1550							FWD
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by IESO	01/10/2022		(Import)
0700	Continuous	1600				SCH - OH - NY	1850 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	2300 MW
<hr/>							
SCH-NYISO-IMO_LIMIT_1400							REV
Mon 01/03/2022	to	Mon 01/10/2022	UPDATED	by IESO	01/10/2022		(Export)
0700	Continuous	1600				SCH - OH - NY	1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	2000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					REV
NIAGARA_-ROBNSNRD_230_64					(Export)
Mon 01/10/2022	to	Mon 01/10/2022	UPDATED	by NYSEG	01/07/2022
0600	Continuous	0700			
Work scheduled by: NYSEG					SCH - OH - NY 1900 MW
					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 2000 MW
<hr/>					
SPRNBRK_-W49TH_ST_345_M51					FWD
Mon 01/10/2022	to	Thu 01/13/2022			(Import)
1553	Continuous	2359			SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
DUNWODIE-SHORE_RD_345_Y50					FWD
Tue 01/11/2022	to	Sun 01/16/2022			(Import)
1838	Continuous	0600			CONED - LIPA 800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK 1					FWD
Tue 01/11/2022	to	Sun 01/16/2022			(Import)
1838	Continuous	0600			CONED - LIPA 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
SHORE_RD_345_138_BK 2					FWD
Tue 01/11/2022	to	Sun 01/16/2022			(Import)
1839	Continuous	0600			CONED - LIPA 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
<hr/>					
HURLYAVE-ROSETON_345_303					FWD
Wed 01/12/2022	to	Sat 01/22/2022	CANCELLED	by CHGE	01/12/2022
1300	Continuous	1600			
Work scheduled by: CHGE					UPNY CONED 4100 MW
					Impacts Total Transfer Capability 3715 MW
					TTC with All Lines In Service 7815 MW
<hr/>					
SCH-IMO-NYISO_LIMIT_1000					FWD
Thu 01/13/2022	to	Tue 01/18/2022			(Import)
0600	Daily	2000			SCH - OH - NY 1300 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability 1000 MW
					TTC with All Lines In Service 2300 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_500

Thu 01/13/2022 to Thu 01/13/2022
 0700 Continuous 1900
 Work scheduled by: HQ

REV
 (Export)
500 MW
 SCH - HQ - NY
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

MOSES -ADIRNDCK_230_MAI

Thu 01/13/2022 to Mon 02/28/2022 **UPDATED by NYPA 01/07/2022**
 0700 Continuous 1600
 Work scheduled by: NYPA

FWD
 (Import)
2300 MW
 MOSES SOUTH
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SCH-IMO-NYISO_LIMIT_1550

Thu 01/13/2022 to Mon 02/28/2022 **UPDATED by IESO 01/10/2022**
 0700 Continuous 1600
 Work scheduled by: IESO

FWD
 (Import)
1850 MW
 SCH - OH - NY
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1400

Thu 01/13/2022 to Mon 02/28/2022 **UPDATED by IESO 01/10/2022**
 0700 Continuous 1600
 Work scheduled by: IESO

REV
 (Export)
1700 MW
 SCH - OH - NY
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 2000 MW

W49TH_ST_345KV_5

Fri 01/14/2022 to Fri 01/14/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
300 MW
 SCH - PJM_HTP
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Fri 01/14/2022 to Fri 01/14/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
300 MW
 SCH - PJM_HTP
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_5

Sat 01/15/2022 to Sat 01/15/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
300 MW
 SCH - PJM_HTP
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Sat 01/15/2022 to Sat 01/15/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1300

Sun 01/16/2022 to Mon 01/17/2022 **UPDATED by IESO 01/13/2022**
 0700 Continuous 1700
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1600 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 2300 MW

SCH-NYISO-IMO_LIMIT_1300

Sun 01/16/2022 to Mon 01/17/2022 **UPDATED by IESO 01/13/2022**
 0700 Continuous 1700
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1600 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 2000 MW

CHATGUAY-MASSENA_765_7040

Mon 01/17/2022 to Thu 01/20/2022 **CANCELLED by NYPA 01/13/2022**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Mon 01/17/2022 to Thu 01/20/2022 **CANCELLED by NYPA 01/13/2022**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

FIVEMILE-STOLLERD_345_29

Mon 01/17/2022 to Fri 01/21/2022
 0700 Continuous 1800
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

S.RIPLEY-DUNKIRK_230_68

Tue 01/18/2022 to Fri 02/04/2022 **CANCELLED by NGrid 01/14/2022**
 0700 Continuous 1730
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK -NIAGARA_345_PA301		FWD
Tue 01/18/2022 to Fri 06/17/2022		(Import) (Export)
0700 Continuous 1700		SCH - OH - NY 1100 MW 950 MW
Work scheduled by: IESO		Impacts Total Transfer Capability 1200 MW 1050 MW
		TTC with All Lines In Service 2300 MW 2000 MW
<hr/>		
SCH-IMO-NYISO_LIMIT_1000		FWD
Wed 01/19/2022 to Fri 01/21/2022		(Import)
0600 Daily 1900		SCH - OH - NY 1300 MW
Work scheduled by: NYISO		Impacts Total Transfer Capability 1000 MW
		TTC with All Lines In Service 2300 MW
<hr/>		
EDIC -N.SCTLND_345_14		FWD
Wed 01/19/2022 to Wed 01/19/2022		(Import)
0630 Daily 1700		CENTRAL EAST - VC 1670 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability 1305 MW
		TTC with All Lines In Service 2975 MW
<hr/>		
E13THSTA-FARRAGUT_345_45		FWD
Sat 01/22/2022 to Mon 01/24/2022	<u>UPDATED</u> by <u>CONED</u> <u>01/14/2022</u>	(Import)
0001 Continuous 0200		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 800 MW
		TTC with All Lines In Service 4600 MW
<hr/>		
W49TH_ST_345KV_5		FWD
Sun 01/23/2022 to Sun 01/23/2022		(Import)
0001 Continuous 0030		SCH - PJM_HTP 300 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 360 MW
		TTC with All Lines In Service 660 MW
<hr/>		
W49TH_ST_345KV_7		FWD
Sun 01/23/2022 to Sun 01/23/2022		(Import)
0001 Continuous 0030		SCH - PJM_HTP 300 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability 360 MW
		TTC with All Lines In Service 660 MW
<hr/>		
FIVEMILE-STOLLERD_345_29		
Mon 01/24/2022 to Sun 01/30/2022		SCH - PJ - NY
0500 Continuous 1900		Impacts Total Transfer Capability
Work scheduled by: PJM		TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-KINTIGH__345_38						FWD
Tue 01/25/2022	to	Fri 01/28/2022	UPDATED	by NYPA	01/11/2022	(Import)
0500	Continuous	1900				DYSINGER EAST 2500 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 650 MW
						TTC with All Lines In Service 3150 MW
NIAGARA_-DYSINGER_345_ND1						FWD
Tue 01/25/2022	to	Fri 01/28/2022	UPDATED	by NYPA	01/11/2022	(Import)
0500	Continuous	1900				DYSINGER EAST 2650 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 3150 MW
OAKDALE_-FRASER__345_32						FWD
Tue 01/25/2022	to	Wed 01/26/2022				(Import)
0700	Continuous	1600				CENTRAL EAST - VC 2650 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 325 MW
						TTC with All Lines In Service 2975 MW
W49TH_ST_345KV_5						FWD
Fri 01/28/2022	to	Fri 01/28/2022				(Import)
0130	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_7						FWD
Fri 01/28/2022	to	Fri 01/28/2022				(Import)
0130	Continuous	0200				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
PLSNTVLY-WOOD_ST__345_F30						FWD
Sat 01/29/2022	to	Sat 01/29/2022	CANCELLED	by ConEd	01/13/2022	(Import)
0001	Continuous	0030				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS5						FWD
Sat 01/29/2022	to	Sat 01/29/2022	CANCELLED	by ConEd	01/13/2022	(Import)
0001	Continuous	0030				UPNY CONED 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday, January 15, 2022 to Monday, July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-STA_255__345_NH2					FWD	
Sat 01/29/2022	to	Sat 03/12/2022	EXTENDED	by NYPA	01/10/2022	(Import)
0500	Continuous	1900				DYSINGER EAST 1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
NIAGARA_-STA_255__345_NH2 & KINTIGH_-STA_255__345_SH1-39					FWD	
Sat 01/29/2022	to	Sat 03/12/2022				(Import)
0500		1900				DYSINGER EAST 1250 MW
Work scheduled by:						Impacts Total Transfer Capability 1900 MW
						TTC with All Lines In Service 3150 MW
PLSNTVLY-WOOD_ST__345_F30					FWD	
Wed 02/02/2022	to	Wed 02/02/2022	CANCELLED	by ConEd	01/13/2022	(Import)
1930	Continuous	2000				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
						TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS5					FWD	
Wed 02/02/2022	to	Wed 02/02/2022	CANCELLED	by ConEd	01/13/2022	(Import)
1930	Continuous	2000				UPNY CONED 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW
NIAGARA_-PACKARD__230_61					FWD	REV
Thu 02/03/2022	to	Sat 02/12/2022	UPDATED	by NGRID	12/03/2021	(Import) (Export)
0615	Continuous	1900				SCH - OH - NY 1400 MW 1850 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 900 MW 150 MW
						TTC with All Lines In Service 2300 MW 2000 MW
MARCY__-N.SCTLND_345_18					FWD	
Tue 02/08/2022	to	Wed 02/09/2022				(Import)
0700	Continuous	1530				CENTRAL EAST - VC 1470 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 1505 MW
						TTC with All Lines In Service 2975 MW
PLSNTVLY_345KV_RNS4					FWD	
Sat 02/12/2022	to	Sat 02/12/2022	UPDATED	by CONED	11/12/2021	(Import)
0600	Continuous	0630				UPNY CONED 3800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 4015 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ATHENS__-PLSNTVLY_345_91				FWD
Sat 02/12/2022	to	Wed 02/16/2022	UPDATED by CONED 11/12/2021	(Import)
0600	Continuous	1900	UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Sun 02/13/2022	to	Mon 02/14/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
RAMAPO__-BUCHAN_N_345_Y94				FWD
Sun 02/13/2022	to	Mon 02/14/2022		(Import)
0001	Continuous	0200	UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 7815 MW
MILLWOOD_345KV_18				FWD
Mon 02/14/2022	to	Tue 02/15/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
EDIC__-FRASER__345_EF24-40				FWD
Mon 02/14/2022	to	Tue 02/22/2022	UPDATED by NYSEG 01/04/2022	(Import)
0700	Continuous	1530	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
EASTVIEW-SPRNBRK__345_W78				FWD
Tue 02/15/2022	to	Wed 02/16/2022	UPDATED by CE 01/07/2022	(Import)
0201	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
MILLWOOD-EASTVIEW_345_W85				FWD
Tue 02/15/2022	to	Wed 02/16/2022	UPDATED by CE 01/07/2022	(Import)
0201	Continuous	0200	UPNY CONED	7550 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 265 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3					FWD	
Tue 02/15/2022	to	Wed 02/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>01/07/2022</u>	(Import)
0201	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
PLSNTVLY_345KV_RNS4					FWD	
Wed 02/16/2022	to	Wed 02/16/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>11/12/2021</u>	(Import)
1830	Continuous	1900				UPNY CONED 3800 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD	
Thu 02/17/2022	to	Sat 02/19/2022				(Import)
0001		2200				UPNY CONED 3800 MW
Work scheduled by:					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
LEEDS__-PLSNTVLY_345_92					FWD	
Thu 02/17/2022	to	Fri 03/25/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/15/2021</u>	(Import)
0001	Continuous	2200				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLY_345KV_RNS5					FWD	
Thu 02/17/2022	to	Fri 03/25/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/15/2021</u>	(Import)
0001	Continuous	2200				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 4015 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLY-WOOD_ST__345_F30					FWD	
Sun 02/20/2022	to	Mon 02/21/2022				(Import)
0001	Continuous	2200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	
EASTVIEW-SPRNBK__345_W64					FWD	
Sun 02/20/2022	to	Mon 02/21/2022				(Import)
2000	Continuous	2359				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	
					TTC with All Lines In Service 7815 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99				FWD
Sun 02/20/2022	to	Mon 02/21/2022		(Import)
2000	Continuous	2359	UPNY CONED	7550 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 265 MW
				TTC with All Lines In Service 7815 MW
SPRNBRK_345KV_RNS5				FWD
Sun 02/20/2022	to	Mon 02/21/2022		(Import)
2000	Continuous	2359	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBRK_345_W64				FWD
Tue 02/22/2022	to	Wed 02/23/2022	UPDATED by CONED 01/13/2022	(Import)
0001	Continuous	0030	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBRK_345KV_RNS5				FWD
Tue 02/22/2022	to	Wed 02/23/2022	UPDATED by CONED 01/13/2022	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99				FWD
Tue 02/22/2022	to	Mon 03/21/2022	UPDATED by CONED 01/13/2022	(Import)
0001	Continuous	0200	UPNY CONED	7550 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 265 MW
				TTC with All Lines In Service 7815 MW
MARCY_-EDIC_345_UE1-7				FWD
Wed 02/23/2022	to	Mon 02/28/2022		(Import)
0700	Continuous	1530	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
W49TH_ST-E13THSTA_345_M54				FWD
Sun 02/27/2022	to	Wed 03/02/2022		(Import)
0201	Continuous	2230	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Tue 03/01/2022 to Tue 04/12/2022
 0500 Continuous 1900
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PORTER_-ROTTDAM_230_31

Tue 03/01/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

N.SCTLND-LEEDS_345_93

Tue 03/01/2022 to Mon 03/28/2022 **UPDATED by NGRID 11/15/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14

Tue 03/01/2022 to Tue 04/12/2022 **UPDATED by NGRID 11/15/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **1670 MW**
 Impacts Total Transfer Capability 1305 MW
 TTC with All Lines In Service 2975 MW

EDIC_-N.SCTLND_345_14 & PORTER_-ROTTDAM_230_31

Tue 03/01/2022 to Tue 04/12/2022
 0700 1900
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

FRASANX-COOPERS_345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANX_345_UCC2-41

Tue 03/01/2022 to Wed 04/20/2022
 0700 Continuous 1530
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS _____ 345_2					FWD	
Tue 03/01/2022	to	Fri 06/24/2022	UPDATED	by NGRID	11/15/2021	(Import)
0700	Continuous	1900				900 MW
Work scheduled by: NGrid				SCH - NE - NY		Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1400 MW
N. SCTLND-ALPS _____ 345_2					FWD	REV
Tue 03/01/2022	to	Fri 06/24/2022	UPDATED	by NGRID	11/15/2021	(Import) (Export)
0700	Continuous	1900				100 MW 100 MW
Work scheduled by: NGrid				SCH - NPX_1385		Impacts Total Transfer Capability 100 MW 100 MW
						TTC with All Lines In Service 200 MW 200 MW
W49TH_ST_345KV_5					FWD	
Fri 03/04/2022	to	Fri 03/04/2022				(Import)
0001	Continuous	0031				300 MW
Work scheduled by: ConEd				SCH - PJM_HTP		Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
SPRNBRK_345KV_RNS4					FWD	
Fri 03/04/2022	to	Sat 03/05/2022				(Import)
0001	Continuous	1800				3200 MW
Work scheduled by: ConEd				SPR/DUN-SOUTH		Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
SPRNBRK_-W49TH_ST_345_M52					FWD	
Fri 03/04/2022	to	Sat 03/19/2022				(Import)
0001	Continuous	0200				3200 MW
Work scheduled by: ConEd				SPR/DUN-SOUTH		Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
GOETHALS_345KV_5						
Sat 03/05/2022	to	Mon 04/04/2022	UPDATED	by CONED	03/26/2021	
0001	Continuous	0200				
Work scheduled by: ConEd				STATEN ISLAND		Impacts Total Transfer Capability
						TTC with All Lines In Service
LINDEN_-GOETHALS_230_A2253						
Sat 03/05/2022	to	Mon 04/04/2022	UPDATED	by CONED	03/26/2021	
0001	Continuous	0200				
Work scheduled by: ConEd				SCH - PJ - NY		Impacts Total Transfer Capability
						TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402			FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022	(Import)	(Export)
0001		0200	SCH - PJ - NY	2550 MW 1900 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW 300 MW
			TTC with All Lines In Service	2850 MW 2200 MW
LINDEN__-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION__-FARRAGUT_345_C3403			FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022	(Import)	(Export)
0001		0200	SCH - PJ - NY	2550 MW 1900 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW 300 MW
			TTC with All Lines In Service	2850 MW 2200 MW
LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403			FWD	REV
Sat 03/05/2022	to	Mon 04/04/2022	(Import)	(Export)
0001		0200	SCH - PJ - NY	2550 MW 1900 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW 300 MW
			TTC with All Lines In Service	2850 MW 2200 MW
W49TH_ST_345KV_5			FWD	
Mon 03/07/2022	to	Sat 03/19/2022	(Import)	
0001	Continuous	0200	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
SPRNBRK__345KV_RNS4			FWD	
Thu 03/10/2022	to	Tue 03/15/2022	(Import)	
0001	Continuous	1800	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
INDPDNCE-SCRIBA__345_25			FWD	
Thu 03/10/2022	to	Wed 03/16/2022	(Import)	
0800	Continuous	1800	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
NIAGARA_-DYSINGER_345_ND1			FWD	
Fri 03/11/2022	to	Fri 03/11/2022	(Import)	
0500	Continuous	1700	CANCELLED by NYPA 01/13/2022	
Work scheduled by: NYPA			DYSINGER EAST	2650 MW
			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 03/17/2022 to Sun 03/20/2022
 0100 2200

Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F30

Mon 03/21/2022 to Wed 03/23/2022
 0001 Continuous 2200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

EGRDNCTY_345_138_AT1

Mon 03/21/2022 to Sat 03/26/2022
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Mon 03/21/2022 to Sat 03/26/2022
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

SPRNBK_-EGRDNCTR_345_Y49

Mon 03/21/2022 to Sat 03/26/2022
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **775 MW**
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

EASTVIEW-SPRNBK_345_W64

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 01/13/2022**
 0130 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

SPRNBK_345KV_RNS5

Mon 03/21/2022 to Mon 03/21/2022 **UPDATED by CONED 01/13/2022**
 0130 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 03/26/2022 to Mon 03/28/2022
0001 2200

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

ATHENS_-PLSNTVLY_345_91

Sat 03/26/2022 to Sun 05/01/2022 UPDATED by CE 01/03/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Sat 03/26/2022 to Sun 05/01/2022 UPDATED by CE 01/03/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY-WOOD_ST_345_F31

Tue 03/29/2022 to Wed 03/30/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_6

Thu 03/31/2022 to Sat 04/02/2022
2100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 03/31/2022 to Sat 04/02/2022
2100 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W90

Thu 03/31/2022 to Tue 04/05/2022
2100 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87					FWD
Thu 03/31/2022	to	Tue 04/05/2022			(Import)
2100	Continuous	2200		UPNY CONED	7260 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 555 MW
					TTC with All Lines In Service 7815 MW
LINDN_CG-LNDVFT___345_V-3022					FWD REV
Sun 04/03/2022	to	Sat 04/09/2022			(Import) (Export)
1400	Continuous	1400		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 315 MW 315 MW
					TTC with All Lines In Service 315 MW 315 MW
SPRNBK_-TREMONT__345_X28					FWD
Tue 04/05/2022	to	Wed 04/06/2022	UPDATED	by CE	01/12/2022
0201	Continuous	0300			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 4200 MW
					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_6					FWD
Tue 04/05/2022	to	Tue 04/05/2022			(Import)
2130	Continuous	2200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8					FWD
Tue 04/05/2022	to	Tue 04/05/2022			(Import)
2130	Continuous	2200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
BUCHAN_N-EASTVIEW_345_W93					FWD
Wed 04/06/2022	to	Wed 04/06/2022	UPDATED	by CONED	08/19/2021
0301	Continuous	0330			(Import)
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
EASTVIEW-SPRNBK__345_W79					FWD
Wed 04/06/2022	to	Thu 04/07/2022	UPDATED	by CONED	08/19/2021
0301	Continuous	0300			(Import)
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

Thu 04/07/2022 to Thu 04/07/2022
0230 Continuous 0300

UPDATED by CONED 08/19/2021

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK__345_W64

Thu 04/07/2022 to Thu 04/07/2022
0301 Continuous 0330

UPDATED by CONED 01/13/2022

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Thu 04/07/2022 to Thu 04/07/2022
0301 Continuous 0330

UPDATED by CONED 01/13/2022

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Thu 04/07/2022 to Tue 04/26/2022
0301 Continuous 2200

UPDATED by CONED 01/13/2022

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7550 MW**
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY__345_Q12

Mon 04/11/2022 to Thu 04/28/2022
0001 Continuous 0200

UPDATED by CONED 01/13/2022

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_____345_1

Mon 04/11/2022 to Fri 04/15/2022
0700 Continuous 1530

UPDATED by CONED 01/13/2022

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

GOETHALS_345KV_5

Wed 04/13/2022 to Fri 05/13/2022
0001 Continuous 0259

UPDATED by CONED 01/13/2022

Work scheduled by: ConEd

FWD
(Import)
STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30

Wed 04/13/2022 to Tue 12/31/2030
 0600 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

PANNELL_-CLAY_____345_2

Mon 04/18/2022 to Fri 04/22/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

SCH-NE-NYISO_LIMIT_700

Tue 04/19/2022 to Fri 04/22/2022
 0601 Continuous 0759
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

EDIC____-FRASER_____345_EF24-40

Thu 04/21/2022 to Tue 06/14/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_____345KV_CSC

Fri 04/22/2022 to Sat 04/23/2022
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

SCH-NE-NYISO_LIMIT_700

Fri 04/22/2022 to Sun 04/24/2022
 1601 Continuous 1800
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sat 04/23/2022 to Tue 04/26/2022
 0001 2200
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1				FWD
Mon 04/25/2022	to	Fri 04/29/2022		(Import)
0500	Continuous	1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
SAND_BAR-PLATSBRG_115_PV20				
Mon 04/25/2022	to	Fri 04/29/2022		SCH - NE - NY
0700	Continuous	1530		Impacts Total Transfer Capability
Work scheduled by: NYPA				TTC with All Lines In Service
EASTVIEW-SPRNBRK__345_W64				FWD
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u> <u>by CONED</u> <u>01/13/2022</u>	(Import)
2130	Continuous	2200		UPNY CONED
Work scheduled by: ConEd				4350 MW
				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBRK__345KV_RNS5				FWD
Tue 04/26/2022	to	Tue 04/26/2022	<u>UPDATED</u> <u>by CONED</u> <u>01/13/2022</u>	(Import)
2130	Continuous	2200		SPR/DUN-SOUTH
Work scheduled by: ConEd				3200 MW
				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
PLSNTVLY-WOOD_ST__345_F31				FWD
Wed 04/27/2022	to	Fri 04/29/2022		(Import)
0001	Continuous	2200		UPNY CONED
Work scheduled by: ConEd				4000 MW
				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW
NIAGARA__345_230_AT4				REV
Fri 04/29/2022	to	Fri 04/29/2022		(Export)
0500	Continuous	1700		SCH - OH - NY
Work scheduled by: NYPA				1750 MW
				Impacts Total Transfer Capability 250 MW
				TTC with All Lines In Service 2000 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Mon 05/02/2022	to	Mon 05/02/2022		(Import)
0001	Continuous	0030		UPNY CONED
Work scheduled by: ConEd				4350 MW
				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79				FWD
Mon 05/02/2022	to	Thu 05/05/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
ROCHESTR-PANNELL__345_RP2				FWD
Mon 05/02/2022	to	Fri 05/06/2022		(Import)
0500	Continuous	1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
BUCHAN_N-EASTVIEW_345_W93				FWD
Thu 05/05/2022	to	Thu 05/05/2022		(Import)
0130	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
SPRNBK_-TREMONT__345_X28				FWD
Fri 05/06/2022	to	Mon 05/09/2022	UPDATED by CONED 08/19/2021	(Import)
0201	Continuous	1800	SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW
FRASER__345_FRASER SVC				FWD
Mon 05/09/2022	to	Fri 05/13/2022		(Import)
0800	Continuous	1700	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW
HURLYAVE-ROSETON__345_303				FWD
Mon 05/09/2022	to	Fri 06/10/2022	CANCELLED by CHGE 01/11/2022	(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 3715 MW
				TTC with All Lines In Service 7815 MW
PLSNTVLE-DUNWODIE_345_W89				FWD
Fri 05/13/2022	to	Fri 05/13/2022		(Import)
0200	Continuous	0230	UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F38			FWD	
Fri 05/13/2022	to	Fri 05/13/2022	(Import)	
0200	Continuous	0430	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
WOOD_ST_-PLSNTVLE_345_Y86			FWD	
Fri 05/13/2022	to	Fri 05/13/2022	(Import)	
0200	Continuous	0430	UPNY CONED	7210 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	605 MW
			TTC with All Lines In Service	7815 MW
PLSNTVLE-DUNWODIE_345_W89			FWD	
Fri 05/13/2022	to	Fri 05/13/2022	(Import)	
0400	Continuous	0430	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
SHOR_NPX-SHOREHAM_138_CSC			FWD	REV
Mon 05/16/2022	to	Fri 05/27/2022	(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
DUNWODIE-MOTTHAVN_345_71			FWD	
Thu 05/19/2022	to	Fri 05/20/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3			FWD	
Thu 05/19/2022	to	Fri 05/20/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5			FWD	
Thu 05/19/2022	to	Fri 05/20/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -EDIC 345 UE1-7

Sat 05/21/2022 to Sat 05/21/2022
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

PORTER -ROTTRDAM 230_30 & VOLNEY -MARC 345_19

Sat 05/21/2022 to Sat 05/21/2022
0700 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2655 MW**
Impacts Total Transfer Capability 320 MW
TTC with All Lines In Service 2975 MW

PORTER -ROTTRDAM 230_31 & VOLNEY -MARC 345_19

Sat 05/21/2022 to Sat 05/21/2022
0700 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2655 MW**
Impacts Total Transfer Capability 320 MW
TTC with All Lines In Service 2975 MW

VOLNEY -MARC 345_19

Sat 05/21/2022 to Sat 05/21/2022
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2825 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY -MARC 345_19

Sat 05/21/2022 to Sat 05/21/2022
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

MOSES -ADIRNDCK 230_MA2

Wed 06/01/2022 to Tue 11/29/2022
0700 Continuous 1800

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA -DYSINGER 345_ND1

Mon 06/13/2022 to Fri 06/17/2022
0500 Continuous 2100

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2650 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-PACKARD__230_62			FWD	REV
Sat 06/18/2022	to	Sat 06/18/2022	(Import) (Export)	
0500	Continuous	1700	SCH - OH - NY	700 MW 1550 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1250 MW 150 MW
			TTC with All Lines In Service	1950 MW 1700 MW
NIAGARA__345_230_AT4			FWD	REV
Tue 06/28/2022	to	Wed 06/29/2022	(Import) (Export)	
0500	Continuous	1700	SCH - OH - NY	1900 MW 1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW 300 MW
			TTC with All Lines In Service	1950 MW 1700 MW
BECK___-NIAGARA__230_PA27				
Tue 07/05/2022	to	Sat 07/09/2022		
0500	Continuous	2100	SCH - OH - NY	
Work scheduled by: NYPA			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
NIAGARA_-DYSINGER_345_ND1			FWD	
Mon 07/11/2022	to	Fri 07/15/2022	(Import)	
0500	Continuous	1700	DYSINGER EAST	2650 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	3150 MW
ROCHESTR-PANNELL__345_RP1			FWD	
Mon 07/25/2022	to	Fri 07/29/2022	(Import)	
0500	Continuous	2100	DYSINGER EAST	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
MARCY___-EDIC____345_UE1-7			FWD	
Sat 08/06/2022	to	Sat 08/06/2022	(Import)	
0500	Continuous	1830	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
PORTER__-ROTTDAM_230_30 & VOLNEY__-MARCY____345_19			FWD	
Sat 08/06/2022	to	Sat 08/06/2022	(Import)	
0500		1830	CENTRAL EAST - VC	2655 MW
Work scheduled by:			Impacts Total Transfer Capability	320 MW
			TTC with All Lines In Service	2975 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_31 & VOLNEY__-MARCY_____345_19

Sat 08/06/2022 to Sat 08/06/2022
 0500 1830

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2655 MW**
 Impacts Total Transfer Capability 320 MW
 TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY_____345_19

Sat 08/06/2022 to Sat 08/06/2022
 0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2825 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 2975 MW

VOLNEY__-MARCY_____345_19

Sat 08/06/2022 to Sat 08/06/2022
 0500 Continuous 1830

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 OSWEGO EXPORT **4900 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 5250 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
 0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROSETON_-ROCKTVRN_345_311

Mon 08/29/2022 to Fri 09/09/2022
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 3415 MW
 TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY_____345_Q12

Thu 09/01/2022 to Mon 09/05/2022
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PANNELL_-CLAY_____345_1

Mon 09/12/2022 to Fri 09/16/2022
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

PANNELL -CLAY 345_2

Mon 09/19/2022 to Fri 09/23/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MARCY -EDIC 345_UE1-7

Mon 09/19/2022 to Sat 10/08/2022
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NIAGARA -DYSINGER 345_ND1

Mon 09/26/2022 to Fri 09/30/2022
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2650 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3150 MW

EGRDNCTY 345_138_AT1

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

EGRDNCTY 345_138_AT2

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SPRNBK -EGRDNCTR 345_Y49

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **775 MW**
Impacts Total Transfer Capability 725 MW
TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC						
Mon 10/03/2022	to	Fri 10/21/2022	UPDATED	by LI	01/07/2022	
1000	Continuous	1500				
Work scheduled by: LI					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	0 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	0 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	375 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2						
Mon 10/10/2022	to	Fri 10/14/2022	CANCELLED	by LI	01/13/2022	
0600	Continuous	1600				
Work scheduled by: LI					SCH - PJM_NEPTUNE	375 MW
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
EDIC_-N.SCTLND_345_14						
Mon 10/10/2022	to	Mon 10/31/2022				
0700	Continuous	1530				
Work scheduled by: NYPA					CENTRAL EAST - VC	1670 MW
					Impacts Total Transfer Capability	1305 MW
					TTC with All Lines In Service	2975 MW
EDIC_-N.SCTLND_345_14 & PORTER_-ROTTDAM_230_30						
Mon 10/10/2022	to	Mon 10/31/2022				
0700		1530				
Work scheduled by:					CENTRAL EAST - VC	1500 MW
					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC ___ -N.SCTLND_345_14 & PORTER ___ -ROTTDAM_230_31				FWD (Import) CENTRAL EAST - VC 1500 MW Impacts Total Transfer Capability 1475 MW TTC with All Lines In Service 2975 MW
Mon 10/10/2022	to	Mon 10/31/2022		
0700		1530		
Work scheduled by:				
GILBOA ___ -N.SCTLND_345_GNS-1				FWD (Import) CENTRAL EAST - VC 2520 MW Impacts Total Transfer Capability 455 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID 12/29/2021
0500	Continuous	1900		
Work scheduled by: NGrid				
LEEDS ___ 345KV_R94301				FWD (Import) UPNY CONED 3800 MW Impacts Total Transfer Capability 4015 MW TTC with All Lines In Service 7815 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID 12/29/2021
0500	Continuous	1900		
Work scheduled by: NGrid				
MARCY ___ -N.SCTLND_345_18				FWD (Import) CENTRAL EAST - VC 1470 MW Impacts Total Transfer Capability 1505 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID 12/29/2021
0500	Continuous	1900		
Work scheduled by: NGrid				ARR: 19
N.SCTLND-LEEDS ___ 345_94				FWD (Import) CENTRAL EAST - VC 2650 MW Impacts Total Transfer Capability 325 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID 12/29/2021
0500	Continuous	1900		
Work scheduled by: NGrid				
PORTER ___ -ROTTDAM_230_30 & MARCY ___ -N.SCTLND_345_18				FWD (Import) CENTRAL EAST - VC 1300 MW Impacts Total Transfer Capability 1675 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022		
0500		1900		
Work scheduled by:				
PORTER ___ -ROTTDAM_230_31 & MARCY ___ -N.SCTLND_345_18				FWD (Import) CENTRAL EAST - VC 1300 MW Impacts Total Transfer Capability 1675 MW TTC with All Lines In Service 2975 MW
Tue 11/01/2022	to	Tue 12/06/2022		
0500		1900		
Work scheduled by:				

NYISO TRANSFER LIMITATIONS

Saturday ,January 15, 2022 to Monday ,July 17, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Wed 11/30/2022 to Wed 03/01/2023
 0700 Continuous 1100

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER 345_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 UPDATED by NYPA 12/30/2021
 0700 Continuous 1730

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/01/2023 to Fri 05/05/2023
 0600 Continuous 1800

Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW