

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402					FWD	
Mon 01/15/2018	to	Sun 07/31/2022	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/04/2022</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY 2050 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD	REV
Mon 01/15/2018	to	Sun 07/31/2022				(Import) (Export)
0001		2359				SCH - PJ - NY 2000 MW 1150 MW
Work scheduled by:					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
MARION_-FARRAGUT_345_C3403					FWD	
Mon 01/15/2018	to	Sun 07/31/2022	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/04/2022</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY 2050 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
STLAWRNC-MOSES_230_L33P						
Mon 04/30/2018	to	Mon 07/25/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>11/04/2021</u>	
0456	Continuous	0800				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
NEWBRDGE_345_138_BK_1					FWD	
Wed 09/02/2020	to	Mon 08/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>12/10/2021</u>	(Import)
1807	Continuous	2359				SCH - PJM_NEPTUNE 375 MW
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
BECK_-NIAGARA_345_PA301					FWD	REV
Wed 02/09/2022	to	Fri 06/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/29/2022</u>	(Import) (Export)
0700	Continuous	1700				SCH - OH - NY 900 MW 800 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	1050 MW 900 MW
					TTC with All Lines In Service	1950 MW 1700 MW
MOSES_-ADIRNDCK_230_MAL					FWD	
Mon 02/28/2022	to	Sat 05/14/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/28/2022</u>	(Import)
0700	Continuous	1300				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS _____ 345_2					FWD		
Tue 03/08/2022	to	Fri 06/03/2022	UPDATED	by NGRID	05/02/2022	(Import)	
0700	Continuous	1900				750 MW	
Work scheduled by: NGrid					SCH - NE - NY	Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	1400 MW	
N. SCTLND-ALPS _____ 345_2					FWD	REV	
Tue 03/08/2022	to	Fri 06/03/2022	UPDATED	by NGRID	05/02/2022	(Import) (Export)	
0700	Continuous	1900				100 MW	100 MW
Work scheduled by: NGrid					SCH - NPX_1385	Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW	200 MW
EGRDNCTY_345_138_AT1					FWD		
Sat 03/12/2022	to	Wed 05/25/2022	EXT FORCE	by CE	05/04/2022	(Import)	
2148	Continuous	2359				1250 MW	
Work scheduled by: ConEd					CONED - LIPA	Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW	
EGRDNCTY_345_138_AT2					FWD		
Sat 03/12/2022	to	Wed 05/25/2022	EXT FORCE	by CE	05/04/2022	(Import)	
2148	Continuous	2359				1250 MW	
Work scheduled by: ConEd					CONED - LIPA	Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW	
SPRNBRK_-EGRDNCTR_345_Y49					FWD		
Sat 03/12/2022	to	Wed 05/25/2022	EXT FORCE	by CE	05/04/2022	(Import)	
2148	Continuous	2359				775 MW	
Work scheduled by: ConEd					CONED - LIPA	Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW	
W49TH_ST_345KV_6					FWD		
Mon 03/21/2022	to	Sat 06/11/2022	EXT FORCE	by CE	05/02/2022	(Import)	
0809	Continuous	2359				300 MW	
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW	
W49TH_ST_345KV_8					FWD		
Mon 03/21/2022	to	Sat 06/11/2022	EXT FORCE	by CE	05/02/2022	(Import)	
0811	Continuous	2359				450 MW	
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability	210 MW
					TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Fri 04/01/2022 to Tue 12/31/2030 **EXTENDED** by NYSEG 04/06/2022
 0500 Continuous 2359
 Work scheduled by: NYSEG
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ATHENS_-PLSNTVLY_345_91

Mon 04/18/2022 to Tue 05/24/2022 **EXTENDED** by CE 04/28/2022
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Mon 04/18/2022 to Tue 05/24/2022 **EXTENDED** by CE 04/28/2022
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

GOETHALS_345KV_5

Wed 04/20/2022 to Fri 05/20/2022
 0301 Continuous 0300
 Work scheduled by: ConEd
 STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN_-GOETHALS_230_A2253

Wed 04/20/2022 to Fri 05/20/2022
 0301 Continuous 0300
 Work scheduled by: ConEd
 FWD
 (Import)
 SCH - PJ - NY **2050 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 2250 MW

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Wed 04/20/2022 to Fri 05/20/2022
 0301 0300
 Work scheduled by:
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2000 MW 1150 MW**
 Impacts Total Transfer Capability 250 MW 100 MW
 TTC with All Lines In Service 2250 MW 1250 MW

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Wed 04/20/2022 to Fri 05/20/2022
 0301 0300
 Work scheduled by:
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2000 MW 1150 MW**
 Impacts Total Transfer Capability 250 MW 100 MW
 TTC with All Lines In Service 2250 MW 1250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Wed 04/20/2022 to Fri 05/20/2022
0301 to 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1150 MW
Impacts Total Transfer Capability	250 MW	100 MW
TTC with All Lines In Service	2250 MW	1250 MW

EDIC___-FRASER___345_EF24-40

Fri 04/22/2022 to Tue 06/14/2022 **UPDATED by NJYPA 04/19/2022**
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2275 MW
Impacts Total Transfer Capability	310 MW
TTC with All Lines In Service	2585 MW

GORDONRD-N.SCTLND_345_55

Wed 04/27/2022 to Wed 06/08/2022
1122 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	2045 MW
Impacts Total Transfer Capability	540 MW
TTC with All Lines In Service	2585 MW

GORDONRD-ROTTRDAM_230_30

Wed 04/27/2022 to Wed 06/15/2022
1122 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	2535 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2585 MW

EDIC___-GORDONRD_345_14

Wed 04/27/2022 to Tue 05/24/2022
1130 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	1695 MW
Impacts Total Transfer Capability	890 MW
TTC with All Lines In Service	2585 MW

EDIC___-GORDONRD_345_14 & GORDONRD-ROTTRDAM_230_30

Wed 04/27/2022 to Tue 05/24/2022
1130 to 0800

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	1645 MW
Impacts Total Transfer Capability	940 MW
TTC with All Lines In Service	2585 MW

EDIC___-GORDONRD_345_14 & GORDONRD-ROTTRDAM_230_31

Wed 04/27/2022 to Tue 05/24/2022
1130 to 0800

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	1645 MW
Impacts Total Transfer Capability	940 MW
TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GORDONRD-ROTTRDAM_230_30 & GORDONRD-ROTTRDAM_230_31

Wed 04/27/2022 to Tue 05/24/2022
1130 to 0800

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2585 MW

GORDONRD-ROTTRDAM_230_31

Wed 04/27/2022 to Tue 05/24/2022
1130 Continuous to 0800

Work scheduled by: NYISO

FWD

(Import)

CENTRAL EAST - VC **2535 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2585 MW

ROTTRDAM-EASTOVER_230_38

Thu 04/28/2022 to Fri 05/06/2022 EXTENDED by NGRID 05/03/2022
0900 Continuous to 1600

Work scheduled by: NGrid

ARR: 77

REV

(Export)

SCH - NE - NY **1400 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1600 MW

SCH-IMO-NYISO_LIMIT_500

Sun 05/01/2022 to Fri 06/17/2022 UPDATED by NYISO 04/29/2022
0001 Continuous to 1700

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY **800 MW**
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 1950 MW

SCH-IMO-NYISO_LIMIT_1400

Sun 05/01/2022 to Mon 07/25/2022
0001 Continuous to 0800

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY **1700 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1950 MW

SCH-IMO-NYISO_LIMIT_1600

Sun 05/01/2022 to Mon 07/25/2022
0001 Continuous to 0800

Work scheduled by: IESO

FWD

(Import)

SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1950 MW

SCH-NYISO-IMO_LIMIT_1200

Sun 05/01/2022 to Mon 07/25/2022
0001 Continuous to 0800

Work scheduled by: IESO

REV

(Export)

SCH - OH - NY **1500 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1400				REV
Sun 05/01/2022	to	Mon 07/25/2022		(Export)
0001	Continuous	0800	SCH - OH - NY	1700 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 1700 MW
CHAT_DC_GC2				FWD
Sun 05/01/2022	to	Sat 06/04/2022		(Import)
0500	Continuous	2200	MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC2				REV
Sun 05/01/2022	to	Sat 06/04/2022		(Export)
0500	Continuous	2200	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
SCH-NYISO-HQ_LIMIT_500				REV
Sun 05/01/2022	to	Sat 06/04/2022		(Export)
0500	Continuous	2200	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
SCH-HQ_CEDARS-NYISO_LIMIT_220				FWD
Mon 05/02/2022	to	Fri 05/20/2022		(Import)
0200	Continuous	0200	SCH - HQ_CEDARS	220 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 270 MW
ROCHESTR-PANNELL_345_RP2				FWD
Mon 05/02/2022	to	Fri 05/06/2022		(Import)
0500	Continuous	1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 3200 MW
SCH-NYISO-NE_LIMIT_1200				REV
Mon 05/02/2022	to	Fri 05/13/2022	UPDATED by ISONE 05/05/2022	(Export)
0600	Continuous	1800	SCH - NE - NY	1400 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1					FWD	
Tue 05/03/2022	to	Fri 05/06/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>04/28/2022</u>	(Import)
0700	Continuous	1500				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1						REV
Tue 05/03/2022	to	Fri 05/06/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>04/28/2022</u>	(Export)
0700	Continuous	1500				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Tue 05/03/2022	to	Fri 05/06/2022				(Import)
0700		1500				MOSES SOUTH 2550 MW
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	REV
Tue 05/03/2022	to	Fri 05/06/2022				(Import) (Export)
0700		1500				SCH - HQ - NY 1370 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
CHATGUAY-MASSENA__765_7040					FWD	
Tue 05/03/2022	to	Fri 05/06/2022				(Import)
0700	Continuous	1530				MOSES SOUTH 1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040					FWD	REV
Tue 05/03/2022	to	Fri 05/06/2022				(Import) (Export)
0700	Continuous	1530				SCH - HQ - NY 0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
SCH-HQ_CEDARS-NYISO_LIMIT_160					FWD	
Thu 05/05/2022	to	Fri 05/06/2022	<u>UPDATED</u>	<u>by NYIOS</u>	<u>05/03/2022</u>	(Import)
0001	Continuous	1600				SCH - HQ_CEDARS 160 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	270 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79						FWD
Thu 05/05/2022	to	Mon 05/09/2022	<u>UPDATED</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
SCH-NYISO-PJM_LIMIT_500						REV
Mon 05/09/2022	to	Fri 05/20/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/07/2022</u>	(Export)
0001	Continuous	1700				SCH - PJ - NY 800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 1250 MW
BUCHAN_N-EASTVIEW_345_W93						FWD
Mon 05/09/2022	to	Mon 05/09/2022	<u>UPDATED</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)
0130	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
SPRNBK_-TREMONT__345_X28						FWD
Mon 05/09/2022	to	Sat 05/14/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/03/2022</u>	(Import)
0201	Continuous	0300				SPR/DUN-SOUTH 4200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 400 MW
						TTC with All Lines In Service 4600 MW
E13THSTA-FARRAGUT_345_46						FWD
Mon 05/09/2022	to	Tue 05/24/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/10/2022</u>	(Import)
0301	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
SCH-HQ_CEDARS-NYISO_LIMIT_20						FWD
Mon 05/09/2022	to	Fri 05/13/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>05/02/2022</u>	(Import)
0800	Continuous	1630				SCH - HQ_CEDARS 20 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 270 MW
FRASER__345_FRASER SVC						FWD
Mon 05/09/2022	to	Fri 05/13/2022	<u>CANCELLED</u>	<u>by NYSEG</u>	<u>05/09/2022</u>	(Import)
0800	Continuous	1700				CENTRAL EAST - VC 2550 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 35 MW
						TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-LADENTWN_345_W72					FWD	
Tue 05/10/2022	to	Wed 05/11/2022	UPDATED	by CE	02/23/2022	(Import)
0700	Continuous	1900				UPNY CONED 4400 MW
Work scheduled by: ORU					Impacts Total Transfer Capability 3415 MW	
					TTC with All Lines In Service 7815 MW	
SAND_BAR-PLATSBRG_115_PV20						
Thu 05/12/2022	to	Tue 05/17/2022	UPDATED	by NYISO	05/09/2022	SCH - NE - NY
0700	Continuous	1730				Impacts Total Transfer Capability
Work scheduled by: NYPA					TTC with All Lines In Service	
SCH-NE-NYISO_LIMIT_400					FWD	
Thu 05/12/2022	to	Tue 05/17/2022	UPDATED	by NYISO	05/09/2022	(Import)
0700	Continuous	1730				SCH - NE - NY 600 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 1400 MW	
SCH-NYISO-NE_LIMIT_1300					REV	
Thu 05/12/2022	to	Tue 05/17/2022	UPDATED	by NYISO	05/09/2022	(Export)
0700	Continuous	1730				SCH - NE - NY 1500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 100 MW	
					TTC with All Lines In Service 1600 MW	
SCRIBA__-VOLNEY__345_21					FWD	
Thu 05/12/2022	to	Fri 05/13/2022	FORCED	by NGRID	05/10/2022	(Import)
1800	Daily(No Weekends)	0400				OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW	
					TTC with All Lines In Service 5250 MW	
EFISHKIL-WOOD_ST_345_F38					FWD	
Thu 05/12/2022	to	Sun 05/15/2022				(Import)
2100	Continuous	0300				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLE-DUNWODIE_345_W89					FWD	
Thu 05/12/2022	to	Sun 05/15/2022				(Import)
2100	Continuous	0300				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y86

Thu 05/12/2022 to Sun 05/15/2022
 2100 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7210 MW**
 Impacts Total Transfer Capability 605 MW
 TTC with All Lines In Service 7815 MW

SCH-NYISO-NE_LIMIT_1200

Mon 05/16/2022 to Tue 05/17/2022
 0600 Continuous 1800
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **1400 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1600 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/16/2022 to Sat 05/21/2022 **UPDATED by LI 02/10/2022**
 0600 Continuous 2000
 Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW

MOSES_-ADIRNDCK_230_MA2

Mon 05/16/2022 to Wed 05/25/2022 **UPDATED by NYPA 05/04/2022**
 0700 Continuous 1930
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

HOMR_NYW-PIERC_NY_345_48

Mon 05/16/2022 to Fri 05/20/2022
 0800 Continuous 1500
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

DENNISON-ROSEMNTA_115_1/11

Mon 05/16/2022 to Fri 05/20/2022
 0800 Continuous 1630
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **95 MW 40 MW**
 Impacts Total Transfer Capability 175 MW 60 MW
 TTC with All Lines In Service 270 MW 100 MW

W49TH_ST-E13THSTA_345_M55

Tue 05/17/2022 to Mon 05/23/2022 **UPDATED by CONED 05/10/2022**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71

Wed 05/18/2022 to Fri 05/20/2022
0001 Continuous 0200

UPDATED by CONED 05/10/2022

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_3

Wed 05/18/2022 to Fri 05/20/2022
0001 Continuous 0200

UPDATED by CONED 05/10/2022

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Wed 05/18/2022 to Fri 05/20/2022
0001 Continuous 0200

UPDATED by CONED 05/10/2022

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Wed 05/18/2022 to Sat 05/21/2022
0001 2200

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

SCH-NE-NYISO_LIMIT_100

Wed 05/18/2022 to Sat 05/21/2022
0001 Continuous 2200

UPDATED by NYISO 05/09/2022

Work scheduled by: ConEd

FWD
(Import)
SCH - NE - NY **300 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 1400 MW

MOTTHAVN-RAINEY_345_Q11

Sat 05/21/2022 to Tue 05/24/2022
0001 Continuous 0200

CANCELLED by ConEd 05/09/2022

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MARCY-EDIC_345_UE1-7

Sat 05/21/2022 to Sun 05/22/2022
0500 Continuous 1730

UPDATED by NYPA 04/07/2022

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -MARCY 345_19					FWD
Sat 05/21/2022	to	Sun 05/22/2022	UPDATED	by NYPA	04/07/2022
0500	Continuous	1730			
Work scheduled by: NYPA					ARR: 19
					CENTRAL EAST - VC 2475 MW
					Impacts Total Transfer Capability 110 MW
					TTC with All Lines In Service 2585 MW
VOLNEY -MARCY 345_19					FWD
Sat 05/21/2022	to	Sun 05/22/2022	UPDATED	by NYPA	04/07/2022
0500	Continuous	1730			
Work scheduled by: NYPA					ARR: 19
					OSWEGO EXPORT 4900 MW
					Impacts Total Transfer Capability 350 MW
					TTC with All Lines In Service 5250 MW
VOLNEY -MARCY 345_19 & GORDONRD-ROTTRDAM 230_30					FWD
Sat 05/21/2022	to	Sun 05/22/2022			
0500		1730			
Work scheduled by:					ARR: 19
					CENTRAL EAST - VC 2425 MW
					Impacts Total Transfer Capability 160 MW
					TTC with All Lines In Service 2585 MW
VOLNEY -MARCY 345_19 & GORDONRD-ROTTRDAM 230_31					FWD
Sat 05/21/2022	to	Sun 05/22/2022			
0500		1730			
Work scheduled by:					ARR: 19
					CENTRAL EAST - VC 2425 MW
					Impacts Total Transfer Capability 160 MW
					TTC with All Lines In Service 2585 MW
PLSNTVLY-WOOD_ST 345_F31					FWD
Sun 05/22/2022	to	Tue 05/24/2022	UPDATED	by CONED	04/28/2022
0001	Continuous	2200			
Work scheduled by: ConEd					
					UPNY CONED 4000 MW
					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
MOTTHAVN-RAINEY 345_Q12					FWD
Tue 05/24/2022	to	Sat 05/28/2022			
0201	Continuous	0200			
Work scheduled by: ConEd					
					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
CRICKVLY-PLSNTVLY 345_F84					FWD
Wed 05/25/2022	to	Fri 05/27/2022	UPDATED	by CE	04/28/2022
0001	Continuous	2200			
Work scheduled by: ConEd					
					SCH - NE - NY 350 MW
					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
CRICKVLY-PLSNTVLY_345_F84							
Wed 05/25/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/28/2022</u>		
0001	Continuous	2200				SCH - NPX_1385	100 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
BUCHAN_S-MILLWOOD_345_W97							
Fri 05/27/2022	to	Sat 05/28/2022					FWD
0001	Continuous	0200				UPNY CONED	7680 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	135 MW
						TTC with All Lines In Service	7815 MW
MARCY__-EDIC____345_UE1-7							
Sat 05/28/2022	to	Sun 05/29/2022					FWD
0600	Continuous	1830				OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
ARR: 19&16							
DUNWODIE_345KV_3							
Sun 05/29/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/12/2022</u>		FWD
0201	Continuous	1800				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_4							
Sun 05/29/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/12/2022</u>		FWD
0201	Continuous	1800				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W89							
Sun 05/29/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/12/2022</u>		FWD
0201	Continuous	1800				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	3815 MW
						TTC with All Lines In Service	7815 MW
MOSES__-ADIRNDCK_230_MA2							
Tue 05/31/2022	to	Thu 09/15/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/04/2022</u>		FWD
0500	Continuous	1930				MOSES SOUTH	2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PIERCBRK-FIVEMILE_345_37

Tue 05/31/2022 to Wed 06/01/2022
 0730 Continuous 1600
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-NE-NYISO_LIMIT_300

Wed 06/01/2022 to Wed 06/08/2022
 0700 Continuous 1600
 Work scheduled by: ISONE

UPDATED by ISONE 03/04/2022

FWD
 (Import)
 SCH - NE - NY **500 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Wed 06/01/2022 to Wed 06/08/2022
 0700 Continuous 1600
 Work scheduled by: ISONE

UPDATED by ISONE 03/04/2022

REV
 (Export)
 SCH - NE - NY **1100 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1600 MW

ADIRNDCK-PORTER_230_12

Wed 06/01/2022 to Tue 11/15/2022
 0700 Continuous 1700
 Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

HUDSONTP-W49TH_ST_345_Y56

Sat 06/04/2022 to Sun 06/05/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sat 06/04/2022 to Sun 06/05/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

EASTVIEW-SPRNBK_345_W64

Sat 06/04/2022 to Mon 06/06/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Sat 06/04/2022 to Mon 06/06/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS5

Sat 06/04/2022 to Mon 06/06/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FROST_BR-LONG_MTN_345_352

Thu 06/09/2022 to Sat 06/18/2022 **UPDATED by ISONE 03/04/2022**
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **1150 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_200

Thu 06/09/2022 to Sat 06/18/2022 **UPDATED by ISONE 03/04/2022**
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **400 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 1400 MW

NIAGARA_-DYSINGER_345_ND1

Mon 06/13/2022 to Fri 06/17/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2700 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3200 MW

OAKDALE_-FRASER_345_32

Wed 06/15/2022 to Fri 06/17/2022
 0800 Continuous 1600
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2450 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 2585 MW

MARCY_-EDIC_345_UE1-7

Sat 06/18/2022 to Sun 06/19/2022
 0600 Continuous 1830
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-PACKARD__230_62

Mon 06/20/2022 to Sun 06/26/2022
0500 Continuous 1700

UPDATED by NYPA 04/19/2022

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	700 MW	1550 MW
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

SAND_BAR-PLATSBURG_115_PV20

Tue 06/21/2022 to Thu 06/23/2022
0700 Continuous 1730

Work scheduled by: NYPA

SCH - NE - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

SCH-NE-NYISO_LIMIT_400

Tue 06/21/2022 to Thu 06/23/2022
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
SCH - NE - NY	600 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1400 MW

SCH-NYISO-NE_LIMIT_1300

Tue 06/21/2022 to Thu 06/23/2022
0700 Continuous 1730

Work scheduled by: NYPA

	REV
	(Export)
SCH - NE - NY	1500 MW
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1600 MW

FRASER_-GILBOA__345_GF5-35

Tue 06/21/2022 to Sun 06/26/2022
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2450 MW
Impacts Total Transfer Capability	135 MW
TTC with All Lines In Service	2585 MW

BEAR SWP-EASTOVER_230_E205W

Mon 06/27/2022 to Tue 06/28/2022
0700 Continuous 0759

Work scheduled by: ISONE

SCH - NE - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

NIAGARA__345_230_AT4

Tue 06/28/2022 to Wed 06/29/2022
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BEAR SWP-EASTOVER_230_E205W

Tue 06/28/2022 to Tue 06/28/2022
 0800 Daily(No Weekends) 1500
 Work scheduled by: NGrid

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

BEAR SWP-EASTOVER_230_E205W

Tue 06/28/2022 to Thu 06/30/2022
 1501 Continuous 1700
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

BECK -NIAGARA_230_PA27

Tue 07/05/2022 to Sat 07/09/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NIAGARA -DYSINGER_345_ND1

Mon 07/11/2022 to Fri 07/15/2022
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2700 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3200 MW

HURLYAVE-ROSETON_345_303

Mon 07/11/2022 to Fri 07/22/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

02/14/2022

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

ROCHESTR-PANNELL_345_RP1

Mon 07/25/2022 to Fri 07/29/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 3200 MW

FRASANX-COOPERS_345_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022
 0700 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2275 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 2585 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -FRASANNX_345_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 2585 MW

NIAGARA -DYSINGER_345_ND2

Mon 08/01/2022 to Fri 08/05/2022
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

MARCY -EDIC_345_UE1-7

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

VOLNEY -MARC_345_19

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2475 MW**
Impacts Total Transfer Capability 110 MW
TTC with All Lines In Service 2585 MW

VOLNEY -MARC_345_19

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASANNX-COOPERS_345_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 2585 MW

MARCY -FRASANNX_345_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBURG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROSETON_-ROCKTVRN_345_311

Mon 08/29/2022 to Fri 09/09/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 3415 MW
 TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY___345_Q12

Thu 09/01/2022 to Mon 09/05/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FRASER_-GILBOA___345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2450 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 2585 MW

MOSES_-ADIRNDCK_230_MA2

Thu 09/15/2022 to Tue 11/29/2022 **UPDATED by NYPA 05/04/2022**
 1931 Continuous 1800
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MARCY_-EDIC___345_UE1-7

Mon 09/19/2022 to Sat 10/08/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

LEEDS_-HURLYAVE_345_301

Mon 09/19/2022 to Fri 10/21/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

10/04/2021

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
EGRDNCTY_345_138_AT2					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
SPRNBK_-EGRDNCTR_345_Y49					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 775 MW
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
CLRKSCRN-OAKDALE_345_36					FWD	
Mon 10/03/2022	to	Fri 10/07/2022	<u>UPDATED</u>	<u>by NYSEG</u>	<u>04/20/2022</u>	(Import)
0830	Continuous	1530				CENTRAL EAST - VC 2450 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	2585 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>	(Import) (Export)
1000	Continuous	1500				SCH - NPX_CSC 0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
EDIC_-GORDONRD_345_14					FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)
0700	Continuous	1530				CENTRAL EAST - VC 1695 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	890 MW
					TTC with All Lines In Service	2585 MW
NIAGARA_-DYSINGER_345_ND1					FWD	
Mon 10/17/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/10/2022</u>	(Import)
0500	Continuous	1700				DYSINGER EAST 2700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	3200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1

Mon 10/24/2022 to Fri 10/28/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON__345_303

Mon 10/24/2022 to Fri 11/04/2022
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 04/13/2022

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

MAINESBG-WATRCURE_345_30

Tue 10/25/2022 to Tue 10/25/2022
0800 Daily 1500

Work scheduled by: NYSEG

FWD
(Import)
SCH - PJ - NY **2200 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2250 MW

WATRCURE-OAKDALE__345_31

Thu 10/27/2022 to Thu 10/27/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY_____345_2

Mon 10/31/2022 to Fri 11/04/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CLAY_-EDIC_____345_1-16

Tue 11/01/2022 to Thu 11/03/2022
0600 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 05/09/2022

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501				FWD	
Tue 11/01/2022	to	Sat 11/19/2022		(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1				FWD	
Tue 11/01/2022	to	Sat 11/19/2022		(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2				FWD	
Tue 11/01/2022	to	Sat 11/19/2022		(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
GILBOA__-N.SCTLND_345_GNS-1				FWD	
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID	12/29/2021
0700	Continuous	1900		CENTRAL EAST - VC	2300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	2585 MW
LEEDS___345KV_R94301				FWD	
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID	12/29/2021
0700	Continuous	1900		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
MARCY___-N.SCTLND_345_18				FWD	
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID	12/29/2021
0700	Continuous	1900		CENTRAL EAST - VC	1400 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1185 MW
				TTC with All Lines In Service	2585 MW
LINDN_CG-LNDVFT___345_V-3022				FWD	REV
Tue 11/01/2022	to	Fri 11/04/2022		(Import)	(Export)
0800	Continuous	1500		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS -HURLYAVE_345_301

Mon 11/07/2022 to Fri 12/09/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

MOSES -ADIRNDCK_230_MAI

Wed 11/30/2022 to Wed 03/01/2023
 0700 Continuous 1100
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

CLAY -EDIC_345_1-16

Fri 12/30/2022 to Sat 12/31/2022 **UPDATED by NGRID 05/09/2022**
 0600 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

FRASER_345_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2550 MW**
 Impacts Total Transfer Capability 35 MW
 TTC with All Lines In Service 2585 MW

PLSNTVLY_345KV_RNS4

Sat 04/01/2023 to Sat 04/01/2023
 0700 Continuous 0730
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

ATHENS -PLSNTVLY_345_91

Sat 04/01/2023 to Sat 04/15/2023
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Sat 04/15/2023 to Sat 04/15/2023
 1830 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Sun 04/16/2023 to Sun 04/16/2023
0700 Continuous 0730

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

LEEDS__-PLSNTVLY_345_92

Sun 04/16/2023 to Sun 04/30/2023
0700 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Sun 04/30/2023 to Sun 04/30/2023
1830 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/01/2023 to Fri 05/05/2023
0600 Continuous 1800

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/06/2023
0600 Continuous 1800

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/09/2023 to Fri 10/13/2023
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, May 11, 2022 to Friday, November 10, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600

Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600

Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW