

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	
Mon 01/15/2018	to	Sun 07/31/2022	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/04/2022</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Sun 07/31/2022				(Import) (Export)
0001		2359				SCH - PJ - NY <b>2000 MW 1150 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	250 MW 100 MW
					TTC with All Lines In Service	2250 MW 1250 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Sun 07/31/2022	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/04/2022</u>	(Import)
0001	Continuous	2359				SCH - PJ - NY <b>2050 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2250 MW
<b>STLAWRNC-MOSES_230_L33P</b>						
Mon 04/30/2018	to	Mon 07/25/2022	<u>EXT FORCE</u>	<u>by IESO</u>	<u>11/04/2021</u>	
0456	Continuous	0800				SCH - OH - NY
Work scheduled by: IESO					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
<b>NEWBRDGE_345_138_BK_1</b>					FWD	
Wed 09/02/2020	to	Mon 08/01/2022	<u>EXT FORCE</u>	<u>by LI</u>	<u>12/10/2021</u>	(Import)
1807	Continuous	2359				SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>BECK_-NIAGARA_345_PA301</b>					FWD	REV
Wed 02/09/2022	to	Fri 06/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/29/2022</u>	(Import) (Export)
0700	Continuous	1700				SCH - OH - NY <b>900 MW 800 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability	1050 MW 900 MW
					TTC with All Lines In Service	1950 MW 1700 MW
<b>MOSES_-ADIRNDCK_230_MAL</b>					FWD	
Mon 02/28/2022	to	Sat 05/14/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/28/2022</u>	(Import)
0700	Continuous	1300				MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-ALPS_____345_2</b>					FWD		
Tue 03/08/2022	to	Fri 06/03/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/02/2022</u>	(Import)	
0700	Continuous	1900				SCH - NE - NY	<b>750 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	650 MW	
					TTC with All Lines In Service	1400 MW	
<b>N. SCTLND-ALPS_____345_2</b>					FWD	REV	
Tue 03/08/2022	to	Fri 06/03/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/02/2022</u>	(Import) (Export)	
0700	Continuous	1900				SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD		
Sat 03/12/2022	to	Wed 05/25/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				CONED - LIPA	<b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>EGRDNCTY_345_138_AT2</b>					FWD		
Sat 03/12/2022	to	Wed 05/25/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				CONED - LIPA	<b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>SPRNBK_-EGRDNCTR_345_Y49</b>					FWD		
Sat 03/12/2022	to	Wed 05/25/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				CONED - LIPA	<b>775 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	725 MW	
					TTC with All Lines In Service	1500 MW	
<b>W49TH_ST_345KV_6</b>					FWD		
Mon 03/21/2022	to	Sat 06/11/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)	
0809	Continuous	2359				SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW	
					TTC with All Lines In Service	660 MW	
<b>W49TH_ST_345KV_8</b>					FWD		
Mon 03/21/2022	to	Sat 06/11/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)	
0811	Continuous	2359				SCH - PJM_HTP	<b>450 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	210 MW	
					TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FIVEMILE-STOLLERD\_345\_29**

Fri 04/01/2022 to Tue 12/31/2030  
0500 Continuous 2359

**EXTENDED by NYSEG 04/06/2022**

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**ATHENS\_-PLSNTVLY\_345\_91**

Mon 04/18/2022 to Tue 05/24/2022  
0001 Continuous 2200

**EXTENDED by CE 04/28/2022**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS4**

Mon 04/18/2022 to Tue 05/24/2022  
0001 Continuous 2200

**EXTENDED by CE 04/28/2022**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**GOETHALS\_345KV\_5**

Wed 04/20/2022 to Fri 05/20/2022  
0301 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**LINDEN\_-GOETHALS\_230\_A2253**

Wed 04/20/2022 to Fri 05/20/2022  
0301 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

**LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402**

Wed 04/20/2022 to Fri 05/20/2022  
0301 0300

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2000 MW 1150 MW**  
Impacts Total Transfer Capability 250 MW 100 MW  
TTC with All Lines In Service 2250 MW 1250 MW

**LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Wed 04/20/2022 to Fri 05/20/2022  
0301 0300

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2000 MW 1150 MW**  
Impacts Total Transfer Capability 250 MW 100 MW  
TTC with All Lines In Service 2250 MW 1250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LINDEN\_\_-GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403**

Wed 04/20/2022 to Fri 05/20/2022  
0301 to 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	250 MW	100 MW
TTC with All Lines In Service	2250 MW	1250 MW

**EDIC\_\_\_-FRASER\_\_\_345\_EF24-40**

Fri 04/22/2022 to Thu 05/12/2022 **UPDATED by NJYPA 04/19/2022**  
0700 Continuous 1416

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2275 MW</b>
Impacts Total Transfer Capability	310 MW
TTC with All Lines In Service	2585 MW

**GORDONRD-N.SCTLND\_345\_55**

Wed 04/27/2022 to Wed 06/08/2022  
1122 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	<b>2045 MW</b>
Impacts Total Transfer Capability	540 MW
TTC with All Lines In Service	2585 MW

**GORDONRD-ROTTRDAM\_230\_30**

Wed 04/27/2022 to Wed 06/15/2022  
1122 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	<b>2535 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2585 MW

**EDIC\_\_\_-GORDONRD\_345\_14**

Wed 04/27/2022 to Tue 05/24/2022  
1130 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	<b>1695 MW</b>
Impacts Total Transfer Capability	890 MW
TTC with All Lines In Service	2585 MW

**EDIC\_\_\_-GORDONRD\_345\_14 & GORDONRD-ROTTRDAM\_230\_30**

Wed 04/27/2022 to Tue 05/24/2022  
1130 to 0800

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	<b>1645 MW</b>
Impacts Total Transfer Capability	940 MW
TTC with All Lines In Service	2585 MW

**EDIC\_\_\_-GORDONRD\_345\_14 & GORDONRD-ROTTRDAM\_230\_31**

Wed 04/27/2022 to Tue 05/24/2022  
1130 to 0800

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	<b>1645 MW</b>
Impacts Total Transfer Capability	940 MW
TTC with All Lines In Service	2585 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GORDONRD-ROTTRDAM\_230\_30 & GORDONRD-ROTTRDAM\_230\_31

Wed 04/27/2022 to Tue 05/24/2022  
1130 0800

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2485 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2585 MW

GORDONRD-ROTTRDAM\_230\_31

Wed 04/27/2022 to Tue 05/24/2022  
1130 Continuous 0800

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2535 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2585 MW

SCH-IMO-NYISO\_LIMIT\_500

Sun 05/01/2022 to Fri 06/17/2022 **UPDATED by NYISO 04/29/2022**  
0001 Continuous 1700

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **800 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 1950 MW

SCH-IMO-NYISO\_LIMIT\_1400

Sun 05/01/2022 to Mon 07/25/2022  
0001 Continuous 0800

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1700 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1950 MW

SCH-IMO-NYISO\_LIMIT\_1600

Sun 05/01/2022 to Mon 07/25/2022  
0001 Continuous 0800

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1950 MW

SCH-NYISO-IMO\_LIMIT\_1200

Sun 05/01/2022 to Mon 07/25/2022  
0001 Continuous 0800

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1500 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1700 MW

SCH-NYISO-IMO\_LIMIT\_1400

Sun 05/01/2022 to Mon 07/25/2022  
0001 Continuous 0800

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1700 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 1700 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>				FWD
Sun 05/01/2022	to	Sat 06/04/2022		(Import)
0500	Continuous	2200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>				REV
Sun 05/01/2022	to	Sat 06/04/2022		(Export)
0500	Continuous	2200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
<b>SCH-NYISO-HQ_LIMIT_500</b>				REV
Sun 05/01/2022	to	Sat 06/04/2022		(Export)
0500	Continuous	2200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_220</b>				FWD
Mon 05/02/2022	to	Fri 05/20/2022		(Import)
0200	Continuous	0200	SCH - HQ_CEDARS	<b>220 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 270 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>				REV
Mon 05/02/2022	to	Fri 05/13/2022	<b>UPDATED by ISONE 05/05/2022</b>	(Export)
0600	Continuous	1800	SCH - NE - NY	<b>1400 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1600 MW
<b>EASTVIEW-SPRNBK_345_W79</b>				FWD
Thu 05/05/2022	to	Mon 05/09/2022	<b>UPDATED by CE 05/02/2022</b>	(Import)
0001	Continuous	0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
<b>SCH-NYISO-PJM_LIMIT_500</b>				REV
Mon 05/09/2022	to	Fri 05/20/2022	<b>UPDATED by NYISO 05/07/2022</b>	(Export)
0001	Continuous	1700	SCH - PJ - NY	<b>800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 1250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Mon 05/09/2022	to	Mon 05/09/2022	<u>UPDATED</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)
0130	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
<b>SPRNBRK_-TREMONT_345_X28</b>					FWD	
Mon 05/09/2022	to	Sat 05/14/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/03/2022</u>	(Import)
0201	Continuous	0300				SPR/DUN-SOUTH <b>4200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	4600 MW
<b>E13THSTA-FARRAGUT_345_46</b>					FWD	
Mon 05/09/2022	to	Tue 05/24/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/10/2022</u>	(Import)
0301	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_20</b>					FWD	
Mon 05/09/2022	to	Thu 05/12/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>05/02/2022</u>	(Import)
0800	Continuous	1357				SCH - HQ_CEDARS <b>20 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	270 MW
<b>FRASER_345_FRASER SVC</b>					FWD	
Mon 05/09/2022	to	Fri 05/13/2022	<u>CANCELLED</u>	<u>by NYSEG</u>	<u>05/09/2022</u>	(Import)
0800	Continuous	1700				CENTRAL EAST - VC <b>2550 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	35 MW
					TTC with All Lines In Service	2585 MW
<b>RAMAPO_-LADENTWN_345_W72</b>					FWD	
Tue 05/10/2022	to	Wed 05/11/2022	<u>UPDATED</u>	<u>by CE</u>	<u>02/23/2022</u>	(Import)
0700	Continuous	1900				UPNY CONED <b>4400 MW</b>
Work scheduled by: ORU					Impacts Total Transfer Capability	3415 MW
					TTC with All Lines In Service	7815 MW
<b>SCH-NYISO-NE_LIMIT_1300</b>					REV	
Thu 05/12/2022	to	Fri 05/13/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/09/2022</u>	(Export)
0700	Continuous	2359				SCH - NE - NY <b>1500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Thu 05/12/2022 to Tue 05/17/2022 **UPDATED** by NYISO 05/09/2022  
 0700 Continuous 1730  
 Work scheduled by: NYPA  
 SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SCH-NE-NYISO\_LIMIT\_400**

Thu 05/12/2022 to Tue 05/17/2022 **UPDATED** by NYISO 05/09/2022  
 0700 Continuous 1730  
 Work scheduled by: NYPA  
 SCH - NE - NY  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 1400 MW

**SCRIBA\_-VOLNEY\_345\_21**

Thu 05/12/2022 to Fri 05/13/2022 **FORCED** by NGRID 05/10/2022  
 1800 Daily(No Weekends) 0400  
 Work scheduled by: NGrid  
 OSWEGO EXPORT  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**EFISHKIL-WOOD\_ST\_345\_F38**

Thu 05/12/2022 to Sun 05/15/2022  
 2100 Continuous 0300  
 Work scheduled by: ConEd  
 UPNY CONED  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Thu 05/12/2022 to Sun 05/15/2022  
 2100 Continuous 0300  
 Work scheduled by: ConEd  
 UPNY CONED  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

Thu 05/12/2022 to Sun 05/15/2022  
 2100 Continuous 0300  
 Work scheduled by: ConEd  
 UPNY CONED  
 Impacts Total Transfer Capability 605 MW  
 TTC with All Lines In Service 7815 MW

**SCH-NYISO-NE\_LIMIT\_1200**

Sat 05/14/2022 to Tue 05/17/2022 **UPDATED** by NYISO 05/09/2022  
 0001 Continuous 1730  
 Work scheduled by: NYPA  
 SCH - NE - NY  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1600 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Mon 05/16/2022 to Wed 05/25/2022  
0500 Continuous 1930

UPDATED by NYPA 05/04/2022

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**SCH-NYISO-NE\_LIMIT\_1200**

Mon 05/16/2022 to Tue 05/17/2022  
0600 Continuous 1800

CANCELLED by ISONE 05/12/2022

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1400 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1600 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 05/16/2022 to Sat 05/21/2022  
0600 Continuous 2000

UPDATED by LI 02/10/2022

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

**DENNISON-ROSEMNTA\_115\_1/11**

Mon 05/16/2022 to Fri 05/20/2022  
0800 Continuous 1630

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 175 MW 60 MW  
TTC with All Lines In Service 270 MW 100 MW

**W49TH\_ST-E13THSTA\_345\_M55**

Tue 05/17/2022 to Mon 05/23/2022  
0001 Continuous 0300

UPDATED by CONED 05/10/2022

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**HOMR\_NYW-PIERC\_NY\_345\_48**

Tue 05/17/2022 to Sat 05/21/2022  
0800 Continuous 1500

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**DUNWODIE-MOTTHAVN\_345\_71**

Wed 05/18/2022 to Fri 05/20/2022  
0001 Continuous 0200

UPDATED by CONED 05/10/2022

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>					FWD	
Wed 05/18/2022	to	Fri 05/20/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/10/2022</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_5</b>					FWD	
Wed 05/18/2022	to	Fri 05/20/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/10/2022</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>					FWD	
Wed 05/18/2022	to	Sat 05/21/2022				(Import)
0001		2200				UPNY CONED <b>3800 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
<b>SCH-NE-NYISO_LIMIT_100</b>					FWD	
Wed 05/18/2022	to	Sat 05/21/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/09/2022</u>	(Import)
0001	Continuous	2200				SCH - NE - NY <b>300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	1400 MW
<b>MOTTHAVN-RAINEY___345_Q11</b>					FWD	
Sat 05/21/2022	to	Tue 05/24/2022	<u>CANCELLED</u>	<u>by ConEd</u>	<u>05/09/2022</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>MARCY___-EDIC___345_UE1-7</b>					FWD	
Sat 05/21/2022	to	Sun 05/22/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/07/2022</u>	(Import)
0500	Continuous	1730				OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>VOLNEY___-MARCYS___345_19</b>					FWD	
Sat 05/21/2022	to	Sun 05/22/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/07/2022</u>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC <b>2475 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	2585 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>VOLNEY__-MARCY__345_19</b>					FWD		
Sat 05/21/2022	to	Sun 05/22/2022	<b>UPDATED</b>	<b>by NYPA</b>	<b>04/07/2022</b>	(Import)	
0500	Continuous	1730				OSWEGO EXPORT <b>4900 MW</b>	
Work scheduled by: NYPA					<b>ARR: 19</b>	Impacts Total Transfer Capability 350 MW	
						TTC with All Lines In Service 5250 MW	
<b>VOLNEY__-MARCY__345_19 &amp; GORDONRD-ROTTRDAM_230_30</b>					FWD		
Sat 05/21/2022	to	Sun 05/22/2022				(Import)	
0500		1730				CENTRAL EAST - VC <b>2425 MW</b>	
Work scheduled by:					<b>ARR: 19</b>	Impacts Total Transfer Capability 160 MW	
						TTC with All Lines In Service 2585 MW	
<b>VOLNEY__-MARCY__345_19 &amp; GORDONRD-ROTTRDAM_230_31</b>					FWD		
Sat 05/21/2022	to	Sun 05/22/2022				(Import)	
0500		1730				CENTRAL EAST - VC <b>2425 MW</b>	
Work scheduled by:					<b>ARR: 19</b>	Impacts Total Transfer Capability 160 MW	
						TTC with All Lines In Service 2585 MW	
<b>PLSNTVLY-WOOD_ST__345_F31</b>					FWD		
Sun 05/22/2022	to	Tue 05/24/2022	<b>UPDATED</b>	<b>by CONED</b>	<b>04/28/2022</b>	(Import)	
0001	Continuous	2200				UPNY CONED <b>4000 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW	
						TTC with All Lines In Service 7815 MW	
<b>MOTTHAVN-RAINEY__345_Q12</b>					FWD		
Tue 05/24/2022	to	Sat 05/28/2022				(Import)	
0201	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW	
						TTC with All Lines In Service 4600 MW	
<b>CRICKVLY-PLSNTVLY_345_F84</b>					FWD		
Wed 05/25/2022	to	Fri 05/27/2022	<b>UPDATED</b>	<b>by CE</b>	<b>04/28/2022</b>	(Import)	
0001	Continuous	2200				SCH - NE - NY <b>350 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability 1050 MW	
						TTC with All Lines In Service 1400 MW	
<b>CRICKVLY-PLSNTVLY_345_F84</b>					FWD	REV	
Wed 05/25/2022	to	Fri 05/27/2022	<b>UPDATED</b>	<b>by CE</b>	<b>04/28/2022</b>	(Import)	(Export)
0001	Continuous	2200				SCH - NPX_1385 <b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 100 MW	100 MW
						TTC with All Lines In Service 200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN\_S-MILLWOOD\_345\_W97

Fri 05/27/2022 to Sat 05/28/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7680 MW**  
 Impacts Total Transfer Capability 135 MW  
 TTC with All Lines In Service 7815 MW

MARCY-EDIC\_345\_UE1-7

Sat 05/28/2022 to Sun 05/29/2022  
 0600 Continuous 1830  
 Work scheduled by: NYPA

ARR: 19&16

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

DUNWODIE\_345KV\_3

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022  
 0201 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_4

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022  
 0201 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE\_345\_W89

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022  
 0201 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

MOSES-ADIRNDCK\_230\_MA2

Tue 05/31/2022 to Thu 09/15/2022 UPDATED by NYPA 05/04/2022  
 0500 Continuous 1930  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

PIERCBRK-FIVEMILE\_345\_37

Tue 05/31/2022 to Wed 06/01/2022  
 0730 Continuous 1600  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_300</b>				FWD
Wed 06/01/2022	to	Wed 06/08/2022	<u>UPDATED</u> <u>by ISONE</u> <u>03/04/2022</u>	(Import)
0700	Continuous	1600		SCH - NE - NY <b>500 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 1400 MW
<b>SCH-NYISO-NE_LIMIT_900</b>				REV
Wed 06/01/2022	to	Wed 06/08/2022	<u>UPDATED</u> <u>by ISONE</u> <u>03/04/2022</u>	(Export)
0700	Continuous	1600		SCH - NE - NY <b>1100 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1600 MW
<b>ADIRNDCK-PORTER__230_12</b>				FWD
Wed 06/01/2022	to	Tue 11/15/2022		(Import)
0700	Continuous	1700		MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>				FWD
Sat 06/04/2022	to	Sun 06/05/2022		(Import)
0001	Continuous	0200		SCH - PJM_HTP <b>0 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
<b>W49TH_ST_345KV_7</b>				FWD
Sat 06/04/2022	to	Sun 06/05/2022		(Import)
0001	Continuous	0200		SCH - PJM_HTP <b>300 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 360 MW
				TTC with All Lines In Service 660 MW
<b>EASTVIEW-SPRNBRK__345_W64</b>				FWD
Sat 06/04/2022	to	Mon 06/06/2022		(Import)
0001	Continuous	0200		UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>				FWD
Sat 06/04/2022	to	Mon 06/06/2022		(Import)
0001	Continuous	0200		UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 265 MW
				TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>				FWD	
Sat 06/04/2022	to	Mon 06/06/2022		(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>FROST_BR-LONG_MTN_345_352</b>				FWD	
Thu 06/09/2022	to	Sat 06/18/2022	<u>UPDATED</u> <u>by ISONE</u> <u>03/04/2022</u>	(Import)	
0700	Continuous	1600	SCH - NE - NY	<b>1150 MW</b>	
Work scheduled by: ISONE				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_200</b>				FWD	
Thu 06/09/2022	to	Sat 06/18/2022	<u>UPDATED</u> <u>by ISONE</u> <u>03/04/2022</u>	(Import)	
0700	Continuous	1600	SCH - NE - NY	<b>400 MW</b>	
Work scheduled by: ISONE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1400 MW
<b>NIAGARA_-DYSINGER_345_ND1</b>				FWD	
Mon 06/13/2022	to	Fri 06/17/2022		(Import)	
0500	Continuous	2100	DYSINGER EAST	<b>2700 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	3200 MW
<b>OAKDALE_-FRASER__345_32</b>				FWD	
Wed 06/15/2022	to	Fri 06/17/2022		(Import)	
0800	Continuous	1600	CENTRAL EAST - VC	<b>2450 MW</b>	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	135 MW
				TTC with All Lines In Service	2585 MW
<b>MARCY_-EDIC__345_UE1-7</b>				FWD	
Sat 06/18/2022	to	Sun 06/19/2022		(Import)	
0600	Continuous	1830	OSWEGO EXPORT	<b>5250 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
<b>NIAGARA_-PACKARD__230_62</b>				FWD	REV
Mon 06/20/2022	to	Sun 06/26/2022	<u>UPDATED</u> <u>by NYPA</u> <u>04/19/2022</u>	(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	<b>700 MW</b>	<b>1550 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1250 MW 150 MW
				TTC with All Lines In Service	1950 MW 1700 MW

ARR: 19&16

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Tue 06/21/2022 to Thu 06/23/2022  
 0700 Continuous 1730  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**SCH-NE-NYISO\_LIMIT\_400**

Tue 06/21/2022 to Thu 06/23/2022  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 SCH - NE - NY **600 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1300**

Tue 06/21/2022 to Thu 06/23/2022  
 0700 Continuous 1730  
 Work scheduled by: NYPA

REV  
 (Export)  
 SCH - NE - NY **1500 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 1600 MW

**FRASER\_-GILBOA\_345\_GF5-35**

Tue 06/21/2022 to Sun 06/26/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2450 MW**  
 Impacts Total Transfer Capability 135 MW  
 TTC with All Lines In Service 2585 MW

**BEAR SWP-EASTOVER\_230\_E205W**

Mon 06/27/2022 to Tue 06/28/2022  
 0700 Continuous 0759  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA\_345\_230\_AT4**

Tue 06/28/2022 to Wed 06/29/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1900 MW 1400 MW**  
 Impacts Total Transfer Capability 50 MW 300 MW  
 TTC with All Lines In Service 1950 MW 1700 MW

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Tue 06/28/2022  
 0800 Daily(No Weekends) 1500  
 Work scheduled by: NGrid

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Thu 06/30/2022  
 1501 Continuous 1700  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**BECK -NIAGARA\_230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**NIAGARA -DYSINGER\_345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2700 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3200 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 07/11/2022 to Fri 07/22/2022  
 0800 Continuous 1600  
 Work scheduled by: CHGE

**02/14/2022**

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 3715 MW  
 TTC with All Lines In Service 7815 MW

**ROCHESTR-PANNELL\_345\_RP1**

Mon 07/25/2022 to Fri 07/29/2022  
 0500 Continuous 2100  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 3200 MW

**FRASANX-COOPERS\_345\_UCC2-41**

Mon 07/25/2022 to Fri 08/05/2022  
 0700 Continuous 1700  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2275 MW**  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 2585 MW

**MARCY -FRASANX\_345\_UCC2-41**

Mon 07/25/2022 to Fri 08/05/2022  
 0700 Continuous 1700  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2275 MW**  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 2585 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NIAGARA\_-DYSINGER\_345\_ND2**

Mon 08/01/2022 to Fri 08/05/2022  
 0500 Continuous 1700

Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2700 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3200 MW

-----  
**MARCY\_-EDIC\_345\_UE1-7**

Sat 08/06/2022 to Sun 08/07/2022  
 0500 Continuous 1830

Work scheduled by: NYPA

**UPDATED by NYPA 04/07/2022**

**ARR: 19&16**

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

-----  
**VOLNEY\_-MARCY\_345\_19**

Sat 08/06/2022 to Sun 08/07/2022  
 0500 Continuous 1830

Work scheduled by: NYPA

**UPDATED by NYPA 04/07/2022**

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2475 MW**  
 Impacts Total Transfer Capability 110 MW  
 TTC with All Lines In Service 2585 MW

-----  
**VOLNEY\_-MARCY\_345\_19**

Sat 08/06/2022 to Sun 08/07/2022  
 0500 Continuous 1830

Work scheduled by: NYPA

**UPDATED by NYPA 04/07/2022**

**ARR: 19**

FWD  
 (Import)  
 OSWEGO EXPORT **4900 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 5250 MW

-----  
**FRASANX-COOPERS\_345\_UCC2-41**

Mon 08/08/2022 to Fri 09/09/2022  
 0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2275 MW**  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 2585 MW

-----  
**MARCY\_-FRASANX\_345\_UCC2-41**

Mon 08/08/2022 to Fri 09/09/2022  
 0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2275 MW**  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 2585 MW

-----  
**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 08/22/2022 to Fri 08/26/2022  
 0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 08/29/2022 to Fri 09/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

4400 MW

Work scheduled by: CHGE

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY\_345\_Q12

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FRASER\_-GILBOA\_345\_GF5-35

FWD

Mon 09/12/2022 to Sun 09/18/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

2450 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

MOSES\_-ADIRNDCK\_230\_MA2

FWD

Thu 09/15/2022 to Tue 11/29/2022

(Import)

1931 Continuous 1800

UPDATED by NYPA 05/04/2022

MOSES SOUTH

2100 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

MARCY\_-EDIC\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT

5250 MW

Work scheduled by: NYPA

ARR: 19&16

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

LEEDS\_-HURLYAVE\_345\_301

FWD

Mon 09/19/2022 to Fri 10/21/2022

(Import)

0800 Continuous 1600

10/04/2021

UPNY CONED

4100 MW

Work scheduled by: CHGE

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

EGRDNCTY\_345\_138\_AT1

FWD

Sat 10/01/2022 to Wed 05/31/2023

(Import)

0001 Continuous 2359

UPDATED by CONED 03/10/2022

CONED - LIPA

1250 MW

Work scheduled by: LI

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EGRDNCTY_345_138_AT2</b>					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA <b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>SPRNBRK_-EGRDNCTR_345_Y49</b>					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA <b>775 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
<b>CLRKSCRN-OAKDALE_345_36</b>					FWD	
Mon 10/03/2022	to	Fri 10/07/2022	<u>UPDATED</u>	<u>by NYSEG</u>	<u>04/20/2022</u>	(Import)
0830	Continuous	1530				CENTRAL EAST - VC <b>2450 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	2585 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>	(Import) (Export)
1000	Continuous	1500				SCH - NPX_CSC <b>0 MW 0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>EDIC___-GORDONRD_345_14</b>					FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)
0700	Continuous	1530				CENTRAL EAST - VC <b>1695 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	890 MW
					TTC with All Lines In Service	2585 MW
<b>NIAGARA_-DYSINGER_345_ND1</b>					FWD	
Mon 10/17/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/10/2022</u>	(Import)
0500	Continuous	1700				DYSINGER EAST <b>2700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	3200 MW
<b>PANNELL_-CLAY_____345_1</b>					FWD	
Mon 10/24/2022	to	Fri 10/28/2022				(Import)
0700	Continuous	1530				WEST CENTRAL <b>1300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Mon 10/24/2022 to Fri 11/04/2022  
0800 Continuous 1600

UPDATED by CH 04/13/2022

(Import)

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

**MAINESBG-WATRCURE\_345\_30**

FWD

Tue 10/25/2022 to Tue 10/25/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY **2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

**WATRCURE-OAKDALE\_\_345\_31**

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Mon 10/31/2022 to Fri 11/04/2022  
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16**

FWD

Tue 11/01/2022 to Thu 11/03/2022  
0600 Continuous 1900

UPDATED by NGRID 05/09/2022

Work scheduled by: NGrid

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

FWD

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

FWD

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE\_345\_138\_BK\_1

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_2

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

GILBOA\_\_-N.SCTLND\_345\_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2585 MW

LEEDS\_\_\_345KV\_R94301

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

MARCY\_\_\_-N.SCTLND\_345\_18

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**  
0700 Continuous 1900

Work scheduled by: NGrid **ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **1400 MW**  
Impacts Total Transfer Capability 1185 MW  
TTC with All Lines In Service 2585 MW

LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Tue 11/01/2022 to Fri 11/04/2022  
0800 Continuous 1500

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 11/07/2022 to Fri 12/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA1**

Wed 11/30/2022 to Wed 03/01/2023  
0700 Continuous 1100

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**CLAY -EDIC 345\_1-16**

Fri 12/30/2022 to Sat 12/31/2022 UPDATED by NGRID 05/09/2022  
0600 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**FRASER 345\_FRASER SVC**

Tue 01/03/2023 to Tue 02/28/2023 UPDATED by NYPA 12/30/2021  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2550 MW**  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 2585 MW

**PLSNTVLY\_345KV\_RNS4**

Sat 04/01/2023 to Sat 04/01/2023  
0700 Continuous 0730

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**ATHENS -PLSNTVLY\_345\_91**

Sat 04/01/2023 to Sat 04/15/2023  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS4**

Sat 04/15/2023 to Sat 04/15/2023  
1830 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

Sun 04/16/2023 to Sun 04/16/2023  
0700 Continuous 0730

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS\_\_\_-PLSNTVLY\_345\_92

Sun 04/16/2023 to Sun 04/30/2023  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

PLSNTVLY\_345KV\_RNS5

Sun 04/30/2023 to Sun 04/30/2023  
1830 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/01/2023 to Fri 05/05/2023  
0600 Continuous 1800

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/06/2023  
0600 Continuous 1800

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_1

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,May 12, 2022 to Saturday ,November 11, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE\_345\_138\_BK\_2

FWD

Mon 10/09/2023 to Fri 10/13/2023  
 0600 Continuous 1600

(Import)

Work scheduled by: LI

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW