

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Reason	Effective Date	SCH	Impacts	TTC	FWD	REV
HUDSONP_-FARRAGUT_345_B3402	Mon 01/15/2018	Sat 12/31/2022	EXT FORCE by CONED	05/14/2022	PJ - NY	200 MW	2250 MW	(Import)	
0001	Continuous	2359							
Work scheduled by: ConEd									
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403	Mon 01/15/2018	Sat 12/31/2022			PJ - NY	250 MW	2250 MW	(Import)	(Export)
0001		2359				100 MW	1250 MW		
Work scheduled by:									
MARION_-FARRAGUT_345_C3403	Mon 01/15/2018	Sat 12/31/2022	EXT FORCE by CONED	05/14/2022	PJ - NY	200 MW	2250 MW	(Import)	
0001	Continuous	2359							
Work scheduled by: ConEd									
STLAWRNC-MOSES_230_L33P	Mon 04/30/2018	Mon 07/25/2022	EXT FORCE by IESO	11/04/2021	OH - NY				
0456	Continuous	0800							
Work scheduled by: IESO									
NEWBRDGE_345_138_BK_1	Wed 09/02/2020	Mon 08/01/2022	EXT FORCE by LI	12/10/2021	PJM_NEPTUNE	285 MW	660 MW	(Import)	
1807	Continuous	2359							
Work scheduled by: LI									
BECK_-NIAGARA_345_PA301	Wed 02/09/2022	Fri 06/17/2022	UPDATED by NYISO	04/29/2022	OH - NY	1050 MW	1950 MW	(Import)	(Export)
0700	Continuous	1700				900 MW	1700 MW		
Work scheduled by: IESO									
MOSES_-ADIRNDCK_230_MAL	Mon 02/28/2022	Sat 05/14/2022	UPDATED by NYPA	04/28/2022	MOSES SOUTH	1050 MW	3150 MW	(Import)	
0700	Continuous	1300							
Work scheduled by: NYPA									

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2					FWD		
Tue 03/08/2022	to	Fri 06/03/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/02/2022</u>	(Import)	
0700	Continuous	1900				750 MW	
Work scheduled by: NGrid					SCH - NE - NY	650 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service		
N. SCTLND-ALPS_____345_2					FWD	REV	
Tue 03/08/2022	to	Fri 06/03/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/02/2022</u>	(Import) (Export)	
0700	Continuous	1900				100 MW	100 MW
Work scheduled by: NGrid					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		
EGRDNCTY_345_138_AT1					FWD		
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				1250 MW	
Work scheduled by: ConEd					CONED - LIPA	250 MW	
					Impacts Total Transfer Capability	1500 MW	
					TTC with All Lines In Service		
EGRDNCTY_345_138_AT2					FWD		
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				1250 MW	
Work scheduled by: ConEd					CONED - LIPA	250 MW	
					Impacts Total Transfer Capability	1500 MW	
					TTC with All Lines In Service		
SPRNBRK_-EGRDNCTR_345_Y49					FWD		
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				775 MW	
Work scheduled by: ConEd					CONED - LIPA	725 MW	
					Impacts Total Transfer Capability	1500 MW	
					TTC with All Lines In Service		
W49TH_ST_345KV_6					FWD		
Mon 03/21/2022	to	Sat 06/11/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)	
0809	Continuous	2359				300 MW	
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW	
					Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service		
W49TH_ST_345KV_8					FWD		
Mon 03/21/2022	to	Sat 06/11/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)	
0811	Continuous	2359				450 MW	
Work scheduled by: ConEd					SCH - PJM_HTP	210 MW	
					Impacts Total Transfer Capability	660 MW	
					TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29

Fri 04/01/2022 to Tue 12/31/2030 **EXTENDED by NYSEG 04/06/2022**
 0500 Continuous 2359
 Work scheduled by: NYSEG
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ATHENS_-PLSNTVLY_345_91

Mon 04/18/2022 to Tue 05/24/2022 **EXTENDED by CE 04/28/2022**
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS4

Mon 04/18/2022 to Tue 05/24/2022 **EXTENDED by CE 04/28/2022**
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

GOETHALS_345KV_5

Wed 04/20/2022 to Fri 05/20/2022
 0301 Continuous 0300
 Work scheduled by: ConEd
 STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

LINDEN_-GOETHALS_230_A2253

Wed 04/20/2022 to Fri 05/20/2022
 0301 Continuous 0300
 Work scheduled by: ConEd
 FWD
 (Import)
 SCH - PJ - NY **2050 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 2250 MW

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402

Wed 04/20/2022 to Fri 05/20/2022
 0301 0300
 Work scheduled by:
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2000 MW 1150 MW**
 Impacts Total Transfer Capability 250 MW 100 MW
 TTC with All Lines In Service 2250 MW 1250 MW

LINDEN_-GOETHALS_230_A2253 & HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Wed 04/20/2022 to Fri 05/20/2022
 0301 0300
 Work scheduled by:
 FWD REV
 (Import) (Export)
 SCH - PJ - NY **2000 MW 1150 MW**
 Impacts Total Transfer Capability 250 MW 100 MW
 TTC with All Lines In Service 2250 MW 1250 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN__-GOETHALS_230_A2253 & MARION__-FARRAGUT_345_C3403

Wed 04/20/2022 to Fri 05/20/2022
0301 to 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2000 MW	1150 MW
Impacts Total Transfer Capability	250 MW	100 MW
TTC with All Lines In Service	2250 MW	1250 MW

EDIC____-FRASER____345_EF24-40

Fri 04/22/2022 to Thu 05/12/2022
0700 Continuous 1416

Work scheduled by: NYPA

UPDATED by NJYPA 04/19/2022

	FWD
	(Import)
CENTRAL EAST - VC	2275 MW
Impacts Total Transfer Capability	310 MW
TTC with All Lines In Service	2585 MW

GORDONRD-N.SCTLND_345_55

Wed 04/27/2022 to Wed 06/08/2022
1122 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	2045 MW
Impacts Total Transfer Capability	540 MW
TTC with All Lines In Service	2585 MW

GORDONRD-ROTTRDAM_230_30

Wed 04/27/2022 to Wed 06/15/2022
1122 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	2535 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2585 MW

EDIC____-GORDONRD_345_14

Wed 04/27/2022 to Tue 05/24/2022
1130 Continuous 0800

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	1695 MW
Impacts Total Transfer Capability	890 MW
TTC with All Lines In Service	2585 MW

EDIC____-GORDONRD_345_14 & GORDONRD-ROTTRDAM_230_30

Wed 04/27/2022 to Tue 05/24/2022
1130 to 0800

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	1645 MW
Impacts Total Transfer Capability	940 MW
TTC with All Lines In Service	2585 MW

EDIC____-GORDONRD_345_14 & GORDONRD-ROTTRDAM_230_31

Wed 04/27/2022 to Tue 05/24/2022
1130 to 0800

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	1645 MW
Impacts Total Transfer Capability	940 MW
TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GORDONRD-ROTTRDAM_230_30 & GORDONRD-ROTTRDAM_230_31

Wed 04/27/2022 to Tue 05/24/2022
1130 0800

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2585 MW

GORDONRD-ROTTRDAM_230_31

Wed 04/27/2022 to Tue 05/24/2022
1130 Continuous 0800

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2535 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2585 MW

SCH-IMO-NYISO_LIMIT_500

Sun 05/01/2022 to Fri 06/17/2022 **UPDATED by NYISO 04/29/2022**
0001 Continuous 1700

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **800 MW**
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 1950 MW

SCH-IMO-NYISO_LIMIT_1400

Sun 05/01/2022 to Mon 07/25/2022
0001 Continuous 0800

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **1700 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1950 MW

SCH-IMO-NYISO_LIMIT_1600

Sun 05/01/2022 to Mon 07/25/2022
0001 Continuous 0800

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 1950 MW

SCH-NYISO-IMO_LIMIT_1200

Sun 05/01/2022 to Mon 07/25/2022
0001 Continuous 0800

Work scheduled by: IESO

REV
(Export)
SCH - OH - NY **1500 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1700 MW

SCH-NYISO-IMO_LIMIT_1400

Sun 05/01/2022 to Mon 07/25/2022
0001 Continuous 0800

Work scheduled by: IESO

REV
(Export)
SCH - OH - NY **1700 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2				FWD
Sun 05/01/2022	to	Sat 06/04/2022		(Import)
0500	Continuous	2200	MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
CHAT_DC_GC2				REV
Sun 05/01/2022	to	Sat 06/04/2022		(Export)
0500	Continuous	2200	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
SCH-NYISO-HQ_LIMIT_500				REV
Sun 05/01/2022	to	Sat 06/04/2022		(Export)
0500	Continuous	2200	SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
SCH-HQ_CEDARS-NYISO_LIMIT_220				FWD
Mon 05/02/2022	to	Fri 05/20/2022		(Import)
0200	Continuous	0200	SCH - HQ_CEDARS	220 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 270 MW
SCH-NYISO-NE_LIMIT_1200				REV
Mon 05/02/2022	to	Fri 05/13/2022	UPDATED by ISONE 05/05/2022	(Export)
0600	Continuous	1800	SCH - NE - NY	1400 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1600 MW
SCH-NYISO-PJM_LIMIT_500				REV
Mon 05/09/2022	to	Fri 05/20/2022	UPDATED by NYISO 05/07/2022	(Export)
0001	Continuous	1700	SCH - PJ - NY	800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 1250 MW
SPRNBRK_-TREMONT__345_X28				FWD
Mon 05/09/2022	to	Sat 05/14/2022	UPDATED by CONED 05/03/2022	(Import)
0201	Continuous	0300	SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46						FWD
Mon 05/09/2022	to	Sat 06/04/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/10/2022</u>	(Import)
0301	Continuous	0200				3800 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
SCH-HQ_CEDARS-NYISO_LIMIT_20						FWD
Mon 05/09/2022	to	Thu 05/12/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>05/02/2022</u>	(Import)
0800	Continuous	1357				20 MW
Work scheduled by: NGrid						SCH - HQ_CEDARS
						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 270 MW
RAMAPO__-LADENTWN_345_W72						FWD
Tue 05/10/2022	to	Wed 05/11/2022	<u>UPDATED</u>	<u>by CE</u>	<u>02/23/2022</u>	(Import)
0700	Continuous	1900				4400 MW
Work scheduled by: ORU						UPNY CONED
						Impacts Total Transfer Capability 3415 MW
						TTC with All Lines In Service 7815 MW
SCH-NYISO-NE_LIMIT_1300						REV
Thu 05/12/2022	to	Fri 05/13/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/09/2022</u>	(Export)
0700	Continuous	2359				1500 MW
Work scheduled by: NYPA						SCH - NE - NY
						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 1600 MW
SAND_BAR-PLATSBURG_115_PV20						
Thu 05/12/2022	to	Tue 05/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/09/2022</u>	
0700	Continuous	1730				
Work scheduled by: NYPA						SCH - NE - NY
						Impacts Total Transfer Capability
						TTC with All Lines In Service
SCH-NE-NYISO_LIMIT_400						FWD
Thu 05/12/2022	to	Tue 05/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/09/2022</u>	(Import)
0700	Continuous	1730				600 MW
Work scheduled by: NYPA						SCH - NE - NY
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1400 MW
SCRIBA__-VOLNEY__345_21						FWD
Thu 05/12/2022	to	Fri 05/13/2022	<u>FORCED</u>	<u>by NGRID</u>	<u>05/10/2022</u>	(Import)
1800	Daily(No Weekends)	0400				5250 MW
Work scheduled by: NGrid						OSWEGO EXPORT
						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F38					FWD	
Thu 05/12/2022	to	Sun 05/15/2022	<u>CANCELLED</u>	<u>by ConEd</u>	<u>05/13/2022</u>	(Import)
2100	Continuous	0300				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	
PLSNTVLE-DUNWODIE_345_W89					FWD	
Thu 05/12/2022	to	Sun 05/15/2022	<u>CANCELLED</u>	<u>by ConEd</u>	<u>05/13/2022</u>	(Import)
2100	Continuous	0300				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW	
					TTC with All Lines In Service 7815 MW	
WOOD_ST_-PLSNTVLE_345_Y86					FWD	
Thu 05/12/2022	to	Sun 05/15/2022	<u>CANCELLED</u>	<u>by ConEd</u>	<u>05/13/2022</u>	(Import)
2100	Continuous	0300				UPNY CONED 7210 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 605 MW	
					TTC with All Lines In Service 7815 MW	
SCH-NYISO-NE_LIMIT_1200					REV	
Sat 05/14/2022	to	Tue 05/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/09/2022</u>	(Export)
0001	Continuous	1730				SCH - NE - NY 1400 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 1600 MW	
MOSES__-ADIRNDCK_230_MA2					FWD	
Mon 05/16/2022	to	Wed 05/25/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/04/2022</u>	(Import)
0500	Continuous	1930				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW	
					TTC with All Lines In Service 3150 MW	
SCH-NYISO-NE_LIMIT_1200					REV	
Mon 05/16/2022	to	Tue 05/17/2022	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/12/2022</u>	(Export)
0600	Continuous	1800				SCH - NE - NY 1400 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 1600 MW	
SHOR_NPX-SHOREHAM_138_CSC					FWD	
Mon 05/16/2022	to	Sat 05/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>02/10/2022</u>	(Import) (Export)
0600	Continuous	2000				SCH - NPX_CSC 0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability 330 MW 330 MW	
					TTC with All Lines In Service 330 MW 330 MW	

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
DENNISON-ROSEMNTA_115_1/11						
Mon 05/16/2022	to	Fri 05/20/2022				
0800	Continuous	1630		SCH - HQ_CEDARS	95 MW	40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	175 MW 60 MW
					TTC with All Lines In Service	270 MW 100 MW
HOMR_NYW-PIERC_NY_345_48						
Tue 05/17/2022	to	Sat 05/21/2022				
0800	Continuous	1500		SCH - PJ - NY		
Work scheduled by: PJM					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
DUNWODIE-MOTTHAVN_345_71						
Wed 05/18/2022	to	Fri 05/20/2022	UPDATED	by CONED	05/10/2022	
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3						
Wed 05/18/2022	to	Fri 05/20/2022	UPDATED	by CONED	05/10/2022	
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5						
Wed 05/18/2022	to	Fri 05/20/2022	UPDATED	by CONED	05/10/2022	
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4						
Wed 05/18/2022	to	Sat 05/21/2022				
0001		2200		UPNY CONED	3800 MW	
Work scheduled by:					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
SCH-NE-NYISO_LIMIT_100						
Wed 05/18/2022	to	Sat 05/21/2022	UPDATED	by NYISO	05/09/2022	
0001	Continuous	2200		SCH - NE - NY	300 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST_345_F31					FWD	
Sun 05/22/2022	to	Tue 05/24/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>04/28/2022</u>	(Import)
0001	Continuous	2200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
MOTHAVN-RAINEY_345_Q12					FWD	
Tue 05/24/2022	to	Sat 05/28/2022				(Import)
0201	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
CRICKVLY-PLSNTVLY_345_F84					FWD	
Wed 05/25/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/28/2022</u>	(Import)
0001	Continuous	2200				SCH - NE - NY 350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F84					FWD	REV
Wed 05/25/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/28/2022</u>	(Import) (Export)
0001	Continuous	2200				SCH - NPX_1385 100 MW 100 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
MARCY_-EDIC_345_UE1-7					FWD	
Wed 05/25/2022	to	Wed 05/25/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/13/2022</u>	(Import)
0500	Continuous	1730				OSWEGO EXPORT 5250 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
VOLNEY_-MARC_345_19					FWD	
Wed 05/25/2022	to	Wed 05/25/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/13/2022</u>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC 2475 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	2585 MW
VOLNEY_-MARC_345_19					FWD	
Wed 05/25/2022	to	Wed 05/25/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/13/2022</u>	(Import)
0500	Continuous	1730				OSWEGO EXPORT 4900 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY___345_19 & GORDONRD-ROTTDAM_230_30

Wed 05/25/2022 to Wed 05/25/2022
0500 1730

Work scheduled by:

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2425 MW**
Impacts Total Transfer Capability 160 MW
TTC with All Lines In Service 2585 MW

BUCHAN_S-MILLWOOD_345_W97

Fri 05/27/2022 to Sat 05/28/2022
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

MARCY__-EDIC___345_UE1-7

Sat 05/28/2022 to Sun 05/29/2022
0600 Continuous 1830

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

DUNWODIE_345KV_3

Sun 05/29/2022 to Sun 05/29/2022
0201 Continuous 1800

Work scheduled by: ConEd

UPDATED by CE 04/12/2022

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Sun 05/29/2022 to Sun 05/29/2022
0201 Continuous 1800

Work scheduled by: ConEd

UPDATED by CE 04/12/2022

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W89

Sun 05/29/2022 to Sun 05/29/2022
0201 Continuous 1800

Work scheduled by: ConEd

UPDATED by CE 04/12/2022

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

MOSES__-ADIRNDCK_230_MA2

Tue 05/31/2022 to Thu 09/15/2022
0500 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 05/04/2022

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PIERCBRK-FIVEMILE_345_37

Tue 05/31/2022 to Wed 06/01/2022
 0730 Continuous 1600
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-NE-NYISO_LIMIT_300

Wed 06/01/2022 to Wed 06/08/2022
 0700 Continuous 1600
 Work scheduled by: ISONE

UPDATED by ISONE 03/04/2022

FWD
 (Import)
 SCH - NE - NY **500 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Wed 06/01/2022 to Wed 06/08/2022
 0700 Continuous 1600
 Work scheduled by: ISONE

UPDATED by ISONE 03/04/2022

REV
 (Export)
 SCH - NE - NY **1100 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1600 MW

ADIRNDCK-PORTER_230_12

Wed 06/01/2022 to Tue 11/15/2022
 0700 Continuous 1700
 Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

HUDSONTP-W49TH_ST_345_Y56

Sat 06/04/2022 to Sun 06/05/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Sat 06/04/2022 to Sun 06/05/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

EASTVIEW-SPRNBK_345_W64

Sat 06/04/2022 to Mon 06/06/2022
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Sat 06/04/2022 to Mon 06/06/2022
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS5

Sat 06/04/2022 to Mon 06/06/2022
 0201 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FROST_BR-LONG_MTN_345_352

Thu 06/09/2022 to Sat 06/18/2022 **UPDATED by ISONE 03/04/2022**
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **1150 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_200

Thu 06/09/2022 to Sat 06/18/2022 **UPDATED by ISONE 03/04/2022**
 0700 Continuous 1600
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **400 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 1400 MW

NIAGARA_-DYSINGER_345_ND1

Mon 06/13/2022 to Fri 06/17/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2700 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3200 MW

OAKDALE_-FRASER_345_32

Wed 06/15/2022 to Fri 06/17/2022
 0800 Continuous 1600
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2450 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 2585 MW

MARCY_-EDIC_345_UE1-7

Sat 06/18/2022 to Sun 06/19/2022
 0600 Continuous 1830
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-PACKARD__230_62

Mon 06/20/2022 to Sun 06/26/2022
0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 04/19/2022

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	700 MW	1550 MW
Impacts Total Transfer Capability	1250 MW	150 MW
TTC with All Lines In Service	1950 MW	1700 MW

SAND_BAR-PLATSBRG_115_PV20

Tue 06/21/2022 to Thu 06/23/2022
0700 Continuous 1730

Work scheduled by: NYPA

SCH - NE - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

SCH-NE-NYISO_LIMIT_400

Tue 06/21/2022 to Thu 06/23/2022
0700 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
SCH - NE - NY	600 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1400 MW

SCH-NYISO-NE_LIMIT_1300

Tue 06/21/2022 to Thu 06/23/2022
0700 Continuous 1730

Work scheduled by: NYPA

	REV
	(Export)
SCH - NE - NY	1500 MW
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1600 MW

FRASER_-GILBOA__345_GF5-35

Tue 06/21/2022 to Sun 06/26/2022
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2450 MW
Impacts Total Transfer Capability	135 MW
TTC with All Lines In Service	2585 MW

BEAR SWP-EASTOVER_230_E205W

Mon 06/27/2022 to Tue 06/28/2022
0700 Continuous 0759

Work scheduled by: ISONE

SCH - NE - NY	
Impacts Total Transfer Capability	
TTC with All Lines In Service	

NIAGARA__345_230_AT4

Tue 06/28/2022 to Wed 06/29/2022
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BEAR SWP-EASTOVER_230_E205W

Tue 06/28/2022 to Tue 06/28/2022
 0800 Daily(No Weekends) 1500
 Work scheduled by: NGrid

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

BEAR SWP-EASTOVER_230_E205W

Tue 06/28/2022 to Thu 06/30/2022
 1501 Continuous 1700
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

BECK -NIAGARA_230_PA27

Tue 07/05/2022 to Sat 07/09/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NIAGARA -DYSINGER_345_ND1

Mon 07/11/2022 to Fri 07/15/2022
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2700 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3200 MW

HURLYAVE-ROSETON_345_303

Mon 07/11/2022 to Fri 07/22/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

02/14/2022

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

ROCHESTR-PANNELL_345_RP1

Mon 07/25/2022 to Fri 07/29/2022
 0500 Continuous 2100
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 3200 MW

FRASANX-COOPERS_345_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022
 0700 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2275 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 2585 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -FRASANNX_345_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 2585 MW

NIAGARA -DYSINGER_345_ND2

Mon 08/01/2022 to Fri 08/05/2022
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

MARCY -EDIC_345_UE1-7

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 05/13/2022

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

VOLNEY -MARC_345_19

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 05/13/2022

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2475 MW**
Impacts Total Transfer Capability 110 MW
TTC with All Lines In Service 2585 MW

VOLNEY -MARC_345_19

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 05/13/2022

ARR: 19

FWD
(Import)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

FRASANNX-COOPERS_345_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 2585 MW

MARCY -FRASANNX_345_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 310 MW
TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L34P

Mon 08/15/2022 to Fri 08/19/2022
 0400 Continuous 1700
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ROSETON_-ROCKTVRN_345_311

Mon 08/29/2022 to Fri 09/09/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 3415 MW
 TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY___345_Q12

Thu 09/01/2022 to Mon 09/05/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FRASER_-GILBOA___345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2450 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 2585 MW

MOSES_-ADIRNDCK_230_MA2

Thu 09/15/2022 to Tue 11/29/2022 **UPDATED by NYPA 05/04/2022**
 1931 Continuous 1800
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MARCY_-EDIC___345_UE1-7

Mon 09/19/2022 to Sat 10/08/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

ARR: 19&16

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301					FWD	
Mon 09/19/2022	to	Fri 10/21/2022	<u>10/04/2021</u>		(Import)	
0800	Continuous	1600		UPNY CONED	4100 MW	
Work scheduled by: CHGE					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW
EGRDNCTY_345_138_AT1					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u> <u>by CONED</u> <u>03/10/2022</u>		(Import)	
0001	Continuous	2359		CONED - LIPA	1250 MW	
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
EGRDNCTY_345_138_AT2					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u> <u>by CONED</u> <u>03/10/2022</u>		(Import)	
0001	Continuous	2359		CONED - LIPA	1250 MW	
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
SPRNBRK_-EGRDNCTR_345_Y49					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u> <u>by CONED</u> <u>03/10/2022</u>		(Import)	
0001	Continuous	2359		CONED - LIPA	775 MW	
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
CLRKSCRN-OAKDALE__345_36					FWD	
Mon 10/03/2022	to	Fri 10/07/2022	<u>UPDATED</u> <u>by NYSEG</u> <u>04/20/2022</u>		(Import)	
0830	Continuous	1530		CENTRAL EAST - VC	2450 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	2585 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u> <u>by LI</u> <u>01/07/2022</u>		(Import)	(Export)
1000	Continuous	1500		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
EDIC___-GORDONRD_345_14					FWD	
Mon 10/10/2022	to	Mon 10/31/2022			(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	1695 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	890 MW
					TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND1

Mon 10/17/2022 to Fri 10/21/2022
0500 Continuous 1700

UPDATED by NYPA 02/10/2022

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

PANNELL_-CLAY_345_1

Mon 10/24/2022 to Fri 10/28/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON_345_303

Mon 10/24/2022 to Fri 11/04/2022
0800 Continuous 1600

UPDATED by CH 04/13/2022

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

MAINESBG-WATRCURE_345_30

Tue 10/25/2022 to Tue 10/25/2022
0800 Daily 1500

Work scheduled by: NYSEG

FWD
(Import)
SCH - PJ - NY **2200 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2250 MW

WATRCURE-OAKDALE_345_31

Thu 10/27/2022 to Thu 10/27/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY_345_2

Mon 10/31/2022 to Fri 11/04/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CLAY_-EDIC_345_1-16

Tue 11/01/2022 to Thu 11/03/2022
0600 Continuous 1900

UPDATED by NGRID 05/09/2022

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

GILBOA_-N.SCTLND_345_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2300 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 2585 MW

LEEDS_345KV_R94301

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

MARCY_-N.SCTLND_345_18

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **1400 MW**
 Impacts Total Transfer Capability 1185 MW
 TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday,November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Type	Impact	TTC
LINDN_CG-LNDVFT_345_V-3022	Tue 11/01/2022	Fri 11/04/2022	0800	Continuous	1500	PJM	SCH - PJM_VFT	0 MW
							Impacts Total Transfer Capability	315 MW
							TTC with All Lines In Service	315 MW
LEEDS_HURLYAVE_345_301	Mon 11/07/2022	Fri 12/09/2022	0800	Continuous	1600	CHGE	UPNY CONED	4100 MW
							Impacts Total Transfer Capability	3715 MW
							TTC with All Lines In Service	7815 MW
MOSES_ADIRNDCK_230_MA1	Wed 11/30/2022	Wed 03/01/2023	0700	Continuous	1100	NYPA	MOSES SOUTH	2300 MW
							Impacts Total Transfer Capability	850 MW
							TTC with All Lines In Service	3150 MW
CLAY_EDIC_345_1-16	Fri 12/30/2022	Sat 12/31/2022	0600	Continuous	1900	NGRID	OSWEGO EXPORT	4850 MW
							Impacts Total Transfer Capability	400 MW
							TTC with All Lines In Service	5250 MW
FRASER_345_FRASER_SVC	Tue 01/03/2023	Tue 02/28/2023	0700	Continuous	1730	NYPA	CENTRAL EAST - VC	2550 MW
							Impacts Total Transfer Capability	35 MW
							TTC with All Lines In Service	2585 MW
PLSNTVLY_345KV_RNS4	Sat 04/01/2023	Sat 04/01/2023	0700	Continuous	0730	NGRID	UPNY CONED	3800 MW
							Impacts Total Transfer Capability	4015 MW
							TTC with All Lines In Service	7815 MW
ATHENS_PLSNTVLY_345_91	Sat 04/01/2023	Sat 04/15/2023	0700	Continuous	1900	NGRID	UPNY CONED	3800 MW
							Impacts Total Transfer Capability	4015 MW
							TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work by	Impact	TTC
PLSNTVLY_345KV_RNS4	Sat 04/15/2023	Sat 04/15/2023	1830	Continuous	1900	NGrid	FWD (Import) UPNY CONED 3800 MW Impacts Total Transfer Capability 4015 MW TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS5	Sun 04/16/2023	Sun 04/16/2023	0700	Continuous	0730	NGrid	FWD (Import) UPNY CONED 3800 MW Impacts Total Transfer Capability 4015 MW TTC with All Lines In Service 7815 MW
LEEDS - PLSNTVLY_345_92	Sun 04/16/2023	Sun 04/30/2023	0700	Continuous	1900	NGrid	FWD (Import) UPNY CONED 3800 MW Impacts Total Transfer Capability 4015 MW TTC with All Lines In Service 7815 MW
PLSNTVLY_345KV_RNS5	Sun 04/30/2023	Sun 04/30/2023	1830	Continuous	1900	NGrid	FWD (Import) UPNY CONED 3800 MW Impacts Total Transfer Capability 4015 MW TTC with All Lines In Service 7815 MW
SHOR_NPX-SHOREHAM_138_CSC	Mon 05/01/2023	Fri 05/05/2023	0600	Continuous	1800	LI	FWD REV (Import) (Export) SCH - NPX_CSC 0 MW 0 MW Impacts Total Transfer Capability 330 MW 330 MW TTC with All Lines In Service 330 MW 330 MW
SHOR_NPX-SHOREHAM_138_CSC	Mon 10/02/2023	Fri 10/06/2023	0600	Continuous	1800	LI	FWD REV (Import) (Export) SCH - NPX_CSC 0 MW 0 MW Impacts Total Transfer Capability 330 MW 330 MW TTC with All Lines In Service 330 MW 330 MW
NEPTUNE - DUFFYAVE_345_NEPTUNE	Mon 10/09/2023	Fri 10/13/2023	0600	Continuous	1600	LI	FWD (Import) SCH - PJM_NEPTUNE 0 MW Impacts Total Transfer Capability 660 MW TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,May 16, 2022 to Wednesday, November 15, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW