

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402				FWD	
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCE</u> <u>by CONED</u> <u>08/06/2022</u>	(Import)	
0001	Continuous	2359		SCH - PJ - NY	2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403				FWD	REV
Mon 01/15/2018	to	Tue 01/31/2023		(Import) (Export)	
0001		2359		SCH - PJ - NY	2000 MW 1150 MW
Work scheduled by:				Impacts Total Transfer Capability	250 MW 50 MW
				TTC with All Lines In Service	2250 MW 1200 MW
MARION_-FARRAGUT_345_C3403				FWD	
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCE</u> <u>by CONED</u> <u>08/06/2022</u>	(Import)	
0001	Continuous	2359		SCH - PJ - NY	2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
GORDONRD-ROTTDAM_230_31				FWD	
Wed 04/27/2022	to	Mon 09/12/2022	<u>UPDATED</u> <u>by NYISO</u> <u>06/30/2022</u>	(Import)	
1130	Continuous	1000		CENTRAL EAST - VC	2805 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW
SCH-IMO-NYISO_LIMIT_1500				FWD	
Wed 07/20/2022	to	Mon 08/15/2022	<u>EXTENDED</u> <u>by IESO</u> <u>07/28/2022</u>	(Import)	
0001	Continuous	0400		SCH - OH - NY	1800 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	1900 MW
STLAWRNC-MOSES_230_L34P					
Sat 07/30/2022	to	Mon 08/15/2022	<u>UPDATED</u> <u>by IESO</u> <u>07/27/2022</u>		
1600	Continuous	0359		SCH - OH - NY	
Work scheduled by: IESO				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
DYSINGER-STA_255_345_DH2				FWD	
Mon 08/01/2022	to	Sun 08/07/2022	<u>UPDATED</u> <u>by NYISO</u> <u>08/07/2022</u>	(Import)	
2000	Continuous	0600		DYSINGER EAST	2850 MW
Work scheduled by: NT				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	3200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2

Mon 08/01/2022 to Sun 08/07/2022
2000 Continuous 0600

Work scheduled by: NT

UPDATED by NYISO 08/07/2022

FWD
(Import)
DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2

Tue 08/02/2022 to Wed 08/03/2022
2000 0600

Work scheduled by:

FWD
(Import)
DYSINGER EAST **2500 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2

Wed 08/03/2022 to Thu 08/04/2022
2000 0600

Work scheduled by:

FWD
(Import)
DYSINGER EAST **2500 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2

Thu 08/04/2022 to Fri 08/05/2022
2000 0600

Work scheduled by:

FWD
(Import)
DYSINGER EAST **2500 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

SCH-IMO-NYISO_LIMIT_1300

Fri 08/05/2022 to Fri 08/05/2022
0700 Continuous 1700

Work scheduled by: IESO

CANCELLED by IESO 08/03/2022

FWD
(Import)
SCH - OH - NY **1600 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 1900 MW

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2

Fri 08/05/2022 to Sat 08/06/2022
2000 0600

Work scheduled by:

FWD
(Import)
DYSINGER EAST **2500 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

MARCY_-EDIC_345_UE1-7

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1200

Work scheduled by: NYPA

UPDATED by NYPA 08/07/2022

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD
VOLNEY__-MARCY__345_19						(Import)
Sat 08/06/2022	to	Sun 08/07/2022	UPDATED	by NYPA	08/07/2022	
0500	Continuous	1200				CENTRAL EAST - VC 2825 MW
Work scheduled by: NYPA				ARR: 19		Impacts Total Transfer Capability 150 MW TTC with All Lines In Service 2975 MW
<hr/>						FWD
VOLNEY__-MARCY__345_19						(Import)
Sat 08/06/2022	to	Sun 08/07/2022	UPDATED	by NYPA	08/07/2022	
0500	Continuous	1200				OSWEGO EXPORT 4900 MW
Work scheduled by: NYPA				ARR: 19		Impacts Total Transfer Capability 350 MW TTC with All Lines In Service 5250 MW
<hr/>						FWD
SCH-IMO-NYISO_LIMIT_1400						(Import)
Sat 08/06/2022	to	Mon 08/08/2022	CANCELLED	by IESO	08/04/2022	
1301	Continuous	0900				SCH - OH - NY 1700 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW TTC with All Lines In Service 1900 MW
<hr/>						FWD
LINDN_CG-LNDVFT__345_V-3022						REV
Sat 08/06/2022	to	Sat 08/06/2022				(Import) (Export)
1900	Continuous	2300				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 315 MW 315 MW TTC with All Lines In Service 315 MW 315 MW
<hr/>						FWD
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255__345_DH2						(Import)
Sat 08/06/2022	to	Sun 08/07/2022				
2000		0600				DYSINGER EAST 2500 MW
Work scheduled by:						Impacts Total Transfer Capability 700 MW TTC with All Lines In Service 3200 MW
<hr/>						FWD
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255__345_DH2						(Import)
Tue 08/09/2022	to	Wed 08/10/2022				
2000		1000				DYSINGER EAST 2500 MW
Work scheduled by:						Impacts Total Transfer Capability 700 MW TTC with All Lines In Service 3200 MW
<hr/>						FWD
DYSINGER-STA_255__345_DH2						(Import)
Tue 08/09/2022	to	Thu 08/11/2022	UPDATED	by NYISO	08/07/2022	
2000	Continuous	1000				DYSINGER EAST 2850 MW
Work scheduled by: NT						Impacts Total Transfer Capability 350 MW TTC with All Lines In Service 3200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2					FWD	
Tue 08/09/2022	to	Thu 08/11/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/07/2022</u>	(Import)
2000	Continuous	1000				DYSINGER EAST 2700 MW
Work scheduled by: NT					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	3200 MW
SCH-IMO-NYISO_LIMIT_1400					FWD	
Wed 08/10/2022	to	Tue 08/16/2022				(Import)
0800	Continuous	1300				SCH - OH - NY 1700 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1900 MW
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2					FWD	
Wed 08/10/2022	to	Thu 08/11/2022				(Import)
2000		1000				DYSINGER EAST 2500 MW
Work scheduled by:					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	3200 MW
BECK_-NIAGARA_345_PA301					FWD	REV
Thu 08/11/2022	to	Sun 08/14/2022				(Import) (Export)
0500	Continuous	1900				SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1000 MW 750 MW
					TTC with All Lines In Service	1900 MW 1550 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Thu 08/11/2022	to	Thu 09/15/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0500	Continuous	1100				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
FRASANNX-COOPERS_345_UCC2-41					FWD	
Thu 08/11/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0700	Continuous	1700				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
MARCY_-FRASANNX_345_UCC2-41					FWD	
Thu 08/11/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0700	Continuous	1700				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-PACKARD__230_61

Fri 08/12/2022 to Fri 08/12/2022
 1100 Daily(No Weekends) 1500
 Work scheduled by: NGrid

REV (Export)
 SCH - OH - NY **1350 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1550 MW

STLAWRNC-MOSES__230_L34P

Mon 08/15/2022 to Tue 04/18/2023 **EXTENDED by IESO 05/18/2022**
 0400 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-NYISO-HQ_LIMIT_800

Mon 08/15/2022 to Tue 08/16/2022
 0600 Continuous 1800
 Work scheduled by: HQ

REV (Export)
 SCH - HQ - NY **800 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1000 MW

SCH-NYISO-HQ_LIMIT_800

Mon 08/22/2022 to Tue 08/23/2022
 0600 Continuous 1800
 Work scheduled by: HQ

REV (Export)
 SCH - HQ - NY **800 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1000 MW

SAND_BAR-PLATSBURG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

BECK_-PACKARD__230_BP76

Mon 08/22/2022 to Mon 08/22/2022 **UPDATED by NGRID 08/06/2022**
 0800 Daily(No Weekends) 1159
 Work scheduled by: NGrid

FWD REV (Import) (Export)
 SCH - OH - NY **1500 MW 1000 MW**
 Impacts Total Transfer Capability 400 MW 550 MW
 TTC with All Lines In Service 1900 MW 1550 MW

W49TH_ST_345KV_6

Sat 08/27/2022 to Sat 08/27/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Sat 08/27/2022 to Mon 08/29/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Mon 08/29/2022 to Mon 08/29/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

ROSETON_-ROCKTVRN_345_311

Mon 08/29/2022 to Fri 09/09/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 3415 MW
 TTC with All Lines In Service 7815 MW

EFISHKIL-WOOD_ST__345_F38

Thu 09/01/2022 to Sat 09/03/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLE-DUNWODIE_345_W89

Thu 09/01/2022 to Sat 09/03/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

WOOD_ST_-PLSNTVLE_345_Y86

Thu 09/01/2022 to Sat 09/03/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7210 MW**
 Impacts Total Transfer Capability 605 MW
 TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY__345_Q12

Thu 09/01/2022 to Mon 09/05/2022 **UPDATED by CE 06/14/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6					FWD	
Mon 09/05/2022	to	Wed 09/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Mon 09/05/2022	to	Wed 09/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Mon 09/05/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	2200				7260 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	555 MW
					TTC with All Lines In Service	7815 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Mon 09/05/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	0200				4000 MW
Work scheduled by: ConEd					UPNY CONED	
					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
NRTH1385-NRTHPORT_138_NNC					FWD	REV
Tue 09/06/2022	to	Sat 09/10/2022				(Import) (Export)
0500	Continuous	1700				0 MW 0 MW
Work scheduled by: ISONE					SCH - NPX_1385	
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
S.RIPLEY-DUNKIRK_230_68						
Tue 09/06/2022	to	Tue 09/06/2022				
0730	Continuous	1800				
Work scheduled by: NGrid					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
EDIC____-N.SCTLND_345_14 & GORDONRD-ROTTRDAM_230_31					FWD	
Thu 09/08/2022	to	Mon 09/12/2022				(Import)
0700		1000				1500 MW
Work scheduled by:					CENTRAL EAST - VC	
					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC___-N.SCTLND_345_14					FWD	
Thu 09/08/2022	to	Tue 12/31/2030	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/30/2022</u>	(Import)
0700	Continuous	2359				CENTRAL EAST - VC 1670 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 1305 MW	TTC with All Lines In Service 2975 MW
DUNWODIE_345KV_6					FWD	
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0130	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8					FWD	
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0130	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0130	Continuous	0200				UPNY CONED 7260 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 555 MW	TTC with All Lines In Service 7815 MW
BUCHAN_S-MILLWOOD_345_W97					FWD	
Sat 09/10/2022	to	Sun 09/11/2022				(Import)
0201	Continuous	2200				UPNY CONED 7680 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 135 MW	TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RNS3					FWD	
Mon 09/12/2022	to	Wed 09/14/2022				(Import)
0201	Continuous	1800				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
FRASER_-GILBOA__345_GF5-35					FWD	
Mon 09/12/2022	to	Sun 09/18/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/02/2022</u>	(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2650 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 325 MW	TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC__-N.SCTLND_345_14 & PORTER__-ROTTDAM_230_30			FWD	
Mon 09/12/2022	to	Tue 12/31/2030	(Import)	
1200		2359	CENTRAL EAST - VC	1500 MW
Work scheduled by:			Impacts Total Transfer Capability	1475 MW
			TTC with All Lines In Service	2975 MW
PORTER__-ROTTDAM_230_30			FWD	
Mon 09/12/2022	to	Tue 12/31/2030	(Import)	
1200	Continuous	2359	CENTRAL EAST - VC	2805 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	170 MW
			TTC with All Lines In Service	2975 MW
SCH-NE-NYISO_LIMIT_500			FWD	
Wed 09/14/2022	to	Wed 09/14/2022	(Import)	
0600	Continuous	1800	SCH - NE - NY	700 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW
W49TH_ST-E13THSTA_345_M54			FWD	
Thu 09/15/2022	to	Thu 09/15/2022	(Import)	
0001	Continuous	0031	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4			FWD	
Thu 09/15/2022	to	Fri 09/16/2022	(Import)	
0001		0300	SPR/DUN-SOUTH	3200 MW
Work scheduled by:			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
CRICKVLY-PLSNTVLY_345_F84			FWD	
Thu 09/15/2022	to	Sat 09/17/2022	(Import)	
0001	Continuous	2200	SCH - NE - NY	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F84			FWD	REV
Thu 09/15/2022	to	Sat 09/17/2022	(Import)	(Export)
0001	Continuous	2200	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 09/15/2022 to Fri 10/14/2022
 0001 0200

Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK__345_W78

Fri 09/16/2022 to Mon 09/19/2022 **UPDATED by CONED 06/25/2022**
 2100 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W85

Fri 09/16/2022 to Mon 09/19/2022 **UPDATED by CONED 06/25/2022**
 2100 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS3

Fri 09/16/2022 to Mon 09/19/2022 **UPDATED by CONED 06/25/2022**
 2100 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Mon 09/19/2022 to Mon 09/19/2022
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Mon 09/19/2022 to Mon 09/19/2022
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Mon 09/19/2022 to Sun 09/25/2022
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **800 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1				FWD
Mon 09/19/2022	to	Sun 09/25/2022		(Import)
0001	Continuous	0200	CONED - LIPA	1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2				FWD
Mon 09/19/2022	to	Sun 09/25/2022		(Import)
0001	Continuous	0200	CONED - LIPA	1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
MILLWOOD_345KV_18				FWD
Mon 09/19/2022	to	Mon 09/19/2022	<u>EXTENDED</u> <u>by CONED</u> <u>07/22/2022</u>	(Import)
0201	Continuous	0230	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
FRASER_345_FRASER SVC				FWD
Mon 09/19/2022	to	Tue 09/27/2022		(Import)
0600	Continuous	1700	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW
MARCY_-EDIC_345_UE1-7				FWD
Mon 09/19/2022	to	Sat 10/08/2022	<u>UPDATED</u> <u>by NGRID</u> <u>06/06/2022</u>	(Import)
0700	Continuous	1530	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
COOPERS_-DOLSONAV_345_CCDA42				FWD
Mon 09/19/2022	to	Thu 09/29/2022		(Import)
0800	Continuous	1630	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
LEEDS_-HURLYAVE_345_301				FWD
Mon 09/19/2022	to	Fri 10/21/2022	<u>10/04/2021</u>	(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 3715 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18

Fri 09/23/2022 to Fri 09/23/2022
2130 Continuous 2200

Work scheduled by: ConEd

EXTENDED by CONED 07/22/2022

UPNY CONED

FWD

(Import)

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_4

Sat 09/24/2022 to Sun 09/25/2022
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD

(Import)

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Sat 09/24/2022 to Sun 09/25/2022
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD

(Import)

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sat 09/24/2022 to Mon 09/26/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

7550 MW

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Sat 09/24/2022 to Mon 09/26/2022
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD

(Import)

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Sat 09/24/2022 to Tue 09/27/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD

(Import)

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

ADIRNDCK-PORTER__230_12

Mon 09/26/2022 to Wed 11/30/2022
0630 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD

(Import)

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Tue 09/27/2022 to Tue 09/27/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS5

Tue 09/27/2022 to Tue 09/27/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK_345_W64

Thu 09/29/2022 to Sat 10/01/2022 **UPDATED by CONED 06/08/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W99

Thu 09/29/2022 to Sat 10/01/2022 **UPDATED by CONED 06/08/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBRK_345KV_RNS5

Thu 09/29/2022 to Sat 10/01/2022 **UPDATED by CONED 06/08/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EGRDNCTY_345_138_AT1

Sat 10/01/2022 to Wed 05/31/2023 **UPDATED by CONED 03/10/2022**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Sat 10/01/2022 to Wed 05/31/2023 **UPDATED by CONED 03/10/2022**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-EGRDNCTR_345_Y49				FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u> <u>by CONED</u> <u>03/10/2022</u>	(Import)	
0001	Continuous	2359		CONED - LIPA	775 MW
Work scheduled by: LI				Impacts Total Transfer Capability	725 MW
				TTC with All Lines In Service	1500 MW
CHAT_DC_GC1				FWD	
Sun 10/02/2022	to	Sun 10/02/2022		(Import)	
0001	Continuous	0200		MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV
Sun 10/02/2022	to	Sun 10/02/2022		(Export)	
0001	Continuous	0200		SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD	
Sun 10/02/2022	to	Sun 10/02/2022		(Import)	
0001		0200		MOSES SOUTH	2550 MW
Work scheduled by:				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD	REV
Sun 10/02/2022	to	Sun 10/02/2022		(Import)	(Export)
0001		0200		SCH - HQ - NY	1370 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	130 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2				FWD	
Sun 10/02/2022	to	Sun 10/02/2022		(Import)	
0001	Continuous	0200		MOSES SOUTH	2850 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					REV
Sun 10/02/2022	to	Sun 10/02/2022		(Export)	
0001	Continuous	0200		SCH - HQ - NY	500 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150					FWD	
Sun 10/02/2022	to	Sun 10/02/2022			(Import)	
0001	Continuous	0200		SCH - HQ - NY	1150 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW
CLRKSCRN-OAKDALE_345_36					FWD	
Mon 10/03/2022	to	Fri 10/07/2022	<u>UPDATED</u>	<u>by NYSEG</u>	<u>04/20/2022</u>	(Import)
0830	Continuous	1530		CENTRAL EAST - VC	2650 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>	(Import) (Export)
1000	Continuous	1500		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
W49TH_ST_345KV_7					FWD	
Tue 10/04/2022	to	Tue 10/04/2022			(Import)	
0201	Continuous	0230		SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8					FWD	
Tue 10/04/2022	to	Tue 10/04/2022			(Import)	
0201	Continuous	0230		SCH - PJM_HTP	450 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	210 MW
					TTC with All Lines In Service	660 MW
HUDSONTP-W49TH_ST_345_Y56					FWD	
Tue 10/04/2022	to	Sat 10/08/2022			(Import)	
0201	Continuous	1800		SCH - PJM_HTP	0 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
DUNWODIE_345KV_3					FWD	
Thu 10/06/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>	(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5					FWD
Thu 10/06/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>
0001	Continuous	0200			
Work scheduled by: ConEd					(Import)
					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE-MOTTHAVN_345_71					FWD
Thu 10/06/2022	to	Thu 11/10/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>
0001	Continuous	0300			
Work scheduled by: ConEd					(Import)
					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_7					FWD
Sat 10/08/2022	to	Sat 10/08/2022			
1730	Continuous	1800			
Work scheduled by: ConEd					(Import)
					SCH - PJM_HTP 300 MW
					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8					FWD
Sat 10/08/2022	to	Sat 10/08/2022			
1730	Continuous	1800			
Work scheduled by: ConEd					(Import)
					SCH - PJM_HTP 450 MW
					Impacts Total Transfer Capability 210 MW
					TTC with All Lines In Service 660 MW
EASTVIEW-SPRNBK__345_W79					FWD
Mon 10/17/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/18/2022</u>
0001	Continuous	0031			
Work scheduled by: ConEd					(Import)
					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
BUCHAN_N-EASTVIEW_345_W93					FWD
Mon 10/17/2022	to	Sat 11/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/18/2022</u>
0001	Continuous	0200			
Work scheduled by: ConEd					(Import)
					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
NIAGARA_-DYSINGER_345_ND1					FWD
Mon 10/17/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/10/2022</u>
0500	Continuous	1700			
Work scheduled by: NYPA					(Import)
					DYSINGER EAST 2700 MW
					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 3200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79

Mon 10/17/2022 to Mon 10/17/2022
2130 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 06/18/2022

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

RAMAPO__-BUCHAN_N_345_Y94

Tue 10/18/2022 to Sun 10/30/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 06/18/2022

FWD
(Import)
UPNY CONED **7580 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 7815 MW

PANNELL_-CLAY____345_1

Mon 10/24/2022 to Fri 10/28/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON__345_303

Mon 10/24/2022 to Fri 11/04/2022
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 04/13/2022

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

MAINESBG-WATRCURE_345_30

Tue 10/25/2022 to Tue 10/25/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

WATRCURE-OAKDALE__345_31

Thu 10/27/2022 to Thu 10/27/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY____345_2

Mon 10/31/2022 to Fri 11/04/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16				FWD
Tue 11/01/2022	to	Thu 11/03/2022	UPDATED by NGRID 05/09/2022	(Import)
0600	Continuous	1900	OSWEGO EXPORT	4850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 400 MW
				TTC with All Lines In Service 5250 MW
NEPTUNE -DUFFYAVE 345_NEPTUNE				FWD
Tue 11/01/2022	to	Sat 11/19/2022		(Import)
0600	Continuous	1600	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE 345_501				FWD
Tue 11/01/2022	to	Sat 11/19/2022		(Import)
0600	Continuous	1600	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE 345_138_BK_1				FWD
Tue 11/01/2022	to	Sat 11/19/2022		(Import)
0600	Continuous	1600	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
NEWBRDGE 345_138_BK_2				FWD
Tue 11/01/2022	to	Sat 11/19/2022		(Import)
0600	Continuous	1600	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
GILBOA -N.SCTLND 345_GNS-1				FWD
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED by NGRID 12/29/2021	(Import)
0700	Continuous	1900	CENTRAL EAST - VC	2520 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 455 MW
				TTC with All Lines In Service 2975 MW
LEEDS 345KV_R94301				FWD
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED by NGRID 12/29/2021	(Import)
0700	Continuous	1900	UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 4015 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED	by NGRID	12/29/2021	(Import)
0700	Continuous	1900				CENTRAL EAST - VC 1470 MW
Work scheduled by: NGrid					ARR: 19	Impacts Total Transfer Capability 1505 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
PORTER___-ROTTDAM_230_30 & MARCY___-N.SCTLND_345_18					FWD	
Tue 11/01/2022	to	Tue 12/06/2022				(Import)
0700		1900				CENTRAL EAST - VC 1300 MW
Work scheduled by:						Impacts Total Transfer Capability 1675 MW
						TTC with All Lines In Service 2975 MW
<hr/>						
LINDN_CG-LNDVFT___345_V-3022					FWD	REV
Tue 11/01/2022	to	Fri 11/04/2022				(Import) (Export)
0800	Continuous	1500				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 315 MW 315 MW
						TTC with All Lines In Service 315 MW 315 MW
<hr/>						
LEEDS___-HURLYAVE_345_301					FWD	
Mon 11/07/2022	to	Fri 12/09/2022				(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 3715 MW
						TTC with All Lines In Service 7815 MW
<hr/>						
DUNWODIE_345KV_3					FWD	
Thu 11/10/2022	to	Thu 11/10/2022	UPDATED	by CE	06/30/2022	(Import)
0230	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
DUNWODIE_345KV_5					FWD	
Thu 11/10/2022	to	Thu 11/10/2022	UPDATED	by CE	06/30/2022	(Import)
0230	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<hr/>						
MAINESBG-WATRCURE_345_30					FWD	
Thu 11/10/2022	to	Thu 11/10/2022				(Import)
0800	Continuous	1600				SCH - PJ - NY 2300 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 550 MW
						TTC with All Lines In Service 2850 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Tue 11/15/2022 to Thu 11/17/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

RAMAPO_-BUCHAN_N_345_Y94

Mon 11/21/2022 to Sat 11/26/2022 **UPDATED by CONED 06/18/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7580 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 7815 MW

E13THSTA-FARRAGUT_345_45

Mon 11/21/2022 to Fri 12/09/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

HOMRC_NY-MAINS_NY_345_47

Thu 11/24/2022 to Thu 11/24/2022
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

EASTVIEW-SPRNBK_345_W79

Sat 11/26/2022 to Sat 11/26/2022 **UPDATED by CONED 06/18/2022**
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W98

Tue 11/29/2022 to Thu 12/01/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD_345KV_18

Tue 11/29/2022 to Thu 12/01/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1			FWD	
Wed 11/30/2022	to	Wed 03/01/2023	(Import)	
0700	Continuous	1100	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
CRICKVLY-PLSNTVLY_345_F84			FWD	
Thu 12/01/2022	to	Thu 12/15/2022	(Import)	
0001	Continuous	2200	SCH - NE - NY	600 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F84			FWD	REV
Thu 12/01/2022	to	Thu 12/15/2022	(Import)	(Export)
0001	Continuous	2200	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
MILLWOOD_345KV_18			FWD	
Fri 12/02/2022	to	Mon 12/12/2022	(Import)	
0001	Continuous	1800	UPNY CONED	4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW
			TTC with All Lines In Service	7815 MW
MARCY___345KV_CSC			FWD	
Wed 12/07/2022	to	Tue 12/20/2022	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW
HOPATCON-RAMAPO___500_5018			FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	1650 MW 1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW 1000 MW
			TTC with All Lines In Service	2850 MW 2200 MW
HOPATCON-RAMAPO___500_5018			FWD	
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	
0001	Continuous	2000	TOTAL EAST	5200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	6000 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018			FWD	
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	
0001	Continuous	2000	UPNY CONED	7480 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
HOPATCON-RAMAPO___500_5018 & MARCY___345KV_CSC			FWD	
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	
0001		2000	TOTAL EAST	5100 MW
Work scheduled by:			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	6000 MW
RAMAPO___345_345_PAR3500			FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	2500 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___345_345_PAR4500			FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	2500 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500			FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	1650 MW 1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW 1000 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500			FWD	
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	
0001	Continuous	2000	UPNY CONED	7480 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
W49TH_ST-E13THSTA_345_M54			FWD	
Tue 12/13/2022	to	Wed 12/14/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F83

Fri 12/16/2022 to Sat 12/31/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - NE - NY **600 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1400 MW

CRICKVLY-PLSNTVLY_345_F83

Fri 12/16/2022 to Sat 12/31/2022
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

HOMRC_NY-MAINS_NY_345_47

Thu 12/22/2022 to Thu 12/22/2022
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

W49TH_ST-E13THSTA_345_M54

Sun 12/25/2022 to Sun 12/25/2022
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

CLAY__-EDIC__345_1-16

Fri 12/30/2022 to Sat 12/31/2022 **UPDATED by NGRID 05/09/2022**
 0600 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

FRASER__345_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

SPRNBRK__345KV_RNS5

Wed 03/01/2023 to Fri 03/17/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-W49TH_ST_345_M51				FWD	
Wed 03/01/2023	to	Sat 04/08/2023		(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
EDIC_-FRASER_345_EF24-40				FWD	
Wed 03/01/2023	to	Sat 04/15/2023		(Import)	
0600	Continuous	1800	CENTRAL EAST - VC	2500 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	475 MW	
			TTC with All Lines In Service	2975 MW	
N.SCTLND-ALPS_345_2				FWD	
Mon 03/27/2023	to	Fri 05/19/2023	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/16/2022</u>
0700	Continuous	1900	SCH - NE - NY	900 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	500 MW	
			TTC with All Lines In Service	1400 MW	
N.SCTLND-ALPS_345_2				FWD	REV
Mon 03/27/2023	to	Fri 05/19/2023	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/16/2022</u>
0700	Continuous	1900	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
PLSNTVLY_345KV_RNS4				FWD	
Sat 04/01/2023	to	Sat 04/01/2023		(Import)	
0700	Continuous	0730	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
ATHENS_-PLSNTVLY_345_91				FWD	
Sat 04/01/2023	to	Sat 04/15/2023		(Import)	
0700	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
MOTTHAVN-RAINEY_345_Q12				FWD	
Thu 04/13/2023	to	Sat 04/22/2023	<u>UPDATED</u>	<u>by CE</u>	<u>06/14/2022</u>
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

Sat 04/15/2023 to Sat 04/15/2023
 1830 Continuous 1900

Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Sun 04/16/2023 to Sun 04/16/2023
 0700 Continuous 0730

Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

LEEDS___-PLSNTVLY_345_92

Sun 04/16/2023 to Sun 04/30/2023
 0700 Continuous 1900

Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

CLAY___-EDIC___345_2-15

Mon 04/17/2023 to Fri 04/28/2023
 0600 Continuous 1800

Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

PANNELL_-CLAY___345_1

Mon 04/24/2023 to Fri 04/28/2023
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

MOTTHAVN-RAINEY___345_Q12

Tue 04/25/2023 to Tue 04/25/2023 **UPDATED by CE 06/14/2022**
 0130 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLY_345KV_RNS5

Sun 04/30/2023 to Sun 04/30/2023
 1830 Continuous 1900

Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
SHOR_NPX-SHOREHAM_138_CSC			FWD	REV
Mon 05/01/2023	to	Fri 05/05/2023	(Import) (Export)	
0600	Continuous	1800	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW 330 MW
			TTC with All Lines In Service	330 MW 330 MW
<hr/>				
PANNELL_-CLAY_____345_2			FWD	
Mon 05/01/2023	to	Fri 05/05/2023	(Import)	
0700	Continuous	1530	WEST CENTRAL	1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
<hr/>				
PLSNTVLY-WOOD_ST__345_F30			FWD	
Wed 05/03/2023	to	Mon 05/15/2023	(Import)	
0001	Continuous	2200	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
<hr/>				
PLSNTVLY_345KV_RNS5			FWD	
Wed 05/03/2023	to	Mon 05/15/2023	(Import)	
0001	Continuous	2200	UPNY CONED	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	4015 MW
			TTC with All Lines In Service	7815 MW
<hr/>				
W49TH_ST_345KV_6			FWD	
Sat 05/06/2023	to	Sat 05/06/2023	(Import)	
0001	Continuous	0030	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
<hr/>				
W49TH_ST_345KV_8			FWD	
Sat 05/06/2023	to	Sat 05/06/2023	(Import)	
0001	Continuous	0030	SCH - PJM_HTP	450 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW
			TTC with All Lines In Service	660 MW
<hr/>				
W49TH_ST_345KV_6			FWD	
Sat 05/13/2023	to	Sat 05/13/2023	(Import)	
0130	Continuous	0200	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY_345_Q11

Wed 05/17/2023 to Sat 05/20/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/06/2023
 0600 Continuous 1800
 Work scheduled by: LI

FWD REV
 (Import) (Export)
 SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/09/2023 to Fri 10/13/2023
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 08, 2022 to Wednesday,February 07, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Fri 12/08/2023 to Fri 12/15/2023 UPDATED by PJM 01/11/2022
 0800 Continuous 1600
 Work scheduled by: PJM
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023 UPDATED by PJM 01/11/2022
 0800 Continuous 1600
 Work scheduled by: PJM
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service