

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

<b>CENTRAL EAST</b>	<b>2650MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6000MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3200MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>HUDSONP_-FARRAGUT_345_B3402</b>			FWD
Mon 01/15/2018	to Tue 01/31/2023	<b><u>EXT FORCE</u> by <u>CONED</u> <u>08/06/2022</u></b>	(Import)
0001	Continuous 2359		<b>2050 MW</b>
Work scheduled by: ConEd			
		SCH - PJ - NY	200 MW
		Impacts Total Transfer Capability	2250 MW
		TTC with All Lines In Service	2250 MW
<hr/>			
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>			FWD REV
Mon 01/15/2018	to Tue 01/31/2023		(Import) (Export)
0001	2359		<b>2000 MW 1150 MW</b>
Work scheduled by:			
		SCH - PJ - NY	250 MW 50 MW
		Impacts Total Transfer Capability	2250 MW 1200 MW
		TTC with All Lines In Service	2250 MW 1200 MW
<hr/>			
<b>MARION_-FARRAGUT_345_C3403</b>			FWD
Mon 01/15/2018	to Tue 01/31/2023	<b><u>EXT FORCE</u> by <u>CONED</u> <u>08/06/2022</u></b>	(Import)
0001	Continuous 2359		<b>2050 MW</b>
Work scheduled by: ConEd			
		SCH - PJ - NY	200 MW
		Impacts Total Transfer Capability	2250 MW
		TTC with All Lines In Service	2250 MW
<hr/>			
<b>GORDONRD-ROTTDAM_230_31</b>			FWD
Wed 04/27/2022	to Mon 09/12/2022	<b><u>UPDATED</u> by <u>NYISO</u> <u>06/30/2022</u></b>	(Import)
1130	Continuous 1000		<b>2805 MW</b>
Work scheduled by: NYISO			
		CENTRAL EAST - VC	170 MW
		Impacts Total Transfer Capability	2975 MW
		TTC with All Lines In Service	2975 MW
<hr/>			
<b>SCH-IMO-NYISO_LIMIT_1500</b>			FWD
Wed 07/20/2022	to Mon 08/15/2022	<b><u>EXTENDED</u> by <u>IESO</u> <u>07/28/2022</u></b>	(Import)
0001	Continuous 0400		<b>1800 MW</b>
Work scheduled by: IESO			
		SCH - OH - NY	100 MW
		Impacts Total Transfer Capability	1900 MW
		TTC with All Lines In Service	1900 MW
<hr/>			
<b>STLAWRNC-MOSES_230_L34P</b>			FWD
Sat 07/30/2022	to Mon 08/15/2022	<b><u>UPDATED</u> by <u>IESO</u> <u>07/27/2022</u></b>	(Import)
1600	Continuous 0359		<b>2850 MW</b>
Work scheduled by: IESO			
		SCH - OH - NY	350 MW
		Impacts Total Transfer Capability	3200 MW
		TTC with All Lines In Service	3200 MW
<hr/>			
<b>DYSINGER-STA_255_345_DH2</b>			FWD
Mon 08/01/2022	to Sun 08/07/2022	<b><u>UPDATED</u> by <u>NYISO</u> <u>08/07/2022</u></b>	(Import)
2000	Continuous 0600		<b>2850 MW</b>
Work scheduled by: NT			
		DYSINGER EAST	350 MW
		Impacts Total Transfer Capability	3200 MW
		TTC with All Lines In Service	3200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-DYSINGER\_345\_ND2**

FWD

Mon 08/01/2022 to Sun 08/07/2022 **UPDATED** **by NYISO** **08/07/2022**  
 2000 Continuous 0600

Work scheduled by: NT

DYSINGER EAST **2700 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3200 MW

**NIAGARA\_-DYSINGER\_345\_ND2 & DYSINGER-STA\_255\_345\_DH2**

FWD

Wed 08/03/2022 to Thu 08/04/2022  
 2000 0600

Work scheduled by:

DYSINGER EAST **2500 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 3200 MW

**NIAGARA\_-DYSINGER\_345\_ND2 & DYSINGER-STA\_255\_345\_DH2**

FWD

Thu 08/04/2022 to Fri 08/05/2022  
 2000 0600

Work scheduled by:

DYSINGER EAST **2500 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 3200 MW

**NIAGARA\_-DYSINGER\_345\_ND2 & DYSINGER-STA\_255\_345\_DH2**

FWD

Fri 08/05/2022 to Sat 08/06/2022  
 2000 0600

Work scheduled by:

DYSINGER EAST **2500 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 3200 MW

**MARCY\_-EDIC\_345\_UE1-7**

FWD

Sat 08/06/2022 to Sun 08/07/2022 **UPDATED** **by NYPA** **08/07/2022**  
 0500 Continuous 1200

Work scheduled by: NYPA

**ARR: 19&16**

OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**VOLNEY\_-MARCY\_345\_19**

FWD

Sat 08/06/2022 to Sun 08/07/2022 **UPDATED** **by NYPA** **08/07/2022**  
 0500 Continuous 1200

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC **2825 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 2975 MW

**VOLNEY\_-MARCY\_345\_19**

FWD

Sat 08/06/2022 to Sun 08/07/2022 **UPDATED** **by NYPA** **08/07/2022**  
 0500 Continuous 1200

Work scheduled by: NYPA

**ARR: 19**

OSWEGO EXPORT **4900 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_1400</b>				FWD	
Sat 08/06/2022	to	Mon 08/08/2022	<b>CANCELLED by IESO 08/04/2022</b>	(Import)	
1301	Continuous	0900		SCH - OH - NY	<b>1700 MW</b>
Work scheduled by: IESO				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1900 MW
<b>LINDN_CG-LNDVFT___345_V-3022</b>				FWD	REV
Sat 08/06/2022	to	Sat 08/06/2022		(Import)	(Export)
1900	Continuous	2300		SCH - PJM_VFT	<b>0 MW 0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
<b>NIAGARA_-DYSINGER_345_ND2 &amp; DYSINGER-STA_255__345_DH2</b>				FWD	
Sat 08/06/2022	to	Sun 08/07/2022		(Import)	
2000		0600		DYSINGER EAST	<b>2500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	3200 MW
<b>NIAGARA_-DYSINGER_345_ND2 &amp; DYSINGER-STA_255__345_DH2</b>				FWD	
Tue 08/09/2022	to	Wed 08/10/2022		(Import)	
2000		1000		DYSINGER EAST	<b>2500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	3200 MW
<b>DYSINGER-STA_255__345_DH2</b>				FWD	
Tue 08/09/2022	to	Thu 08/11/2022	<b>UPDATED by NYISO 08/07/2022</b>	(Import)	
2000	Continuous	1000		DYSINGER EAST	<b>2850 MW</b>
Work scheduled by: NT				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	3200 MW
<b>NIAGARA_-DYSINGER_345_ND2</b>				FWD	
Tue 08/09/2022	to	Thu 08/11/2022	<b>UPDATED by NYISO 08/07/2022</b>	(Import)	
2000	Continuous	1000		DYSINGER EAST	<b>2700 MW</b>
Work scheduled by: NT				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	3200 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>				FWD	
Wed 08/10/2022	to	Tue 08/16/2022		(Import)	
0800	Continuous	1300		SCH - OH - NY	<b>1700 MW</b>
Work scheduled by: IESO				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1900 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NIAGARA\_-DYSINGER\_345\_ND2 & DYSINGER-STA\_255\_\_345\_DH2**

Wed 08/10/2022 to Thu 08/11/2022  
 2000 1000

Work scheduled by:

FWD  
 (Import)  
 DYSINGER EAST **2500 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 3200 MW

-----  
**BECK\_\_-NIAGARA\_345\_PA301**

Thu 08/11/2022 to Sun 08/14/2022  
 0500 Continuous 1900

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **900 MW 800 MW**  
 Impacts Total Transfer Capability 1000 MW 750 MW  
 TTC with All Lines In Service 1900 MW 1550 MW

-----  
**MOSES\_\_-ADIRNDCK\_230\_MA2**

Thu 08/11/2022 to Thu 09/15/2022 **UPDATED by NYPA 08/05/2022**  
 0500 Continuous 1100

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

-----  
**FRASANX-COOPERS\_\_345\_UCC2-41**

Thu 08/11/2022 to Fri 09/09/2022 **UPDATED by NYPA 08/05/2022**  
 0700 Continuous 1700

Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MARCY\_\_-FRASANX\_345\_UCC2-41**

Thu 08/11/2022 to Fri 09/09/2022 **UPDATED by NYPA 08/05/2022**  
 0700 Continuous 1700

Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

-----  
**NIAGARA\_-PACKARD\_\_230\_61**

Fri 08/12/2022 to Fri 08/12/2022  
 1100 Daily(No Weekends) 1500

Work scheduled by: NGrid

REV  
 (Export)  
 SCH - OH - NY **1350 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1550 MW

-----  
**STLAWRNC-MOSES\_\_230\_L34P**

Mon 08/15/2022 to Tue 04/18/2023 **EXTENDED by IESO 05/18/2022**  
 0400 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ\_LIMIT\_800

Mon 08/15/2022 to Tue 08/16/2022  
 0600 Continuous 1800  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1000 MW

REV  
 (Export)

800 MW

SCH-NYISO-HQ\_LIMIT\_800

Mon 08/22/2022 to Tue 08/23/2022  
 0600 Continuous 1800  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1000 MW

REV  
 (Export)

800 MW

SAND\_BAR-PLATSBURG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

BECK - PACKARD\_230\_BP76

Mon 08/22/2022 to Mon 08/22/2022 **UPDATED by NGRID 08/06/2022**  
 0800 Daily(No Weekends) 1159  
 Work scheduled by: NGrid

SCH - OH - NY  
 Impacts Total Transfer Capability 400 MW 550 MW  
 TTC with All Lines In Service 1900 MW 1550 MW

FWD REV  
 (Import) (Export)

1500 MW 1000 MW

W49TH\_ST\_345KV\_6

Sat 08/27/2022 to Sat 08/27/2022  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD  
 (Import)

300 MW

W49TH\_ST-E13THSTA\_345\_M55

Sat 08/27/2022 to Mon 08/29/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)

3800 MW

W49TH\_ST\_345KV\_6

Mon 08/29/2022 to Mon 08/29/2022  
 0130 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD  
 (Import)

300 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON\_-ROCKTVRN\_345\_311

Mon 08/29/2022 to Fri 09/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

EFISHKIL-WOOD\_ST\_345\_F38

Thu 09/01/2022 to Sat 09/03/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

PLSNTVLE-DUNWODIE\_345\_W89

Thu 09/01/2022 to Sat 09/03/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y86

Thu 09/01/2022 to Sat 09/03/2022  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

MOTTHAVN-RAINEY\_\_345\_Q12

Thu 09/01/2022 to Mon 09/05/2022 **UPDATED by CE 06/14/2022**  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_6

Mon 09/05/2022 to Wed 09/07/2022 **UPDATED by CONED 06/27/2022**  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_8

Mon 09/05/2022 to Wed 09/07/2022 **UPDATED by CONED 06/27/2022**  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>WOOD_ST_-PLSNTVLE_345_Y87</b>				FWD	
Mon 09/05/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>
0001	Continuous	2200			
Work scheduled by: ConEd			UPNY CONED		<b>7260 MW</b>
			Impacts Total Transfer Capability		555 MW
			TTC with All Lines In Service		7815 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>				FWD	
Mon 09/05/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>
0001	Continuous	0200			
Work scheduled by: ConEd			UPNY CONED		<b>4000 MW</b>
			Impacts Total Transfer Capability		3815 MW
			TTC with All Lines In Service		7815 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>				FWD	REV
Tue 09/06/2022	to	Sat 09/10/2022			
0500	Continuous	1700			
Work scheduled by: ISONE			SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					
Tue 09/06/2022	to	Tue 09/06/2022			
0730	Continuous	1800			
Work scheduled by: NGrid			SCH - PJ - NY		
			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
<b>EDIC___-N.SCTLND_345_14 &amp; GORDONRD-ROTRDAM_230_31</b>				FWD	
Thu 09/08/2022	to	Mon 09/12/2022			
0700		1000			
Work scheduled by:			CENTRAL EAST - VC	<b>1500 MW</b>	
			Impacts Total Transfer Capability	1475 MW	
			TTC with All Lines In Service	2975 MW	
<b>EDIC___-N.SCTLND_345_14</b>				FWD	
Thu 09/08/2022	to	Tue 12/31/2030	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/30/2022</u>
0700	Continuous	2359			
Work scheduled by: NGrid			CENTRAL EAST - VC	<b>1670 MW</b>	
			Impacts Total Transfer Capability	1305 MW	
			TTC with All Lines In Service	2975 MW	
<b>DUNWODIE_345KV_6</b>				FWD	
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>
0130	Continuous	0200			
Work scheduled by: ConEd			SPR/DUN-SOUTH	<b>3800 MW</b>	
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_8**

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200

UPDATED by CONED 06/27/2022

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200

UPDATED by CONED 06/27/2022

Work scheduled by: ConEd

FWD  
(Import)  
**7260 MW**  
UPNY CONED  
Impacts Total Transfer Capability 555 MW  
TTC with All Lines In Service 7815 MW

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sat 09/10/2022 to Sun 09/11/2022  
0201 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
**7680 MW**  
UPNY CONED  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

**SPRNBRK\_\_345KV\_RNS3**

Mon 09/12/2022 to Wed 09/14/2022  
0201 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**FRASER\_-GILBOA\_\_345\_GF5-35**

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

UPDATED by NYPA 08/02/2022

Work scheduled by: NYPA

FWD  
(Import)  
**2650 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**EDIC\_-N.SCTLND\_345\_14 & PORTER\_-ROTTDAM\_230\_30**

Mon 09/12/2022 to Tue 12/31/2030  
1200 Continuous 2359

Work scheduled by:

FWD  
(Import)  
**1500 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW

**PORTER\_-ROTTDAM\_230\_30**

Mon 09/12/2022 to Tue 12/31/2030  
1200 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
**2805 MW**  
CENTRAL EAST - VC  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Capability	Impacts	TTC
SCH-NE-NYISO_LIMIT_500	Wed 09/14/2022	Wed 09/14/2022	0600	Continuous	ISONE	700 MW	700 MW	1400 MW
W49TH_ST-E13THSTA_345_M54	Thu 09/15/2022	Thu 09/15/2022	0001	Continuous	ConEd	3800 MW	800 MW	4600 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4	Thu 09/15/2022	Fri 09/16/2022	0001			3200 MW	1400 MW	4600 MW
CRICKVLY-PLSNTVLY_345_F84	Thu 09/15/2022	Sat 09/17/2022	0001	Continuous	ConEd	300 MW	1100 MW	1400 MW
CRICKVLY-PLSNTVLY_345_F84	Thu 09/15/2022	Sat 09/17/2022	0001	Continuous	ConEd	100 MW	100 MW	200 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4	Thu 09/15/2022	Fri 10/14/2022	0001			3800 MW	4015 MW	7815 MW
EASTVIEW-SPRNBK__345_W78	Fri 09/16/2022	Mon 09/19/2022	2100	Continuous	ConEd	4350 MW	3465 MW	7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W85**

Fri 09/16/2022 to Mon 09/19/2022  
2100 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 06/25/2022

UPNY CONED

FWD

(Import)

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

**SPRNBRK\_345KV\_RNS3**

Fri 09/16/2022 to Mon 09/19/2022  
2100 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 06/25/2022

SPR/DUN-SOUTH

FWD

(Import)

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Mon 09/19/2022 to Mon 09/19/2022  
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD

(Import)

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

Mon 09/19/2022 to Mon 09/19/2022  
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD

(Import)

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Mon 09/19/2022 to Sun 09/25/2022  
0001 Continuous 0200

Work scheduled by: ConEd

CONED - LIPA

FWD

(Import)

**800 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 1**

Mon 09/19/2022 to Sun 09/25/2022  
0001 Continuous 0200

Work scheduled by: ConEd

CONED - LIPA

FWD

(Import)

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Mon 09/19/2022 to Sun 09/25/2022  
0001 Continuous 0200

Work scheduled by: ConEd

CONED - LIPA

FWD

(Import)

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD\_345KV\_18**

Mon 09/19/2022 to Mon 09/19/2022  
0201 Continuous 0230

**EXTENDED by CONED 07/22/2022**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**FRASER\_345\_FRASER SVC**

Mon 09/19/2022 to Tue 09/27/2022  
0600 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_-EDIC\_345\_UE1-7**

Mon 09/19/2022 to Sat 10/08/2022  
0700 Continuous 1530

**UPDATED by NGRID 06/06/2022**

Work scheduled by: NYPA

**ARR: 19&16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**COOPERS\_-DOLSONAV\_345\_CCDA42**

Mon 09/19/2022 to Thu 09/29/2022  
0800 Continuous 1630

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**LEEDS\_-HURLYAVE\_345\_301**

Mon 09/19/2022 to Fri 10/21/2022  
0800 Continuous 1600

Work scheduled by: CHGE

**10/04/2021**

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

**MILLWOOD\_345KV\_18**

Fri 09/23/2022 to Fri 09/23/2022  
2130 Continuous 2200

**EXTENDED by CONED 07/22/2022**

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**DUNWODIE\_345KV\_4**

Sat 09/24/2022 to Sun 09/25/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_6**

Sat 09/24/2022 to Sun 09/25/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Sat 09/24/2022 to Mon 09/26/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

Sat 09/24/2022 to Mon 09/26/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Sat 09/24/2022 to Tue 09/27/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**ADIRNDCK-PORTER\_\_230\_12**

Mon 09/26/2022 to Wed 11/30/2022  
 0630 Continuous 1700  
 Work scheduled by: NGrid

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Tue 09/27/2022 to Tue 09/27/2022  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7550 MW**  
 Impacts Total Transfer Capability 265 MW  
 TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

Tue 09/27/2022 to Tue 09/27/2022  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

Thu 09/29/2022 to Sat 10/01/2022  
0001 Continuous 0200

UPDATED by CONED 06/08/2022

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Thu 09/29/2022 to Sat 10/01/2022  
0001 Continuous 0200

UPDATED by CONED 06/08/2022

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

**SPRNBK\_\_345KV\_RNS5**

Thu 09/29/2022 to Sat 10/01/2022  
0001 Continuous 0200

UPDATED by CONED 06/08/2022

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**EGRDNCTY\_345\_138\_AT1**

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by CONED 03/10/2022

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by CONED 03/10/2022

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**SPRNBK\_-EGRDNCTR\_345\_Y49**

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by CONED 03/10/2022

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

**CHAT\_DC\_GC1**

Sun 10/02/2022 to Sun 10/02/2022  
0001 Continuous 0200

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>							REV
Sun 10/02/2022	to	Sun 10/02/2022					(Export)
0001	Continuous	0200		SCH - HQ - NY			<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability			500 MW
				TTC with All Lines In Service			1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>							FWD
Sun 10/02/2022	to	Sun 10/02/2022					(Import)
0001		0200		MOSES SOUTH			<b>2550 MW</b>
Work scheduled by:				Impacts Total Transfer Capability			600 MW
				TTC with All Lines In Service			3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>							FWD REV
Sun 10/02/2022	to	Sun 10/02/2022					(Import) (Export)
0001		0200		SCH - HQ - NY			<b>1370 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability			130 MW 1000 MW
				TTC with All Lines In Service			1500 MW 1000 MW
<b>CHAT_DC_GC2</b>							FWD
Sun 10/02/2022	to	Sun 10/02/2022					(Import)
0001	Continuous	0200		MOSES SOUTH			<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability			300 MW
				TTC with All Lines In Service			3150 MW
<b>CHAT_DC_GC2</b>							REV
Sun 10/02/2022	to	Sun 10/02/2022					(Export)
0001	Continuous	0200		SCH - HQ - NY			<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability			500 MW
				TTC with All Lines In Service			1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>							FWD
Sun 10/02/2022	to	Sun 10/02/2022					(Import)
0001	Continuous	0200		SCH - HQ - NY			<b>1150 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability			350 MW
				TTC with All Lines In Service			1500 MW
<b>CLRKSCRN-OAKDALE__345_36</b>							FWD
Mon 10/03/2022	to	Fri 10/07/2022	<b>UPDATED</b>				(Import)
0830	Continuous	1530	<b>by NYSEG 04/20/2022</b>	CENTRAL EAST - VC			<b>2650 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability			325 MW
				TTC with All Lines In Service			2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>SHOR_NPX-SHOREHAM_138_CSC</b>							
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>		
1000	Continuous	1500				SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
<b>W49TH_ST_345KV_7</b>							
Tue 10/04/2022	to	Tue 10/04/2022				SCH - PJM_HTP	<b>300 MW</b>
0201	Continuous	0230				Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>							
Tue 10/04/2022	to	Tue 10/04/2022				SCH - PJM_HTP	<b>450 MW</b>
0201	Continuous	0230				Impacts Total Transfer Capability	210 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>							
Tue 10/04/2022	to	Sat 10/08/2022				SCH - PJM_HTP	<b>0 MW</b>
0201	Continuous	1800				Impacts Total Transfer Capability	660 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
<b>DUNWODIE_345KV_3</b>							
Thu 10/06/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>		
0001	Continuous	0200				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_5</b>							
Thu 10/06/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>		
0001	Continuous	0200				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>							
Thu 10/06/2022	to	Thu 11/10/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>		
0001	Continuous	0300				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

Sat 10/08/2022 to Sat 10/08/2022  
 1730 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Sat 10/08/2022 to Sat 10/08/2022  
 1730 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP **450 MW**  
 Impacts Total Transfer Capability 210 MW  
 TTC with All Lines In Service 660 MW

**EASTVIEW-SPRNBK\_345\_W79**

Mon 10/17/2022 to Mon 10/17/2022 **UPDATED by CONED 06/18/2022**  
 0001 Continuous 0031  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Mon 10/17/2022 to Sat 11/26/2022 **UPDATED by CONED 06/18/2022**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 10/17/2022 to Fri 10/21/2022 **UPDATED by NYPA 02/10/2022**  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **2700 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3200 MW

**EASTVIEW-SPRNBK\_345\_W79**

Mon 10/17/2022 to Mon 10/17/2022 **UPDATED by CONED 06/18/2022**  
 2130 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

Tue 10/18/2022 to Sun 10/30/2022 **UPDATED by CONED 06/18/2022**  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7580 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL\_-CLAY\_\_\_\_\_345\_1

Mon 10/24/2022 to Fri 10/28/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON\_\_345\_303

Mon 10/24/2022 to Fri 11/04/2022 **UPDATED by CH 04/13/2022**  
0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

MAINESBG-WATRCURE\_345\_30

Tue 10/25/2022 to Tue 10/25/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

WATRCURE-OAKDALE\_\_345\_31

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 10/31/2022 to Fri 11/04/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

CLAY\_-EDIC\_\_\_\_\_345\_1-16

Tue 11/01/2022 to Thu 11/03/2022 **UPDATED by NGRID 05/09/2022**  
0600 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRDGE-DUFFYAVE\_345\_501**

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**GILBOA\_\_-N.SCTLND\_345\_GNS-1**

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by: NGrid

**UPDATED by NGRID 12/29/2021**

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

**LEEDS\_\_\_345KV\_R94301**

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by: NGrid

**UPDATED by NGRID 12/29/2021**

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**MARCY\_\_\_-N.SCTLND\_345\_18**

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by: NGrid

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

**PORTER\_\_-ROTTRDAM\_230\_30 & MARCY\_\_\_-N.SCTLND\_345\_18**

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1300 MW**  
Impacts Total Transfer Capability 1675 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Duration	Work by	Transfer Type	Import (MW)	Export (MW)	
LINDN_CG-LNDVFT_345_V-3022	Tue 11/01/2022	Fri 11/04/2022	0800	Continuous	1500	SCH - PJM_VFT	0 MW	0 MW	
Work scheduled by: PJM							Impacts Total Transfer Capability	315 MW	315 MW
							TTC with All Lines In Service	315 MW	315 MW
LEEDS_HURLYAVE_345_301	Mon 11/07/2022	Fri 12/09/2022	0800	Continuous	1600	UPNY CONED	4100 MW		
Work scheduled by: CHGE							Impacts Total Transfer Capability	3715 MW	
							TTC with All Lines In Service	7815 MW	
DUNWODIE_345KV_3	Thu 11/10/2022	Thu 11/10/2022	0230	Continuous	0300	SPR/DUN-SOUTH	3800 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_5	Thu 11/10/2022	Thu 11/10/2022	0230	Continuous	0300	SPR/DUN-SOUTH	3800 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
MAINESBG-WATRCURE_345_30	Thu 11/10/2022	Thu 11/10/2022	0800	Continuous	1600	SCH - PJ - NY	2300 MW		
Work scheduled by: PJM							Impacts Total Transfer Capability	550 MW	
							TTC with All Lines In Service	2850 MW	
W49TH_ST-E13THSTA_345_M54	Tue 11/15/2022	Thu 11/17/2022	0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
RAMAPO_BUCHAN_N_345_Y94	Mon 11/21/2022	Sat 11/26/2022	0001	Continuous	0200	UPNY CONED	7580 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	235 MW	
							TTC with All Lines In Service	7815 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_45**

Mon 11/21/2022 to Fri 12/09/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Wed 11/23/2022 to Wed 11/23/2022 UPDATED by PJM 08/09/2022  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**EASTVIEW-SPRNBK\_345\_W79**

Sat 11/26/2022 to Sat 11/26/2022 UPDATED by CONED 06/18/2022  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

Tue 11/29/2022 to Thu 12/01/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **7680 MW**  
 Impacts Total Transfer Capability 135 MW  
 TTC with All Lines In Service 7815 MW

**MILLWOOD\_345KV\_18**

Tue 11/29/2022 to Thu 12/01/2022  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**MOSES -ADIRNDCK\_230\_MA1**

Wed 11/30/2022 to Wed 03/01/2023  
 0700 Continuous 1100  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**CRICKVLY-PLSNTVLY\_345\_F84**

Thu 12/01/2022 to Thu 12/15/2022  
 0001 Continuous 2200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - NE - NY **600 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
<b>CRICKVLY-PLSNTVLY_345_F84</b>				
Thu 12/01/2022	to	Thu 12/15/2022		
0001	Continuous	2200	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
<b>MILLWOOD_345KV_18</b>				
Fri 12/02/2022	to	Mon 12/12/2022		
0001	Continuous	1800	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW
			TTC with All Lines In Service	7815 MW
<b>MARCY___345KV_CSC</b>				
Wed 12/07/2022	to	Tue 12/20/2022		
0700	Continuous	1530	CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW
<b>HOPATCON-RAMAPO___500_5018</b>				
Mon 12/12/2022	to	Fri 12/16/2022		
0001	Continuous	2000	SCH - PJ - NY	<b>1650 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW
			TTC with All Lines In Service	2850 MW
<b>HOPATCON-RAMAPO___500_5018</b>				
Mon 12/12/2022	to	Fri 12/16/2022		
0001	Continuous	2000	TOTAL EAST	<b>5200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	6000 MW
<b>HOPATCON-RAMAPO___500_5018</b>				
Mon 12/12/2022	to	Fri 12/16/2022		
0001	Continuous	2000	UPNY CONED	<b>7480 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
<b>HOPATCON-RAMAPO___500_5018 &amp; MARCY___345KV_CSC</b>				
Mon 12/12/2022	to	Fri 12/16/2022		
0001		2000	TOTAL EAST	<b>5100 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	6000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500			FWD	REV
			(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022		
0001	Continuous	2000	SCH - PJ - NY	<b>2500 MW</b> <b>1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___345_345_PAR4500			FWD	REV
			(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022		
0001	Continuous	2000	SCH - PJ - NY	<b>2500 MW</b> <b>1250 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500			FWD	REV
			(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022		
0001	Continuous	2000	SCH - PJ - NY	<b>1650 MW</b> <b>1200 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW 1000 MW
			TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500			FWD	
			(Import)	
Mon 12/12/2022	to	Fri 12/16/2022		
0001	Continuous	2000	UPNY CONED	<b>7480 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
W49TH_ST-E13THSTA_345_M54			FWD	
			(Import)	
Tue 12/13/2022	to	Wed 12/14/2022		
0001	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
CRICKVLY-PLSNTVLY_345_F83			FWD	
			(Import)	
Fri 12/16/2022	to	Sat 12/31/2022		
0001	Continuous	2200	SCH - NE - NY	<b>600 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F83			FWD	REV
			(Import)	(Export)
Fri 12/16/2022	to	Sat 12/31/2022		
0001	Continuous	2200	SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC\_NY-MAINS\_NY\_345\_47

Thu 12/22/2022 to Thu 12/22/2022  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

W49TH\_ST-E13THSTA\_345\_M54

Sun 12/25/2022 to Sun 12/25/2022  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

CLAY -EDIC 345\_1-16

Fri 12/30/2022 to Sat 12/31/2022 **UPDATED by NGRID 05/09/2022**  
 0600 Continuous 1900  
 Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

FRASER 345\_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2935 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW

SPRNBK\_345KV\_RNS5

Wed 03/01/2023 to Fri 03/17/2023  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

SPRNBK\_-W49TH\_ST\_345\_M51

Wed 03/01/2023 to Sat 04/08/2023  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

EDIC -FRASER 345\_EF24-40

Wed 03/01/2023 to Sat 04/15/2023  
 0600 Continuous 1800  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-ALPS</b> _____ <b>345_2</b>					FWD	
Mon 03/27/2023	to	Fri 05/19/2023	<b>UPDATED</b>	<b>by NGRID</b>	<b>06/16/2022</b>	(Import)
0700	Continuous	1900				<b>900 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	500 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	
<b>N. SCTLND-ALPS</b> _____ <b>345_2</b>					FWD	REV
Mon 03/27/2023	to	Fri 05/19/2023	<b>UPDATED</b>	<b>by NGRID</b>	<b>06/16/2022</b>	(Import) (Export)
0700	Continuous	1900				<b>100 MW 100 MW</b>
Work scheduled by: NGrid					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>PLSNTVLY_345KV_RNS4</b>					FWD	
Sat 04/01/2023	to	Sat 04/01/2023				(Import)
0700	Continuous	0730				<b>3800 MW</b>
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
<b>ATHENS</b> ___- <b>PLSNTVLY_345_91</b>					FWD	
Sat 04/01/2023	to	Sat 04/15/2023				(Import)
0700	Continuous	1900				<b>3800 MW</b>
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
<b>MOTTHAVN-RAINEY</b> _____ <b>345_Q12</b>					FWD	
Thu 04/13/2023	to	Sat 04/22/2023	<b>UPDATED</b>	<b>by CE</b>	<b>06/14/2022</b>	(Import)
0001	Continuous	0200				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
<b>PLSNTVLY_345KV_RNS4</b>					FWD	
Sat 04/15/2023	to	Sat 04/15/2023				(Import)
1830	Continuous	1900				<b>3800 MW</b>
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Sun 04/16/2023	to	Sun 04/16/2023				(Import)
0700	Continuous	0730				<b>3800 MW</b>
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	



# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS -PLSNTVLY_345_92</b>					FWD	
Sun 04/16/2023	to	Sun 04/30/2023			(Import)	
0700	Continuous	1900		UPNY CONED	<b>3800 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
<b>CLAY -EDIC_345_2-15</b>					FWD	
Mon 04/17/2023	to	Fri 04/28/2023			(Import)	
0600	Continuous	1800		OSWEGO EXPORT	<b>4850 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
<b>PANNELL -CLAY_345_1</b>					FWD	
Mon 04/24/2023	to	Fri 04/28/2023			(Import)	
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>MOTTHAVN-RAINEY_345_Q12</b>					FWD	
Tue 04/25/2023	to	Tue 04/25/2023	<b>UPDATED</b>	<b>by CE</b>	<b>06/14/2022</b>	(Import)
0130	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	<b>3800 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Sun 04/30/2023	to	Sun 04/30/2023			(Import)	
1830	Continuous	1900		UPNY CONED	<b>3800 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 05/01/2023	to	Fri 05/05/2023			(Import)	(Export)
0600	Continuous	1800		SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
<b>PANNELL -CLAY_345_2</b>					FWD	
Mon 05/01/2023	to	Fri 05/05/2023			(Import)	
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD\_ST\_\_345\_F30

Wed 05/03/2023 to Mon 05/15/2023  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

PLSNTVLY\_345KV\_RNS5

Wed 05/03/2023 to Mon 05/15/2023  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

W49TH\_ST\_345KV\_6

Sat 05/06/2023 to Sat 05/06/2023  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

W49TH\_ST\_345KV\_8

Sat 05/06/2023 to Sat 05/06/2023  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

W49TH\_ST\_345KV\_6

Sat 05/13/2023 to Sat 05/13/2023  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

W49TH\_ST\_345KV\_8

Sat 05/13/2023 to Sat 05/13/2023  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY\_\_345\_Q11

Wed 05/17/2023 to Sat 05/20/2023  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,August 09, 2022 to Thursday ,February 08, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC		FWD	REV
		(Import)	(Export)
Mon 10/02/2023	to Fri 10/06/2023		
0600	Continuous 1800	SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	330 MW 330 MW
		TTC with All Lines In Service	330 MW 330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE		FWD	
		(Import)	
Mon 10/09/2023	to Fri 10/13/2023		
0600	Continuous 1600	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	660 MW
		TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501		FWD	
		(Import)	
Mon 10/09/2023	to Fri 10/13/2023		
0600	Continuous 1600	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	660 MW
		TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1		FWD	
		(Import)	
Mon 10/09/2023	to Fri 10/13/2023		
0600	Continuous 1600	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2		FWD	
		(Import)	
Mon 10/09/2023	to Fri 10/13/2023		
0600	Continuous 1600	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
HOMRC_NY-MAINS_NY_345_47			
Fri 12/08/2023	to Fri 12/15/2023	<u>UPDATED</u>	<u>by PJM</u> <u>01/11/2022</u>
0800	Continuous 1600		
Work scheduled by: PJM		SCH - PJ - NY	
		Impacts Total Transfer Capability	
		TTC with All Lines In Service	
HOMR_NYW-PIERC_NY_345_48			
Fri 12/08/2023	to Fri 12/15/2023	<u>UPDATED</u>	<u>by PJM</u> <u>01/11/2022</u>
0800	Continuous 1600		
Work scheduled by: PJM		SCH - PJ - NY	
		Impacts Total Transfer Capability	
		TTC with All Lines In Service	