

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402				FWD	
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCE</u> <u>by CONED</u> <u>08/06/2022</u>	(Import)	
0001	Continuous	2359		SCH - PJ - NY	2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403				FWD	REV
Mon 01/15/2018	to	Tue 01/31/2023		(Import)	(Export)
0001		2359		SCH - PJ - NY	2000 MW 1150 MW
Work scheduled by:				Impacts Total Transfer Capability	250 MW 50 MW
				TTC with All Lines In Service	2250 MW 1200 MW
MARION_-FARRAGUT_345_C3403				FWD	
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCE</u> <u>by CONED</u> <u>08/06/2022</u>	(Import)	
0001	Continuous	2359		SCH - PJ - NY	2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
GORDONRD-ROTTDAM_230_31				FWD	
Wed 04/27/2022	to	Mon 09/12/2022	<u>UPDATED</u> <u>by NYISO</u> <u>06/30/2022</u>	(Import)	
1130	Continuous	1000		CENTRAL EAST - VC	2805 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW
SCH-IMO-NYISO_LIMIT_1500				FWD	
Wed 07/20/2022	to	Mon 08/15/2022	<u>EXTENDED</u> <u>by IESO</u> <u>07/28/2022</u>	(Import)	
0001	Continuous	0400		SCH - OH - NY	1800 MW
Work scheduled by: IESO				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	1900 MW
STLAWRNC-MOSES_230_L34P					
Sat 07/30/2022	to	Mon 08/15/2022	<u>UPDATED</u> <u>by IESO</u> <u>07/27/2022</u>		
1600	Continuous	0359		SCH - OH - NY	
Work scheduled by: IESO				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
DYSINGER-STA_255_345_DH2				FWD	
Mon 08/01/2022	to	Sun 08/07/2022	<u>UPDATED</u> <u>by NYISO</u> <u>08/07/2022</u>	(Import)	
2000	Continuous	0600		DYSINGER EAST	2850 MW
Work scheduled by: NT				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	3200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2				FWD	
Mon 08/01/2022	to	Sun 08/07/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/07/2022</u>
2000	Continuous	0600		DYSINGER EAST	2700 MW
Work scheduled by: NT				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	3200 MW
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA 255_345_DH2				FWD	
Fri 08/05/2022	to	Sat 08/06/2022		DYSINGER EAST	2500 MW
2000		0600		Impacts Total Transfer Capability	700 MW
Work scheduled by:				TTC with All Lines In Service	3200 MW
MARCY_-EDIC_345_UE1-7				FWD	
Sat 08/06/2022	to	Sun 08/07/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/07/2022</u>
0500	Continuous	1200		OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
VOLNEY_-MARC_345_19				FWD	
Sat 08/06/2022	to	Sun 08/07/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/07/2022</u>
0500	Continuous	1200		CENTRAL EAST - VC	2825 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2975 MW
VOLNEY_-MARC_345_19				FWD	
Sat 08/06/2022	to	Sun 08/07/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/07/2022</u>
0500	Continuous	1200		OSWEGO EXPORT	4900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	5250 MW
LINDN_CG-LNDVFT_345_V-3022				FWD	REV
Sat 08/06/2022	to	Sat 08/06/2022		SCH - PJM_VFT	0 MW 0 MW
1900	Continuous	2300		Impacts Total Transfer Capability	315 MW 315 MW
Work scheduled by: PJM				TTC with All Lines In Service	315 MW 315 MW
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA 255_345_DH2				FWD	
Sat 08/06/2022	to	Sun 08/07/2022		DYSINGER EAST	2500 MW
2000		0600		Impacts Total Transfer Capability	700 MW
Work scheduled by:				TTC with All Lines In Service	3200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255__345_DH2

Tue 08/09/2022 to Wed 08/10/2022
2000 1000

Work scheduled by:

FWD
(Import)
DYSINGER EAST **2500 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

DYSINGER-STA_255__345_DH2

Tue 08/09/2022 to Thu 08/11/2022 **UPDATED by NYISO 08/07/2022**
2000 Continuous 1000

Work scheduled by: NT

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

NIAGARA_-DYSINGER_345_ND2

Tue 08/09/2022 to Thu 08/11/2022 **UPDATED by NYISO 08/07/2022**
2000 Continuous 1000

Work scheduled by: NT

FWD
(Import)
DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

SCH-IMO-NYISO_LIMIT_1400

Wed 08/10/2022 to Tue 08/16/2022
0800 Continuous 1300

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY **1700 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1900 MW

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255__345_DH2

Wed 08/10/2022 to Thu 08/11/2022
2000 1000

Work scheduled by:

FWD
(Import)
DYSINGER EAST **2500 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

BECK_-NIAGARA_345_PA301

Thu 08/11/2022 to Sun 08/14/2022
0500 Continuous 1900

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **900 MW 800 MW**
Impacts Total Transfer Capability 1000 MW 750 MW
TTC with All Lines In Service 1900 MW 1550 MW

MOSES_-ADIRNDCK_230_MA2

Thu 08/11/2022 to Thu 09/15/2022 **UPDATED by NYPA 08/05/2022**
0500 Continuous 1100

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANX-COOPERS__345_UCC2-41

Thu 08/11/2022 to Fri 09/09/2022
0700 Continuous 1700

UPDATED by NYPA 08/05/2022

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Thu 08/11/2022 to Fri 09/09/2022
0700 Continuous 1700

UPDATED by NYPA 08/05/2022

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY_SO_SERIES_COMP_I/S

Thu 08/11/2022 to Fri 09/09/2022
0711 Continuous 1700

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

PLSNTVLE-DUNWODIE_345_W89

Fri 08/12/2022 to Fri 08/12/2022
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

EFISHKIL-WOOD_ST_345_F38

Fri 08/12/2022 to Mon 08/15/2022
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

WOOD_ST_-PLSNTVLE_345_Y86

Fri 08/12/2022 to Mon 08/15/2022
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7210 MW**
Impacts Total Transfer Capability 605 MW
TTC with All Lines In Service 7815 MW

NIAGARA_-PACKARD_230_61

Fri 08/12/2022 to Fri 08/12/2022
1100 Daily(No Weekends) 1500

Work scheduled by: NGrid

REV
(Export)
SCH - OH - NY **1350 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1550 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Mon 08/15/2022 to Mon 08/15/2022
0130 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

STLAWRNC-MOSES_230_L34P

Mon 08/15/2022 to Tue 04/18/2023
0400 Continuous 2359

Work scheduled by: IESO

EXTENDED by IESO 05/18/2022

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-NYISO-HQ_LIMIT_800

Mon 08/15/2022 to Tue 08/16/2022
0600 Continuous 1800

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY **800 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1000 MW

BECK_-PACKARD_230_BP76

Wed 08/17/2022 to Wed 08/17/2022
0800 Daily(No Weekends) 1159

Work scheduled by: NGrid

UPDATED by NGRID 08/06/2022

FWD

REV

(Import) (Export)

SCH - OH - NY **1500 MW 1000 MW**
Impacts Total Transfer Capability 400 MW 550 MW
TTC with All Lines In Service 1900 MW 1550 MW

SCH-NYISO-HQ_LIMIT_800

Mon 08/22/2022 to Tue 08/23/2022
0600 Continuous 1800

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY **800 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1000 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 08/22/2022 to Fri 08/26/2022
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

W49TH_ST_345KV_6

Sat 08/27/2022 to Sat 08/27/2022
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55			FWD	
Sat 08/27/2022	to	Mon 08/29/2022	(Import)	
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_6			FWD	
Mon 08/29/2022	to	Mon 08/29/2022	(Import)	
0130	Continuous	0200	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
ROSETON_-ROCKTVRN_345_311			FWD	
Mon 08/29/2022	to	Fri 09/09/2022	(Import)	
0800	Continuous	1600	UPNY CONED	4400 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability	3415 MW
			TTC with All Lines In Service	7815 MW
SCH-NYISO-IMO_NIAGARA_CB_3022			FWD	REV
Tue 08/30/2022	to	Tue 08/30/2022	(Import)	(Export)
0500	Continuous	1800	SCH - OH - NY	1250 MW 1100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	650 MW 450 MW
			TTC with All Lines In Service	1900 MW 1550 MW
EFISHKIL-WOOD_ST__345_F38			FWD	
Thu 09/01/2022	to	Sat 09/03/2022	(Import)	
0001	Continuous	2200	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
PLSNTVLE-DUNWODIE_345_W89			FWD	
Thu 09/01/2022	to	Sat 09/03/2022	(Import)	
0001	Continuous	2200	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
WOOD_ST_-PLSNTVLE_345_Y86			FWD	
Thu 09/01/2022	to	Sat 09/03/2022	(Import)	
0001	Continuous	2200	UPNY CONED	7210 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	605 MW
			TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY_345_Q12					FWD	
Thu 09/01/2022	to	Mon 09/05/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/14/2022</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_6					FWD	
Mon 09/05/2022	to	Wed 09/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	0300				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Mon 09/05/2022	to	Wed 09/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	0300				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Mon 09/05/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	2200				
Work scheduled by: ConEd					UPNY CONED	7260 MW
					Impacts Total Transfer Capability	555 MW
					TTC with All Lines In Service	7815 MW
PLSNTVLE-DUNWODIE_345_W90					FWD	
Mon 09/05/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
NRTH1385-NRTHPORT_138_NNC					FWD	REV
Tue 09/06/2022	to	Sat 09/10/2022				(Import) (Export)
0500	Continuous	1700				
Work scheduled by: ISONE					SCH - NPX_1385	0 MW 0 MW
					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
S.RIPLEY-DUNKIRK_230_68						
Tue 09/06/2022	to	Tue 09/06/2022				
0730	Continuous	1800				
Work scheduled by: NGrid					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC____-N.SCTLND_345_14 & MARCY_SO_SERIES_COMP_I/S

Thu 09/08/2022 to Fri 09/09/2022
0700 1700

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **1435 MW**
Impacts Total Transfer Capability 1540 MW
TTC with All Lines In Service 2975 MW

EDIC____-N.SCTLND_345_14 & GORDONRD-ROTTRDAM_230_31

Thu 09/08/2022 to Mon 09/12/2022
0700 1000

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **1500 MW**
Impacts Total Transfer Capability 1475 MW
TTC with All Lines In Service 2975 MW

EDIC____-N.SCTLND_345_14

Thu 09/08/2022 to Tue 12/31/2030 UPDATED by NGRID 06/30/2022
0700 Continuous 2359

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **1670 MW**
Impacts Total Transfer Capability 1305 MW
TTC with All Lines In Service 2975 MW

DUNWODIE_345KV_6

Sat 09/10/2022 to Sat 09/10/2022 UPDATED by CONED 06/27/2022
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sat 09/10/2022 to Sat 09/10/2022 UPDATED by CONED 06/27/2022
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

WOOD_ST_-PLSNTVLE_345_Y87

Sat 09/10/2022 to Sat 09/10/2022 UPDATED by CONED 06/27/2022
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7260 MW**
Impacts Total Transfer Capability 555 MW
TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W97

Sat 09/10/2022 to Sun 09/11/2022
0201 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3

Mon 09/12/2022 to Wed 09/14/2022
 0201 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FRASER__-GILBOA__345_GF5-35

Mon 09/12/2022 to Sun 09/18/2022 **UPDATED by NYPA 08/02/2022**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

EDIC__-N.SCTLND_345_14 & PORTER__-ROTTRDAM_230_30

Mon 09/12/2022 to Tue 12/31/2030
 1200 2359
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1500 MW**
 Impacts Total Transfer Capability 1475 MW
 TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_30

Mon 09/12/2022 to Tue 12/31/2030
 1200 Continuous 2359
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

SCH-NE-NYISO_LIMIT_500

Wed 09/14/2022 to Wed 09/14/2022
 0600 Continuous 1800
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **700 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1400 MW

W49TH_ST-E13THSTA_345_M54

Thu 09/15/2022 to Thu 09/15/2022
 0001 Continuous 0031
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Thu 09/15/2022 to Fri 09/16/2022
 0001 0300
 Work scheduled by:

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F84				FWD	
Thu 09/15/2022	to	Sat 09/17/2022		(Import)	
0001	Continuous	2200	SCH - NE - NY	300 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1100 MW	
			TTC with All Lines In Service	1400 MW	
CRICKVLY-PLSNTVLY_345_F84				FWD	REV
Thu 09/15/2022	to	Sat 09/17/2022		(Import)	(Export)
0001	Continuous	2200	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD	
Thu 09/15/2022	to	Fri 10/14/2022		(Import)	
0001		0200	UPNY CONED	3800 MW	
Work scheduled by:			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
MOSES -ADIRNDCK_230_MA2				FWD	
Thu 09/15/2022	to	Tue 11/29/2022		(Import)	
1101	Continuous	1800	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
EASTVIEW-SPRNBK__345_W78				FWD	
Fri 09/16/2022	to	Mon 09/19/2022	UPDATED	(Import)	
2100	Continuous	0200	by CONED 06/25/2022	UPNY CONED	4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
MILLWOOD-EASTVIEW_345_W85				FWD	
Fri 09/16/2022	to	Mon 09/19/2022	UPDATED	(Import)	
2100	Continuous	0200	by CONED 06/25/2022	UPNY CONED	7550 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	265 MW	
			TTC with All Lines In Service	7815 MW	
SPRNBK__345KV_RNS3				FWD	
Fri 09/16/2022	to	Mon 09/19/2022	UPDATED	(Import)	
2100	Continuous	0200	by CONED 06/25/2022	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

Mon 09/19/2022 to Mon 09/19/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Mon 09/19/2022 to Mon 09/19/2022
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Mon 09/19/2022 to Sun 09/25/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **800 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Mon 09/19/2022 to Sun 09/25/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Mon 09/19/2022 to Sun 09/25/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

MILLWOOD_345KV_18

Mon 09/19/2022 to Mon 09/19/2022 **EXTENDED** **by CONED** **07/22/2022**
 0201 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

FRASER_345_FRASER SVC

Mon 09/19/2022 to Tue 09/27/2022
 0600 Continuous 1700
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -EDIC 345 UE1-7

Mon 09/19/2022 to Sat 10/08/2022
0600 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 08/10/2022

ARR: 19&16

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

COOPERS -DOLSONAV 345 CCDA42

Mon 09/19/2022 to Thu 09/29/2022
0800 Continuous 1630

Work scheduled by: NYSEG

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

FWD
(Import)

LEEDS -HURLYAVE 345 301

Mon 09/19/2022 to Fri 10/21/2022
0800 Continuous 1600

Work scheduled by: CHGE

10/04/2021

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

MILLWOOD 345KV 18

Fri 09/23/2022 to Fri 09/23/2022
2130 Continuous 2200

Work scheduled by: ConEd

EXTENDED by CONED 07/22/2022

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

DUNWODIE 345KV 4

Sat 09/24/2022 to Sun 09/25/2022
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

DUNWODIE 345KV 6

Sat 09/24/2022 to Sun 09/25/2022
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

MILLWOOD-EASTVIEW 345 W99

Sat 09/24/2022 to Mon 09/26/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **7550 MW**
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5

Sat 09/24/2022 to Mon 09/26/2022
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Sat 09/24/2022 to Tue 09/27/2022
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

ADIRNDCK-PORTER__230_12

Mon 09/26/2022 to Wed 11/30/2022
 0630 Continuous 1700

Work scheduled by: NGrid

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MILLWOOD-EASTVIEW_345_W99

Tue 09/27/2022 to Tue 09/27/2022
 0130 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS5

Tue 09/27/2022 to Tue 09/27/2022
 0130 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Thu 09/29/2022 to Sat 10/01/2022 **UPDATED by CONED 06/08/2022**
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W99

Thu 09/29/2022 to Sat 10/01/2022 **UPDATED by CONED 06/08/2022**
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5					FWD	
Thu 09/29/2022	to	Sat 10/01/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/08/2022</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 4600 MW	
EGRDNCTY_345_138_AT1					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1500 MW	
EGRDNCTY_345_138_AT2					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW	
					TTC with All Lines In Service 1500 MW	
SPRNBK_-EGRDNCTR_345_Y49					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 775 MW
Work scheduled by: LI					Impacts Total Transfer Capability 725 MW	
					TTC with All Lines In Service 1500 MW	
CHAT_DC_GC1					FWD	
Sun 10/02/2022	to	Sun 10/02/2022				(Import)
0001	Continuous	0200				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	
CHAT_DC_GC1					REV	
Sun 10/02/2022	to	Sun 10/02/2022				(Export)
0001	Continuous	0200				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 1000 MW	
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Sun 10/02/2022	to	Sun 10/02/2022				(Import)
0001		0200				MOSES SOUTH 2550 MW
Work scheduled by:					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Start	End	Notes	FWD	REV
CHAT_DC_GC1 & CHAT_DC_GC2	Sun 10/02/2022	Sun 10/02/2022		(Import)	(Export)
0001	0001	0200		SCH - HQ - NY Impacts Total Transfer Capability TTC with All Lines In Service	1370 MW 0 MW 130 MW 1000 MW 1500 MW
Work scheduled by:					
CHAT_DC_GC2	Sun 10/02/2022	Sun 10/02/2022		FWD	(Import)
0001	0001	0200	Continuous	MOSES SOUTH	2850 MW
Work scheduled by: HQ					
CHAT_DC_GC2	Sun 10/02/2022	Sun 10/02/2022			REV
0001	0001	0200	Continuous	SCH - HQ - NY	500 MW
Work scheduled by: HQ					
SCH-HQ-NYISO_LIMIT_1150	Sun 10/02/2022	Sun 10/02/2022		FWD	(Import)
0001	0001	0200	Continuous	SCH - HQ - NY	1150 MW
Work scheduled by: HQ					
CLRKSCRN-OAKDALE__345_36	Mon 10/03/2022	Fri 10/07/2022	UPDATED by NYSEG 04/20/2022	FWD	(Import)
0830	0830	1530	Continuous	CENTRAL EAST - VC	2650 MW
Work scheduled by: NYSEG					
SHOR_NPX-SHOREHAM_138_CSC	Mon 10/03/2022	Fri 10/21/2022	UPDATED by LI 01/07/2022	FWD	REV
1000	1000	1500	Continuous	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI					
W49TH_ST_345KV_7	Tue 10/04/2022	Tue 10/04/2022		FWD	(Import)
0201	0201	0230	Continuous	SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Tue 10/04/2022 to Tue 10/04/2022
 0201 Continuous 0230
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

HUDSONTP-W49TH_ST_345_Y56

Tue 10/04/2022 to Sat 10/08/2022
 0201 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

DUNWODIE_345KV_3

Thu 10/06/2022 to Sun 10/16/2022 **UPDATED by CE 06/30/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Thu 10/06/2022 to Sun 10/16/2022 **UPDATED by CE 06/30/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_71

Thu 10/06/2022 to Thu 11/10/2022 **UPDATED by CE 06/30/2022**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_7

Sat 10/08/2022 to Sat 10/08/2022
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 10/08/2022 to Sat 10/08/2022
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79

Mon 10/17/2022 to Mon 10/17/2022
0001 Continuous 0031

UPDATED by CONED 06/18/2022

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

BUCHAN_N-EASTVIEW_345_W93

Mon 10/17/2022 to Sat 11/26/2022
0001 Continuous 0200

UPDATED by CONED 06/18/2022

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

NIAGARA_-DYSINGER_345_ND1

Mon 10/17/2022 to Fri 10/21/2022
0500 Continuous 1700

UPDATED by NYPA 02/10/2022

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

EASTVIEW-SPRNBK__345_W79

Mon 10/17/2022 to Mon 10/17/2022
2130 Continuous 2200

UPDATED by CONED 06/18/2022

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

RAMAPO__-BUCHAN_N_345_Y94

Tue 10/18/2022 to Sun 10/30/2022
0001 Continuous 0200

UPDATED by CONED 06/18/2022

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7580 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 7815 MW

PANNELL_-CLAY_____345_1

Mon 10/24/2022 to Fri 10/28/2022
0700 Continuous 1530

UPDATED by CH 04/13/2022

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON__345_303

Mon 10/24/2022 to Fri 11/04/2022
0800 Continuous 1600

UPDATED by CH 04/13/2022

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MAINESBG-WATRCURE_345_30

Tue 10/25/2022 to Tue 10/25/2022
 0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

WATRCURE-OAKDALE_345_31

Thu 10/27/2022 to Thu 10/27/2022
 0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL_-CLAY_345_2

Mon 10/31/2022 to Fri 11/04/2022
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

CLAY_-EDIC_345_1-16

Tue 11/01/2022 to Thu 11/03/2022
 0600 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 05/09/2022

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600

Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600

Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600

Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Tue 11/01/2022 to Sat 11/19/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

GILBOA__-N.SCTLND_345_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021
0700 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

LEEDS___345KV_R94301

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021
0700 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

MARCY___-N.SCTLND_345_18

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021
0700 Continuous 1900

Work scheduled by: NGrid

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **1470 MW**
Impacts Total Transfer Capability 1505 MW
TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_30 & MARCY___-N.SCTLND_345_18

Tue 11/01/2022 to Tue 12/06/2022
0700 1900

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **1300 MW**
Impacts Total Transfer Capability 1675 MW
TTC with All Lines In Service 2975 MW

LINDN_CG-LNDVFT___345_V-3022

Tue 11/01/2022 to Fri 11/04/2022
0800 Continuous 1500

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJM_VFT **0 MW 0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

LEEDS___-HURLYAVE_345_301

Mon 11/07/2022 to Fri 12/09/2022
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Thu 11/10/2022 to Thu 11/10/2022
 0230 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CE 06/30/2022

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

DUNWODIE_345KV_5

Thu 11/10/2022 to Thu 11/10/2022
 0230 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CE 06/30/2022

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

MAINESBG-WATRCURE_345_30

Thu 11/10/2022 to Thu 11/10/2022
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY **2300 MW**
 Impacts Total Transfer Capability 550 MW
 TTC with All Lines In Service 2850 MW

FWD
 (Import)

W49TH_ST-E13THSTA_345_M54

Tue 11/15/2022 to Thu 11/17/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

RAMAPO__-BUCHAN_N_345_Y94

Mon 11/21/2022 to Sat 11/26/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 06/18/2022

UPNY CONED **7580 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 7815 MW

FWD
 (Import)

E13THSTA-FARRAGUT_345_45

Mon 11/21/2022 to Fri 12/09/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

HOMRC_NY-MAINS_NY_345_47

Wed 11/23/2022 to Wed 11/23/2022
 0800 Continuous 1600
 Work scheduled by: PJM

UPDATED by PJM 08/09/2022

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79				FWD	
Sat 11/26/2022	to	Sat 11/26/2022	<u>UPDATED</u> <u>by CONED</u> <u>06/18/2022</u>	(Import)	
0130	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
BUCHAN_S-MILLWOOD_345_W98				FWD	
Tue 11/29/2022	to	Thu 12/01/2022		(Import)	
0001	Continuous	0200		UPNY CONED	7680 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	135 MW
				TTC with All Lines In Service	7815 MW
MILLWOOD_345KV_18				FWD	
Tue 11/29/2022	to	Thu 12/01/2022		(Import)	
0001	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
MOSES__-ADIRNDCK_230_MA1				FWD	
Wed 11/30/2022	to	Wed 03/01/2023		(Import)	
0700	Continuous	1100		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
CRICKVLY-PLSNTVLY_345_F84				FWD	
Thu 12/01/2022	to	Thu 12/15/2022		(Import)	
0001	Continuous	2200		SCH - NE - NY	600 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F84				FWD	REV
Thu 12/01/2022	to	Thu 12/15/2022		(Import)	(Export)
0001	Continuous	2200		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
MILLWOOD_345KV_18				FWD	
Fri 12/02/2022	to	Mon 12/12/2022		(Import)	
0001	Continuous	1800		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Wed 12/07/2022 to Tue 12/20/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

HOPATCON-RAMAPO___500_5018

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY **1650 MW 1200 MW**
Impacts Total Transfer Capability 1200 MW 1000 MW
TTC with All Lines In Service 2850 MW 2200 MW

HOPATCON-RAMAPO___500_5018

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD

(Import)

TOTAL EAST **5200 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 6000 MW

HOPATCON-RAMAPO___500_5018

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **7480 MW**
Impacts Total Transfer Capability 335 MW
TTC with All Lines In Service 7815 MW

HOPATCON-RAMAPO___500_5018 & MARCY___345KV_CSC

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by:

FWD

(Import)

TOTAL EAST **5100 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 6000 MW

RAMAPO___345_345_PAR3500

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY **2500 MW 1250 MW**
Impacts Total Transfer Capability 350 MW 950 MW
TTC with All Lines In Service 2850 MW 2200 MW

RAMAPO___345_345_PAR4500

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY **2500 MW 1250 MW**
Impacts Total Transfer Capability 350 MW 950 MW
TTC with All Lines In Service 2850 MW 2200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Area	Start	End	Time	Work	SCH	FWD	REV
RAMAPO_500_345_BK_1500	Mon 12/12/2022	Fri 12/16/2022	0001	Continuous	2000	(Import)	(Export)
				Work scheduled by: ConEd	SCH - PJ - NY	1650 MW	1200 MW
					Impacts Total Transfer Capability	1200 MW	1000 MW
					TTC with All Lines In Service	2850 MW	2200 MW
RAMAPO_500_345_BK_1500	Mon 12/12/2022	Fri 12/16/2022	0001	Continuous	2000	(Import)	
				Work scheduled by: ConEd	UPNY CONED	7480 MW	
					Impacts Total Transfer Capability	335 MW	
					TTC with All Lines In Service	7815 MW	
W49TH_ST-E13THSTA_345_M54	Tue 12/13/2022	Wed 12/14/2022	0001	Continuous	0200	(Import)	
				Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
CRICKVLY-PLSNTVLY_345_F83	Fri 12/16/2022	Sat 12/31/2022	0001	Continuous	2200	(Import)	
				Work scheduled by: ConEd	SCH - NE - NY	600 MW	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	1400 MW	
CRICKVLY-PLSNTVLY_345_F83	Fri 12/16/2022	Sat 12/31/2022	0001	Continuous	2200	(Import)	(Export)
				Work scheduled by: ConEd	SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
HOMRC_NY-MAINS_NY_345_47	Thu 12/22/2022	Thu 12/22/2022	0800	Continuous	1600		
				Work scheduled by: PJM	SCH - PJ - NY		
					Impacts Total Transfer Capability		
					TTC with All Lines In Service		
W49TH_ST-E13THSTA_345_M54	Sun 12/25/2022	Sun 12/25/2022	0130	Continuous	0200	(Import)	
				Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16				FWD	
Fri 12/30/2022	to	Sat 12/31/2022	<u>UPDATED</u> <u>by NGRID</u> <u>05/09/2022</u>	(Import)	
0600	Continuous	1900		OSWEGO EXPORT	4850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
FRASER 345_FRASER SVC				FWD	
Tue 01/03/2023	to	Tue 02/28/2023	<u>UPDATED</u> <u>by NYPA</u> <u>12/30/2021</u>	(Import)	
0700	Continuous	1730		CENTRAL EAST - VC	2935 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	2975 MW
EDIC -FRASER 345_EF24-40				FWD	
Wed 03/01/2023	to	Sat 04/15/2023		(Import)	
0600	Continuous	1800		CENTRAL EAST - VC	2500 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
N.SCTLND-ALPS 345_2				FWD	
Mon 03/27/2023	to	Fri 05/19/2023	<u>UPDATED</u> <u>by NGRID</u> <u>06/16/2022</u>	(Import)	
0700	Continuous	1900		SCH - NE - NY	900 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS 345_2				FWD	REV
Mon 03/27/2023	to	Fri 05/19/2023	<u>UPDATED</u> <u>by NGRID</u> <u>06/16/2022</u>	(Import)	(Export)
0700	Continuous	1900		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
PLSNTVLY_345KV_RNS4				FWD	
Sat 04/01/2023	to	Sat 04/01/2023		(Import)	
0700	Continuous	0730		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
ATHENS -PLSNTVLY_345_91				FWD	
Sat 04/01/2023	to	Sat 04/15/2023		(Import)	
0700	Continuous	1900		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q12

Thu 04/13/2023 to Sat 04/22/2023
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/14/2022

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

PLSNTVLY_345KV_RNS4

Sat 04/15/2023 to Sat 04/15/2023
1830 Continuous 1900

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

PLSNTVLY_345KV_RNS5

Sun 04/16/2023 to Sun 04/16/2023
0700 Continuous 0730

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

LEEDS___-PLSNTVLY_345_92

Sun 04/16/2023 to Sun 04/30/2023
0700 Continuous 1900

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

FWD
(Import)

CLAY___-EDIC___345_2-15

Mon 04/17/2023 to Fri 04/28/2023
0600 Continuous 1800

Work scheduled by: NGrid

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

FWD
(Import)

PANNELL_-CLAY___345_1

Mon 04/24/2023 to Fri 04/28/2023
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FWD
(Import)

MOTTHAVN-RAINEY___345_Q12

Tue 04/25/2023 to Tue 04/25/2023
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/14/2022

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Sun 04/30/2023 to Sun 04/30/2023
1830 Continuous 1900

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/01/2023 to Fri 05/05/2023
0600 Continuous 1800

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

PANNELL_-CLAY___345_2

Mon 05/01/2023 to Fri 05/05/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

PLSNTVLY-WOOD_ST__345_F30

Wed 05/03/2023 to Mon 05/15/2023
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Wed 05/03/2023 to Mon 05/15/2023
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_6

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY___345_Q11

Wed 05/17/2023 to Sat 05/20/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

CLAY___-EDIC___345_1-16

Mon 09/11/2023 to Fri 09/15/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

FRASER__-GILBOA___345_GF5-35

Mon 09/11/2023 to Sun 09/17/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

SPRNBRK_-W49TH_ST_345_M51

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15		FWD	
Mon 09/18/2023	to Fri 09/22/2023	(Import)	
0700	Continuous 1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
MARCY 345KV_CSC		FWD	
Mon 09/25/2023	to Sat 10/07/2023	(Import)	
0700	Continuous 1530	CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	50 MW
		TTC with All Lines In Service	2975 MW
SHOR_NPX-SHOREHAM_138_CSC		FWD	REV
Mon 10/02/2023	to Fri 10/06/2023	(Import)	(Export)
0600	Continuous 1800	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI		Impacts Total Transfer Capability	330 MW 330 MW
		TTC with All Lines In Service	330 MW 330 MW
NEPTUNE -DUFFYAVE_345_NEPTUNE		FWD	
Mon 10/09/2023	to Fri 10/13/2023	(Import)	
0600	Continuous 1600	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI		Impacts Total Transfer Capability	660 MW
		TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501		FWD	
Mon 10/09/2023	to Fri 10/13/2023	(Import)	
0600	Continuous 1600	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI		Impacts Total Transfer Capability	660 MW
		TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1		FWD	
Mon 10/09/2023	to Fri 10/13/2023	(Import)	
0600	Continuous 1600	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2		FWD	
Mon 10/09/2023	to Fri 10/13/2023	(Import)	
0600	Continuous 1600	SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI		Impacts Total Transfer Capability	285 MW
		TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Thursday ,August 11, 2022 to Saturday ,February 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-N.SCTLND_345_GNS-1

FWD

Mon 10/09/2023 to Fri 10/13/2023
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

HOMRC_NY-MAINS_NY_345_47

Fri 12/08/2023 to Fri 12/15/2023
0800 Continuous 1600

UPDATED by PJM 01/11/2022

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023
0800 Continuous 1600

UPDATED by PJM 01/11/2022

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service