

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 01/31/2023
0001 Continuous 2359

EXT FORCE by CONED 08/06/2022

Work scheduled by: ConEd

FWD
(Import)
SCH - PJ - NY 2050 MW
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 2250 MW

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Tue 01/31/2023
0001 2359

Work scheduled by:

FWD REV
(Import) (Export)
SCH - PJ - NY 2000 MW 1150 MW
Impacts Total Transfer Capability 250 MW 50 MW
TTC with All Lines In Service 2250 MW 1200 MW

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Tue 01/31/2023
0001 Continuous 2359

EXT FORCE by CONED 08/06/2022

Work scheduled by: ConEd

FWD
(Import)
SCH - PJ - NY 2050 MW
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 2250 MW

GORDONRD-ROTTDAM_230_31

Wed 04/27/2022 to Mon 09/12/2022
1130 Continuous 1000

UPDATED by NYISO 06/30/2022

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC 2805 MW
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

SCH-IMO-NYISO_LIMIT_1500

Wed 07/20/2022 to Mon 08/15/2022
0001 Continuous 0400

EXTENDED by IESO 07/28/2022

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY 1800 MW
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1900 MW

STLAWRNC-MOSES_230_L34P

Sat 07/30/2022 to Mon 08/15/2022
1600 Continuous 0359

UPDATED by IESO 07/27/2022

Work scheduled by: IESO

FWD
(Import)
SCH - OH - NY 1800 MW
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1900 MW

DYSINGER-STA_255_345_DH2

Mon 08/01/2022 to Sun 08/07/2022
2000 Continuous 0600

UPDATED by NYISO 08/07/2022

Work scheduled by: NT

FWD
(Import)
DYSINGER EAST 2850 MW
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2

Mon 08/01/2022 to Sun 08/07/2022
2000 Continuous 0600

UPDATED by NYISO 08/07/2022

Work scheduled by: NT

FWD
(Import)
DYSINGER EAST 2700 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

MARCY_-EDIC_345_UE1-7

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1200

UPDATED by NYPA 08/07/2022

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

VOLNEY_-MARCY_345_19

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1200

UPDATED by NYPA 08/07/2022

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC 2825 MW
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2975 MW

VOLNEY_-MARCY_345_19

Sat 08/06/2022 to Sun 08/07/2022
0500 Continuous 1200

UPDATED by NYPA 08/07/2022

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
OSWEGO EXPORT 4900 MW
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2

Sat 08/06/2022 to Sun 08/07/2022
2000 0600

Work scheduled by:

FWD
(Import)
DYSINGER EAST 2500 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2

Tue 08/09/2022 to Wed 08/10/2022
2000 1000

Work scheduled by:

FWD
(Import)
DYSINGER EAST 2500 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 3200 MW

DYSINGER-STA_255_345_DH2

Tue 08/09/2022 to Thu 08/11/2022
2000 Continuous 1000

UPDATED by NYISO 08/07/2022

Work scheduled by: NT

FWD
(Import)
DYSINGER EAST 2850 MW
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2					FWD	
Tue 08/09/2022	to	Thu 08/11/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/07/2022</u>	(Import)
2000	Continuous	1000				DYSINGER EAST 2700 MW
Work scheduled by: NT					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	3200 MW
SCH-IMO-NYISO_LIMIT_1400					FWD	
Wed 08/10/2022	to	Mon 08/22/2022		<u>by IESO</u>	<u>08/12/2022</u>	(Import)
0800	Continuous	0759				SCH - OH - NY 1700 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1900 MW
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2					FWD	
Wed 08/10/2022	to	Thu 08/11/2022				(Import)
2000		1000				DYSINGER EAST 2500 MW
Work scheduled by:					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	3200 MW
BECK_-NIAGARA_345_PA301					FWD	REV
Thu 08/11/2022	to	Sun 08/14/2022				(Import) (Export)
0500	Continuous	1900				SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1000 MW 750 MW
					TTC with All Lines In Service	1900 MW 1550 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Thu 08/11/2022	to	Thu 09/15/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0500	Continuous	1100				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
FRASANNX-COOPERS_345_UCC2-41					FWD	
Thu 08/11/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0700	Continuous	1700				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
MARCY_-FRASANNX_345_UCC2-41					FWD	
Thu 08/11/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0700	Continuous	1700				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

FWD

Thu 08/11/2022 to Fri 09/09/2022
0711 Continuous 1700

(Import)

Work scheduled by: NYISO

CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

HOMRC_NY-MAINS_NY_345_47

Thu 08/11/2022 to Mon 09/12/2022
2219 Continuous 2359

FORCED by NYSEG 08/12/2022

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PLSNTVLE-DUNWODIE_345_W89

FWD

Fri 08/12/2022 to Fri 08/12/2022
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

EFISHKIL-WOOD_ST_345_F38

FWD

Fri 08/12/2022 to Mon 08/15/2022
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

WOOD_ST_-PLSNTVLE_345_Y86

FWD

Fri 08/12/2022 to Mon 08/15/2022
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **7210 MW**
Impacts Total Transfer Capability 605 MW
TTC with All Lines In Service 7815 MW

NIAGARA_-PACKARD_230_61

REV

Fri 08/12/2022 to Fri 08/12/2022
1100 Daily(No Weekends) 1500

(Export)

Work scheduled by: NGrid

SCH - OH - NY **1350 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1550 MW

PLSNTVLE-DUNWODIE_345_W89

FWD

Mon 08/15/2022 to Mon 08/15/2022
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES 230_L34P									
Mon 08/15/2022	to	Tue 04/18/2023	EXTENDED	by IESO	05/18/2022	SCH - OH - NY			
0400	Continuous	2359				Impacts Total Transfer Capability			
Work scheduled by: IESO						TTC with All Lines In Service			
SCH-NYISO-HQ_LIMIT_800									
Mon 08/15/2022	to	Tue 08/16/2022				SCH - HQ - NY			REV
0600	Continuous	1800				Impacts Total Transfer Capability			(Export)
Work scheduled by: HQ						TTC with All Lines In Service			800 MW
									200 MW
									1000 MW
SCH-IMO-NYISO_LIMIT_1300									
Mon 08/15/2022	to	Mon 08/15/2022	UPDATED	by IESO	08/12/2022	SCH - OH - NY		FWD	
0700	Continuous	1759				Impacts Total Transfer Capability		(Import)	1600 MW
Work scheduled by: IESO						TTC with All Lines In Service			300 MW
									1900 MW
SCH-NYISO-IMO_LIMIT_1200									
Mon 08/15/2022	to	Mon 08/15/2022	UPDATED	by IESO	08/12/2022	SCH - OH - NY			REV
0700	Continuous	1759				Impacts Total Transfer Capability			(Export)
Work scheduled by: IESO						TTC with All Lines In Service			1500 MW
									50 MW
									1550 MW
BECK -PACKARD_230_BP76									
Wed 08/17/2022	to	Wed 08/17/2022	UPDATED	by NGRID	08/06/2022	SCH - OH - NY		FWD	REV
0800	Daily(No Weekends)	1159				Impacts Total Transfer Capability		(Import)	(Export)
Work scheduled by: NGrid						TTC with All Lines In Service			1500 MW 1000 MW
									400 MW 550 MW
									1900 MW 1550 MW
SCH-IMO-NYISO_LIMIT_1300									
Wed 08/17/2022	to	Sun 08/21/2022	UPDATED	by IESO	08/12/2022	SCH - OH - NY		FWD	
1200	Continuous	1659				Impacts Total Transfer Capability		(Import)	1600 MW
Work scheduled by: IESO						TTC with All Lines In Service			300 MW
									1900 MW
SCH-NYISO-IMO_LIMIT_1200									
Wed 08/17/2022	to	Sun 08/21/2022	UPDATED	by IESO	08/12/2022	SCH - OH - NY			REV
1200	Continuous	1659				Impacts Total Transfer Capability			(Export)
Work scheduled by: IESO						TTC with All Lines In Service			1500 MW
									50 MW
									1550 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_800					REV
Mon 08/22/2022	to	Tue 08/23/2022			(Export)
0600	Continuous	1800		SCH - HQ - NY	800 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1000 MW
<hr/>					
SAND_BAR-PLATSBURG_115_PV20					
Mon 08/22/2022	to	Fri 08/26/2022	UPDATED	by NYPA	08/12/2022
0700	Continuous	1530		SCH - NE - NY	
Work scheduled by: NYPA					Impacts Total Transfer Capability
					TTC with All Lines In Service
<hr/>					
W49TH_ST_345KV_6					FWD
Sat 08/27/2022	to	Sat 08/27/2022			(Import)
0001	Continuous	0030		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
<hr/>					
W49TH_ST-E13THSTA_345_M55					FWD
Sat 08/27/2022	to	Mon 08/29/2022			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
W49TH_ST_345KV_6					FWD
Mon 08/29/2022	to	Mon 08/29/2022			(Import)
0130	Continuous	0200		SCH - PJM_HTP	300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 360 MW
					TTC with All Lines In Service 660 MW
<hr/>					
ROSETON_-ROCKTVRN_345_311					FWD
Mon 08/29/2022	to	Fri 09/09/2022			(Import)
0800	Continuous	1600		UPNY CONED	4400 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability 3415 MW
					TTC with All Lines In Service 7815 MW
<hr/>					
SCH-NYISO-IMO_NIAGARA_CB_3022					FWD
Tue 08/30/2022	to	Tue 08/30/2022			REV
0500	Continuous	1800		SCH - OH - NY	1250 MW 1100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 650 MW 450 MW
					TTC with All Lines In Service 1900 MW 1550 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F38					FWD
Thu 09/01/2022	to	Sat 09/03/2022			(Import)
0001	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
PLSNTVLE-DUNWODIE_345_W89					FWD
Thu 09/01/2022	to	Sat 09/03/2022			(Import)
0001	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW
WOOD_ST_-PLSNTVLE_345_Y86					FWD
Thu 09/01/2022	to	Sat 09/03/2022			(Import)
0001	Continuous	2200		UPNY CONED	7210 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 605 MW
					TTC with All Lines In Service 7815 MW
MOTTHAVN-RAINEY__345_Q12					FWD
Thu 09/01/2022	to	Mon 09/05/2022	UPDATED	by CE	06/14/2022
0001	Continuous	0200			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_6					FWD
Mon 09/05/2022	to	Wed 09/07/2022	UPDATED	by CONED	06/27/2022
0001	Continuous	0300			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8					FWD
Mon 09/05/2022	to	Wed 09/07/2022	UPDATED	by CONED	06/27/2022
0001	Continuous	0300			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD
Mon 09/05/2022	to	Fri 09/09/2022	UPDATED	by CONED	06/27/2022
0001	Continuous	2200			(Import)
Work scheduled by: ConEd					UPNY CONED 7260 MW
					Impacts Total Transfer Capability 555 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90				FWD	
Mon 09/05/2022	to	Sat 09/10/2022	UPDATED	by CONED	06/27/2022
0001	Continuous	0200		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
NRTH1385-NRTHPORT_138_NNC				FWD	REV
Tue 09/06/2022	to	Sat 09/10/2022		(Import)	(Export)
0500	Continuous	1700		SCH - NPX_1385	0 MW 0 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
S.RIPLEY-DUNKIRK_230_68					
Tue 09/06/2022	to	Tue 09/06/2022		SCH - PJ - NY	
0730	Continuous	1800		Impacts Total Transfer Capability	
Work scheduled by: NGrid				TTC with All Lines In Service	
EDIC____-N.SCTLND_345_14 & MARCY_SO_SERIES_COMP_I/S				FWD	
Thu 09/08/2022	to	Fri 09/09/2022		(Import)	
0700		1700		CENTRAL EAST - VC	1435 MW
Work scheduled by:				Impacts Total Transfer Capability	1540 MW
				TTC with All Lines In Service	2975 MW
EDIC____-N.SCTLND_345_14 & GORDONRD-ROTTRDAM_230_31				FWD	
Thu 09/08/2022	to	Mon 09/12/2022		(Import)	
0700		1000		CENTRAL EAST - VC	1500 MW
Work scheduled by:				Impacts Total Transfer Capability	1475 MW
				TTC with All Lines In Service	2975 MW
EDIC____-N.SCTLND_345_14				FWD	
Thu 09/08/2022	to	Tue 12/31/2030	UPDATED	by NGRID	06/30/2022
0700	Continuous	2359		CENTRAL EAST - VC	1670 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1305 MW
				TTC with All Lines In Service	2975 MW
DUNWODIE_345KV_6				FWD	
Sat 09/10/2022	to	Sat 09/10/2022	UPDATED	by CONED	06/27/2022
0130	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8					FWD	
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0130	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/27/2022</u>	(Import)
0130	Continuous	0200				UPNY CONED 7260 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	555 MW
					TTC with All Lines In Service	7815 MW
BUCHAN_S-MILLWOOD_345_W97					FWD	
Sat 09/10/2022	to	Sun 09/11/2022				(Import)
0201	Continuous	2200				UPNY CONED 7680 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	7815 MW
SPRNBRK__345KV_RNS3					FWD	
Mon 09/12/2022	to	Wed 09/14/2022				(Import)
0201	Continuous	1800				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
FRASER_-GILBOA__345_GF5-35					FWD	
Mon 09/12/2022	to	Sun 09/18/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/02/2022</u>	(Import)
0700	Continuous	1530				CENTRAL EAST - VC 2650 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
EDIC____-N.SCTLND_345_14 & PORTER_-ROTTDAM_230_30					FWD	
Mon 09/12/2022	to	Tue 12/31/2030				(Import)
1200		2359				CENTRAL EAST - VC 1500 MW
Work scheduled by:					Impacts Total Transfer Capability	1475 MW
					TTC with All Lines In Service	2975 MW
PORTER_-ROTTDAM_230_30					FWD	
Mon 09/12/2022	to	Tue 12/31/2030				(Import)
1200	Continuous	2359				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Work Scheduled by	Zone	Impact	TTC
SCH-NE-NYISO_LIMIT_500	Wed 09/14/2022	Wed 09/14/2022	0600 - 1800	ISONE	SCH - NE - NY	700 MW	1400 MW
W49TH_ST-E13THSTA_345_M54	Thu 09/15/2022	Thu 09/15/2022	0001 - 0031	ConEd	SPR/DUN-SOUTH	800 MW	4600 MW
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4	Thu 09/15/2022	Fri 09/16/2022	0001 - 0300		SPR/DUN-SOUTH	1400 MW	4600 MW
CRICKVLY-PLSNTVLY_345_F84	Thu 09/15/2022	Sat 09/17/2022	0001 - 2200	ConEd	SCH - NE - NY	1100 MW	1400 MW
CRICKVLY-PLSNTVLY_345_F84	Thu 09/15/2022	Sat 09/17/2022	0001 - 2200	ConEd	SCH - NPX_1385	100 MW	200 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4	Thu 09/15/2022	Fri 10/14/2022	0001 - 0200		UPNY CONED	4015 MW	7815 MW
MOSES__-ADIRNDCK_230_MA2	Thu 09/15/2022	Tue 11/29/2022	1101 - 1800	NYPA	MOSES SOUTH	1050 MW	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W78					FWD	
Fri 09/16/2022	to	Mon 09/19/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/25/2022</u>	(Import)
2100	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW	TTC with All Lines In Service 7815 MW
MILLWOOD-EASTVIEW_345_W85					FWD	
Fri 09/16/2022	to	Mon 09/19/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/25/2022</u>	(Import)
2100	Continuous	0200				UPNY CONED 7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW	TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RNS3					FWD	
Fri 09/16/2022	to	Mon 09/19/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/25/2022</u>	(Import)
2100	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_4					FWD	
Mon 09/19/2022	to	Mon 09/19/2022				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_6					FWD	
Mon 09/19/2022	to	Mon 09/19/2022				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
DUNWODIE-SHORE_RD_345_Y50					FWD	
Mon 09/19/2022	to	Sun 09/25/2022				(Import)
0001	Continuous	0200				CONED - LIPA 800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 700 MW	TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK_1					FWD	
Mon 09/19/2022	to	Sun 09/25/2022				(Import)
0001	Continuous	0200				CONED - LIPA 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW	TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2				FWD
Mon 09/19/2022	to	Sun 09/25/2022		(Import)
0001	Continuous	0200	CONED - LIPA	1350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
MILLWOOD_345KV_18				FWD
Mon 09/19/2022	to	Mon 09/19/2022	EXTENDED by CONED 07/22/2022	(Import)
0201	Continuous	0230	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
FRASER_345_FRASER SVC				FWD
Mon 09/19/2022	to	Tue 09/27/2022		(Import)
0600	Continuous	1700	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 40 MW
				TTC with All Lines In Service 2975 MW
MARCY_-EDIC_345_UE1-7				FWD
Mon 09/19/2022	to	Sat 10/08/2022	UPDATED by NYPA 08/10/2022	(Import)
0600	Continuous	1930	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
COOPERS_-DOLSONAV_345_CCDA42				FWD
Mon 09/19/2022	to	Thu 09/29/2022		(Import)
0800	Continuous	1630	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
LEEDS_-HURLYAVE_345_301				FWD
Mon 09/19/2022	to	Fri 10/21/2022	10/04/2021	(Import)
0800	Continuous	1600	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 3715 MW
				TTC with All Lines In Service 7815 MW
MILLWOOD_345KV_18				FWD
Fri 09/23/2022	to	Fri 09/23/2022	EXTENDED by CONED 07/22/2022	(Import)
2130	Continuous	2200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
DUNWODIE_345KV_4			FWD	
Sat 09/24/2022	to	Sun 09/25/2022		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
DUNWODIE_345KV_6			FWD	
Sat 09/24/2022	to	Sun 09/25/2022		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
MILLWOOD-EASTVIEW_345_W99			FWD	
Sat 09/24/2022	to	Mon 09/26/2022		(Import)
0001	Continuous	0200	UPNY CONED	7550 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	265 MW
			TTC with All Lines In Service	7815 MW
<hr/>				
SPRNBRK__345KV_RNS5			FWD	
Sat 09/24/2022	to	Mon 09/26/2022		(Import)
0001	Continuous	0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
<hr/>				
EASTVIEW-SPRNBRK__345_W64			FWD	
Sat 09/24/2022	to	Tue 09/27/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW
			TTC with All Lines In Service	7815 MW
<hr/>				
ADIRNDCK-PORTER__230_12			FWD	
Mon 09/26/2022	to	Wed 11/30/2022		(Import)
0630	Continuous	1700	MOSES SOUTH	2100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
MILLWOOD-EASTVIEW_345_W99			FWD	
Tue 09/27/2022	to	Tue 09/27/2022		(Import)
0130	Continuous	0200	UPNY CONED	7550 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	265 MW
			TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5					FWD
Tue 09/27/2022	to	Tue 09/27/2022			(Import)
0130	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK__345_W64					FWD
Thu 09/29/2022	to	Sat 10/01/2022	<u>UPDATED</u>	<u>by CONED</u> <u>06/08/2022</u>	(Import)
0001	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3465 MW
					TTC with All Lines In Service 7815 MW
MILLWOOD-EASTVIEW_345_W99					FWD
Thu 09/29/2022	to	Sat 10/01/2022	<u>UPDATED</u>	<u>by CONED</u> <u>06/08/2022</u>	(Import)
0001	Continuous	0200		UPNY CONED	7550 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 265 MW
					TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RNS5					FWD
Thu 09/29/2022	to	Sat 10/01/2022	<u>UPDATED</u>	<u>by CONED</u> <u>06/08/2022</u>	(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
EGRDNCTY_345_138_AT1					FWD
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u> <u>03/10/2022</u>	(Import)
0001	Continuous	2359		CONED - LIPA	1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT2					FWD
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u> <u>03/10/2022</u>	(Import)
0001	Continuous	2359		CONED - LIPA	1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49					FWD
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u> <u>03/10/2022</u>	(Import)
0001	Continuous	2359		CONED - LIPA	775 MW
Work scheduled by: LI					Impacts Total Transfer Capability 725 MW
					TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1			FWD
Sun 10/02/2022	to	Sun 10/02/2022	(Import)
0001	Continuous	0200	MOSES SOUTH 2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
CHAT_DC_GC1			REV
Sun 10/02/2022	to	Sun 10/02/2022	(Export)
0001	Continuous	0200	SCH - HQ - NY 500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2			FWD
Sun 10/02/2022	to	Sun 10/02/2022	(Import)
0001		0200	MOSES SOUTH 2550 MW
Work scheduled by:			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2			FWD REV
Sun 10/02/2022	to	Sun 10/02/2022	(Import) (Export)
0001		0200	SCH - HQ - NY 1370 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability 130 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW
CHAT_DC_GC2			FWD
Sun 10/02/2022	to	Sun 10/02/2022	(Import)
0001	Continuous	0200	MOSES SOUTH 2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
CHAT_DC_GC2			REV
Sun 10/02/2022	to	Sun 10/02/2022	(Export)
0001	Continuous	0200	SCH - HQ - NY 500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_1150			FWD
Sun 10/02/2022	to	Sun 10/02/2022	(Import)
0001	Continuous	0200	SCH - HQ - NY 1150 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 350 MW
			TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Time	Duration	Work Scheduled by	Status	Authority	Effective Date	Impact	TTC with All Lines In Service
CLRKSCRN-OAKDALE__345_36	Mon 10/03/2022	Fri 10/07/2022	0830	Continuous	1530	Work scheduled by: NYSEG	UPDATED	by NYSEG	04/20/2022	FWD (Import) CENTRAL EAST - VC 2650 MW Impacts Total Transfer Capability 325 MW TTC with All Lines In Service 2975 MW
SHOR_NPX-SHOREHAM_138_CSC	Mon 10/03/2022	Fri 10/21/2022	1000	Continuous	1500	Work scheduled by: LI	UPDATED	by LI	01/07/2022	FWD REV (Import) (Export) SCH - NPX_CSC 0 MW 0 MW Impacts Total Transfer Capability 330 MW 330 MW TTC with All Lines In Service 330 MW 330 MW
W49TH_ST_345KV_7	Tue 10/04/2022	Tue 10/04/2022	0201	Continuous	0230	Work scheduled by: ConEd				FWD (Import) SCH - PJM_HTP 300 MW Impacts Total Transfer Capability 360 MW TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8	Tue 10/04/2022	Tue 10/04/2022	0201	Continuous	0230	Work scheduled by: ConEd				FWD (Import) SCH - PJM_HTP 450 MW Impacts Total Transfer Capability 210 MW TTC with All Lines In Service 660 MW
HUDSONTP-W49TH_ST_345_Y56	Tue 10/04/2022	Sat 10/08/2022	0201	Continuous	1800	Work scheduled by: ConEd				FWD (Import) SCH - PJM_HTP 0 MW Impacts Total Transfer Capability 660 MW TTC with All Lines In Service 660 MW
DUNWODIE_345KV_3	Thu 10/06/2022	Sun 10/16/2022	0001	Continuous	0200	Work scheduled by: ConEd	UPDATED	by CE	06/30/2022	FWD (Import) SPR/DUN-SOUTH 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_5	Thu 10/06/2022	Sun 10/16/2022	0001	Continuous	0200	Work scheduled by: ConEd	UPDATED	by CE	06/30/2022	FWD (Import) SPR/DUN-SOUTH 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71						FWD
Thu 10/06/2022	to	Thu 11/10/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_7						FWD
Sat 10/08/2022	to	Sat 10/08/2022				(Import)
1730	Continuous	1800				SCH - PJM_HTP 300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 360 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8						FWD
Sat 10/08/2022	to	Sat 10/08/2022				(Import)
1730	Continuous	1800				SCH - PJM_HTP 450 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 210 MW
						TTC with All Lines In Service 660 MW
EASTVIEW-SPRNBK__345_W79						FWD
Mon 10/17/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/18/2022</u>	(Import)
0001	Continuous	0031				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
BUCHAN_N-EASTVIEW_345_W93						FWD
Mon 10/17/2022	to	Sat 11/26/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/18/2022</u>	(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
NIAGARA_-DYSINGER_345_ND1						FWD
Mon 10/17/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/10/2022</u>	(Import)
0500	Continuous	1700				DYSINGER EAST 2700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 3200 MW
EASTVIEW-SPRNBK__345_W79						FWD
Mon 10/17/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/18/2022</u>	(Import)
2130	Continuous	2200				UPNY CONED 4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-BUCHAN_N_345_Y94

Tue 10/18/2022 to Sun 10/30/2022
0001 Continuous 0200

UPDATED by CONED 06/18/2022

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7580 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 7815 MW

PANNELL_-CLAY_____345_1

Mon 10/24/2022 to Fri 10/28/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON__345_303

Mon 10/24/2022 to Fri 11/04/2022
0800 Continuous 1600

UPDATED by CH 04/13/2022

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

MAINESBG-WATRCURE_345_30

Tue 10/25/2022 to Tue 10/25/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

WATRCURE-OAKDALE__345_31

Thu 10/27/2022 to Thu 10/27/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY_____345_2

Mon 10/31/2022 to Fri 11/04/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CLAY_____-EDIC_____345_1-16

Tue 11/01/2022 to Thu 11/03/2022
0600 Continuous 1900

UPDATED by NGRID 05/09/2022

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

GILBOA_-N.SCTLND_345_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

LEEDS_345KV_R94301

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

MARCY_-N.SCTLND_345_18

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **1470 MW**
 Impacts Total Transfer Capability 1505 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER__-ROTTRDAM_230_30 & MARCY__-N.SCTLND_345_18

Tue 11/01/2022 to Tue 12/06/2022
 0700 1900

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW

LINDN_CG-LNDVFT__345_V-3022

Tue 11/01/2022 to Fri 11/04/2022
 0800 Continuous 1500

Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJM_VFT **0 MW 0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

LEEDS__-HURLYAVE_345_301

Mon 11/07/2022 to Fri 12/09/2022
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_3

Thu 11/10/2022 to Thu 11/10/2022 **UPDATED by CE 06/30/2022**
 0230 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Thu 11/10/2022 to Thu 11/10/2022 **UPDATED by CE 06/30/2022**
 0230 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MAINESBG-WATRCURE_345_30

Thu 11/10/2022 to Thu 11/10/2022
 0800 Continuous 1600

Work scheduled by: PJM

FWD
 (Import)
 SCH - PJ - NY **2300 MW**
 Impacts Total Transfer Capability 550 MW
 TTC with All Lines In Service 2850 MW

W49TH_ST-E13THSTA_345_M54

Tue 11/15/2022 to Thu 11/17/2022
 0001 Continuous 0200

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-BUCHAN_N_345_Y94

FWD

Mon 11/21/2022 to Sat 11/26/2022 UPDATED by CONED 06/18/2022
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **7580 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 7815 MW

E13THSTA-FARRAGUT_345_45

FWD

Mon 11/21/2022 to Fri 12/09/2022
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

HOMRC_NY-MAINS_NY_345_47

Wed 11/23/2022 to Wed 11/23/2022 UPDATED by PJM 08/09/2022
 0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

EASTVIEW-SPRNBK__345_W79

FWD

Sat 11/26/2022 to Sat 11/26/2022 UPDATED by CONED 06/18/2022
 0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W98

FWD

Tue 11/29/2022 to Thu 12/01/2022
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD_345KV_18

FWD

Tue 11/29/2022 to Thu 12/01/2022
 0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MOSES__-ADIRNDCK_230_MAL

FWD

Wed 11/30/2022 to Wed 03/01/2023
 0700 Continuous 1100

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F84	FWD	REV
Thu 12/01/2022 to Thu 12/15/2022	(Import)	
0001 Continuous 2200	SCH - NE - NY Impacts Total Transfer Capability TTC with All Lines In Service	600 MW 800 MW 1400 MW
Work scheduled by: ConEd		
CRICKVLY-PLSNTVLY_345_F84	FWD	REV
Thu 12/01/2022 to Thu 12/15/2022	(Import)	(Export)
0001 Continuous 2200	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	100 MW 100 MW 100 MW 100 MW 200 MW 200 MW
Work scheduled by: ConEd		
MILLWOOD_345KV_18	FWD	
Fri 12/02/2022 to Mon 12/12/2022	(Import)	
0001 Continuous 1800	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	4350 MW 3465 MW 7815 MW
Work scheduled by: ConEd		
MARCY___345KV_CSC	FWD	
Wed 12/07/2022 to Tue 12/20/2022	(Import)	
0700 Continuous 1530	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	2925 MW 50 MW 2975 MW
Work scheduled by: NYPA		
HOPATCON-RAMAPO___500_5018	FWD	REV
Mon 12/12/2022 to Fri 12/16/2022	(Import)	(Export)
0001 Continuous 2000	SCH - PJ - NY Impacts Total Transfer Capability TTC with All Lines In Service	1650 MW 1200 MW 1200 MW 1000 MW 2850 MW 2200 MW
Work scheduled by: ConEd		
HOPATCON-RAMAPO___500_5018	FWD	
Mon 12/12/2022 to Fri 12/16/2022	(Import)	
0001 Continuous 2000	TOTAL EAST Impacts Total Transfer Capability TTC with All Lines In Service	5200 MW 800 MW 6000 MW
Work scheduled by: ConEd		
HOPATCON-RAMAPO___500_5018	FWD	
Mon 12/12/2022 to Fri 12/16/2022	(Import)	
0001 Continuous 2000	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	7480 MW 335 MW 7815 MW
Work scheduled by: ConEd		

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018 & MARCY___345KV_CSC

Mon 12/12/2022 to Fri 12/16/2022
0001 2000

Work scheduled by:

FWD
(Import)
TOTAL EAST **5100 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 6000 MW

RAMAPO___345_345_PAR3500

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - PJ - NY **2500 MW 1250 MW**
Impacts Total Transfer Capability 350 MW 950 MW
TTC with All Lines In Service 2850 MW 2200 MW

RAMAPO___345_345_PAR4500

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - PJ - NY **2500 MW 1250 MW**
Impacts Total Transfer Capability 350 MW 950 MW
TTC with All Lines In Service 2850 MW 2200 MW

RAMAPO___500_345_BK 1500

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - PJ - NY **1650 MW 1200 MW**
Impacts Total Transfer Capability 1200 MW 1000 MW
TTC with All Lines In Service 2850 MW 2200 MW

RAMAPO___500_345_BK 1500

Mon 12/12/2022 to Fri 12/16/2022
0001 Continuous 2000

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7480 MW**
Impacts Total Transfer Capability 335 MW
TTC with All Lines In Service 7815 MW

W49TH_ST-E13THSTA_345_M54

Tue 12/13/2022 to Wed 12/14/2022
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

CRICKVLY-PLSNTVLY_345_F83

Fri 12/16/2022 to Sat 12/31/2022
0001 Continuous 2200

Work scheduled by: ConEd

FWD
(Import)
SCH - NE - NY **600 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Details	FWD	REV
CRICKVLY-PLSNTVLY_345_F83	Fri 12/16/2022	Sat 12/31/2022	0001	Continuous	2200	ConEd	SCH - NPX_1385 Impacts Total Transfer Capability TTC with All Lines In Service	(Import) (Export) 100 MW 100 MW 100 MW 100 MW 200 MW 200 MW
HOMRC_NY-MAINS_NY_345_47	Thu 12/22/2022	Thu 12/22/2022	0800	Continuous	1600	PJM	SCH - PJ - NY Impacts Total Transfer Capability TTC with All Lines In Service	
W49TH_ST-E13THSTA_345_M54	Sun 12/25/2022	Sun 12/25/2022	0130	Continuous	0200	ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 3800 MW 800 MW 4600 MW
CLAY -EDIC 345_1-16	Fri 12/30/2022	Sat 12/31/2022	0600	Continuous	1900	NGrid	<u>UPDATED</u> <u>by NGRID</u> <u>05/09/2022</u> OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 4850 MW 400 MW 5250 MW
FRASER 345_FRASER SVC	Tue 01/03/2023	Tue 02/28/2023	0700	Continuous	1730	NYPA	<u>UPDATED</u> <u>by NYPA</u> <u>12/30/2021</u> CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 2935 MW 40 MW 2975 MW
NIAGARA -PACKARD 230_62	Mon 01/09/2023	Fri 01/20/2023	0500	Continuous	1900	NYPA	SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service	FWD REV (Import) (Export) 900 MW 1850 MW 1400 MW 150 MW 2300 MW 2000 MW
EDIC -FRASER 345_EF24-40	Wed 03/01/2023	Sat 04/15/2023	0600	Continuous	1800	NGrid	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 2500 MW 475 MW 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2					FWD	
Mon 03/27/2023	to	Fri 05/19/2023	UPDATED	by NGRID	06/16/2022	(Import)
0700	Continuous	1900				900 MW
Work scheduled by: NGrid					SCH - NE - NY	500 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	900 MW
N. SCTLND-ALPS_____345_2					FWD	REV
Mon 03/27/2023	to	Fri 05/19/2023	UPDATED	by NGRID	06/16/2022	(Import) (Export)
0700	Continuous	1900				100 MW 100 MW
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
PLSNTVLY_345KV_RNS4					FWD	
Sat 04/01/2023	to	Sat 04/01/2023				(Import)
0700	Continuous	0730				3800 MW
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	3800 MW
ATHENS__-PLSNTVLY_345_91					FWD	
Sat 04/01/2023	to	Sat 04/15/2023				(Import)
0700	Continuous	1900				3800 MW
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	3800 MW
MOTTHAVN-RAINEY____345_Q12					FWD	
Thu 04/13/2023	to	Sat 04/22/2023	UPDATED	by CE	06/14/2022	(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	3800 MW
PLSNTVLY_345KV_RNS4					FWD	
Sat 04/15/2023	to	Sat 04/15/2023				(Import)
1830	Continuous	1900				3800 MW
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	3800 MW
PLSNTVLY_345KV_RNS5					FWD	
Sun 04/16/2023	to	Sun 04/16/2023				(Import)
0700	Continuous	0730				3800 MW
Work scheduled by: NGrid					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	3800 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>LEEDS ___ -PLSNTVLY_345_92</p> <p>Sun 04/16/2023 to Sun 04/30/2023</p> <p style="padding-left: 40px;">0700 Continuous 1900</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 4015 MW</p> <p>TTC with All Lines In Service 7815 MW</p>
<p>CLAY ___ -EDIC ___ 345_2-15</p> <p>Mon 04/17/2023 to Fri 04/28/2023</p> <p style="padding-left: 40px;">0600 Continuous 1800</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>PANNELL -CLAY ___ 345_1</p> <p>Mon 04/24/2023 to Fri 04/28/2023</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>WEST CENTRAL 1300 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>
<p>MOTTHAVN-RAINEY ___ 345_Q12</p> <p>Tue 04/25/2023 to Tue 04/25/2023</p> <p style="padding-left: 40px;">0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>PLSNTVLY_345KV_RNS5</p> <p>Sun 04/30/2023 to Sun 04/30/2023</p> <p style="padding-left: 40px;">1830 Continuous 1900</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>UPNY CONED 3800 MW</p> <p>Impacts Total Transfer Capability 4015 MW</p> <p>TTC with All Lines In Service 7815 MW</p>
<p>SHOR_NPX-SHOREHAM_138_CSC</p> <p>Mon 05/01/2023 to Fri 05/05/2023</p> <p style="padding-left: 40px;">0600 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - NPX_CSC 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 330 MW 330 MW</p> <p>TTC with All Lines In Service 330 MW 330 MW</p>
<p>PANNELL -CLAY ___ 345_2</p> <p>Mon 05/01/2023 to Fri 05/05/2023</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>WEST CENTRAL 1300 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

Wed 05/03/2023 to Mon 05/15/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 3815 MW
 TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

Wed 05/03/2023 to Mon 05/15/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_6

Sat 05/06/2023 to Sat 05/06/2023
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/06/2023 to Sat 05/06/2023
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 05/08/2023 to Sat 05/13/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/08/2023 to Sun 05/21/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY_345_Q11

Wed 05/17/2023 to Sat 05/20/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

CLAY -EDIC_345_1-16

Mon 09/11/2023 to Fri 09/15/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

FRASER -GILBOA_345_GF5-35

Mon 09/11/2023 to Sun 09/17/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

SPRNBRK -W49TH_ST_345_M51

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_345KV_RNS5

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

CLAY -EDIC_345_2-15

Mon 09/18/2023 to Fri 09/22/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Mon 09/25/2023 to Sat 10/07/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/06/2023
0600 Continuous 1800

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/09/2023 to Fri 10/13/2023
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 10/09/2023 to Fri 10/13/2023
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/09/2023 to Fri 10/13/2023
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 10/09/2023 to Fri 10/13/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,August 12, 2022 to Sunday ,February 11, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Fri 12/08/2023	to	Fri 12/15/2023	<u>UPDATED</u>	<u>by PJM</u>	<u>01/11/2022</u>	SCH - PJ - NY
0800	Continuous	1600				Impacts Total Transfer Capability
Work scheduled by: PJM						TTC with All Lines In Service

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023	to	Fri 12/15/2023	<u>UPDATED</u>	<u>by PJM</u>	<u>01/11/2022</u>	SCH - PJ - NY
0800	Continuous	1600				Impacts Total Transfer Capability
Work scheduled by: PJM						TTC with All Lines In Service