

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402				FWD
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCE</u> by <u>CONED</u> <u>08/06/2022</u>	(Import)
0001	Continuous	2359		2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403				FWD REV
Mon 01/15/2018	to	Tue 01/31/2023		(Import) (Export)
0001		2359		2000 MW 1150 MW
Work scheduled by:				Impacts Total Transfer Capability 250 MW 50 MW
				TTC with All Lines In Service 2250 MW 1200 MW
MARION_-FARRAGUT_345_C3403				FWD
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCE</u> by <u>CONED</u> <u>08/06/2022</u>	(Import)
0001	Continuous	2359		2050 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 2250 MW
GORDONRD-ROTTDAM_230_31				FWD
Wed 04/27/2022	to	Mon 09/12/2022	<u>UPDATED</u> by <u>NYISO</u> <u>06/30/2022</u>	(Import)
1130	Continuous	1000		2805 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability 170 MW
				TTC with All Lines In Service 2975 MW
SCH-IMO-NYISO_LIMIT_1500				FWD
Wed 07/20/2022	to	Mon 08/15/2022	<u>EXTENDED</u> by <u>IESO</u> <u>07/28/2022</u>	(Import)
0001	Continuous	0400		1800 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 1900 MW
STLAWRNC-MOSES_230_L34P				FWD
Sat 07/30/2022	to	Sun 10/02/2022	<u>EXTENDED</u> by <u>IESO</u> <u>08/15/2022</u>	(Import)
1600	Continuous	2359		2500 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 3200 MW
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255_345_DH2				FWD
Tue 08/09/2022	to	Wed 08/10/2022		(Import)
2000		1000		2500 MW
Work scheduled by:				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 3200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255__345_DH2					FWD	
Tue 08/09/2022	to	Thu 08/11/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/07/2022</u>	(Import)
2000	Continuous	1000				DYSINGER EAST 2850 MW
Work scheduled by: NT					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	3200 MW
NIAGARA_-DYSINGER_345_ND2					FWD	
Tue 08/09/2022	to	Thu 08/11/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/07/2022</u>	(Import)
2000	Continuous	1000				DYSINGER EAST 2700 MW
Work scheduled by: NT					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	3200 MW
SCH-IMO-NYISO_LIMIT_1400					FWD	
Wed 08/10/2022	to	Mon 08/22/2022		<u>by IESO</u>	<u>08/12/2022</u>	(Import)
0800	Continuous	0759				SCH - OH - NY 1700 MW
Work scheduled by: IESO					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1900 MW
NIAGARA_-DYSINGER_345_ND2 & DYSINGER-STA_255__345_DH2					FWD	
Wed 08/10/2022	to	Thu 08/11/2022				(Import)
2000		1000				DYSINGER EAST 2500 MW
Work scheduled by:					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	3200 MW
BECK___-NIAGARA_345_PA301					FWD	REV
Thu 08/11/2022	to	Sun 08/14/2022				(Import) (Export)
0500	Continuous	1900				SCH - OH - NY 900 MW 800 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1000 MW 750 MW
					TTC with All Lines In Service	1900 MW 1550 MW
MOSES___-ADIRNDCK_230_MA2					FWD	
Thu 08/11/2022	to	Thu 09/15/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0500	Continuous	1100				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
FRASANNX-COOPERS__345_UCC2-41					FWD	
Thu 08/11/2022	to	Fri 09/09/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/05/2022</u>	(Import)
0700	Continuous	1700				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41					FWD	
Thu 08/11/2022	to	Fri 09/09/2022	UPDATED	by NYPA	08/05/2022	(Import)
0700	Continuous	1700				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service	2975 MW
MARCY_SO_SERIES_COMP_I/S					FWD	
Thu 08/11/2022	to	Fri 09/09/2022				(Import)
0711	Continuous	1700				CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service	2975 MW
HOMRC_NY-MAINS_NY_345_47						
Thu 08/11/2022	to	Mon 09/12/2022	FORCED	by NYSEG	08/12/2022	
2219	Continuous	2359				SCH - PJ - NY
Work scheduled by: NYSEG						Impacts Total Transfer Capability
					TTC with All Lines In Service	
PLSNTVLE-DUNWODIE_345_W89					FWD	
Fri 08/12/2022	to	Fri 08/12/2022	EXTENDED	by CONED	08/15/2022	(Import)
0001	Continuous	0030				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service	7815 MW
EFISHKIL-WOOD_ST_345_F38					FWD	
Fri 08/12/2022	to	Wed 08/17/2022	EXTENDED	by CONED	08/15/2022	(Import)
0001	Continuous	0259				UPNY CONED 4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service	7815 MW
WOOD_ST_-PLSNTVLE_345_Y86					FWD	
Fri 08/12/2022	to	Wed 08/17/2022	EXTENDED	by CONED	08/15/2022	(Import)
0001	Continuous	0259				UPNY CONED 7210 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 605 MW
					TTC with All Lines In Service	7815 MW
NIAGARA_-PACKARD_230_61					REV	
Fri 08/12/2022	to	Fri 08/12/2022				(Export)
1100	Daily(No Weekends)	1500				SCH - OH - NY 1350 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	1550 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_800						REV	
Mon 08/15/2022	to	Tue 08/16/2022				(Export)	
0600	Continuous	1800			SCH - HQ - NY	800 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	1000 MW
SCH-IMO-NYISO_LIMIT_1300						FWD	
Mon 08/15/2022	to	Mon 08/15/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>08/12/2022</u>	(Import)	
0700	Continuous	1759			SCH - OH - NY	1600 MW	
Work scheduled by: IESO						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1900 MW
SCH-NYISO-IMO_LIMIT_1200						REV	
Mon 08/15/2022	to	Mon 08/15/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>08/12/2022</u>	(Export)	
0700	Continuous	1759			SCH - OH - NY	1500 MW	
Work scheduled by: IESO						Impacts Total Transfer Capability	50 MW
						TTC with All Lines In Service	1550 MW
PLSNTVLE-DUNWODIE_345_W89						FWD	
Wed 08/17/2022	to	Wed 08/17/2022	<u>EXTENDED</u>	<u>by CONED</u>	<u>08/15/2022</u>	(Import)	
0230	Continuous	0259			UPNY CONED	4000 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3815 MW
						TTC with All Lines In Service	7815 MW
SCH-NYISO-HQ_LIMIT_800						REV	
Wed 08/17/2022	to	Thu 08/18/2022				(Export)	
0600	Continuous	1800			SCH - HQ - NY	800 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	1000 MW
BECK -PACKARD_230_BP76						FWD	REV
Wed 08/17/2022	to	Wed 08/17/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>08/06/2022</u>	(Import)	(Export)
0800	Daily(No Weekends)	1159			SCH - OH - NY	1500 MW	1000 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	1900 MW
SCH-IMO-NYISO_LIMIT_1300						FWD	
Wed 08/17/2022	to	Sun 08/21/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>08/12/2022</u>	(Import)	
1200	Continuous	1659			SCH - OH - NY	1600 MW	
Work scheduled by: IESO						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1900 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1200					REV	
Wed 08/17/2022	to	Sun 08/21/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>08/12/2022</u>	(Export)
1200	Continuous	1659				1500 MW
Work scheduled by: IESO					SCH - OH - NY	50 MW
					Impacts Total Transfer Capability	1550 MW
					TTC with All Lines In Service	
SCH-NYISO-HQ_LIMIT_800					REV	
Mon 08/22/2022	to	Tue 08/23/2022				(Export)
0600	Continuous	1800				800 MW
Work scheduled by: HQ					SCH - HQ - NY	200 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	
SAND_BAR-PLATSBURG_115_PV20						
Mon 08/22/2022	to	Fri 08/26/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/12/2022</u>	
0700	Continuous	1530				
Work scheduled by: NYPA					SCH - NE - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
W49TH_ST_345KV_6					FWD	
Sat 08/27/2022	to	Sat 08/27/2022				(Import)
0001	Continuous	0030				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	
W49TH_ST-E13THSTA_345_M55					FWD	
Sat 08/27/2022	to	Mon 08/29/2022				(Import)
0001	Continuous	0200				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
W49TH_ST_345KV_6					FWD	
Mon 08/29/2022	to	Mon 08/29/2022				(Import)
0130	Continuous	0200				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	360 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	
ROSETON_-ROCKTVRN_345_311					FWD	
Mon 08/29/2022	to	Fri 09/09/2022				(Import)
0800	Continuous	1600				4400 MW
Work scheduled by: CHGE					UPNY CONED	3415 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_NIAGARA_CB_3022						FWD	REV
						(Import)	(Export)
Tue 08/30/2022	to	Tue 08/30/2022					
0500	Continuous	1800			SCH - OH - NY	1250 MW	1100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	650 MW 450 MW
						TTC with All Lines In Service	1900 MW 1550 MW
EFISHKIL-WOOD_ST_345_F38						FWD	
						(Import)	
Thu 09/01/2022	to	Mon 09/05/2022	<u>EXTENDED</u>	<u>by CE</u>	<u>08/15/2022</u>	UPNY CONED	4000 MW
0001	Continuous	0200				Impacts Total Transfer Capability	3815 MW
Work scheduled by: ConEd						TTC with All Lines In Service	7815 MW
MOTHAVN-RAINEY_345_Q12						FWD	
						(Import)	
Thu 09/01/2022	to	Mon 09/05/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/14/2022</u>	SPR/DUN-SOUTH	3800 MW
0001	Continuous	0200				Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W89						FWD	
						(Import)	
Thu 09/01/2022	to	Mon 09/05/2022	<u>EXTENDED</u>	<u>by CE</u>	<u>08/15/2022</u>	UPNY CONED	4000 MW
0001	Continuous	0200				Impacts Total Transfer Capability	3815 MW
Work scheduled by: ConEd						TTC with All Lines In Service	7815 MW
WOOD_ST_-PLSNTVLE_345_Y86						FWD	
						(Import)	
Thu 09/01/2022	to	Mon 09/05/2022	<u>EXTENDED</u>	<u>by CE</u>	<u>08/15/2022</u>	UPNY CONED	7210 MW
0001	Continuous	0200				Impacts Total Transfer Capability	605 MW
Work scheduled by: ConEd						TTC with All Lines In Service	7815 MW
DUNWODIE_345KV_6						FWD	
						(Import)	
Mon 09/05/2022	to	Wed 09/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/15/2022</u>	SPR/DUN-SOUTH	3800 MW
0201	Continuous	0300				Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8						FWD	
						(Import)	
Mon 09/05/2022	to	Wed 09/07/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>08/15/2022</u>	SPR/DUN-SOUTH	3800 MW
0201	Continuous	0300				Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87				FWD
Mon 09/05/2022	to	Fri 09/09/2022	UPDATED	(Import)
0201	Continuous	2200	by CONED 08/15/2022	7260 MW
Work scheduled by: ConEd				UPNY CONED
				Impacts Total Transfer Capability 555 MW
				TTC with All Lines In Service 7815 MW
PLSNTVLE-DUNWODIE_345_W90				FWD
Mon 09/05/2022	to	Sat 09/10/2022	UPDATED	(Import)
0201	Continuous	0200	by CONED 08/15/2022	4000 MW
Work scheduled by: ConEd				UPNY CONED
				Impacts Total Transfer Capability 3815 MW
				TTC with All Lines In Service 7815 MW
NRTH1385-NRTHPORT_138_NNC				FWD
Tue 09/06/2022	to	Sat 09/10/2022		REV
0500	Continuous	1700		(Import) (Export)
Work scheduled by: ISONE				SCH - NPX_1385
				0 MW 0 MW
				Impacts Total Transfer Capability 200 MW 200 MW
				TTC with All Lines In Service 200 MW 200 MW
SCH-HQ_CEDARS-NYISO_LIMIT_240				FWD
Tue 09/06/2022	to	Thu 09/29/2022		(Import)
0500	Continuous	2200		240 MW
Work scheduled by: HQ				SCH - HQ_CEDARS
				Impacts Total Transfer Capability 30 MW
				TTC with All Lines In Service 270 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0				REV
Tue 09/06/2022	to	Thu 09/29/2022		(Export)
0500	Continuous	2200		0 MW
Work scheduled by: HQ				SCH - HQ_CEDARS
				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 100 MW
S.RIPLEY-DUNKIRK_230_68				
Tue 09/06/2022	to	Tue 09/06/2022		
0730	Continuous	1800		
Work scheduled by: NGrid				SCH - PJ - NY
				Impacts Total Transfer Capability
				TTC with All Lines In Service
EDIC____-N.SCTLND_345_14 & MARCY_SO_SERIES_COMP_I/S				FWD
Thu 09/08/2022	to	Fri 09/09/2022		(Import)
0700		1700		1435 MW
Work scheduled by:				CENTRAL EAST - VC
				Impacts Total Transfer Capability 1540 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC____-N.SCTLND_345_14 & GORDONRD-ROTTDAM_230_31				FWD
Thu 09/08/2022	to	Mon 09/12/2022		(Import)
0700		1000	CENTRAL EAST - VC	1500 MW
Work scheduled by:				Impacts Total Transfer Capability 1475 MW
				TTC with All Lines In Service 2975 MW
EDIC____-N.SCTLND_345_14				FWD
Thu 09/08/2022	to	Tue 12/31/2030	<u>UPDATED</u> <u>by NGRID</u> <u>06/30/2022</u>	(Import)
0700	Continuous	2359	CENTRAL EAST - VC	1670 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 1305 MW
				TTC with All Lines In Service 2975 MW
DUNWODIE_345KV_6				FWD
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/15/2022</u>	(Import)
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8				FWD
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/15/2022</u>	(Import)
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
WOOD_ST_-PLSNTVLE_345_Y87				FWD
Sat 09/10/2022	to	Sat 09/10/2022	<u>UPDATED</u> <u>by CONED</u> <u>08/15/2022</u>	(Import)
0130	Continuous	0200	UPNY CONED	7260 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 555 MW
				TTC with All Lines In Service 7815 MW
BUCHAN_S-MILLWOOD_345_W97				FWD
Sat 09/10/2022	to	Sun 09/11/2022		(Import)
0201	Continuous	2200	UPNY CONED	7680 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 135 MW
				TTC with All Lines In Service 7815 MW
SPRNBRK__345KV_RNS3				FWD
Mon 09/12/2022	to	Wed 09/14/2022		(Import)
0201	Continuous	1800	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35				FWD	
Mon 09/12/2022	to	Sun 09/18/2022	UPDATED	by NYPA	08/02/2022
0700	Continuous	1530			
Work scheduled by: NYPA				CENTRAL EAST - VC	2650 MW
				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
EDIC -N.SCTLND 345_14 & PORTER -ROTTRDAM 230_30				FWD	
Mon 09/12/2022	to	Tue 12/31/2030			
1200		2359			
Work scheduled by:				CENTRAL EAST - VC	1500 MW
				Impacts Total Transfer Capability	1475 MW
				TTC with All Lines In Service	2975 MW
PORTER -ROTTRDAM 230_30				FWD	
Mon 09/12/2022	to	Tue 12/31/2030			
1200	Continuous	2359			
Work scheduled by: NGrid				CENTRAL EAST - VC	2805 MW
				Impacts Total Transfer Capability	170 MW
				TTC with All Lines In Service	2975 MW
SCH-NE-NYISO_LIMIT_500				FWD	
Wed 09/14/2022	to	Wed 09/14/2022			
0600	Continuous	1800			
Work scheduled by: ISONE				SCH - NE - NY	700 MW
				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	1400 MW
SPRNBK 345KV_RS3 & SPRNBK 345KV_RS4				FWD	
Thu 09/15/2022	to	Fri 09/16/2022			
0001		0300			
Work scheduled by:				SPR/DUN-SOUTH	3200 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
CRICKVLY-PLSNTVLY 345_F84				FWD	
Thu 09/15/2022	to	Sat 09/17/2022			
0001	Continuous	2200			
Work scheduled by: ConEd				SCH - NE - NY	300 MW
				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY 345_F84				FWD	REV
Thu 09/15/2022	to	Sat 09/17/2022			
0001	Continuous	2200			
Work scheduled by: ConEd				SCH - NPX_1385	100 MW
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
					100 MW
					200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Thu 09/15/2022 to Fri 10/14/2022
0001 to 0200

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

W49TH_ST-E13THSTA_345_M54

Thu 09/15/2022 to Sat 12/24/2022 **UPDATED by CE 08/15/2022**
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MOSES__-ADIRNDCK_230_MA2

Thu 09/15/2022 to Tue 11/29/2022
1101 Continuous 1800

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

EASTVIEW-SPRNBK__345_W78

Fri 09/16/2022 to Mon 09/19/2022 **UPDATED by CONED 06/25/2022**
2100 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W85

Fri 09/16/2022 to Mon 09/19/2022 **UPDATED by CONED 06/25/2022**
2100 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7550 MW**
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

SPRNBK__345KV_RNS3

Fri 09/16/2022 to Mon 09/19/2022 **UPDATED by CONED 06/25/2022**
2100 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Mon 09/19/2022 to Mon 09/19/2022
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
DUNWODIE_345KV_6			FWD
Mon 09/19/2022	to	Mon 09/19/2022	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
DUNWODIE-SHORE_RD_345_Y50			FWD
Mon 09/19/2022	to	Sun 09/25/2022	(Import)
0001	Continuous	0200	CONED - LIPA 800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 700 MW
			TTC with All Lines In Service 1500 MW
<hr/>			
SHORE_RD_345_138_BK 1			FWD
Mon 09/19/2022	to	Sun 09/25/2022	(Import)
0001	Continuous	0200	CONED - LIPA 1350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 150 MW
			TTC with All Lines In Service 1500 MW
<hr/>			
SHORE_RD_345_138_BK 2			FWD
Mon 09/19/2022	to	Sun 09/25/2022	(Import)
0001	Continuous	0200	CONED - LIPA 1350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 150 MW
			TTC with All Lines In Service 1500 MW
<hr/>			
MILLWOOD_345KV_18			FWD
Mon 09/19/2022	to	Mon 09/19/2022	(Import)
0201	Continuous	0230	<u>EXTENDED</u> by CONED 07/22/2022
Work scheduled by: ConEd			UPNY CONED 4350 MW
			Impacts Total Transfer Capability 3465 MW
			TTC with All Lines In Service 7815 MW
<hr/>			
FRASER_345_FRASER SVC			FWD
Mon 09/19/2022	to	Tue 09/27/2022	(Import)
0600	Continuous	1700	CENTRAL EAST - VC 2935 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability 40 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
MARCY_-EDIC_345_UE1-7			FWD
Mon 09/19/2022	to	Sat 10/08/2022	(Import)
0600	Continuous	1930	<u>UPDATED</u> by NYPA 08/10/2022
Work scheduled by: NYPA			OSWEGO EXPORT 5250 MW
			Impacts Total Transfer Capability 0 MW
			TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42

Mon 09/19/2022 to Thu 09/29/2022
 0800 Continuous 1630
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

LEEDS_-HURLYAVE_345_301

Mon 09/19/2022 to Fri 10/21/2022
 0800 Continuous 1600
 Work scheduled by: CHGE

10/04/2021

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD_345KV_18

Fri 09/23/2022 to Fri 09/23/2022
 2130 Continuous 2200
 Work scheduled by: ConEd

EXTENDED by CONED 07/22/2022

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_4

Sat 09/24/2022 to Sun 09/25/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Sat 09/24/2022 to Sun 09/25/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sat 09/24/2022 to Mon 09/26/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7550 MW**
 Impacts Total Transfer Capability 265 MW
 TTC with All Lines In Service 7815 MW

SPRNBK_345KV_RNS5

Sat 09/24/2022 to Mon 09/26/2022
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64				FWD
Sat 09/24/2022	to	Tue 09/27/2022		(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
ADIRNDCK-PORTER__230_12				FWD
Mon 09/26/2022	to	Wed 11/30/2022		(Import)
0630	Continuous	1700	MOSES SOUTH	2100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 3150 MW
MILLWOOD-EASTVIEW_345_W99				FWD
Tue 09/27/2022	to	Tue 09/27/2022		(Import)
0130	Continuous	0200	UPNY CONED	7550 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 265 MW
				TTC with All Lines In Service 7815 MW
SPRNBK__345KV_RNS5				FWD
Tue 09/27/2022	to	Tue 09/27/2022		(Import)
0130	Continuous	0200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
SPRNBK__345KV_RNS4				FWD
Tue 09/27/2022	to	Tue 09/27/2022		(Import)
0201	Continuous	2200	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK__345_W64				FWD
Thu 09/29/2022	to	Sat 10/01/2022	UPDATED by CONED 06/08/2022	(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 3465 MW
				TTC with All Lines In Service 7815 MW
MILLWOOD-EASTVIEW_345_W99				FWD
Thu 09/29/2022	to	Sat 10/01/2022	UPDATED by CONED 06/08/2022	(Import)
0001	Continuous	0200	UPNY CONED	7550 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 265 MW
				TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5					FWD	
Thu 09/29/2022	to	Sat 10/01/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>06/08/2022</u>	(Import)
0001	Continuous	0200				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
EGRDNCTY_345_138_AT1					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
EGRDNCTY_345_138_AT2					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
SPRNBRK_-EGRDNCTR_345_Y49					FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)
0001	Continuous	2359				CONED - LIPA 775 MW
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
CHAT_DC_GC1					FWD	
Sun 10/02/2022	to	Sun 10/02/2022				(Import)
0001	Continuous	0200				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV	
Sun 10/02/2022	to	Sun 10/02/2022				(Export)
0001	Continuous	0200				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Sun 10/02/2022	to	Sun 10/02/2022				(Import)
0001		0200				MOSES SOUTH 2550 MW
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Start	End	By	Update	Limit	Impact	FWD	REV
CHAT_DC_GC1 & CHAT_DC_GC2	Sun 10/02/2022	Sun 10/02/2022					(Import)	(Export)
0001	0001	0200				SCH - HQ - NY	1370 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	130 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
CHAT_DC_GC2	Sun 10/02/2022	Sun 10/02/2022					(Import)	
0001	Continuous	0200				MOSES SOUTH	2850 MW	
Work scheduled by:						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2	Sun 10/02/2022	Sun 10/02/2022						(Export)
0001	Continuous	0200				SCH - HQ - NY		500 MW
Work scheduled by:						Impacts Total Transfer Capability		500 MW
						TTC with All Lines In Service		1000 MW
SCH-HQ-NYISO_LIMIT_1150	Sun 10/02/2022	Sun 10/02/2022					(Import)	
0001	Continuous	0200				SCH - HQ - NY	1150 MW	
Work scheduled by:						Impacts Total Transfer Capability	350 MW	
						TTC with All Lines In Service	1500 MW	
STLAWRNC-MOSES_230_L34P	Mon 10/03/2022	Tue 04/18/2023	IESO	08/15/2022				
0001	Continuous	2359				SCH - OH - NY		
Work scheduled by:						Impacts Total Transfer Capability		
						TTC with All Lines In Service		
CLRKSCRN-OAKDALE_345_36	Mon 10/03/2022	Fri 10/07/2022	NYSEG	04/20/2022			(Import)	
0830	Continuous	1530				CENTRAL EAST - VC	2650 MW	
Work scheduled by:						Impacts Total Transfer Capability	325 MW	
						TTC with All Lines In Service	2975 MW	
LEEDS_345_LEEDS_SVC	Mon 10/03/2022	Fri 10/07/2022	NGRID	08/15/2022			(Import)	
0900	Continuous	1200				CENTRAL EAST - VC	2950 MW	
Work scheduled by:						Impacts Total Transfer Capability	25 MW	
						TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC							
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>		
1000	Continuous	1500				SCH - NPX_CSC	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
W49TH_ST_345KV_7							
Tue 10/04/2022	to	Tue 10/04/2022				SCH - PJM_HTP	300 MW
0201	Continuous	0230				Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8							
Tue 10/04/2022	to	Tue 10/04/2022				SCH - PJM_HTP	450 MW
0201	Continuous	0230				Impacts Total Transfer Capability	210 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
HUDSONTP-W49TH_ST_345_Y56							
Tue 10/04/2022	to	Sat 10/08/2022				SCH - PJM_HTP	0 MW
0201	Continuous	1800				Impacts Total Transfer Capability	660 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
DUNWODIE_345KV_3							
Thu 10/06/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>		
0001	Continuous	0200				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5							
Thu 10/06/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>		
0001	Continuous	0200				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_71							
Thu 10/06/2022	to	Thu 11/10/2022	<u>UPDATED</u>	<u>by CE</u>	<u>06/30/2022</u>		
0001	Continuous	0300				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Sat 10/08/2022 to Sat 10/08/2022
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 10/08/2022 to Sat 10/08/2022
 1730 Continuous 1800
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

EASTVIEW-SPRNBK__345_W79

Mon 10/17/2022 to Mon 10/17/2022 **UPDATED by CONED 06/18/2022**
 0001 Continuous 0031
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_N-EASTVIEW_345_W93

Mon 10/17/2022 to Sat 11/26/2022 **UPDATED by CONED 06/18/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

NIAGARA_-DYSINGER_345_ND1

Mon 10/17/2022 to Fri 10/21/2022 **UPDATED by NYPA 02/10/2022**
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2700 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3200 MW

EASTVIEW-SPRNBK__345_W79

Mon 10/17/2022 to Mon 10/17/2022 **UPDATED by CONED 06/18/2022**
 2130 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

RAMAPO_-BUCHAN_N_345_Y94

Tue 10/18/2022 to Sun 10/30/2022 **UPDATED by CONED 06/18/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **7580 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1

Mon 10/24/2022 to Fri 10/28/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HURLYAVE-ROSETON__345_303

Mon 10/24/2022 to Fri 11/04/2022
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 04/13/2022

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 3715 MW
TTC with All Lines In Service 7815 MW

MAINESBG-WATRCURE_345_30

Tue 10/25/2022 to Tue 10/25/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

WATRCURE-OAKDALE__345_31

Thu 10/27/2022 to Thu 10/27/2022
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

PANNELL_-CLAY_____345_2

Mon 10/31/2022 to Fri 11/04/2022
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CLAY_____-EDIC_____345_1-16

Tue 11/01/2022 to Thu 11/03/2022
0600 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 05/09/2022

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022
0600 Continuous 1600

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Tue 11/01/2022 to Sat 11/19/2022
 0600 Continuous 1600
 Work scheduled by: LI

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

GILBOA__-N.SCTLND_345_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

LEEDS___345KV_R94301

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

MARCY___-N.SCTLND_345_18

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**
 0700 Continuous 1900
 Work scheduled by: NGrid **ARR: 19**

FWD
 (Import)
 CENTRAL EAST - VC **1470 MW**
 Impacts Total Transfer Capability 1505 MW
 TTC with All Lines In Service 2975 MW

PORTER__-ROTTRDAM_230_30 & MARCY___-N.SCTLND_345_18

Tue 11/01/2022 to Tue 12/06/2022
 0700 Continuous 1900
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **1300 MW**
 Impacts Total Transfer Capability 1675 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work Scheduled by	Update Info	Direction	Impact	TTC
LINDN_CG-LNDVFT_345_V-3022	Tue 11/01/2022	Fri 11/04/2022	0800 - 1500	PJM		FWD (Import)	0 MW	315 MW
							Impacts Total Transfer Capability	315 MW
							TTC with All Lines In Service	315 MW
LEEDS_HURLYAVE_345_301	Mon 11/07/2022	Fri 12/09/2022	0800 - 1600	CHGE		FWD (Import)	4100 MW	3715 MW
							Impacts Total Transfer Capability	3715 MW
							TTC with All Lines In Service	7815 MW
DUNWODIE_345KV_3	Thu 11/10/2022	Thu 11/10/2022	0230 - 0300	ConEd	<u>UPDATED</u> <u>by CE</u> <u>06/30/2022</u>	FWD (Import)	3800 MW	800 MW
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5	Thu 11/10/2022	Thu 11/10/2022	0230 - 0300	ConEd	<u>UPDATED</u> <u>by CE</u> <u>06/30/2022</u>	FWD (Import)	3800 MW	800 MW
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	4600 MW
MAINESBG-WATRCURE_345_30	Thu 11/10/2022	Thu 11/10/2022	0800 - 1600	PJM		FWD (Import)	2300 MW	550 MW
							Impacts Total Transfer Capability	550 MW
							TTC with All Lines In Service	2850 MW
RAMAPO_BUCHAN_N_345_Y94	Mon 11/21/2022	Sat 11/26/2022	0001 - 0200	ConEd	<u>UPDATED</u> <u>by CONED</u> <u>06/18/2022</u>	FWD (Import)	7580 MW	235 MW
							Impacts Total Transfer Capability	235 MW
							TTC with All Lines In Service	7815 MW
E13THSTA-FARRAGUT_345_45	Mon 11/21/2022	Fri 12/09/2022	0001 - 0200	ConEd		FWD (Import)	3800 MW	800 MW
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Wed 11/23/2022 to Wed 11/23/2022 **UPDATED** by **PJM** **08/09/2022**
 0800 Continuous 1600
 Work scheduled by: PJM
 SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

EASTVIEW-SPRNBK_345_W79

Sat 11/26/2022 to Sat 11/26/2022 **UPDATED** by **CONED** **06/18/2022**
 0130 Continuous 0200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

BUCHAN_S-MILLWOOD_345_W98

Tue 11/29/2022 to Thu 12/01/2022
 0001 Continuous 0200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **7680 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 7815 MW

MILLWOOD_345KV_18

Tue 11/29/2022 to Thu 12/01/2022
 0001 Continuous 0200
 Work scheduled by: ConEd
 FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 3465 MW
 TTC with All Lines In Service 7815 MW

MOSES__-ADIRNDCK_230_MA1

Wed 11/30/2022 to Wed 03/01/2023
 0700 Continuous 1100
 Work scheduled by: NYPA
 FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

CRICKVLY-PLSNTVLY_345_F84

Thu 12/01/2022 to Thu 12/15/2022
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD
 (Import)
 SCH - NE - NY **600 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 1400 MW

CRICKVLY-PLSNTVLY_345_F84

Thu 12/01/2022 to Thu 12/15/2022
 0001 Continuous 2200
 Work scheduled by: ConEd
 FWD REV
 (Import) (Export)
 SCH - NPX_1385 **100 MW 100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18			FWD	
Fri 12/02/2022	to	Mon 12/12/2022	(Import)	
0001	Continuous	1800	UPNY CONED	4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW
			TTC with All Lines In Service	7815 MW
MARCY_345KV_CSC			FWD	
Wed 12/07/2022	to	Tue 12/20/2022	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW
HOPATCON-RAMAPO_500_5018			FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	1650 MW 1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW 1000 MW
			TTC with All Lines In Service	2850 MW 2200 MW
HOPATCON-RAMAPO_500_5018			FWD	
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	
0001	Continuous	2000	TOTAL EAST	5200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	6000 MW
HOPATCON-RAMAPO_500_5018			FWD	
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	
0001	Continuous	2000	UPNY CONED	7480 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW
			TTC with All Lines In Service	7815 MW
HOPATCON-RAMAPO_500_5018 & MARCY_345KV_CSC			FWD	
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	
0001		2000	TOTAL EAST	5100 MW
Work scheduled by:			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	6000 MW
RAMAPO_345_345_PAR3500			FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022	(Import)	(Export)
0001	Continuous	2000	SCH - PJ - NY	2500 MW 1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW 950 MW
			TTC with All Lines In Service	2850 MW 2200 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO___345_345_PAR4500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	2500 MW	1250 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	350 MW 950 MW
				TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	1650 MW	1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1200 MW 1000 MW
				TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	UPNY CONED	7480 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	335 MW
				TTC with All Lines In Service	7815 MW
CRICKVLY-PLSNTVLY_345_F83					
Fri 12/16/2022	to	Sat 12/31/2022			
0001	Continuous	2200	SCH - NE - NY	600 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F83					
Fri 12/16/2022	to	Sat 12/31/2022			
0001	Continuous	2200	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
HOMRC_NY-MAINS_NY_345_47					
Thu 12/22/2022	to	Thu 12/22/2022			
0800	Continuous	1600	SCH - PJ - NY		
Work scheduled by: PJM				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
W49TH_ST-E13THSTA_345_M54					
Sun 12/25/2022	to	Sun 12/25/2022	UPDATED	by CE	08/15/2022
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16			FWD
Fri 12/30/2022 to Sat 12/31/2022	UPDATED	by NGRID	(Import)
0600 Continuous 1900			OSWEGO EXPORT 4850 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 400 MW
			TTC with All Lines In Service 5250 MW
<hr/>			
FRASER 345_FRASER SVC			FWD
Tue 01/03/2023 to Tue 02/28/2023	UPDATED	by NYPA	(Import)
0700 Continuous 1730			CENTRAL EAST - VC 2935 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 40 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
NIAGARA -PACKARD 230_62			FWD REV
Mon 01/09/2023 to Fri 01/20/2023			(Import) (Export)
0500 Continuous 1900			SCH - OH - NY 900 MW 1850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW 150 MW
			TTC with All Lines In Service 2300 MW 2000 MW
<hr/>			
E13THSTA-FARRAGUT 345_45			FWD
Wed 02/08/2023 to Wed 02/08/2023			(Import)
0001 Continuous 0030			SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
E13THSTA-FARRAGUT 345_45			FWD
Wed 02/22/2023 to Wed 02/22/2023			(Import)
0230 Continuous 0300			SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
EDIC -FRASER 345_EF24-40			FWD
Wed 03/01/2023 to Sat 04/15/2023			(Import)
0600 Continuous 1800			CENTRAL EAST - VC 2500 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 475 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
N. SCTLND-ALPS 345_2			FWD
Mon 03/27/2023 to Fri 05/19/2023	UPDATED	by NGRID	(Import)
0700 Continuous 1900			SCH - NE - NY 900 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
N. SCTLND-ALPS_____345_2						
Mon 03/27/2023	to	Fri 05/19/2023	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/16/2022</u>	
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
PLSNTVLY_345KV_RNS4						
Sat 04/01/2023	to	Sat 04/01/2023				
0700	Continuous	0730				
Work scheduled by: NGrid					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
ATHENS__-PLSNTVLY_345_91						
Sat 04/01/2023	to	Sat 04/15/2023				
0700	Continuous	1900				
Work scheduled by: NGrid					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
MOTTHAVN-RAINEY_____345_Q12						
Thu 04/13/2023	to	Sat 04/22/2023	<u>UPDATED</u>	<u>by CE</u>	<u>06/14/2022</u>	
0001	Continuous	0200				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLY_345KV_RNS4						
Sat 04/15/2023	to	Sat 04/15/2023				
1830	Continuous	1900				
Work scheduled by: NGrid					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RNS5						
Sun 04/16/2023	to	Sun 04/16/2023				
0700	Continuous	0730				
Work scheduled by: NGrid					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
LEEDS____-PLSNTVLY_345_92						
Sun 04/16/2023	to	Sun 04/30/2023				
0700	Continuous	1900				
Work scheduled by: NGrid					UPNY CONED	3800 MW
					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15					FWD
Mon 04/17/2023	to	Fri 04/28/2023			(Import)
0600	Continuous	1800		OSWEGO EXPORT	4850 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW
PANNELL -CLAY 345_1					FWD
Mon 04/24/2023	to	Fri 04/28/2023			(Import)
0700	Continuous	1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW
MOTTHAVN-RAINEY 345_Q12					FWD
Tue 04/25/2023	to	Tue 04/25/2023	<u>UPDATED</u>	<u>by CE</u>	<u>06/14/2022</u>
0130	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
PLSNTVLY_345KV_RNS5					FWD
Sun 04/30/2023	to	Sun 04/30/2023			(Import)
1830	Continuous	1900		UPNY CONED	3800 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 4015 MW
					TTC with All Lines In Service 7815 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD
Mon 05/01/2023	to	Fri 05/05/2023			(Import) (Export)
0600	Continuous	1800		SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability 330 MW 330 MW
					TTC with All Lines In Service 330 MW 330 MW
PANNELL -CLAY 345_2					FWD
Mon 05/01/2023	to	Fri 05/05/2023			(Import)
0700	Continuous	1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW
PLSNTVLY-WOOD_ST_345_F30					FWD
Wed 05/03/2023	to	Mon 05/15/2023			(Import)
0001	Continuous	2200		UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 3815 MW
					TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Wed 05/03/2023 to Mon 05/15/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 4015 MW
 TTC with All Lines In Service 7815 MW

W49TH_ST_345KV_6

Sat 05/06/2023 to Sat 05/06/2023
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/06/2023 to Sat 05/06/2023
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 05/08/2023 to Sat 05/13/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/08/2023 to Sun 05/21/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q11

Wed 05/17/2023 to Sat 05/20/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

CLAY___-EDIC___345_1-16

Mon 09/11/2023 to Fri 09/15/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

FRASER___-GILBOA___345_GF5-35

Mon 09/11/2023 to Sun 09/17/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

SPRNBRK_-W49TH_ST_345_M51

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS5

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

CLAY___-EDIC___345_2-15

Mon 09/18/2023 to Fri 09/22/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

MARCY___345KV_CSC

Mon 09/25/2023 to Sat 10/07/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC					
Mon 10/02/2023	to	Fri 10/06/2023			
0600	Continuous	1800			
Work scheduled by: LI				SCH - NPX_CSC	0 MW
				Impacts Total Transfer Capability	330 MW
				TTC with All Lines In Service	330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Mon 10/09/2023	to	Fri 10/13/2023			
0600	Continuous	1600			
Work scheduled by: LI				SCH - PJM_NEPTUNE	0 MW
				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					
Mon 10/09/2023	to	Fri 10/13/2023			
0600	Continuous	1600			
Work scheduled by: LI				SCH - PJM_NEPTUNE	0 MW
				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1					
Mon 10/09/2023	to	Fri 10/13/2023			
0600	Continuous	1600			
Work scheduled by: LI				SCH - PJM_NEPTUNE	375 MW
				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					
Mon 10/09/2023	to	Fri 10/13/2023			
0600	Continuous	1600			
Work scheduled by: LI				SCH - PJM_NEPTUNE	375 MW
				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
GILBOA_-N.SCTLND_345_GNS-1					
Mon 10/09/2023	to	Fri 10/13/2023			
0700	Continuous	1530			
Work scheduled by: NYPA				CENTRAL EAST - VC	2520 MW
				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW
HOMRC_NY-MAINS_NY_345_47					
Fri 12/08/2023	to	Fri 12/15/2023	UPDATED	by PJM	01/11/2022
0800	Continuous	1600			
Work scheduled by: PJM				SCH - PJ - NY	
				Impacts Total Transfer Capability	
				TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Monday ,August 15, 2022 to Wednesday,February 14, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023 UPDATED by PJM 01/11/2022

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service