

NYISO TRANSFER LIMITATIONS

Saturday, March 25, 2023 to Tuesday, September 24, 2024

Seasonal Limits

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 08/31/2023
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 08/31/2023
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 08/31/2023
 0001 2359
 Work scheduled by:

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2350 MW 2050 MW
 100 MW 100 MW
 2450 MW 2150 MW

EGRDNCTY_345_138_AT1

Sat 10/01/2022 to Wed 05/31/2023
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

EGRDNCTY_345_138_AT2

Sat 10/01/2022 to Wed 05/31/2023
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_EGRDNCTR_345_Y49

Sat 10/01/2022 to Wed 05/31/2023
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
775 MW
 725 MW
 1500 MW

STLAWRNC-MOSES_230_L34P

Mon 10/03/2022 to Mon 11/06/2023
 1800 Continuous 0800
 Work scheduled by: IESO

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 725 MW
 1500 MW

SCH-IMO-NYISO_LIMIT_1750

Fri 01/20/2023 to Sun 04/30/2023
 1601 Continuous 2359
 Work scheduled by: IESO

UPDATED by IESO 01/18/2023 16:31

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2050 MW
 350 MW
 2400 MW

SCH-NYISO-IMO_LIMIT_1600

Sat 01/21/2023 to Sun 04/30/2023
 1800 Continuous 2359
 Work scheduled by: IESO

UPDATED by IESO 01/18/2023 16:31

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1900 MW
 100 MW
 2000 MW

PRINCTWN-N.SCTLND_345_361

Tue 02/14/2023 to Thu 04/27/2023
 1128 Continuous 1200
 Work scheduled by: LS

UPDATED by LS 02/21/2023 14:36

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 100 MW
 2000 MW

PRINCTWN-N.SCTLND_345_362

Tue 02/14/2023 to Thu 04/27/2023
 1129 Continuous 1600
 Work scheduled by: LS

UPDATED by LS 02/21/2023 14:36

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 100 MW
 2000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits
Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST **2650 MW**
CENTRAL EAST - VC **2585 MW**
TOTAL EAST **6000 MW**
UPNY CONED **7815 MW**
SPR/DUN-SOUTH **4600 MW**
DYSINGER EAST **3200 MW**
MOSES SOUTH **3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Tue 02/21/2023 to Sat 07/15/2023
0630 Continuous 1730

Work scheduled by: NGrid

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2300 MW

850 MW

3150 MW

REV (Export)

N.SCTLND-ALPS__345_2

Mon 02/27/2023 to Mon 04/24/2023
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NYISO 03/22/2023 10:09

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

900 MW

700 MW

1600 MW

REV (Export)

N.SCTLND-ALPS__345_2

Mon 02/27/2023 to Mon 04/24/2023
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NYISO 03/22/2023 10:09

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

100 MW

100 MW

200 MW

REV (Export)

100 MW

100 MW

200 MW

EDIC__-FRASER__345_EF24-40

Wed 03/01/2023 to Tue 04/11/2023
0600 Continuous 1800

Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2275 MW

310 MW

2585 MW

REV (Export)

MOSES__-ADIRNDCK_230_MA1

Sun 03/05/2023 to Fri 05/26/2023
2000 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2300 MW

850 MW

3150 MW

REV (Export)

NYISO TRANSFER LIMITATIONS

Saturday, March 25, 2023 to Tuesday, September 24, 2024

Seasonal Limits

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_ROBNSNRD_230_64

Mon 03/13/2023 to Fri 03/31/2023
 0500 Continuous 1900
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability **1900 MW**
 TTC with All Lines In Service 100 MW
 2000 MW

SCH-HQ_CEDARS-NYISO_LIMIT_240

Mon 03/13/2023 to Thu 04/06/2023
 0500 Continuous 2200
 Work scheduled by: HQ
UPDATED by HQ 03/22/2023 11:52

SCH - HQ_CEDARS
 Impacts Total Transfer Capability **240 MW**
 TTC with All Lines In Service 39 MW
 279 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/13/2023 to Thu 04/06/2023
 0500 Continuous 2200
 Work scheduled by: HQ
UPDATED by HQ 03/22/2023 11:52

SCH - HQ_CEDARS
 Impacts Total Transfer Capability **0 MW**
 TTC with All Lines In Service 100 MW
 100 MW

BECK__-NIAGARA_345_PA302

Mon 03/20/2023 to Fri 03/31/2023
 0500 Continuous 1600
 Work scheduled by: IESO
UPDATED by IESO 03/16/2023 10:28

SCH - OH - NY
 Impacts Total Transfer Capability **1100 MW**
 TTC with All Lines In Service 1300 MW
 1050 MW
 2400 MW
 2000 MW

GORDONRD-PRINCTWN_345_371

Mon 03/20/2023 to Wed 04/19/2023
 0700 Continuous 1000
 Work scheduled by: LS
UPDATED by NYISO 02/21/2023 14:40

CENTRAL EAST - VC
 Impacts Total Transfer Capability **2045 MW**
 TTC with All Lines In Service 540 MW
 2585 MW

PRINCTWN-N.SCTLND_345_55

Mon 03/20/2023 to Wed 04/19/2023
 0700 Continuous 1000
 Work scheduled by: LS
UPDATED by NYISO 02/21/2023 14:40

CENTRAL EAST - VC
 Impacts Total Transfer Capability **2045 MW**
 TTC with All Lines In Service 540 MW
 2585 MW

NYISO TRANSFER LIMITATIONS

Saturday, March 25, 2023 to Tuesday, September 24, 2024

Seasonal Limits

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_500

Fri 03/24/2023 to Mon 04/24/2023
 0001 Continuous 1600
 Work scheduled by: NGrid

UPDATED by NYISO 03/22/2023 10:09

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
700 MW
 900 MW
 1600 MW

ADIRNDCK-PORTER__230_12

Fri 03/24/2023 to Mon 03/27/2023
 1700 Continuous 0700
 Work scheduled by: LS

UPDATED by LS 03/25/2023 14:09

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
 850 MW
 3150 MW

ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11

Fri 03/24/2023 to Mon 03/27/2023
 1700 0700
 Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
140 MW
 139 MW
 279 MW

ADIRNDCK-PORTER__230_12 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11

Fri 03/24/2023 to Mon 03/27/2023
 1700 0700
 Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
140 MW
 139 MW
 279 MW

EASTVIEW-SPRNBK__345_W78

Sat 03/25/2023 to Mon 03/27/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
4350 MW
 3465 MW
 7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Sat 03/25/2023 to Mon 03/27/2023

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

7550 MW

265 MW

7815 MW

REV (Export)

SPRNBK_345KV_RNS3

Sat 03/25/2023 to Mon 03/27/2023

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

3800 MW

800 MW

4600 MW

REV (Export)

VOLNEY_-MARCY_345_19

Sat 03/25/2023 to Sun 03/26/2023

0430 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 01/25/2023 11:58

ARR: 19

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

4900 MW

350 MW

5250 MW

REV (Export)

VOLNEY_-MARCY_345_19

Sat 03/25/2023 to Sun 03/26/2023

0430 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 01/25/2023 11:58

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2475 MW

110 MW

2585 MW

REV (Export)

LADENTWN-BUCHAN_S_345_Y88

Mon 03/27/2023 to Wed 03/29/2023

0001 Continuous 2300

Work scheduled by: ORU

UPDATED by ConEd 02/22/2023 12:04

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

7560 MW

255 MW

7815 MW

REV (Export)

EASTVIEW-SPRNBK_345_W65

Mon 03/27/2023 to Wed 03/29/2023

0201 Continuous 1800

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

4350 MW

3465 MW

7815 MW

REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W82				
Mon 03/27/2023	to	Wed 03/29/2023	UPNY CONED	FWD (Import) REV (Export)
0201	Continuous	1800	Impacts Total Transfer Capability	7550 MW
Work scheduled by: ConEd			TTC with All Lines In Service	265 MW
				7815 MW
SPRNBK_345KV_RNS4				
Mon 03/27/2023	to	Wed 03/29/2023	SPR/DUN-SOUTH	FWD (Import) REV (Export)
0201	Continuous	0200	Impacts Total Transfer Capability	3200 MW
Work scheduled by: ConEd			TTC with All Lines In Service	1400 MW
				4600 MW
NINEMILE-CLAY___345_8				
Mon 03/27/2023	to	Tue 04/04/2023	OSWEGO EXPORT	FWD (Import) REV (Export)
0800	Continuous	1900	Impacts Total Transfer Capability	5150 MW
Work scheduled by: NGrid			TTC with All Lines In Service	100 MW
				5250 MW
<u>UPDATED by NGrid 03/25/2023 14:10</u>				
EASTVIEW-SPRNBK_345_W65				
Wed 03/29/2023	to	Fri 04/07/2023	UPNY CONED	FWD (Import) REV (Export)
1801	Continuous	0200	Impacts Total Transfer Capability	4350 MW
Work scheduled by: ConEd			TTC with All Lines In Service	3465 MW
				7815 MW
MILLWOOD-EASTVIEW_345_W82				
Wed 03/29/2023	to	Fri 04/07/2023	UPNY CONED	FWD (Import) REV (Export)
1801	Continuous	0200	Impacts Total Transfer Capability	7550 MW
Work scheduled by: ConEd			TTC with All Lines In Service	265 MW
				7815 MW
ATHENS_-PLSNTVLY_345_91				
Fri 03/31/2023	to	Sat 04/15/2023	UPNY CONED	FWD (Import) REV (Export)
0001	Continuous	1800	Impacts Total Transfer Capability	3800 MW
Work scheduled by: NGrid			TTC with All Lines In Service	4015 MW
				7815 MW
<u>UPDATED by NGrid 03/14/2023 10:15</u>				

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

Fri 03/31/2023 to Sat 04/15/2023

0001 Continuous 1800

Work scheduled by: NGrid

UPDATED by NGrid 03/14/2023 10:15

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

4015 MW

7815 MW

E13THSTA-FARRAGUT_345_45

Sat 04/01/2023 to Sat 04/01/2023

0001 Continuous 2200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

VOLNEY_-MARCY__345_19

Sat 04/01/2023 to Sun 04/02/2023

0500 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 03/10/2023 13:25

ARR: 19

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

4900 MW

350 MW

5250 MW

VOLNEY_-MARCY__345_19

Sat 04/01/2023 to Sun 04/02/2023

0500 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 03/10/2023 13:25

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2475 MW

110 MW

2585 MW

CHAT_DC_GC1

Sun 04/02/2023 to Sun 04/02/2023

0001 Continuous 0200

Work scheduled by: HQ

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2850 MW

300 MW

3150 MW

CHAT_DC_GC1

Sun 04/02/2023 to Sun 04/02/2023

0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

500 MW

500 MW

1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 , CHAT_DC_GC2	FWD (Import)	REV (Export)
Sun 04/02/2023 to Sun 04/02/2023		
0001 to 0200		
MOSES SOUTH	2550 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	3150 MW	
Work scheduled by:		
<hr/>		
CHAT_DC_GC1 , CHAT_DC_GC2	FWD (Import)	REV (Export)
Sun 04/02/2023 to Sun 04/02/2023		
0001 to 0200		
SCH - HQ - NY	1370 MW	0 MW
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW
Work scheduled by:		
<hr/>		
CHAT_DC_GC2	FWD (Import)	REV (Export)
Sun 04/02/2023 to Sun 04/02/2023		
0001 Continuous to 0200		
MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	
Work scheduled by: HQ		
<hr/>		
CHAT_DC_GC2	FWD (Import)	REV (Export)
Sun 04/02/2023 to Sun 04/02/2023		
0001 Continuous to 0200		
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW
Work scheduled by: HQ		
<hr/>		
SCH-HQ-NYISO_LIMIT_1050	FWD (Import)	REV (Export)
Sun 04/02/2023 to Sun 04/02/2023		
0001 Continuous to 0200		
SCH - HQ - NY	1050 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	1500 MW	
Work scheduled by: HQ		
<hr/>		
DOLSONAV-ROCKTVRN_345_DART44	FWD (Import)	REV (Export)
Mon 04/03/2023 to Fri 04/14/2023		
0730 Continuous to 1600		
CENTRAL EAST - VC	2485 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	2585 MW	
Work scheduled by: CHGE		

UPDATED by CHGE 03/15/2023 09:53

NYISO TRANSFER LIMITATIONS

Saturday, March 25, 2023 to Tuesday, September 24, 2024

Seasonal Limits

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WATRCURE-OAKDALE_345_31

FWD (Import) REV (Export)

Tue 04/04/2023 to Tue 04/04/2023
0700 Daily 1800

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

Work scheduled by: NYSEG

EASTVIEW-SPRNBK_345_W64

FWD (Import) REV (Export)

Fri 04/07/2023 to Sun 04/16/2023
0201 Continuous 0200

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

4350 MW
3465 MW
7815 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW_345_W99

FWD (Import) REV (Export)

Fri 04/07/2023 to Fri 04/07/2023
0201 Continuous 0230

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

7550 MW
265 MW
7815 MW

Work scheduled by: ConEd

SPRNBK_345KV_RNS5

FWD (Import) REV (Export)

Fri 04/07/2023 to Fri 04/07/2023
0201 Continuous 0230

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

3200 MW
1400 MW
4600 MW

Work scheduled by: ConEd

CHAT_DC_GC1

FWD (Import) REV (Export)

Sun 04/09/2023 to Sun 04/09/2023
0001 Continuous 0200

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

2850 MW
300 MW
3150 MW

Work scheduled by: HQ

CHAT_DC_GC1

FWD (Import) REV (Export)

Sun 04/09/2023 to Sun 04/09/2023
0001 Continuous 0200

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

500 MW
500 MW
1000 MW

Work scheduled by: HQ

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 04/09/2023 to Sun 04/09/2023
 0001 0200

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2550 MW
 600 MW
 3150 MW

Work scheduled by:

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 04/09/2023 to Sun 04/09/2023
 0001 0200

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1370 MW **0 MW**
 130 MW 1000 MW
 1500 MW 1000 MW

Work scheduled by:

CHAT_DC_GC2

Sun 04/09/2023 to Sun 04/09/2023
 0001 Continuous 0200

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
 300 MW
 3150 MW

Work scheduled by: HQ

CHAT_DC_GC2

Sun 04/09/2023 to Sun 04/09/2023
 0001 Continuous 0200

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
500 MW
 500 MW
 1000 MW

Work scheduled by: HQ

SCH-HQ-NYISO_LIMIT_1050

Sun 04/09/2023 to Sun 04/09/2023
 0001 Continuous 0200

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1050 MW
 450 MW
 1500 MW

Work scheduled by: HQ

LINDN_CG-LNDVFT__345_V-3022

Sun 04/09/2023 to Sat 04/15/2023
 1400 Continuous 2300

UPDATED by PJM, 02/06/2023 07:36

SCH - PJM_VFT
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW **0 MW**
 315 MW 315 MW
 315 MW 315 MW

Work scheduled by: PJM

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FROST_BR-LONG_MTN_345_352

Sun 04/09/2023 to Tue 04/18/2023
2030 Continuous 1300

UPDATED by ISONE 03/07/2023 11:22

SCH - NE - NY

FWD (Import) REV (Export)

1300 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_600

Sun 04/09/2023 to Tue 04/18/2023
2030 Continuous 1300

UPDATED by ISONE 03/07/2023 11:22

SCH - NE - NY

FWD (Import) REV (Export)

800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

DYSINGER-STA_255_345_DH1

Mon 04/10/2023 to Fri 04/14/2023
0500 Continuous 2000

DYSINGER EAST

FWD (Import) REV (Export)

2850 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

Work scheduled by: NYPA

OSWEGO_-VOLNEY_345_12

Tue 04/11/2023 to Tue 04/11/2023
0630 Continuous 1800

OSWEGO EXPORT

FWD (Import) REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

LEEDS_-ATHENS_345_95

Tue 04/11/2023 to Tue 04/11/2023
0830 Daily 1100

UPDATED by NGrid 03/24/2023 11:12

UPNY CONED

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: NGrid

DUNWODIE_345KV_3

Wed 04/12/2023 to Wed 04/12/2023
0201 Continuous 0230

SPR/DUN-SOUTH

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

Wed 04/12/2023 to Wed 04/12/2023
 0201 Continuous 0230
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

PLSNTVLE-DUNWODIE_345_W89

Wed 04/12/2023 to Wed 04/12/2023
 0201 Continuous 0230
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	4000 MW	
Impacts Total Transfer Capability	3815 MW	
TTC with All Lines In Service	7815 MW	

FRASANNX-COOPERS_345_UCC2-41

Wed 04/12/2023 to Fri 05/05/2023
 0600 Continuous 1730
 Work scheduled by: NYPA
 ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2275 MW	
Impacts Total Transfer Capability	310 MW	
TTC with All Lines In Service	2585 MW	

MARCY_-FRASANNX_345_UCC2-41

Wed 04/12/2023 to Fri 05/05/2023
 0600 Continuous 1730
 Work scheduled by: NYPA
 ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2275 MW	
Impacts Total Transfer Capability	310 MW	
TTC with All Lines In Service	2585 MW	

OSWEGO_-VOLNEY_345_11

Wed 04/12/2023 to Wed 04/12/2023
 0630 Continuous 1800
 Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

SCH-NPX_1385-NYISO_LIMIT_100

Thu 04/13/2023 to Fri 04/28/2023
 2030 Continuous 2000
 Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>ADIRNDCK-PORTER__230_12</p> <p>Fri 04/14/2023 to Tue 04/18/2023</p> <p>1700 Continuous 0700</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: center;"><u>UPDATED by NGrid 03/16/2023 11:27</u></p> <p>MOSES SOUTH</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>2300 MW</p> <p>850 MW</p> <p>3150 MW</p>	<p>REV (Export)</p>
<p>ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11</p> <p>Fri 04/14/2023 to Tue 04/18/2023</p> <p>1700 0700</p> <p>Work scheduled by:</p>	<p>SCH - HQ_CEDARS</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>140 MW</p> <p>139 MW</p> <p>279 MW</p>	<p>REV (Export)</p>
<p>ADIRNDCK-PORTER__230_12 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11</p> <p>Fri 04/14/2023 to Tue 04/18/2023</p> <p>1700 0700</p> <p>Work scheduled by:</p>	<p>SCH - HQ_CEDARS</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>140 MW</p> <p>139 MW</p> <p>279 MW</p>	<p>REV (Export)</p>
<p>PLSNTVLY_345KV_RNS5</p> <p>Sun 04/16/2023 to Sun 04/16/2023</p> <p>0100 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>UPNY CONED</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>3800 MW</p> <p>4015 MW</p> <p>7815 MW</p>	<p>REV (Export)</p>
<p>MILLWOOD-EASTVIEW_345_W99</p> <p>Sun 04/16/2023 to Sun 04/16/2023</p> <p>0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>UPNY CONED</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>7550 MW</p> <p>265 MW</p> <p>7815 MW</p>	<p>REV (Export)</p>

NYISO TRANSFER LIMITATIONS**Seasonal Limits**

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS5

Sun 04/16/2023 to Sun 04/16/2023
0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

LEEDS__PLSNTVLY_345_92

Sun 04/16/2023 to Sun 04/30/2023
0700 Continuous 2200

Work scheduled by: NGrid

UPDATED by ConEd 03/10/2023 10:36

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

PLSNTVLY_345KV_RNS5

Sun 04/16/2023 to Sun 04/30/2023
0700 Continuous 2200

Work scheduled by: NGrid

UPDATED by ConEd 03/10/2023 10:36

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

BECK__-NIAGARA_230_PA27

Mon 04/17/2023 to Fri 05/05/2023
0400 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

FWD (Import)

REV (Export)

2100 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

2400 MW

DYSINGER-STA_255_345_DH2

Mon 04/17/2023 to Fri 04/21/2023
0500 Continuous 2000

Work scheduled by: NYPA

DYSINGER EAST

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

CLAY__-EDIC__345_2-15

Mon 04/17/2023 to Fri 04/28/2023
0600 Continuous 1800

Work scheduled by: NGrid

UPDATED by NGrid 03/20/2023 14:42

OSWEGO EXPORT

FWD (Import)

REV (Export)

4850 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

Wed 04/19/2023 to Mon 05/01/2023
 1000 Continuous 0559
 Work scheduled by: NYISO

UPDATED by NYISO 02/27/2023 17:19

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) **2360 MW**
 REV (Export)
 225 MW
 2585 MW

ADIRNDCK-PORTER__230_12

Thu 04/20/2023 to Tue 04/25/2023
 1700 Continuous 0700
 Work scheduled by: LS

UPDATED by NGrid 03/16/2023 11:38

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) **2300 MW**
 REV (Export)
 850 MW
 3150 MW

ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11

Thu 04/20/2023 to Tue 04/25/2023
 1700 0700
 Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) **140 MW**
 REV (Export)
 139 MW
 279 MW

ADIRNDCK-PORTER__230_12 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11

Thu 04/20/2023 to Tue 04/25/2023
 1700 0700
 Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) **140 MW**
 REV (Export)
 139 MW
 279 MW

CHAT_DC_GC1

Sun 04/23/2023 to Sun 04/23/2023
 0001 Continuous 0200
 Work scheduled by: HQ

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) **2850 MW**
 REV (Export)
 300 MW
 3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Location	FWD (Import)	REV (Export)
CHAT_DC_GC1					
Sun 04/23/2023	to	Sun 04/23/2023	SCH - HQ - NY		
0001	Continuous	0200	Impacts Total Transfer Capability		500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
<hr/>					
CHAT_DC_GC1 , CHAT_DC_GC2					
Sun 04/23/2023	to	Sun 04/23/2023	MOSES SOUTH		
0001		0200	Impacts Total Transfer Capability	600 MW	
Work scheduled by:				TTC with All Lines In Service	3150 MW
<hr/>					
CHAT_DC_GC1 , CHAT_DC_GC2					
Sun 04/23/2023	to	Sun 04/23/2023	SCH - HQ - NY		
0001		0200	Impacts Total Transfer Capability	130 MW	1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW
<hr/>					
CHAT_DC_GC2					
Sun 04/23/2023	to	Sun 04/23/2023	MOSES SOUTH		
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
<hr/>					
CHAT_DC_GC2					
Sun 04/23/2023	to	Sun 04/23/2023	SCH - HQ - NY		
0001	Continuous	0200	Impacts Total Transfer Capability		500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
<hr/>					
SCH-HQ-NYISO_LIMIT_1150					
Sun 04/23/2023	to	Sun 04/23/2023	SCH - HQ - NY		
0001	Continuous	0200	Impacts Total Transfer Capability	350 MW	
Work scheduled by: HQ				TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W98

Mon 04/24/2023 to Wed 04/26/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7680 MW	
Impacts Total Transfer Capability	135 MW	
TTC with All Lines In Service	7815 MW	

MILLWOOD_345KV_18

Mon 04/24/2023 to Wed 04/26/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	4350 MW	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

DUNWODIE_345KV_3

Mon 04/24/2023 to Mon 04/24/2023
0130 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_4

Mon 04/24/2023 to Mon 04/24/2023
0130 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

PANNELL_-CLAY___345_1

Mon 04/24/2023 to Fri 04/28/2023
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	1300 MW	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

NRTH1385-NOR HBR_138_601

Tue 04/25/2023 to Sat 04/29/2023
0500 Continuous 2359
Work scheduled by: LI

UPDATED by LI 02/02/2023 09:40

SCH - NPX_1385	FWD (Import)	REV (Export)
	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR_138_602				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500	Continuous	2359	<u>UPDATED by LI 02/02/2023 09:40</u>	SCH - NPX_1385	100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_603				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500	Continuous	2359	<u>UPDATED by LI 02/02/2023 09:40</u>	SCH - NPX_1385	100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_601				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500		2359		SCH - NPX_1385	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_601				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500		2359		SCH - NPX_1385	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500		2359		SCH - NPX_1385	0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500	Continuous	2359	<u>UPDATED by LI 02/02/2023 09:40</u>	SCH - NPX_1385	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK_230_68

Wed 04/26/2023 to Wed 05/10/2023
0700 Continuous 1630

UPDATED by NGrid 03/21/2023 12:58

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: NGrid

CHAT_DC_GC2

Sun 04/30/2023 to Sun 05/21/2023
0500 Continuous 2000

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: HQ

2850 MW

300 MW

3150 MW

CHAT_DC_GC2

Sun 04/30/2023 to Sun 05/21/2023
0500 Continuous 2000

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: HQ

500 MW

500 MW

1000 MW

SCH-HQ-NYISO_LIMIT_1150

Sun 04/30/2023 to Fri 05/05/2023
0500 Continuous 1659

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: HQ

1150 MW

350 MW

1500 MW

NRTH1385-NOR HBR_138_601

Mon 05/01/2023 to Fri 06/09/2023
0500 Continuous 2359

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: LI

100 MW

100 MW

100 MW

100 MW

200 MW

200 MW

NRTH1385-NOR HBR_138_602

Mon 05/01/2023 to Fri 06/09/2023
0500 Continuous 2359

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: LI

100 MW

100 MW

100 MW

100 MW

200 MW

200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR_138_603				
Mon 05/01/2023	to	Fri 06/09/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0500	Continuous	2359	Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: LI			TTC with All Lines In Service	100 MW 100 MW
				200 MW 200 MW
NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_601				
Mon 05/01/2023	to	Fri 06/09/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0500		2359	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	200 MW 200 MW
				200 MW 200 MW
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_601				
Mon 05/01/2023	to	Fri 06/09/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0500		2359	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	200 MW 200 MW
				200 MW 200 MW
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602				
Mon 05/01/2023	to	Fri 06/09/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0500		2359	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	200 MW 200 MW
				200 MW 200 MW
NRTH1385-NRTHPORT_138_NNC				
Mon 05/01/2023	to	Fri 06/09/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0500	Continuous	2359	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by: LI			TTC with All Lines In Service	200 MW 200 MW
				200 MW 200 MW
HUDSONTP-W49TH_ST_345_Y56				
Mon 05/01/2023	to	Fri 05/05/2023	SCH - PJM_HTP	FWD (Import) REV (Export)
0600	Continuous	1800	Impacts Total Transfer Capability	0 MW
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW
				660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Mon 05/01/2023 to Mon 05/01/2023
 0600 Continuous 0630
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 05/01/2023 to Mon 05/01/2023
 0600 Continuous 0630
 Work scheduled by: ConEd

SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

PANNELL_-CLAY___345_2

Mon 05/01/2023 to Fri 05/05/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

LEEDS_-HURLYAVE_345_301

Mon 05/01/2023 to Fri 06/02/2023
 0800 Continuous 1700
 Work scheduled by: CHGE

UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

PIERCBRK-FIVEMILE_345_37

Tue 05/02/2023 to Tue 05/02/2023
 0830 Continuous 1230
 Work scheduled by: NGrid

SCH - PJ - NY **FWD (Import) REV (Export)**
 Impacts Total Transfer Capability
 TTC with All Lines In Service

E13THSTA-FARRAGUT_345_46

Wed 05/03/2023 to Fri 05/05/2023
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-CRICKVLY_345_398

Wed 05/03/2023 to Wed 05/03/2023
 0830 Continuous 1600
 Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-CRICKVLY_345_398

Wed 05/03/2023 to Wed 05/03/2023
 0830 Continuous 1600
 Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	500 MW	1150 MW
Impacts Total Transfer Capability	900 MW	450 MW
TTC with All Lines In Service	1400 MW	1600 MW

LONG_MTN-CRICKVLY_345_398 , NRTH1385-NORHBR_138_601

Wed 05/03/2023 to Wed 05/03/2023
 0830 1600
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-CRICKVLY_345_398 , NRTH1385-NORHBR_138_602

Wed 05/03/2023 to Wed 05/03/2023
 0830 1600
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-CRICKVLY_345_398 , NRTH1385-NORHBR_138_603

Wed 05/03/2023 to Wed 05/03/2023
 0830 1600
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1050

Fri 05/05/2023 to Sun 05/21/2023
 1700 Continuous 2000
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY	1050 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	1500 MW	

W49TH_ST_345KV_7

Fri 05/05/2023 to Fri 05/05/2023
 1730 Continuous 1800
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

Fri 05/05/2023 to Fri 05/05/2023
 1730 Continuous 1800
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	450 MW	
Impacts Total Transfer Capability	210 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_6

Sat 05/06/2023 to Sat 05/06/2023
 0001 Continuous 0030
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

Sat 05/06/2023 to Sat 05/06/2023
 0001 Continuous 0030
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	450 MW	
Impacts Total Transfer Capability	210 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY_-MARCY__345_19

Sat 05/06/2023 to Sun 05/28/2023

0500 Continuous 1900

Work scheduled by: NYPA

ARR: 19

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

4900 MW

350 MW

5250 MW

VOLNEY_-MARCY__345_19

Sat 05/06/2023 to Sun 05/28/2023

0500 Continuous 1900

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2475 MW

110 MW

2585 MW

ATHENS_-PLSNTVLY_345_91

Mon 05/08/2023 to Thu 05/18/2023

0001 Continuous 2200

Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:27

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

4015 MW

7815 MW

PLSNTVLY_345KV_RNS4

Mon 05/08/2023 to Thu 05/18/2023

0001 Continuous 2200

Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:27

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

4015 MW

7815 MW

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/08/2023 to Sun 05/21/2023

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2485 MW

100 MW

2585 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 05/08/2023 to Sat 05/13/2023

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2485 MW

100 MW

2585 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST 2650 MW
 CENTRAL EAST - VC 2585 MW
 TOTAL EAST 6000 MW
 UPNY CONED 7815 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OAKDALE_FRASER__345_32

Tue 05/09/2023 to Tue 05/09/2023
 0700 Daily 1800

UPDATED by NYSEG 03/07/2023 14:15

CENTRAL EAST - VC

FWD (Import) REV (Export)

2450 MW

Impacts Total Transfer Capability

135 MW

TTC with All Lines In Service

2585 MW

Work scheduled by: NYSEG

LADENTWN-BUCHAN_S_345_Y88

Wed 05/10/2023 to Sat 05/13/2023
 0101 Continuous 0100

UPDATED by ConEd 02/22/2023 12:04

UPNY CONED

FWD (Import) REV (Export)

7560 MW

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ORU

SPRNBK_345KV_RNS4

Sat 05/13/2023 to Mon 05/15/2023
 0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SPR/DUN-SOUTH

FWD (Import) REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

SPRNBK-W49TH_ST_345_M52

Sat 05/13/2023 to Mon 05/15/2023
 0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SPR/DUN-SOUTH

FWD (Import) REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_5

Sat 05/13/2023 to Mon 05/15/2023
 0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SCH - PJM_HTP

FWD (Import) REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200

SCH - PJM_HTP

FWD (Import) REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
 0130 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
450 MW
 210 MW
 660 MW

W49TH_ST_345KV_6

Mon 05/15/2023 to Mon 05/15/2023
 0301 Continuous 0330
 Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

W49TH_ST-E13THSTA_345_M55

Mon 05/15/2023 to Wed 05/17/2023
 0301 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

W49TH_ST_345KV_6

Tue 05/16/2023 to Wed 05/17/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

SHOR_NPX-SHOREHAM_138_CSC

Tue 05/16/2023 to Sun 05/21/2023
 0500 Continuous 1500
 Work scheduled by: LI

SCH - NPX_CSC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW **0 MW**
 330 MW 330 MW
 330 MW 330 MW

MOTTHAVN-RAINEY__345_Q11

Fri 05/19/2023 to Sat 05/20/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 02/18/2023 08:38

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__345KV_CSC

Fri 05/19/2023 to Tue 05/23/2023
 0500 Continuous 1900
 Work scheduled by: NYPA

UPDATED by NYPA 10/05/2022 11:11

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2535 MW
 50 MW
 2585 MW

LEEDS__PLSNTVLY_345_92

Sat 05/20/2023 to Sat 05/27/2023
 0001 Continuous 2200
 Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:21

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 4015 MW
 7815 MW

PLSNTVLY_345KV_RNS5

Sat 05/20/2023 to Sat 05/27/2023
 0001 Continuous 2200
 Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:21

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 4015 MW
 7815 MW

CHATGUAY-MASSENA_765_7040

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930
 Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW **0 MW**
 1500 MW 1000 MW
 1500 MW 1000 MW

CHATGUAY-MASSENA_765_7040

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930
 Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1550 MW
 1600 MW
 3150 MW

CHATGUAY-MASSENA_765_7040 , MASSENA-MARCY__765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
 0600 1930
 Work scheduled by:

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
500 MW
 2650 MW
 3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1750 MW

1400 MW

3150 MW

Work scheduled by: NYPA

MARCY___765_345_AT2

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 16:34

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1700 MW

1450 MW

3150 MW

Work scheduled by: NYPA

MASSENA_-MARCYS___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1720 MW

865 MW

2585 MW

Work scheduled by: NYPA

MASSENA_-MARCYS___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

Work scheduled by: NYPA

MASSENA_-MARCYS___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

475 MW

1000 MW

1025 MW

0 MW

1500 MW

1000 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY__765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
500 MW
2650 MW
3150 MW

Work scheduled by: NYPA

MASSENA -MARCY__765_MSU1 , CHASLAKE-PORTER__230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
90 MW
180 MW
270 MW

Work scheduled by:

MASSENA -MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
90 MW
180 MW
270 MW

Work scheduled by:

MASSENA -MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
90 MW
180 MW
270 MW

Work scheduled by:

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
90 MW
180 MW
270 MW

Work scheduled by:

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
850 MW 0 MW
650 MW 1000 MW
1500 MW 1000 MW

Work scheduled by:

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
CHASLAKE-PORTER_230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
90 MW	
180 MW	
270 MW	

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
STLAWRNC-MOSES_230_L34P

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
90 MW	
180 MW	
270 MW	

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
STLAWRNC-MOSES_230_L34P , CHASLAKE-PORTER_230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
90 MW	
180 MW	
270 MW	

LEEDS__345KV_R94301

Mon 06/05/2023 to Tue 06/06/2023
0830 Continuous 1400

Work scheduled by: NGrid

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
4015 MW	
7815 MW	

ELBRIDGE-LAFAYTTE_345_17-LE

Wed 06/07/2023 to Wed 06/07/2023
0630 Daily 1800

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
5250 MW	
0 MW	
5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_-ELBRIDGE_345_17					FWD (Import)	REV (Export)
Wed 06/07/2023	to	Wed 06/07/2023		OSWEGO EXPORT	5250 MW	
0630	Daily	1800	ARR: 75	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
NIAGARA_-PACKARD_230_62					FWD (Import)	REV (Export)
Mon 06/26/2023	to	Fri 06/30/2023		SCH - OH - NY	1500 MW	
0500	Continuous	1900		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	1900 MW	
NIAGARA_345_230_AT4					FWD (Import)	REV (Export)
Wed 06/28/2023	to	Thu 06/29/2023		SCH - OH - NY	1150 MW	
0500	Continuous	1900		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW	
MARCY_-EDIC_345_UE1-7					FWD (Import)	REV (Export)
Sat 07/08/2023	to	Sun 07/09/2023	<u>UPDATED by NYPA 10/28/2022 10:56</u>	OSWEGO EXPORT	5250 MW	
0500	Continuous	1900	ARR: 19,16	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	
MARCY_-EDIC_345_UE1-7					FWD (Import)	REV (Export)
Sat 07/15/2023	to	Sun 07/16/2023	<u>UPDATED by NYPA 10/28/2022 11:17</u>	OSWEGO EXPORT	5250 MW	
0500	Continuous	1930	ARR: 19,16	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	
ADIRNDCK-PORTER_230_12					FWD (Import)	REV (Export)
Sun 07/16/2023	to	Sun 07/16/2023	<u>UPDATED by NYPA 12/14/2022 14:55</u>	MOSES SOUTH	2100 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA2

Sun 07/16/2023 to Sun 07/16/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

SCH-IMO_NY_NIAG_CB_3122_W/BB

Mon 07/17/2023 to Fri 07/28/2023
 0500 Continuous 2100
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1800 MW	1300 MW
Impacts Total Transfer Capability	100 MW	250 MW
TTC with All Lines In Service	1900 MW	1550 MW

ADIRNDCK-CHASLAKE_230_13

Mon 07/17/2023 to Mon 07/17/2023
 0700 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 02/17/2023 15:10

	FWD (Import)	REV (Export)
MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

MOSES__-ADIRNDCK_230_MA1

Mon 07/17/2023 to Mon 07/17/2023
 0700 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 02/17/2023 15:10

	FWD (Import)	REV (Export)
MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

ADIRNDCK-CHASLAKE_230_13

Tue 07/18/2023 to Fri 09/15/2023
 0630 Continuous 1600
 Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

HURLYAVE-ROSETON_345_303

Mon 07/31/2023 to Fri 08/25/2023
 0800 Continuous 1600
 Work scheduled by: CHGE

	FWD (Import)	REV (Export)
UPNY CONED	4100 MW	
Impacts Total Transfer Capability	3715 MW	
TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH2

Fri 08/04/2023 to Mon 08/14/2023
 0500 Continuous 2300
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Mon 08/07/2023 to Fri 08/11/2023
 0500 Continuous 1900
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1300 MW	1100 MW
Impacts Total Transfer Capability	600 MW	450 MW
TTC with All Lines In Service	1900 MW	1550 MW

DYSINGER-STA_255_345_DH1

Tue 08/15/2023 to Fri 08/25/2023
 0500 Continuous 2300
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

MARCY_345KV_CSC

Sat 08/19/2023 to Sun 08/20/2023
 0500 Continuous 1930
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2535 MW	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	2585 MW	

MARCY_-EDIC_345_UE1-7

Sat 08/19/2023 to Sun 08/20/2023
 0500 Continuous 1930
 Work scheduled by: NYPA

ARR: 19,16

	FWD (Import)	REV (Export)
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

NIAGARA_345_230_AT4

Mon 08/28/2023 to Fri 09/01/2023
 0500 Continuous 2100
 Work scheduled by: NYPA

UPDATED by NYPA 03/16/2023 08:43

	FWD (Import)	REV (Export)
SCH - OH - NY		1150 MW
Impacts Total Transfer Capability		400 MW
TTC with All Lines In Service		1550 MW

NYISO TRANSFER LIMITATIONS

Saturday, March 25, 2023 to Tuesday, September 24, 2024

Seasonal Limits

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY__-EDIC__345_1-16				FWD (Import)	REV (Export)
Mon 09/11/2023	to	Fri 09/15/2023	<u>UPDATED by NYISO 02/22/2023 09:21</u>	OSWEGO EXPORT	4850 MW
0700	Continuous	1530		Impacts Total Transfer Capability	400 MW
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW
FRASER_-GILBOA__345_GF5-35				FWD (Import)	REV (Export)
Mon 09/11/2023	to	Sun 09/17/2023		CENTRAL EAST - VC	2450 MW
0700	Continuous	1530		Impacts Total Transfer Capability	135 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
LONG_MTN-CRICKVLY_345_398				FWD (Import)	REV (Export)
Fri 09/15/2023	to	Sun 10/01/2023		SCH - NPX_1385	100 MW 100 MW
0001	Continuous	2200		Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: ConEd				TTC with All Lines In Service	200 MW 200 MW
LONG_MTN-CRICKVLY_345_398				FWD (Import)	REV (Export)
Fri 09/15/2023	to	Sun 10/01/2023		SCH - NE - NY	500 MW 1150 MW
0001	Continuous	2200		Impacts Total Transfer Capability	900 MW 450 MW
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS5

Fri 09/15/2023 to Mon 10/23/2023
0001 Continuous 0200

UPDATED by ConEd 08/10/2022 13:51

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

SPRNBK_W49TH_ST_345_M51

Fri 09/15/2023 to Mon 10/23/2023
0001 Continuous 0200

UPDATED by ConEd 08/10/2022 13:51

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

CHASLAKE-PORTER_230_11

Sat 09/16/2023 to Sun 10/15/2023
0630 Continuous 1730

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

FWD (Import)

REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

CLAY_-EDIC_345_2-15

Mon 09/18/2023 to Fri 09/22/2023
0700 Continuous 1530

OSWEGO EXPORT

FWD (Import)

REV (Export)

4850 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

MARCY_-EDIC_345_UE1-7

Sat 09/23/2023 to Sun 09/24/2023
0500 Continuous 1900

UPDATED by NYPA 10/28/2022 11:09

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

ARR: 19,16

NIAGARA_-DYSINGER_345_ND2

Mon 09/25/2023 to Fri 09/29/2023
0500 Continuous 2000

DYSINGER EAST

FWD (Import)

REV (Export)

2700 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3200 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__345KV_CSC

Mon 09/25/2023 to Sat 10/07/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2535 MW	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	2585 MW	

ROSETON_-EFISHKIL_345_RFK305

Mon 09/25/2023 to Fri 10/13/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
UPNY CONED	6680 MW	
Impacts Total Transfer Capability	1135 MW	
TTC with All Lines In Service	7815 MW	

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/06/2023
 0600 Continuous 1800
 Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

ROSETON_-ROCKTVRN_345_311

Mon 10/02/2023 to Fri 11/03/2023
 0800 Continuous 1600
 Work scheduled by: CHGE

	FWD (Import)	REV (Export)
UPNY CONED	4400 MW	
Impacts Total Transfer Capability	3415 MW	
TTC with All Lines In Service	7815 MW	

GILBOA_-N.SCTLND_345_GNS-1

Mon 10/09/2023 to Fri 10/13/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2300 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	2585 MW	

NIAGARA_-PACKARD_230_61

Fri 10/13/2023 to Fri 10/13/2023
 0500 Continuous 1900
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		1350 MW
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1550 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Mon 10/16/2023 to Tue 11/14/2023
0630 Continuous 1730

UPDATED by NGrid 11/07/2022 15:17

MOSES SOUTH

FWD (Import) REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

NEPTUNE_DUFFYAVE_345_NEPTUNE

Sun 10/29/2023 to Fri 11/17/2023
0001 Continuous 2359

SCH - PJM_NEPTUNE

FWD (Import) REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

NEWBRDGE_345_138_BK_1

Sun 10/29/2023 to Fri 11/17/2023
0001 Continuous 2359

SCH - PJM_NEPTUNE

FWD (Import) REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

NEWBRDGE_345_138_BK_2

Sun 10/29/2023 to Fri 11/17/2023
0001 Continuous 2359

SCH - PJM_NEPTUNE

FWD (Import) REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

NEWBRDGE-DUFFYAVE_345_501

Sun 10/29/2023 to Fri 11/17/2023
0001 Continuous 2359

SCH - PJM_NEPTUNE

FWD (Import) REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

LONG_MTN-CRICKVLY_345_398

Mon 11/06/2023 to Thu 11/30/2023
0001 Continuous 2200

SCH - NPX_1385

FWD (Import) REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-CRICKVLY_345_398

Mon 11/06/2023 to Thu 11/30/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
700 MW	1300 MW
900 MW	500 MW
1600 MW	1800 MW

LINDN_CG-LNDVFT_345_V-3022

Mon 11/06/2023 to Thu 11/09/2023
 0800 Continuous 1500
 Work scheduled by: PJM

SCH - PJM_VFT
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
315 MW	315 MW
315 MW	315 MW

HURLYAVE-ROSETON_345_303

Mon 11/13/2023 to Fri 12/22/2023
 0800 Continuous 1600
 Work scheduled by: CHGE

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
4100 MW	
3715 MW	
7815 MW	

CHATGUAY-MASSENA_765_7040

Wed 11/15/2023 to Mon 11/27/2023
 0700 Continuous 1730
 Work scheduled by: NYPA

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
1500 MW	1000 MW
1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Wed 11/15/2023 to Mon 11/27/2023
 0700 Continuous 1730
 Work scheduled by: NYPA

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
1550 MW	
1600 MW	
3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040 , MASSENA-MARCY_765_MSU1				FWD (Import)	REV (Export)
Wed 11/15/2023	to	Mon 11/27/2023	MOSES SOUTH	500 MW	
0700		1730	Impacts Total Transfer Capability	2650 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
MASSENA-MARCY_765_MSU1				FWD (Import)	REV (Export)
Wed 11/15/2023	to	Mon 11/27/2023	CENTRAL EAST - VC	1720 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	865 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	
MASSENA-MARCY_765_MSU1				FWD (Import)	REV (Export)
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ_CEDARS	90 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	189 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	279 MW	
MASSENA-MARCY_765_MSU1				FWD (Import)	REV (Export)
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ - NY	475 MW	1000 MW
0700	Continuous	1730	Impacts Total Transfer Capability	1025 MW	0 MW
Work scheduled by: NYPA			TTC with All Lines In Service	1500 MW	1000 MW
MASSENA-MARCY_765_MSU1				FWD (Import)	REV (Export)
Wed 11/15/2023	to	Mon 11/27/2023	MOSES SOUTH	500 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Saturday, March 25, 2023 to Tuesday, September 24, 2024

Seasonal Limits

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Description	Start Date	End Date	Schedule	Impacts	FWD (Import)	REV (Export)
MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2						
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ_CEDARS	Impacts Total Transfer Capability	90 MW	
0700		1530		TTC with All Lines In Service	189 MW	
Work scheduled by:					279 MW	
MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2						
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ - NY	Impacts Total Transfer Capability	850 MW	0 MW
0700		1530		TTC with All Lines In Service	650 MW	1000 MW
Work scheduled by:					1500 MW	1000 MW
LINDN_CG-LNDVFT__345_V-3022						
Wed 11/15/2023	to	Wed 11/15/2023	SCH - PJM_VFT	Impacts Total Transfer Capability	0 MW	0 MW
1500	Continuous	1700		TTC with All Lines In Service	315 MW	315 MW
Work scheduled by: PJM					315 MW	315 MW
NIAGARA_345_230_AT4						
Mon 12/04/2023	to	Fri 12/08/2023	SCH - OH - NY	Impacts Total Transfer Capability	350 MW	1650 MW
0500	Continuous	1900	<u>UPDATED by NYPA 03/21/2023 14:25</u>	TTC with All Lines In Service	2000 MW	
Work scheduled by: NYPA						
HOMR_NYW-PIERC_NY_345_48						
Fri 12/08/2023	to	Fri 12/15/2023	SCH - PJ - NY	Impacts Total Transfer Capability		
0800	Continuous	1600	<u>UPDATED by PJM 07/28/2022 14:08</u>	TTC with All Lines In Service		
Work scheduled by: PJM						
LONG_MTN-CRICKVLY_345_398						
Tue 12/12/2023	to	Thu 12/21/2023	SCH - NPX_1385	Impacts Total Transfer Capability	100 MW	100 MW
0001	Continuous	2200		TTC with All Lines In Service	100 MW	100 MW
Work scheduled by: ConEd					200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, March 25, 2023 to Tuesday, September 24, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-CRICKVLY_345_398

Tue 12/12/2023 to Thu 12/21/2023
0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

700 MW

1300 MW

900 MW

500 MW

1600 MW

1800 MW

S.RIPLEY-DUNKIRK_230_68

Wed 12/27/2023 to Fri 12/29/2023
0730 Continuous 1600

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

W49TH_ST_345KV_6

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201

Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

310 MW

350 MW

660 MW

W49TH_ST-E13THSTA_345_M55

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

W49TH_ST_345KV_8

Sat 02/03/2024 to Mon 02/19/2024
0001 Continuous 0201

Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

310 MW

350 MW

660 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2024 to Fri 05/10/2024
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX_CSC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

0 MW

0 MW

330 MW

330 MW

330 MW

330 MW

NYISO TRANSFER LIMITATIONS