

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 08/31/2023
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 08/31/2023
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 08/31/2023
 0001 2359
 Work scheduled by:

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2350 MW 2050 MW
 100 MW 100 MW
 2450 MW 2150 MW

EGRDNCTY_345_138_AT1

Sat 10/01/2022 to Wed 05/31/2023
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

EGRDNCTY_345_138_AT2

Sat 10/01/2022 to Wed 05/31/2023
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_EGRDNCTR_345_Y49

Sat 10/01/2022 to Wed 05/31/2023
 0001 Continuous 2359
 Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
775 MW
 725 MW
 1500 MW

STLAWRNC-MOSES_230_L34P

Mon 10/03/2022 to Mon 11/06/2023
 1800 Continuous 0800
 Work scheduled by: IESO

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 725 MW
 1500 MW

SCH-IMO-NYISO_LIMIT_1750

Fri 01/20/2023 to Sun 04/30/2023
 1601 Continuous 2359
 Work scheduled by: IESO

UPDATED by IESO 01/18/2023 16:31

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2050 MW
 350 MW
 2400 MW

SCH-NYISO-IMO_LIMIT_1600

Sat 01/21/2023 to Sun 04/30/2023
 1800 Continuous 2359
 Work scheduled by: IESO

UPDATED by IESO 01/18/2023 16:31

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1900 MW
 100 MW
 2000 MW

PRINCTWN-N.SCTLND_345_361

Tue 02/14/2023 to Thu 04/27/2023
 1128 Continuous 1200
 Work scheduled by: LS

UPDATED by LS 02/21/2023 14:36

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 725 MW
 1500 MW

PRINCTWN-N.SCTLND_345_362

Tue 02/14/2023 to Thu 04/27/2023
 1129 Continuous 1600
 Work scheduled by: LS

UPDATED by LS 02/21/2023 14:36

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 725 MW
 1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Tue 02/21/2023 to Sat 07/15/2023
0630 Continuous 1730

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

FWD (Import) REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

N.SCTLND-ALPS__345_2

Mon 02/27/2023 to Mon 04/24/2023
0700 Continuous 1600

UPDATED by NYISO 03/22/2023 10:09

SCH - NE - NY

FWD (Import) REV (Export)

900 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: NGrid

N.SCTLND-ALPS__345_2

Mon 02/27/2023 to Mon 04/24/2023
0700 Continuous 1600

UPDATED by NYISO 03/22/2023 10:09

SCH - NPX_1385

FWD (Import) REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: NGrid

EDIC__-FRASER__345_EF24-40

Wed 03/01/2023 to Tue 04/11/2023
0600 Continuous 1800

CENTRAL EAST - VC

FWD (Import) REV (Export)

2275 MW

Impacts Total Transfer Capability

310 MW

TTC with All Lines In Service

2585 MW

Work scheduled by: NGrid

MOSES__-ADIRNDCK_230_MA1

Sun 03/05/2023 to Fri 05/26/2023
2000 Continuous 1930

MOSES SOUTH

FWD (Import) REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA - ROBNSNRD_230_64			FWD (Import)	REV (Export)
Mon 03/13/2023 to Fri 03/31/2023				
0500 Continuous 1900		SCH - OH - NY		1900 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability		100 MW
		TTC with All Lines In Service		2000 MW
SCH-HQ_CEDARS-NYISO_LIMIT_240			FWD (Import)	REV (Export)
Mon 03/13/2023 to Thu 04/06/2023				
0500 Continuous 2200	<u>UPDATED by HQ 03/22/2023 11:52</u>	SCH - HQ_CEDARS		240 MW
Work scheduled by: HQ		Impacts Total Transfer Capability		39 MW
		TTC with All Lines In Service		279 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0			FWD (Import)	REV (Export)
Mon 03/13/2023 to Thu 04/06/2023				
0500 Continuous 2200	<u>UPDATED by HQ 03/22/2023 11:52</u>	SCH - HQ_CEDARS		0 MW
Work scheduled by: HQ		Impacts Total Transfer Capability		100 MW
		TTC with All Lines In Service		100 MW
GORDONRD-PRINCTWN_345_371			FWD (Import)	REV (Export)
Mon 03/20/2023 to Wed 04/19/2023				
0700 Continuous 1000	<u>UPDATED by NYISO 02/21/2023 14:40</u>	CENTRAL EAST - VC		2045 MW
Work scheduled by: LS		Impacts Total Transfer Capability		540 MW
		TTC with All Lines In Service		2585 MW
PRINCTWN-N.SCTLND_345_55			FWD (Import)	REV (Export)
Mon 03/20/2023 to Wed 04/19/2023				
0700 Continuous 1000	<u>UPDATED by NYISO 02/21/2023 14:40</u>	CENTRAL EAST - VC		2045 MW
Work scheduled by: LS		Impacts Total Transfer Capability		540 MW
		TTC with All Lines In Service		2585 MW
SCH-NE-NYISO_LIMIT_500			FWD (Import)	REV (Export)
Fri 03/24/2023 to Mon 04/24/2023				
0001 Continuous 1600	<u>UPDATED by NYISO 03/22/2023 10:09</u>	SCH - NE - NY		700 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability		900 MW
		TTC with All Lines In Service		1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

Mon 03/27/2023 to Wed 03/29/2023
0001 Continuous 2300

UPDATED by ConEd 03/27/2023 15:57

UPNY CONED

FWD (Import) REV (Export)

7560 MW

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ORU

EASTVIEW-SPRNBK_345_W65

Mon 03/27/2023 to Wed 03/29/2023
0201 Continuous 1800

UPNY CONED

FWD (Import) REV (Export)

4350 MW

Impacts Total Transfer Capability

3465 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW_345_W82

Mon 03/27/2023 to Wed 03/29/2023
0201 Continuous 1800

UPNY CONED

FWD (Import) REV (Export)

7550 MW

Impacts Total Transfer Capability

265 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

SPRNBK_345KV_RNS4

Mon 03/27/2023 to Wed 03/29/2023
0201 Continuous 0200

SPR/DUN-SOUTH

FWD (Import) REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

NINEMILE-CLAY_345_8

Mon 03/27/2023 to Tue 04/04/2023
0800 Continuous 1900

UPDATED by NGrid 03/25/2023 14:10

OSWEGO EXPORT

FWD (Import) REV (Export)

5150 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

EASTVIEW-SPRNBK_345_W65

Wed 03/29/2023 to Fri 04/07/2023
1801 Continuous 0200

UPNY CONED

FWD (Import) REV (Export)

4350 MW

Impacts Total Transfer Capability

3465 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work ID	Start Date	End Date	Status	Update Info	Zone	FWD (Import)	REV (Export)
MILLWOOD-EASTVIEW_345_W82	Wed 03/29/2023	Fri 04/07/2023	Continuous		UPNY CONED	7550 MW	
1801		0200			Impacts Total Transfer Capability	265 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	7815 MW	
ATHENS_-PLSNTVLY_345_91	Fri 03/31/2023	Sat 04/15/2023	Continuous	<u>UPDATED by NGrid 03/14/2023 10:15</u>	UPNY CONED	3800 MW	
0001		1800			Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	7815 MW	
PLSNTVLY_345KV_RNS4	Fri 03/31/2023	Sat 04/15/2023	Continuous	<u>UPDATED by NGrid 03/14/2023 10:15</u>	UPNY CONED	3800 MW	
0001		1800			Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	7815 MW	
ELBRIDGE-LAFAYTTE_345_17-LE	Fri 03/31/2023	Fri 03/31/2023	Continuous	ARR: 75	OSWEGO EXPORT	5250 MW	
1230		1500			Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	5250 MW	
OSWEGO_-ELBRIDGE_345_17	Fri 03/31/2023	Fri 03/31/2023	Continuous	ARR: 75	OSWEGO EXPORT	5250 MW	
1230		1500			Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	5250 MW	
ADIRNDCK-PORTER__230_12	Fri 03/31/2023	Mon 04/03/2023	Continuous		MOSES SOUTH	2300 MW	
1700		0600			Impacts Total Transfer Capability	850 MW	
Work scheduled by: LS					TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11				FWD (Import)	REV (Export)
Fri 03/31/2023	to	Mon 04/03/2023			
1700		0600	SCH - HQ_CEDARS	140 MW	
Work scheduled by:			Impacts Total Transfer Capability	139 MW	
			TTC with All Lines In Service	279 MW	
ADIRNDCK-PORTER__230_12 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11				FWD (Import)	REV (Export)
Fri 03/31/2023	to	Mon 04/03/2023			
1700		0600	SCH - HQ_CEDARS	140 MW	
Work scheduled by:			Impacts Total Transfer Capability	139 MW	
			TTC with All Lines In Service	279 MW	
E13THSTA-FARRAGUT_345_45				FWD (Import)	REV (Export)
Sat 04/01/2023	to	Sat 04/01/2023			
0001	Continuous	2200	<u>UPDATED by ConEd 03/28/2023 13:51</u>	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
VOLNEY_-MARCY__345_19				FWD (Import)	REV (Export)
Sat 04/01/2023	to	Sun 04/02/2023	<u>UPDATED by NYPA 03/10/2023 13:25</u>		
0500	Continuous	1900	ARR: 19	OSWEGO EXPORT	4900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	5250 MW	
VOLNEY_-MARCY__345_19				FWD (Import)	REV (Export)
Sat 04/01/2023	to	Sun 04/02/2023	<u>UPDATED by NYPA 03/10/2023 13:25</u>		
0500	Continuous	1900	ARR: 19	CENTRAL EAST - VC	2475 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	110 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Location	FWD (Import)	REV (Export)
CHAT_DC_GC1					
Sun 04/02/2023	to	Sun 04/02/2023	MOSES SOUTH	2850 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW	
<hr/>					
CHAT_DC_GC1					
Sun 04/02/2023	to	Sun 04/02/2023	SCH - HQ - NY	500 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	500 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1000 MW	
<hr/>					
CHAT_DC_GC1 , CHAT_DC_GC2					
Sun 04/02/2023	to	Sun 04/02/2023	MOSES SOUTH	2550 MW	
0001		0200	Impacts Total Transfer Capability	600 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
<hr/>					
CHAT_DC_GC1 , CHAT_DC_GC2					
Sun 04/02/2023	to	Sun 04/02/2023	SCH - HQ - NY	1370 MW	0 MW
0001		0200	Impacts Total Transfer Capability	130 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
<hr/>					
CHAT_DC_GC2					
Sun 04/02/2023	to	Sun 04/02/2023	MOSES SOUTH	2850 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW	
<hr/>					
CHAT_DC_GC2					
Sun 04/02/2023	to	Sun 04/02/2023	SCH - HQ - NY	500 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	500 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1000 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1050

Sun 04/02/2023 to Sun 04/02/2023
 0001 Continuous 0200
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
	1050 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	1500 MW	

DOLSONAV-ROCKTVRN_345_DART44

Mon 04/03/2023 to Fri 04/14/2023
 0730 Continuous 1600
 Work scheduled by: CHGE

UPDATED by CHGE 03/15/2023 09:53

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	2485 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	2585 MW	

WATRCURE-OAKDALE_345_31

Tue 04/04/2023 to Tue 04/04/2023
 0700 Daily 1800
 Work scheduled by: NYSEG

SCH - PJ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

EASTVIEW-SPRNBRK_345_W64

Fri 04/07/2023 to Sun 04/16/2023
 0201 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	4350 MW	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

MILLWOOD-EASTVIEW_345_W99

Fri 04/07/2023 to Fri 04/07/2023
 0201 Continuous 0230
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7550 MW	
Impacts Total Transfer Capability	265 MW	
TTC with All Lines In Service	7815 MW	

SPRNBRK_345KV_RNS5

Fri 04/07/2023 to Fri 04/07/2023
 0201 Continuous 0230
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1	FWD (Import)	REV (Export)																								
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 40%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0001</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td>MOSES SOUTH</td> <td style="text-align: right;">2850 MW</td> <td></td> </tr> <tr> <td colspan="3">Work scheduled by: HQ</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">300 MW</td> <td></td> </tr> <tr> <td colspan="3"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">3150 MW</td> <td></td> </tr> </table>	Sun 04/09/2023	to	Sun 04/09/2023				0001	Continuous	0200	MOSES SOUTH	2850 MW		Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW					TTC with All Lines In Service	3150 MW			
Sun 04/09/2023	to	Sun 04/09/2023																								
0001	Continuous	0200	MOSES SOUTH	2850 MW																						
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW																						
			TTC with All Lines In Service	3150 MW																						
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 40%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0001</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td>SCH - HQ - NY</td> <td style="text-align: right;">500 MW</td> <td></td> </tr> <tr> <td colspan="3">Work scheduled by: HQ</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">500 MW</td> <td></td> </tr> <tr> <td colspan="3"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1000 MW</td> <td></td> </tr> </table>	Sun 04/09/2023	to	Sun 04/09/2023				0001	Continuous	0200	SCH - HQ - NY	500 MW		Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW					TTC with All Lines In Service	1000 MW			
Sun 04/09/2023	to	Sun 04/09/2023																								
0001	Continuous	0200	SCH - HQ - NY	500 MW																						
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW																						
			TTC with All Lines In Service	1000 MW																						
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 40%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0001</td> <td></td> <td>0200</td> <td>MOSES SOUTH</td> <td style="text-align: right;">2550 MW</td> <td></td> </tr> <tr> <td colspan="3">Work scheduled by:</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">600 MW</td> <td></td> </tr> <tr> <td colspan="3"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">3150 MW</td> <td></td> </tr> </table>	Sun 04/09/2023	to	Sun 04/09/2023				0001		0200	MOSES SOUTH	2550 MW		Work scheduled by:			Impacts Total Transfer Capability	600 MW					TTC with All Lines In Service	3150 MW			
Sun 04/09/2023	to	Sun 04/09/2023																								
0001		0200	MOSES SOUTH	2550 MW																						
Work scheduled by:			Impacts Total Transfer Capability	600 MW																						
			TTC with All Lines In Service	3150 MW																						
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 40%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0001</td> <td></td> <td>0200</td> <td>SCH - HQ - NY</td> <td style="text-align: right;">1370 MW</td> <td style="text-align: right;">0 MW</td> </tr> <tr> <td colspan="3">Work scheduled by:</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">130 MW</td> <td style="text-align: right;">1000 MW</td> </tr> <tr> <td colspan="3"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td style="text-align: right;">1000 MW</td> </tr> </table>	Sun 04/09/2023	to	Sun 04/09/2023				0001		0200	SCH - HQ - NY	1370 MW	0 MW	Work scheduled by:			Impacts Total Transfer Capability	130 MW	1000 MW				TTC with All Lines In Service	1500 MW	1000 MW		
Sun 04/09/2023	to	Sun 04/09/2023																								
0001		0200	SCH - HQ - NY	1370 MW	0 MW																					
Work scheduled by:			Impacts Total Transfer Capability	130 MW	1000 MW																					
			TTC with All Lines In Service	1500 MW	1000 MW																					
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 40%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0001</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td>MOSES SOUTH</td> <td style="text-align: right;">2850 MW</td> <td></td> </tr> <tr> <td colspan="3">Work scheduled by: HQ</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">300 MW</td> <td></td> </tr> <tr> <td colspan="3"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">3150 MW</td> <td></td> </tr> </table>	Sun 04/09/2023	to	Sun 04/09/2023				0001	Continuous	0200	MOSES SOUTH	2850 MW		Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW					TTC with All Lines In Service	3150 MW			
Sun 04/09/2023	to	Sun 04/09/2023																								
0001	Continuous	0200	MOSES SOUTH	2850 MW																						
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW																						
			TTC with All Lines In Service	3150 MW																						
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Sun 04/09/2023</td> <td style="width: 40%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0001</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td>SCH - HQ - NY</td> <td style="text-align: right;">500 MW</td> <td></td> </tr> <tr> <td colspan="3">Work scheduled by: HQ</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">500 MW</td> <td></td> </tr> <tr> <td colspan="3"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1000 MW</td> <td></td> </tr> </table>	Sun 04/09/2023	to	Sun 04/09/2023				0001	Continuous	0200	SCH - HQ - NY	500 MW		Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW					TTC with All Lines In Service	1000 MW			
Sun 04/09/2023	to	Sun 04/09/2023																								
0001	Continuous	0200	SCH - HQ - NY	500 MW																						
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW																						
			TTC with All Lines In Service	1000 MW																						

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1050

Sun 04/09/2023 to Sun 04/09/2023
 0001 Continuous 0200
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY	1050 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	1500 MW	

LINDN_CG-LNDVFT_345_V-3022

Sun 04/09/2023 to Sat 04/15/2023
 1400 Continuous 2300
 Work scheduled by: PJM
UPDATED by PJM 02/06/2023 07:36

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

FROST_BR-LONG_MTN_345_352

Sun 04/09/2023 to Tue 04/18/2023
 2030 Continuous 1300
 Work scheduled by: ISONE
UPDATED by ISONE 03/07/2023 11:22

	FWD (Import)	REV (Export)
SCH - NE - NY	1300 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

Sun 04/09/2023 to Tue 04/18/2023
 2030 Continuous 1300
 Work scheduled by: ISONE
UPDATED by ISONE 03/07/2023 11:22

	FWD (Import)	REV (Export)
SCH - NE - NY	800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	1600 MW	

DYSINGER-STA_255_345_DH1

Mon 04/10/2023 to Fri 04/14/2023
 0500 Continuous 2000
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

OSWEGO_-VOLNEY_345_12

Tue 04/11/2023 to Tue 04/11/2023
 0630 Continuous 1800
 Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS__-ATHENS__345_95

Tue 04/11/2023 to Tue 04/11/2023
0830 Daily 1100

UPDATED by NGrid 03/24/2023 11:12

UPNY CONED

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: NGrid

DUNWODIE_345KV_3

Wed 04/12/2023 to Wed 04/12/2023
0201 Continuous 0230

SPR/DUN-SOUTH

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

DUNWODIE_345KV_4

Wed 04/12/2023 to Wed 04/12/2023
0201 Continuous 0230

SPR/DUN-SOUTH

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

PLSNTVLE-DUNWODIE_345_W89

Wed 04/12/2023 to Wed 04/12/2023
0201 Continuous 0230

UPNY CONED

FWD (Import) REV (Export)

4000 MW

Impacts Total Transfer Capability

3815 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

FRASANNX-COOPERS__345_UCC2-41

Wed 04/12/2023 to Fri 05/05/2023
0600 Continuous 1730

ARR: 19

CENTRAL EAST - VC

FWD (Import) REV (Export)

2275 MW

Impacts Total Transfer Capability

310 MW

TTC with All Lines In Service

2585 MW

Work scheduled by: NYPA

MARCY__-FRASANNX_345_UCC2-41

Wed 04/12/2023 to Fri 05/05/2023
0600 Continuous 1730

ARR: 19

CENTRAL EAST - VC

FWD (Import) REV (Export)

2275 MW

Impacts Total Transfer Capability

310 MW

TTC with All Lines In Service

2585 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_VOLNEY__345_11

Wed 04/12/2023 to Wed 04/12/2023
 0630 Continuous 1800
 Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

SCH-NPX_1385-NYISO_LIMIT_100

Thu 04/13/2023 to Fri 04/28/2023
 2030 Continuous 2000
 Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	200 MW	

ADIRNDCK-PORTER__230_12

Fri 04/14/2023 to Tue 04/18/2023
 1700 Continuous 0700
 Work scheduled by: NGrid

UPDATED by NGrid 03/16/2023 11:27

	FWD (Import)	REV (Export)
MOSES SOUTH	2300 MW	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11

Fri 04/14/2023 to Tue 04/18/2023
 1700 Continuous 0700
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	140 MW	
Impacts Total Transfer Capability	139 MW	
TTC with All Lines In Service	279 MW	

**ADIRNDCK-PORTER__230_12 , STLAWRNC-MOSES__230_L34P ,
 CHASLAKE-PORTER__230_11**

Fri 04/14/2023 to Tue 04/18/2023
 1700 Continuous 0700
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	140 MW	
Impacts Total Transfer Capability	139 MW	
TTC with All Lines In Service	279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work ID	Start Date	End Date	Time	Type	Work Scheduled by	Zone	Impacts	TTC	FWD (Import)	REV (Export)
<hr/>										
PLSNTVLY_345KV_RNS5	Sun 04/16/2023	to	Sun 04/16/2023	0100	Continuous	0200	UPNY CONED		3800 MW	
							Impacts Total Transfer Capability		4015 MW	
							TTC with All Lines In Service		7815 MW	
	Work scheduled by: ConEd									
<hr/>										
MILLWOOD-EASTVIEW_345_W99	Sun 04/16/2023	to	Sun 04/16/2023	0130	Continuous	0200	UPNY CONED		7550 MW	
							Impacts Total Transfer Capability		265 MW	
							TTC with All Lines In Service		7815 MW	
	Work scheduled by: ConEd									
<hr/>										
SPRNBK_345KV_RNS5	Sun 04/16/2023	to	Sun 04/16/2023	0130	Continuous	0200	SPR/DUN-SOUTH		3200 MW	
							Impacts Total Transfer Capability		1400 MW	
							TTC with All Lines In Service		4600 MW	
	Work scheduled by: ConEd									
<hr/>										
LEEDS__PLSNTVLY_345_92	Sun 04/16/2023	to	Sun 04/30/2023	0700	Continuous	2200	UPNY CONED	<u>UPDATED by ConEd 03/10/2023 10:36</u>	3800 MW	
							Impacts Total Transfer Capability		4015 MW	
							TTC with All Lines In Service		7815 MW	
	Work scheduled by: NGrid									
<hr/>										
PLSNTVLY_345KV_RNS5	Sun 04/16/2023	to	Sun 04/30/2023	0700	Continuous	2200	UPNY CONED	<u>UPDATED by ConEd 03/10/2023 10:36</u>	3800 MW	
							Impacts Total Transfer Capability		4015 MW	
							TTC with All Lines In Service		7815 MW	
	Work scheduled by: NGrid									
<hr/>										
MOTTHAVN-RAINEY__345_Q12	Mon 04/17/2023	to	Tue 04/25/2023	0001	Continuous	0200	SPR/DUN-SOUTH		3800 MW	
							Impacts Total Transfer Capability		800 MW	
							TTC with All Lines In Service		4600 MW	
	Work scheduled by: ConEd									

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST 2650 MW
 CENTRAL EAST - VC 2585 MW
 TOTAL EAST 6000 MW
 UPNY CONED 7815 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-NIAGARA_230_PA27

Mon 04/17/2023 to Fri 05/05/2023
 0400 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2100 MW

300 MW

2400 MW

DYSINGER-STA_255_345_DH2

Mon 04/17/2023 to Fri 04/21/2023
 0500 Continuous 2000

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2850 MW

350 MW

3200 MW

CLAY__-EDIC__345_2-15

Mon 04/17/2023 to Fri 04/28/2023
 0600 Continuous 1800

Work scheduled by: NGrid

UPDATED by NGrid 03/20/2023 14:42

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

4850 MW

400 MW

5250 MW

MARCY_SO_SERIES_COMP_I/S

Wed 04/19/2023 to Mon 05/01/2023
 1000 Continuous 0559

Work scheduled by: NYISO

UPDATED by NYISO 02/27/2023 17:19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2360 MW

225 MW

2585 MW

ADIRNDCK-PORTER__230_12

Thu 04/20/2023 to Tue 04/25/2023
 1700 Continuous 0700

Work scheduled by: LS

UPDATED by NGrid 03/16/2023 11:38

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2300 MW

850 MW

3150 MW

ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11

Thu 04/20/2023 to Tue 04/25/2023
 1700 Continuous 0700

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

140 MW

139 MW

279 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ADIRNDCK-PORTER__230_12 , STLAWRNC-MOSES__230_L34P ,
 CHASLAKE-PORTER__230_11**

Thu 04/20/2023 to Tue 04/25/2023
 1700 0700

Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
140 MW	
139 MW	
279 MW	

CHAT_DC_GC1

Sun 04/23/2023 to Sun 04/23/2023
 0001 Continuous 0200

Work scheduled by: HQ

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
2850 MW	
300 MW	
3150 MW	

CHAT_DC_GC1

Sun 04/23/2023 to Sun 04/23/2023
 0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
500 MW	
500 MW	
1000 MW	

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
 0001 0200

Work scheduled by:

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
2550 MW	
600 MW	
3150 MW	

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
 0001 0200

Work scheduled by:

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
1370 MW	0 MW
130 MW	1000 MW
1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
 0001 Continuous 0200
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
 0001 Continuous 0200
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

SCH-HQ-NYISO_LIMIT_1150

Sun 04/23/2023 to Sun 04/23/2023
 0001 Continuous 0200
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		1150 MW
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	1500 MW	

BUCHAN_S-MILLWOOD_345_W98

Mon 04/24/2023 to Wed 04/26/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED		7680 MW
Impacts Total Transfer Capability	135 MW	
TTC with All Lines In Service	7815 MW	

MILLWOOD_345KV_18

Mon 04/24/2023 to Wed 04/26/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED		4350 MW
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work ID	Start Date	End Date	Time	Duration	Work Scheduled by	Zone	Impacts	TTC	FWD (Import)	REV (Export)
DUNWODIE_345KV_3	Mon 04/24/2023	Mon 04/24/2023	0130	Continuous	ConEd	SPR/DUN-SOUTH	Impacts Total Transfer Capability	4600 MW	3800 MW	800 MW
Work scheduled by: ConEd										
DUNWODIE_345KV_4	Mon 04/24/2023	Mon 04/24/2023	0130	Continuous	ConEd	SPR/DUN-SOUTH	Impacts Total Transfer Capability	4600 MW	3800 MW	800 MW
Work scheduled by: ConEd										
PANNELL_-CLAY___345_1	Mon 04/24/2023	Fri 04/28/2023	0700	Continuous	NYPA	WEST CENTRAL	Impacts Total Transfer Capability	2250 MW	1300 MW	950 MW
Work scheduled by: NYPA										
NRTH1385-NOR HBR_138_601	Tue 04/25/2023	Sat 04/29/2023	0500	Continuous	LI	SCH - NPX_1385	Impacts Total Transfer Capability	200 MW	100 MW	100 MW
Work scheduled by: LI						<u>UPDATED by LI 02/02/2023 09:40</u>				
TTC with All Lines In Service										
NRTH1385-NOR HBR_138_602	Tue 04/25/2023	Sat 04/29/2023	0500	Continuous	LI	SCH - NPX_1385	Impacts Total Transfer Capability	200 MW	100 MW	100 MW
Work scheduled by: LI						<u>UPDATED by LI 02/02/2023 09:40</u>				
TTC with All Lines In Service										
NRTH1385-NOR HBR_138_603	Tue 04/25/2023	Sat 04/29/2023	0500	Continuous	LI	SCH - NPX_1385	Impacts Total Transfer Capability	200 MW	100 MW	100 MW
Work scheduled by: LI						<u>UPDATED by LI 02/02/2023 09:40</u>				
TTC with All Lines In Service										

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_601				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_601				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500		2359	SCH - NPX_1385	0 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NRTHPORT_138_NNC				FWD (Import)	REV (Export)
Tue 04/25/2023	to	Sat 04/29/2023			
0500	Continuous	2359	<u>UPDATED by LI 02/02/2023 09:40</u>	SCH - NPX_1385	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	200 MW	200 MW
			TTC with All Lines In Service	200 MW	200 MW
S.RIPLEY-DUNKIRK_230_68				FWD (Import)	REV (Export)
Wed 04/26/2023	to	Wed 05/10/2023			
0700	Continuous	1630	<u>UPDATED by NGrid 03/21/2023 12:58</u>	SCH - PJ - NY	
Work scheduled by: NGrid			Impacts Total Transfer Capability		
			TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Sun 04/30/2023 to Sun 05/21/2023
 0500 Continuous 2000
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC2

Sun 04/30/2023 to Sun 05/21/2023
 0500 Continuous 2000
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

SCH-HQ-NYISO_LIMIT_1150

Sun 04/30/2023 to Fri 05/05/2023
 0500 Continuous 1659
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		1150 MW
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	1500 MW	

NRTH1385-NOR HBR_138_601

Mon 05/01/2023 to Fri 06/09/2023
 0500 Continuous 2359
 Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR_138_602

Mon 05/01/2023 to Fri 06/09/2023
 0500 Continuous 2359
 Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr style="border-top: 1px dashed black;"/>				
NRTH1385-NOR HBR_138_603			FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 06/09/2023		
0500	Continuous	2359	SCH - NPX_1385	100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
<hr style="border-top: 1px dashed black;"/>				
NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_601			FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 06/09/2023		
0500		2359	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
<hr style="border-top: 1px dashed black;"/>				
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_601			FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 06/09/2023		
0500		2359	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
<hr style="border-top: 1px dashed black;"/>				
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602			FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 06/09/2023		
0500		2359	SCH - NPX_1385	0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
<hr style="border-top: 1px dashed black;"/>				
NRTH1385-NRTHPORT_138_NNC			FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 06/09/2023		
0500	Continuous	2359	SCH - NPX_1385	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
<hr style="border-top: 1px dashed black;"/>				
HUDSONTP-W49TH_ST_345_Y56			FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 05/05/2023		
0600	Continuous	1800	SCH - PJM_HTP	0 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Mon 05/01/2023 to Mon 05/01/2023
 0600 Continuous 0630
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 05/01/2023 to Mon 05/01/2023
 0600 Continuous 0630
 Work scheduled by: ConEd

SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

PANNELL_-CLAY___345_2

Mon 05/01/2023 to Fri 05/05/2023
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

LEEDS_-HURLYAVE_345_301

Mon 05/01/2023 to Fri 06/02/2023
 0800 Continuous 1700
 Work scheduled by: CHGE

UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 3715 MW
 TTC with All Lines In Service 7815 MW

PIERCBRK-FIVEMILE_345_37

Tue 05/02/2023 to Tue 05/02/2023
 0830 Continuous 1230
 Work scheduled by: NGrid

SCH - PJ - NY **300 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 300 MW

E13THSTA-FARRAGUT_345_46

Wed 05/03/2023 to Fri 05/05/2023
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-CRICKVLY_345_398				
Wed 05/03/2023	to	Wed 05/03/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0830	Continuous	1600	Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: ISONE			TTC with All Lines In Service	100 MW 100 MW
				200 MW 200 MW
LONG_MTN-CRICKVLY_345_398				
Wed 05/03/2023	to	Wed 05/03/2023	SCH - NE - NY	FWD (Import) REV (Export)
0830	Continuous	1600	Impacts Total Transfer Capability	500 MW 1150 MW
Work scheduled by: ISONE			TTC with All Lines In Service	900 MW 450 MW
				1400 MW 1600 MW
LONG_MTN-CRICKVLY_345_398 , NRTH1385-NORHBR_138_601				
Wed 05/03/2023	to	Wed 05/03/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0830		1600	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	200 MW 200 MW
				200 MW 200 MW
LONG_MTN-CRICKVLY_345_398 , NRTH1385-NORHBR_138_602				
Wed 05/03/2023	to	Wed 05/03/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0830		1600	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	200 MW 200 MW
				200 MW 200 MW
LONG_MTN-CRICKVLY_345_398 , NRTH1385-NORHBR_138_603				
Wed 05/03/2023	to	Wed 05/03/2023	SCH - NPX_1385	FWD (Import) REV (Export)
0830		1600	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	200 MW 200 MW
				200 MW 200 MW
SCH-HQ-NYISO_LIMIT_1050				
Fri 05/05/2023	to	Sun 05/21/2023	SCH - HQ - NY	FWD (Import) REV (Export)
1700	Continuous	2000	Impacts Total Transfer Capability	1050 MW
Work scheduled by: HQ			TTC with All Lines In Service	450 MW
				1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
W49TH_ST_345KV_7					
Fri 05/05/2023	to	Fri 05/05/2023	SCH - PJM_HTP	300 MW	
1730	Continuous	1800	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
<hr/>					
W49TH_ST_345KV_8					
Fri 05/05/2023	to	Fri 05/05/2023	SCH - PJM_HTP	450 MW	
1730	Continuous	1800	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
<hr/>					
W49TH_ST_345KV_6					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
<hr/>					
W49TH_ST_345KV_8					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	450 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
<hr/>					
VOLNEY_-MARCY__345_19					
Sat 05/06/2023	to	Sun 05/28/2023	OSWEGO EXPORT	4900 MW	
0500	Continuous	1900	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			ARR: 19	TTC with All Lines In Service	5250 MW
<hr/>					
VOLNEY_-MARCY__345_19					
Sat 05/06/2023	to	Sun 05/28/2023	CENTRAL EAST - VC	2475 MW	
0500	Continuous	1900	Impacts Total Transfer Capability	110 MW	
Work scheduled by: NYPA			ARR: 19	TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST 2650 MW
 CENTRAL EAST - VC 2585 MW
 TOTAL EAST 6000 MW
 UPNY CONED 7815 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ATHENS_-PLSNTVLY_345_91

Mon 05/08/2023 to Thu 05/18/2023
 0001 Continuous 2200

UPDATED by ConEd 02/21/2023 15:27

UPNY CONED

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: NGrid

PLSNTVLY_345KV_RNS4

Mon 05/08/2023 to Thu 05/18/2023
 0001 Continuous 2200

UPDATED by ConEd 02/21/2023 15:27

UPNY CONED

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: NGrid

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/08/2023 to Sun 05/21/2023
 0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import) REV (Export)

2485 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

2585 MW

Work scheduled by: NYPA

DOLSONAV-ROCKTVRN_345_DART44

Mon 05/08/2023 to Sat 05/13/2023
 0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import) REV (Export)

2485 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

2585 MW

Work scheduled by: NYPA

OAKDALE_-FRASER_345_32

Tue 05/09/2023 to Tue 05/09/2023
 0700 Daily 1800

UPDATED by NYSEG 03/07/2023 14:15

CENTRAL EAST - VC

FWD (Import) REV (Export)

2450 MW

Impacts Total Transfer Capability

135 MW

TTC with All Lines In Service

2585 MW

Work scheduled by: NYSEG

LADENTWN-BUCHAN_S_345_Y88

Wed 05/10/2023 to Sat 05/13/2023
 0101 Continuous 0100

UPDATED by ConEd 03/27/2023 15:57

UPNY CONED

FWD (Import) REV (Export)

7560 MW

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ORU

NYISO TRANSFER LIMITATIONS**Seasonal Limits**

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS4

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

SPRNBK_W49TH_ST_345_M52

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_5

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200

SCH - PJM_HTP

FWD (Import)

REV (Export)

450 MW

Impacts Total Transfer Capability

210 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

Mon 05/15/2023 to Mon 05/15/2023
0301 Continuous 0330

UPDATED by ConEd 03/20/2023 09:13

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Mon 05/15/2023 to Wed 05/17/2023
 0301 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

W49TH_ST_345KV_6

Tue 05/16/2023 to Wed 05/17/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

SHOR_NPX-SHOREHAM_138_CSC

Tue 05/16/2023 to Sun 05/21/2023
 0500 Continuous 1500
 Work scheduled by: LI

SCH - NPX_CSC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW **0 MW**
 330 MW 330 MW
 330 MW 330 MW

MOTTHAVN-RAINEY_345_Q11

Fri 05/19/2023 to Sat 05/20/2023
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 02/18/2023 08:38

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

MARCY_345KV_CSC

Fri 05/19/2023 to Tue 05/23/2023
 0500 Continuous 1900
 Work scheduled by: NYPA

UPDATED by NYPA 10/05/2022 11:11

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2535 MW
 50 MW
 2585 MW

LEEDS_-PLSNTVLY_345_92

Sat 05/20/2023 to Sat 05/27/2023
 0001 Continuous 2200
 Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:21

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 4015 MW
 7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Sat 05/20/2023 to Sat 05/27/2023
0001 Continuous 2200

UPDATED by ConEd 02/21/2023 15:21

UPNY CONED

FWD (Import) REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: NGrid

CHATGUAY-MASSENA_765_7040

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ - NY

FWD (Import) REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

1500 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA_765_7040

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

MOSES SOUTH

FWD (Import) REV (Export)

1550 MW

Impacts Total Transfer Capability

1600 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA_765_7040 , MASSENA-MARCY_765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

MOSES SOUTH

FWD (Import) REV (Export)

500 MW

Impacts Total Transfer Capability

2650 MW

TTC with All Lines In Service

3150 MW

Work scheduled by:

MARCY_765_345_AT1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930

UPDATED by NYPA 12/13/2022 09:46

MOSES SOUTH

FWD (Import) REV (Export)

1750 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

ARR: 19

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST 2650 MW
 CENTRAL EAST - VC 2585 MW
 TOTAL EAST 6000 MW
 UPNY CONED 7815 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 16:34

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1700 MW

1450 MW

3150 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1720 MW

865 MW

2585 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

475 MW
1000 MW

1025 MW

0 MW

1500 MW

1000 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

500 MW

2650 MW

3150 MW

MASSENA_-MARCY___765_MSU1 , CHASLAKE-PORTER___230_11

Tue 05/30/2023 to Tue 05/30/2023
 0600 Continuous 1930

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

MASSENA -MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

850 MW

0 MW

650 MW

1000 MW

1500 MW

1000 MW

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 , CHASLAKE-PORTER__230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
STLAWRNC-MOSES__230_L34P**

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

**MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11**

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

90 MW

180 MW

270 MW

LEEDS__345KV_R94301

Mon 06/05/2023 to Tue 06/06/2023
0830 Continuous 1400

Work scheduled by: NGrid

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

4015 MW

7815 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Wed 06/07/2023 to Wed 06/07/2023
0630 Daily 1800

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

5250 MW

0 MW

5250 MW

OSWEGO_-ELBRIDGE_345_17

Wed 06/07/2023 to Wed 06/07/2023
0630 Daily 1800

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

5250 MW

0 MW

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_PACKARD_230_62				FWD (Import)	REV (Export)
Mon 06/26/2023	to	Fri 06/30/2023			
0500	Continuous	1900	SCH - OH - NY	1500 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	1900 MW	
NIAGARA_345_230_AT4				FWD (Import)	REV (Export)
Wed 06/28/2023	to	Thu 06/29/2023			
0500	Continuous	1900	SCH - OH - NY	1150 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	1550 MW	
MARCY_EDIC_345_UE1-7				FWD (Import)	REV (Export)
Sat 07/08/2023	to	Sun 07/09/2023	<u>UPDATED by NYPA 10/28/2022 10:56</u>		
0500	Continuous	1900	ARR: 19,16	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	5250 MW	
MARCY_EDIC_345_UE1-7				FWD (Import)	REV (Export)
Sat 07/15/2023	to	Sun 07/16/2023	<u>UPDATED by NYPA 10/28/2022 11:17</u>		
0500	Continuous	1930	ARR: 19,16	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	5250 MW	
ADIRNDCK-PORTER_230_12				FWD (Import)	REV (Export)
Sun 07/16/2023	to	Sun 07/16/2023	<u>UPDATED by NYPA 12/14/2022 14:55</u>		
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
MOSES_ADIRNDCK_230_MA2				FWD (Import)	REV (Export)
Sun 07/16/2023	to	Sun 07/16/2023			
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO_NY_NIAG_CB_3122_W/BB

Mon 07/17/2023 to Fri 07/28/2023
0500 Continuous 2100

SCH - OH - NY

FWD (Import) REV (Export)

1800 MW 1300 MW

Impacts Total Transfer Capability

100 MW 250 MW

TTC with All Lines In Service

1900 MW 1550 MW

Work scheduled by: NYPA

ADIRNDCK-CHASLAKE_230_13

Mon 07/17/2023 to Mon 07/17/2023
0700 Continuous 1730

UPDATED by NYPA 02/17/2023 15:10

MOSES SOUTH

FWD (Import) REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

MOSES__ADIRNDCK_230_MA1

Mon 07/17/2023 to Mon 07/17/2023
0700 Continuous 1730

UPDATED by NYPA 02/17/2023 15:10

MOSES SOUTH

FWD (Import) REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

ADIRNDCK-CHASLAKE_230_13

Tue 07/18/2023 to Fri 09/15/2023
0630 Continuous 1600

MOSES SOUTH

FWD (Import) REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

HURLYAVE-ROSETON_345_303

Mon 07/31/2023 to Fri 08/25/2023
0800 Continuous 1600

UPNY CONED

FWD (Import) REV (Export)

4100 MW

Impacts Total Transfer Capability

3715 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: CHGE

DYSINGER-ST_A_255_345_DH2

Fri 08/04/2023 to Mon 08/14/2023
0500 Continuous 2300

DYSINGER EAST

FWD (Import) REV (Export)

2850 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits
Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Mon 08/07/2023 to Fri 08/11/2023

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1300 MW
1100 MW

600 MW

450 MW

1900 MW

1550 MW

DYSINGER-STA_255_345_DH1

Tue 08/15/2023 to Fri 08/25/2023

0500 Continuous 2300

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2850 MW

350 MW

3200 MW

MARCY__345KV_CSC

Sat 08/19/2023 to Sun 08/20/2023

0500 Continuous 1930

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2535 MW

50 MW

2585 MW

MARCY_-EDIC__345_UE1-7

Sat 08/19/2023 to Sun 08/20/2023

0500 Continuous 1930

Work scheduled by: NYPA

ARR: 19,16

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

5250 MW

0 MW

5250 MW

NIAGARA_345_230_AT4

Mon 08/28/2023 to Fri 09/01/2023

0500 Continuous 2100

Work scheduled by: NYPA

UPDATED by NYPA 03/16/2023 08:43

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1150 MW

400 MW

1550 MW

CLAY_-EDIC__345_1-16

Mon 09/11/2023 to Fri 09/15/2023

0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYISO 02/22/2023 09:21

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

4850 MW

400 MW

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>CHASLAKE-PORTER__230_11</p> <p>Sat 09/16/2023 to Sun 10/15/2023</p> <p>0630 Continuous 1730</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: center;"><u>UPDATED by NGrid 02/01/2023 11:03</u></p> <p>MOSES SOUTH</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>2100 MW</p> <p>1050 MW</p> <p>3150 MW</p>	<p>REV (Export)</p>
<p>CLAY__-EDIC__345_2-15</p> <p>Mon 09/18/2023 to Fri 09/22/2023</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>OSWEGO EXPORT</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>4850 MW</p> <p>400 MW</p> <p>5250 MW</p>	<p>REV (Export)</p>
<p>MARCY__-EDIC__345_UE1-7</p> <p>Sat 09/23/2023 to Sun 09/24/2023</p> <p>0500 Continuous 1900</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: center;"><u>UPDATED by NYPA 10/28/2022 11:09</u></p> <p>OSWEGO EXPORT</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p> <p style="text-align: center;">ARR: 19,16</p>	<p>FWD (Import)</p> <p>5250 MW</p> <p>0 MW</p> <p>5250 MW</p>	<p>REV (Export)</p>
<p>NIAGARA_-DYSINGER_345_ND2</p> <p>Mon 09/25/2023 to Fri 09/29/2023</p> <p>0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p>DYSINGER EAST</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>2700 MW</p> <p>500 MW</p> <p>3200 MW</p>	<p>REV (Export)</p>
<p>MARCY__345KV_CSC</p> <p>Mon 09/25/2023 to Sat 10/07/2023</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>CENTRAL EAST - VC</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>2535 MW</p> <p>50 MW</p> <p>2585 MW</p>	<p>REV (Export)</p>
<p>ROSETON_-EFISHKIL_345_RFK305</p> <p>Mon 09/25/2023 to Fri 10/13/2023</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>UPNY CONED</p> <p>Impacts Total Transfer Capability</p> <p>TTC with All Lines In Service</p>	<p>FWD (Import)</p> <p>6680 MW</p> <p>1135 MW</p> <p>7815 MW</p>	<p>REV (Export)</p>

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/06/2023
0600 Continuous 1800

FWD (Import) REV (Export)

SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

Work scheduled by: LI

ROSETON_-ROCKTVRN_345_311

Mon 10/02/2023 to Fri 11/03/2023
0800 Continuous 1600

FWD (Import) REV (Export)

UPNY CONED	4400 MW	
Impacts Total Transfer Capability	3415 MW	
TTC with All Lines In Service	7815 MW	

Work scheduled by: CHGE

GILBOA_-N.SCTLND_345_GNS-1

Mon 10/09/2023 to Fri 10/13/2023
0700 Continuous 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC	2300 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	2585 MW	

Work scheduled by: NYPA

NIAGARA_-PACKARD_230_61

Fri 10/13/2023 to Fri 10/13/2023
0500 Continuous 1900

FWD (Import) REV (Export)

SCH - OH - NY		1350 MW
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1550 MW

Work scheduled by: NYPA

ADIRNDCK-CHASLAKE_230_13

Mon 10/16/2023 to Tue 11/14/2023
0630 Continuous 1730

FWD (Import) REV (Export)

UPDATED by NGrid 11/07/2022 15:17

MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

Work scheduled by: NGrid

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Sun 10/29/2023 to Fri 11/17/2023
0001 Continuous 2359

FWD (Import) REV (Export)

SCH - PJM_NEPTUNE	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

Work scheduled by: LI

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1

Sun 10/29/2023 to Fri 11/17/2023
 0001 Continuous 2359
 Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NEWBRDGE_345_138_BK_2

Sun 10/29/2023 to Fri 11/17/2023
 0001 Continuous 2359
 Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NEWBRDGE-DUFFYAVE_345_501

Sun 10/29/2023 to Fri 11/17/2023
 0001 Continuous 2359
 Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

LONG_MTN-CRICKVLY_345_398

Mon 11/06/2023 to Thu 11/30/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

SCH - NPX_1385 **100 MW** **100 MW**
 Impacts Total Transfer Capability 100 MW 100 MW
 TTC with All Lines In Service 200 MW 200 MW

FWD (Import) REV (Export)

LONG_MTN-CRICKVLY_345_398

Mon 11/06/2023 to Thu 11/30/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

SCH - NE - NY **700 MW** **1300 MW**
 Impacts Total Transfer Capability 900 MW 500 MW
 TTC with All Lines In Service 1600 MW 1800 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Description	Start Date	End Date	Time	Type	Impact	FWD (Import)	REV (Export)	
LINDN_CG-LNDVFT__345_V-3022								
Mon 11/06/2023	to	Thu 11/09/2023	0800	Continuous	1500			
Work scheduled by: PJM						SCH - PJM_VFT	0 MW	0 MW
						Impacts Total Transfer Capability	315 MW	315 MW
						TTC with All Lines In Service	315 MW	315 MW
HURLYAVE-ROSETON__345_303								
Mon 11/13/2023	to	Fri 12/22/2023	0800	Continuous	1600			
Work scheduled by: CHGE						UPNY CONED	4100 MW	
						Impacts Total Transfer Capability	3715 MW	
						TTC with All Lines In Service	7815 MW	
CHATGUAY-MASSENA__765_7040								
Wed 11/15/2023	to	Mon 11/27/2023	0700	Continuous	1730			
Work scheduled by: NYPA						SCH - HQ - NY	0 MW	0 MW
						Impacts Total Transfer Capability	1500 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
CHATGUAY-MASSENA__765_7040								
Wed 11/15/2023	to	Mon 11/27/2023	0700	Continuous	1730			
Work scheduled by: NYPA						MOSES SOUTH	1550 MW	
						Impacts Total Transfer Capability	1600 MW	
						TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA__765_7040 , MASSENA_-MARCY__765_MSU1								
Wed 11/15/2023	to	Mon 11/27/2023	0700		1730			
Work scheduled by:						MOSES SOUTH	500 MW	
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY__765_MSU1								
Wed 11/15/2023	to	Mon 11/27/2023	0700	Continuous	1730			
Work scheduled by: NYPA						CENTRAL EAST - VC	1720 MW	
						Impacts Total Transfer Capability	865 MW	
						TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ_CEDARS	90 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	189 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	279 MW	
<hr/>					
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ - NY	475 MW	1000 MW
0700	Continuous	1730	Impacts Total Transfer Capability	1025 MW	0 MW
Work scheduled by: NYPA			TTC with All Lines In Service	1500 MW	1000 MW
<hr/>					
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	MOSES SOUTH	500 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW	
<hr/>					
MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2					
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ_CEDARS	90 MW	
0700		1530	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<hr/>					
MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2					
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ - NY	850 MW	0 MW
0700		1530	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT__345_V-3022

Wed 11/15/2023 to Wed 11/15/2023
 1500 Continuous 1700
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

NIAGARA_345_230_AT4

Mon 12/04/2023 to Fri 12/08/2023
 0500 Continuous 1900
 Work scheduled by: NYPA

UPDATED by NYPA 03/21/2023 14:25

	FWD (Import)	REV (Export)
SCH - OH - NY		1650 MW
Impacts Total Transfer Capability		350 MW
TTC with All Lines In Service		2000 MW

S.RIPLEY-DUNKIRK_230_68

Mon 12/04/2023 to Fri 12/08/2023
 0800 Continuous 1600
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023
 0800 Continuous 1600
 Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

LONG_MTN-CRICKVLY_345_398

Tue 12/12/2023 to Thu 12/21/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/12/2023 to Thu 12/21/2023
 0001 Continuous 2200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	700 MW	1300 MW
Impacts Total Transfer Capability	900 MW	500 MW
TTC with All Lines In Service	1600 MW	1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, March 28, 2023 to Friday, September 27, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2585 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK_230_68

Wed 12/27/2023 to Fri 12/29/2023
0730 Continuous 1600

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

Work scheduled by: NGrid

W49TH_ST_345KV_6

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

Work scheduled by: ConEd

310 MW
350 MW
660 MW

W49TH_ST-E13THSTA_345_M55

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

Work scheduled by: ConEd

3800 MW
800 MW
4600 MW

W49TH_ST_345KV_8

Sat 02/03/2024 to Mon 02/19/2024
0001 Continuous 0201

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

Work scheduled by: ConEd

310 MW
350 MW
660 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2024 to Fri 05/10/2024
0600 Continuous 1800

SCH - NPX_CSC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

Work scheduled by: LI

0 MW **0 MW**
330 MW 330 MW
330 MW 330 MW