

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 2359
 Work scheduled by:

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|----------------|
| FWD (Import) | REV (Export) |
| 2400 MW | 2400 MW |
| 100 MW | 250 MW |
| 2500 MW | 2650 MW |

OSWEGO_COMPLEX_AVR_O/S

Wed 01/29/2025 to Sun 03/08/2026
 0001 Continuous 2359
 Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 3640 MW | |
| 85 MW | |
| 3725 MW | |

HAVERSTK-ADIRNDCK_345_HA1

Tue 08/19/2025 to Fri 03/27/2026
 1128 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 01/21/2026 16:09

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 2300 MW | |
| 1100 MW | |
| 3400 MW | |

MARCY_-ADIRNDCK_345_12

Tue 08/19/2025 to Sat 03/28/2026
 1129 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 11/04/2025 10:05

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 2300 MW | |
| 1100 MW | |
| 3400 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1900

Sat 11/01/2025 to Thu 04/30/2026
 0001 Continuous 2359
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|---------------------------|
| SCH - OH - NY | 2200 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 300 MW | |
| TTC with All Lines In Service | 2500 MW | |

MARCY__345KV_CSC

Fri 12/05/2025 to Sat 03/14/2026
 1541 Continuous 2359
 Work scheduled by: NYPA

EXT FORCED by NYPA 02/03/2026 13:26

| | | |
|-----------------------------------|----------------|---------------------------|
| CENTRAL EAST - VC | 3650 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 75 MW | |
| TTC with All Lines In Service | 3725 MW | |

HERTELHQ-ASTANNEX_345_G180

Tue 02/10/2026 to Sun 05/31/2026
 1121 Continuous 2359
 Work scheduled by: NYISO

| | | |
|-----------------------------------|-------------|---------------------------|
| SCH - HQ_CHPE | 0 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 1250 MW | |
| TTC with All Lines In Service | 1250 MW | |

W49TH_ST_345KV_5

Mon 02/23/2026 to Tue 03/17/2026
 0506 Continuous 2359
 Work scheduled by: ConEd

FORCED by ConEd 02/24/2026 13:24

| | | |
|-----------------------------------|---------------|---------------------------|
| SCH - PJM_HTP | 175 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 485 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_7

Mon 02/23/2026 to Tue 03/17/2026
 0506 Continuous 2359
 Work scheduled by: ConEd

FORCED by ConEd 02/24/2026 13:24

| | | |
|-----------------------------------|---------------|---------------------------|
| SCH - PJM_HTP | 175 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 485 MW | |
| TTC with All Lines In Service | 660 MW | |

NRTH1385-NOR_HBR_138_601

Thu 02/26/2026 to Fri 05/15/2026
 0600 Continuous 1500
 Work scheduled by: LI

| | | |
|-----------------------------------|--------------|---------------------------|
| SCH - NPX_1385 | 60 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 160 MW | 160 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| NRTH1385-NOR HBR_138_602 | | | | | | | | | |
|--|------------|----------------|--|-----------------------------------|--|--------------|--|--------------|--|
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | FWD (Import) | | REV (Export) | |
| 0600 | Continuous | 1500 | | Impacts Total Transfer Capability | | 60 MW | | 60 MW | |
| Work scheduled by: LI | | | | TTC with All Lines In Service | | 100 MW | | 100 MW | |
| | | | | | | 160 MW | | 160 MW | |
| NRTH1385-NOR HBR_138_603 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | FWD (Import) | | REV (Export) | |
| 0600 | Continuous | 1500 | | Impacts Total Transfer Capability | | 60 MW | | 60 MW | |
| Work scheduled by: LI | | | | TTC with All Lines In Service | | 100 MW | | 100 MW | |
| | | | | | | 160 MW | | 160 MW | |
| NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | FWD (Import) | | REV (Export) | |
| 0600 | | 1500 | | Impacts Total Transfer Capability | | 0 MW | | 0 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | | 160 MW | | 160 MW | |
| | | | | | | 160 MW | | 160 MW | |
| NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | FWD (Import) | | REV (Export) | |
| 0600 | | 1500 | | Impacts Total Transfer Capability | | 0 MW | | 0 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | | 160 MW | | 160 MW | |
| | | | | | | 160 MW | | 160 MW | |
| NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | FWD (Import) | | REV (Export) | |
| 0600 | | 1500 | | Impacts Total Transfer Capability | | 0 MW | | 0 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | | 160 MW | | 160 MW | |
| | | | | | | 160 MW | | 160 MW | |
| NRTH1385-NRTHPORT_138_NNC | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | FWD (Import) | | REV (Export) | |
| 0600 | Continuous | 1500 | | Impacts Total Transfer Capability | | 0 MW | | 0 MW | |
| Work scheduled by: LI | | | | TTC with All Lines In Service | | 160 MW | | 160 MW | |
| | | | | | | 160 MW | | 160 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Thu 02/26/2026 to Mon 03/09/2026
 0800 Continuous 0659
 Work scheduled by: HQ

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | | 0 MW |
| TTC with All Lines In Service | | 100 MW |

DYSINGER-STA_255_345_DH2

Mon 03/02/2026 to Sat 03/28/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

EXTENDED by NYPA 06/17/2025 15:09

| | | |
|-----------------------------------|--------------|----------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | | 2850 MW |
| TTC with All Lines In Service | | 350 MW |
| | | 3200 MW |

WOOD_ST_PLSNTVLE_345_Y86

Tue 03/03/2026 to Fri 03/13/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|--------------|----------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | | 7820 MW |
| TTC with All Lines In Service | | 390 MW |
| | | 8210 MW |

DENNISON-ROSEMNTA_115_1/11

Mon 03/09/2026 to Tue 03/10/2026
 0700 Continuous 0559
 Work scheduled by: HQ

| | | |
|-----------------------------------|--------------|----------------------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | | 95 MW 100 MW |
| TTC with All Lines In Service | | 184 MW 0 MW |
| | | 279 MW 100 MW |

SCH-HQ_CEDARS-NYISO_LIMIT_40

Mon 03/09/2026 to Thu 03/26/2026
 0700 Continuous 1900
 Work scheduled by: HQ

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | | 40 MW |
| TTC with All Lines In Service | | 239 MW |
| | | 279 MW |

SCH-HQ_CEDARS-NYISO_LIMIT_80

Mon 03/09/2026 to Tue 03/10/2026
 0700 Continuous 0559
 Work scheduled by: HQ

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | | 80 MW |
| TTC with All Lines In Service | | 199 MW |
| | | 279 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/09/2026 to Thu 03/26/2026
 0700 Continuous 1900
 Work scheduled by: HQ

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| | | 0 MW |
| Impacts Total Transfer Capability | | 100 MW |
| TTC with All Lines In Service | | 100 MW |

DENNISON-ROSEMNTA_115_1/11

Tue 03/10/2026 to Mon 03/30/2026
 0600 Continuous 1730
 Work scheduled by: NGrid

UPDATED by NYISO 03/05/2026 11:47

| | | |
|-----------------------------------|--------------|---------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| | 95 MW | 100 MW |
| Impacts Total Transfer Capability | 184 MW | 0 MW |
| TTC with All Lines In Service | 279 MW | 100 MW |

SCH-HQ_CEDARS-NYISO_LIMIT_80

Tue 03/10/2026 to Mon 03/30/2026
 0600 Continuous 1730
 Work scheduled by: NGrid

UPDATED by NYISO 03/05/2026 11:47

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| | 80 MW | |
| Impacts Total Transfer Capability | 199 MW | |
| TTC with All Lines In Service | 279 MW | |

GORDONRD-ROTTRDAM_230_30

Tue 03/10/2026 to Tue 03/10/2026
 0830 Daily(No Weekends) 1200
 Work scheduled by: NGrid

| | | |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | FWD (Import) | REV (Export) |
| | 3690 MW | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 3725 MW | |

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Fri 03/13/2026 to Fri 03/13/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

UPDATED by NYPA 01/15/2026 11:02

| | | |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1550 MW | 1450 MW |
| Impacts Total Transfer Capability | 950 MW | 400 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

BECK__-NIAGARA_345_PA302

Mon 03/16/2026 to Fri 03/20/2026
 0630 Continuous 1600
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1150 MW | 1000 MW |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| MARCY__FRASANNX_345_UCC2-41 | FWD (Import) | REV (Export) |
|--|---|--|
| Wed 03/18/2026 to Thu 03/26/2026 0600 Continuous 2100 Work scheduled by: NGrid | <u>UPDATED by NGrid 01/21/2026 15:38</u> CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service | 3225 MW 500 MW 3725 MW |
| WOOD_ST_PLSNTVLE_345_Y86 | | |
| Wed 03/25/2026 to Tue 04/28/2026 0001 Continuous 0200 Work scheduled by: ConEd | UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service | FWD (Import) REV (Export) 7820 MW 390 MW 8210 MW |
| DYSINGER_STA_255_345_DH1 | | |
| Sun 03/29/2026 to Mon 04/20/2026 0500 Continuous 2100 Work scheduled by: NYPA | <u>UPDATED by NYPA 02/23/2026 11:15</u> DYSINGER EAST Impacts Total Transfer Capability TTC with All Lines In Service | FWD (Import) REV (Export) 2850 MW 350 MW 3200 MW |
| DUNWODIE_345KV_3 | | |
| Mon 03/30/2026 to Mon 03/30/2026 0130 Continuous 2359 Work scheduled by: ConEd | SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service | FWD (Import) REV (Export) 3800 MW 800 MW 4600 MW |
| DUNWODIE_345KV_4 | | |
| Mon 03/30/2026 to Mon 03/30/2026 0130 Continuous 2359 Work scheduled by: ConEd | SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service | FWD (Import) REV (Export) 3800 MW 800 MW 4600 MW |
| OSWEGO_COMPLEX_AVR_O/S | | |
| Tue 03/31/2026 to Sun 09/13/2026 0001 Continuous 2359 Work scheduled by: NGrid | <u>FORCED by NGrid 01/27/2025 10:33</u> CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service | FWD (Import) REV (Export) 3640 MW 85 MW 3725 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_345KV_RNS3

Mon 04/06/2026 to Tue 04/07/2026
 0001 Continuous 2130
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

LINDN_CG-LNDVFT_345_V-3022

Mon 04/06/2026 to Sat 04/11/2026
 0800 Continuous 1500
 Work scheduled by: ConEd

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_VFT | FWD (Import) | REV (Export) |
| | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

BECK_-NIAGARA_345_PA302

Wed 04/08/2026 to Wed 04/08/2026
 0900 Continuous 1700
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1150 MW | 1000 MW |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

DYSINGER-STA_255_345_DH1 , NIAGARA_-DYSINGER_345_ND1

Thu 04/09/2026 to Thu 04/09/2026
 0500 Continuous 1900
 Work scheduled by:

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2500 MW | |
| Impacts Total Transfer Capability | 700 MW | |
| TTC with All Lines In Service | 3200 MW | |

NIAGARA_-DYSINGER_345_ND1

Thu 04/09/2026 to Thu 04/09/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2700 MW | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3200 MW | |

FRASER_345_FRASER SVC

Mon 04/13/2026 to Fri 04/17/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

| | | |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | FWD (Import) | REV (Export) |
| | 3655 MW | |
| Impacts Total Transfer Capability | 70 MW | |
| TTC with All Lines In Service | 3725 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WATRCURE-OAKDALE_345_31

Mon 04/13/2026 to Fri 05/08/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

| | | |
|-----------------------------------|----------------|----------------|
| SCH - PJ - NY | FWD (Import) | REV (Export) |
| | 2400 MW | 2400 MW |
| Impacts Total Transfer Capability | 100 MW | 250 MW |
| TTC with All Lines In Service | 2500 MW | 2650 MW |

MARCY_765_345_AT2

Tue 04/14/2026 to Thu 04/16/2026
 0600 Continuous 1730
 Work scheduled by: NYPA
 ARR: 19

| | | |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1700 MW | |
| Impacts Total Transfer Capability | 1700 MW | |
| TTC with All Lines In Service | 3400 MW | |

BECK_-NIAGARA_345_PA301

Tue 04/14/2026 to Tue 04/14/2026
 0900 Continuous 1700
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1150 MW | 1000 MW |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

BECK_-NIAGARA_345_PA301

Wed 04/15/2026 to Thu 04/16/2026
 0900 Continuous 1700
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1150 MW | 1000 MW |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

DYSINGER-STA_255_345_DH1 , NIAGARA_-DYSINGER_345_ND2

Thu 04/16/2026 to Thu 04/16/2026
 0500 Continuous 1800
 Work scheduled by:

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2500 MW | |
| Impacts Total Transfer Capability | 700 MW | |
| TTC with All Lines In Service | 3200 MW | |

NIAGARA_-DYSINGER_345_ND2

Thu 04/16/2026 to Thu 04/16/2026
 0500 Continuous 1800
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2700 MW | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3200 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT__345_V-3022

Thu 04/16/2026 to Thu 04/16/2026
 1200 Continuous 1500
 Work scheduled by: PJM

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_VFT | FWD (Import) | REV (Export) |
| | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

MOSES__WILLIS__230_MW1 , HAVERSTK-WILLISNX_345_HW2

Sun 04/19/2026 to Sun 04/26/2026
 0700 1730
 Work scheduled by:

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 279 MW | |
| TTC with All Lines In Service | 279 MW | |

SPRNBK_-UNIONHBS_345_Y49

Mon 04/20/2026 to Sun 05/03/2026
 0001 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

| | | |
|-----------------------------------|---------------|--------------|
| CONED - LIPA | FWD (Import) | REV (Export) |
| | 775 MW | |
| Impacts Total Transfer Capability | 725 MW | |
| TTC with All Lines In Service | 1500 MW | |

UNIONDHB_345_138_AT1

Mon 04/20/2026 to Sun 05/03/2026
 0001 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

| | | |
|-----------------------------------|----------------|--------------|
| CONED - LIPA | FWD (Import) | REV (Export) |
| | 1250 MW | |
| Impacts Total Transfer Capability | 250 MW | |
| TTC with All Lines In Service | 1500 MW | |

UNIONDHB_345_138_AT2

Mon 04/20/2026 to Sun 05/03/2026
 0001 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

| | | |
|-----------------------------------|----------------|--------------|
| CONED - LIPA | FWD (Import) | REV (Export) |
| | 1250 MW | |
| Impacts Total Transfer Capability | 250 MW | |
| TTC with All Lines In Service | 1500 MW | |

DYSINGER-STA_255_345_DH2

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-NIAGARA_345_PA302

Tue 04/21/2026 to Wed 04/22/2026
 0900 Continuous 1700
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1150 MW | 1000 MW |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

PIERCBRK-FIVEMILE_345_37

Thu 04/23/2026 to Fri 05/08/2026
 0800 Continuous 1600
 Work scheduled by: PJM

| | | |
|-----------------------------------|----------------|----------------|
| SCH - PJ - NY | FWD (Import) | REV (Export) |
| | 2300 MW | 2300 MW |
| Impacts Total Transfer Capability | 200 MW | 350 MW |
| TTC with All Lines In Service | 2500 MW | 2650 MW |

BECK__-NIAGARA_230_PA27

Thu 04/23/2026 to Thu 04/23/2026
 0900 Continuous 1700
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|--------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 2050 MW | |
| Impacts Total Transfer Capability | 450 MW | |
| TTC with All Lines In Service | 2500 MW | |

DUNWODIE_345KV_3

Fri 04/24/2026 to Fri 04/24/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

DUNWODIE_345KV_4

Fri 04/24/2026 to Fri 04/24/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

BECK__-NIAGARA_345_PA301

Mon 04/27/2026 to Fri 05/01/2026
 0630 Continuous 1600
 Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1150 MW | 1000 MW |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Tue 04/28/2026 to Tue 04/28/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_4

Tue 04/28/2026 to Tue 04/28/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

GOETHALS_345KV_5

Sat 05/02/2026 to Fri 05/08/2026
 0001 Continuous 0300 UPDATED by ConEd 03/05/2026 15:19
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

SHOR_NPX-SHOREHAM_138_CSC

Sun 05/03/2026 to Fri 05/15/2026
 0700 Continuous 1800 UPDATED by ISONE 02/18/2026 11:51
 Work scheduled by: ISONE

SCH - NPX_CSC **0 MW 0 MW**
 Impacts Total Transfer Capability 330 MW 330 MW
 TTC with All Lines In Service 330 MW 330 MW

FWD (Import) REV (Export)

CHATGUAY-MASSENA_765_7040

Sun 05/03/2026 to Wed 05/06/2026
 2301 Continuous 0259
 Work scheduled by: NYPA

SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import) REV (Export)

CHATGUAY-MASSENA_765_7040

Sun 05/03/2026 to Wed 05/06/2026
 2301 Continuous 0259
 Work scheduled by: NYPA

MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1650 MW
 TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__765_345_AT1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 1750 MW | |
| 1650 MW | |
| 3400 MW | |

MARCY__765_345_AT2

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 1700 MW | |
| 1700 MW | |
| 3400 MW | |

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|---------------|----------------|
| FWD (Import) | REV (Export) |
| 475 MW | 1000 MW |
| 1025 MW | 0 MW |
| 1500 MW | 1000 MW |

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 2595 MW | |
| 1130 MW | |
| 3725 MW | |

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|---------------|--------------|
| FWD (Import) | REV (Export) |
| 190 MW | |
| 80 MW | |
| 270 MW | |

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|---------------|--------------|
| FWD (Import) | REV (Export) |
| 500 MW | |
| 2900 MW | |
| 3400 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| MASSENA_MARCY__765_MSU1 , ADIRNDCK-CHASLAKE_230_13 | | | | |
|--|------------|----------------|-----------------------------------|-------------------------------|
| Mon 05/04/2026 | to | Wed 05/06/2026 | SCH - HQ_CEDARS | FWD (Import) REV (Export) |
| 0001 | | 0130 | Impacts Total Transfer Capability | 0 MW |
| Work scheduled by: | | | TTC with All Lines In Service | 270 MW |
| | | | | 270 MW |
| MASSENA_MARCY__765_MSU1 , CHASLAKE-PORTER__230_11 | | | | |
| Mon 05/04/2026 | to | Wed 05/06/2026 | SCH - HQ_CEDARS | FWD (Import) REV (Export) |
| 0001 | | 0130 | Impacts Total Transfer Capability | 0 MW |
| Work scheduled by: | | | TTC with All Lines In Service | 270 MW |
| | | | | 270 MW |
| MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040 | | | | |
| Mon 05/04/2026 | to | Wed 05/06/2026 | MOSES SOUTH | FWD (Import) REV (Export) |
| 0001 | | 0130 | Impacts Total Transfer Capability | 500 MW |
| Work scheduled by: | | | TTC with All Lines In Service | 2900 MW |
| | | | | 3400 MW |
| MASSENA_MARCY__765_MSU1 , MOSES__ADIRNDCK_230_MA2 | | | | |
| Mon 05/04/2026 | to | Wed 05/06/2026 | SCH - HQ_CEDARS | FWD (Import) REV (Export) |
| 0001 | | 0130 | Impacts Total Transfer Capability | 0 MW |
| Work scheduled by: | | | TTC with All Lines In Service | 270 MW |
| | | | | 270 MW |
| MASSENA_MARCY__765_MSU1 , MOSES__WILLIS__230_MW1 | | | | |
| Mon 05/04/2026 | to | Wed 05/06/2026 | SCH - HQ_CEDARS | FWD (Import) REV (Export) |
| 0001 | | 0130 | Impacts Total Transfer Capability | 0 MW |
| Work scheduled by: | | | TTC with All Lines In Service | 270 MW |
| | | | | 270 MW |
| BECK__NIAGARA_230_PA27 | | | | |
| Mon 05/04/2026 | to | Fri 05/08/2026 | SCH - OH - NY | FWD (Import) REV (Export) |
| 0900 | Continuous | 1700 | Impacts Total Transfer Capability | 1900 MW 1650 MW |
| Work scheduled by: IESO | | | TTC with All Lines In Service | 100 MW -50 MW |
| | | | | 2000 MW 1600 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|---|------------|----------------|---|-------------------------------|----------------|
| MARCY__FRASANNX_345_UCC2-41 | | | | FWD (Import) | REV (Export) |
| Wed 05/06/2026 | to | Fri 05/29/2026 | CENTRAL EAST - VC | 3225 MW | |
| 0700 | Continuous | 1530 | Impacts Total Transfer Capability | 500 MW | |
| Work scheduled by: NYPA | | | ARR: 19 | TTC with All Lines In Service | 3725 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| BECK__PACKARD_230_BP76 | | | | FWD (Import) | REV (Export) |
| Sun 05/10/2026 | to | Fri 05/15/2026 | SCH - OH - NY | 1600 MW | 1050 MW |
| 0530 | Continuous | 1600 | Impacts Total Transfer Capability | 400 MW | 550 MW |
| Work scheduled by: IESO | | | <u>UPDATED by IESO 01/21/2026 07:51</u> | TTC with All Lines In Service | 2000 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| FIVEMILE-ESTOLERD_345_29 | | | | FWD (Import) | REV (Export) |
| Mon 05/11/2026 | to | Thu 06/25/2026 | SCH - PJ - NY | 2000 MW | 1050 MW |
| 0500 | Continuous | 1800 | Impacts Total Transfer Capability | 200 MW | 150 MW |
| Work scheduled by: NGrid | | | TTC with All Lines In Service | 2200 MW | 1200 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| NEPTUNE_-DUFFYAVE_345_NEPTUNE | | | | FWD (Import) | REV (Export) |
| Mon 05/11/2026 | to | Fri 05/15/2026 | SCH - PJM_NEPTUNE | 0 MW | |
| 0600 | Continuous | 1600 | Impacts Total Transfer Capability | 660 MW | |
| Work scheduled by: LI | | | TTC with All Lines In Service | 660 MW | |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| NEWBRDGE_345_138_BK_1 | | | | FWD (Import) | REV (Export) |
| Mon 05/11/2026 | to | Fri 05/15/2026 | SCH - PJM_NEPTUNE | 375 MW | |
| 0600 | Continuous | 1600 | Impacts Total Transfer Capability | 285 MW | |
| Work scheduled by: LI | | | TTC with All Lines In Service | 660 MW | |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| NEWBRDGE_345_138_BK_2 | | | | FWD (Import) | REV (Export) |
| Mon 05/11/2026 | to | Fri 05/15/2026 | SCH - PJM_NEPTUNE | 375 MW | |
| 0600 | Continuous | 1600 | Impacts Total Transfer Capability | 285 MW | |
| Work scheduled by: LI | | | TTC with All Lines In Service | 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 05/11/2026 to Fri 05/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

DYSINGER-STA_255_345_DH1

Tue 05/12/2026 to Sun 05/31/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

MILLWOOD-EASTVIEW_345_W99

Fri 05/15/2026 to Sat 05/16/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 8015 MW | |
| Impacts Total Transfer Capability | 195 MW | |
| TTC with All Lines In Service | 8210 MW | |

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

SPRNBK_345KV_RNS5

Fri 05/15/2026 to Fri 05/15/2026
 0201 Continuous 0230
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3200 MW | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_W49TH_ST_345_M51

Fri 05/15/2026 to Mon 06/01/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_5

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_4

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
800 MW
 700 MW
 1500 MW

SHORE_RD_345_138_BK 1

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
 150 MW
 1500 MW

SHORE_RD_345_138_BK 2

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
 150 MW
 1500 MW

W49TH_ST_345KV_5

Mon 05/18/2026 to Mon 05/18/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

W49TH_ST_345KV_7

Mon 05/18/2026 to Mon 05/18/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL_345_RP2

Mon 05/18/2026 to Fri 05/22/2026
 0700 Continuous 1500
 Work scheduled by: RGE

| | | | |
|--|-----------------------------------|----------------|--------------|
| | DYSINGER EAST | FWD (Import) | REV (Export) |
| | | 2300 MW | |
| | Impacts Total Transfer Capability | 900 MW | |
| | TTC with All Lines In Service | 3200 MW | |

NIAGARA_345_230_AT4

Tue 05/26/2026 to Sat 05/30/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

| | | | |
|--|-----------------------------------|----------------|----------------|
| | SCH - OH - NY | FWD (Import) | REV (Export) |
| | | 1900 MW | 1200 MW |
| | Impacts Total Transfer Capability | 100 MW | 400 MW |
| | TTC with All Lines In Service | 2000 MW | 1600 MW |

SPRNBK_345KV_RNS5

Mon 06/01/2026 to Mon 06/01/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

| | | | |
|--|-----------------------------------|----------------|--------------|
| | SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | | 3200 MW | |
| | Impacts Total Transfer Capability | 1400 MW | |
| | TTC with All Lines In Service | 4600 MW | |

HUDSONTP-W49TH_ST_345_Y56

Mon 06/01/2026 to Fri 06/05/2026
 0600 Continuous 1600
 Work scheduled by: ConEd

| | | | |
|--|-----------------------------------|--------------|--------------|
| | SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | | 0 MW | |
| | Impacts Total Transfer Capability | 660 MW | |
| | TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_7

Mon 06/01/2026 to Mon 06/01/2026
 0600 Continuous 0630
 Work scheduled by: ConEd

| | | | |
|--|-----------------------------------|---------------|--------------|
| | SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | | 300 MW | |
| | Impacts Total Transfer Capability | 360 MW | |
| | TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_8

Mon 06/01/2026 to Mon 06/01/2026
 0600 Continuous 0630
 Work scheduled by: ConEd

| | | | |
|--|-----------------------------------|---------------|--------------|
| | SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | | 300 MW | |
| | Impacts Total Transfer Capability | 360 MW | |
| | TTC with All Lines In Service | 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__345KV_CSC

Mon 06/01/2026 to Sun 06/14/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | CENTRAL EAST - VC | 3650 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 75 MW | | |
| | TTC with All Lines In Service | 3725 MW | | |

LEEDS__-HURLYAVE_345_301

Mon 06/01/2026 to Fri 07/03/2026
 0800 Continuous 1600
 Work scheduled by: CHGE

UPDATED by CHGE 01/16/2026 09:18

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | UPNY CONED | 8120 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 90 MW | | |
| | TTC with All Lines In Service | 8210 MW | | |

SAND_BAR-PLATSBRG_115_PV20

Tue 06/02/2026 to Wed 06/03/2026
 0600 Continuous 1700
 Work scheduled by: ISONE

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | SCH - NE - NY | 3650 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 100 MW | | |
| | TTC with All Lines In Service | 3725 MW | | |

SAND_BAR-PLATSBRG_115_PV20

Tue 06/02/2026 to Wed 06/03/2026
 0600 Continuous 1700
 Work scheduled by: ISONE

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | CENTRAL EAST - VC | 3625 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 100 MW | | |
| | TTC with All Lines In Service | 3725 MW | | |

MOTTHAVN-RAINEY__345_Q11

Thu 06/04/2026 to Sun 06/07/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | SPR/DUN-SOUTH | 3800 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 800 MW | | |
| | TTC with All Lines In Service | 4600 MW | | |

W49TH_ST_345KV_7

Fri 06/05/2026 to Fri 06/05/2026
 1530 Continuous 1600
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|---------------|--------------|--------------|
| | SCH - PJM_HTP | 300 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 360 MW | | |
| | TTC with All Lines In Service | 660 MW | | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Fri 06/05/2026 to Fri 06/05/2026
 1530 Continuous 1600
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

MAINESBG-WATRCURE_345_30

Wed 06/10/2026 to Fri 06/12/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1600 MW 1050 MW
 600 MW 150 MW
 2200 MW 1200 MW

INGHAM_C_115_115_PAR 2

Mon 06/22/2026 to Sat 08/29/2026
 0500 Continuous 1900
 Work scheduled by: NGrid

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3605 MW
 120 MW
 3725 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3625 MW
 100 MW
 3725 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3625 MW
 100 MW
 3725 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3625 MW
 100 MW
 3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

CENTRAL EAST - VC **3625 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH2

Tue 08/25/2026 to Wed 09/02/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Sat 09/05/2026 to Sat 09/05/2026
 0201 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

E13THSTA-FARRAGUT_345_45

Wed 09/09/2026 to Fri 09/11/2026
 0001 Continuous 1830
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

MARCY__765_345_AT1

Wed 09/09/2026 to Thu 09/10/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1650 MW
 TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

W49TH_ST-E13THSTA_345_M54

Fri 09/11/2026 to Fri 09/11/2026
 0001 Continuous 1830
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__765_345_AT2

Fri 09/11/2026 to Sat 09/12/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

HUDSONTP-W49TH_ST_345_Y56

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Sat 09/12/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_8

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

STLAWRNC-MOSES__230_L34P

Mon 09/14/2026 to Fri 09/18/2026
 0600 Continuous 1630
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

DUNWODIE_345KV_7

Tue 09/15/2026 to Tue 09/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8

Tue 09/15/2026 to Tue 09/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE-MOTTHAVN_345_72

Tue 09/15/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

BECK__-NIAGARA_230_PA27

Tue 09/15/2026 to Tue 11/17/2026
 0500 Continuous 2330
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1900 MW 1650 MW
 100 MW -50 MW
 2000 MW 1600 MW

MARCY__FRASANNX_345_UCC2-41

Tue 09/15/2026 to Tue 09/29/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3225 MW
 500 MW
 3725 MW

PLSNTVLY-EFISHKIL_345_F37

Wed 09/16/2026 to Thu 10/22/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
8195 MW
 15 MW
 8210 MW

WOOD_ST-PLSNTVLE_345_Y87

Wed 09/16/2026 to Wed 09/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7795 MW
 415 MW
 8210 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH2

Wed 09/16/2026 to Sat 10/10/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| DYSINGER EAST | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

WOOD_ST_-PLSNTVLE_345_Y87

Fri 09/18/2026 to Fri 09/18/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| UPNY CONED | 7795 MW | |
| Impacts Total Transfer Capability | 415 MW | |
| TTC with All Lines In Service | 8210 MW | |

W49TH_ST_345KV_5

Sat 09/26/2026 to Thu 12/24/2026
 0201 Continuous 2359
 Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - PJM_HTP | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

GOETHALS_345KV_5

Mon 09/28/2026 to Sat 10/03/2026
 0001 Continuous 0300
 Work scheduled by: ConEd

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| STATEN ISLAND | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

PANNELL_-CLAY___345_1

Mon 09/28/2026 to Fri 10/02/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| WEST CENTRAL | 1300 MW | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

PANNELL_-CLAY___345_2

Mon 10/05/2026 to Fri 10/09/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| WEST CENTRAL | 1300 MW | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Sun 10/11/2026 to Wed 11/04/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

| | | | |
|-----------------------------------|----------------|--------------|--------------|
| DYSINGER EAST | 2850 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 350 MW | | |
| TTC with All Lines In Service | 3200 MW | | |

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

| | | | |
|-----------------------------------|-------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 0 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 660 MW | | |
| TTC with All Lines In Service | 660 MW | | |

NEWBRDGE_345_138_BK_1

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

| | | | |
|-----------------------------------|---------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 375 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 285 MW | | |
| TTC with All Lines In Service | 660 MW | | |

NEWBRDGE_345_138_BK_2

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

| | | | |
|-----------------------------------|---------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 375 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 285 MW | | |
| TTC with All Lines In Service | 660 MW | | |

NEWBRDGE-DUFFYAVE_345_501

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

| | | | |
|-----------------------------------|-------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 0 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 660 MW | | |
| TTC with All Lines In Service | 660 MW | | |

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

| | | | |
|-----------------------------------|-------------|--------------|--------------|
| SCH - HQ - NY | 0 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 1500 MW | | 1000 MW |
| TTC with All Lines In Service | 1500 MW | | 1000 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

| | | | |
|--|-----------------------------------|--------------|--------------|
| | MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1750 MW | | |
| | Impacts Total Transfer Capability | 1650 MW | |
| | TTC with All Lines In Service | 3400 MW | |

MARCY_765_345_AT1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

| | | | |
|--|-----------------------------------|--------------|--------------|
| | MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1750 MW | | |
| | Impacts Total Transfer Capability | 1650 MW | |
| | TTC with All Lines In Service | 3400 MW | |

MARCY_765_345_AT2

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

| | | | |
|--|-----------------------------------|--------------|--------------|
| | MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1700 MW | | |
| | Impacts Total Transfer Capability | 1700 MW | |
| | TTC with All Lines In Service | 3400 MW | |

MASSENA_-MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

| | | | |
|--|-----------------------------------|----------------|--------------|
| | SCH - HQ - NY | FWD (Import) | REV (Export) |
| | 475 MW | 1000 MW | |
| | Impacts Total Transfer Capability | 1025 MW | 0 MW |
| | TTC with All Lines In Service | 1500 MW | 1000 MW |

MASSENA_-MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

| | | | |
|--|-----------------------------------|--------------|--------------|
| | CENTRAL EAST - VC | FWD (Import) | REV (Export) |
| | 2595 MW | | |
| | Impacts Total Transfer Capability | 1130 MW | |
| | TTC with All Lines In Service | 3725 MW | |

MASSENA_-MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

| | | | |
|--|-----------------------------------|--------------|--------------|
| | SCH - HQ_CEDARS | FWD (Import) | REV (Export) |
| | 190 MW | | |
| | Impacts Total Transfer Capability | 80 MW | |
| | TTC with All Lines In Service | 270 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| MOSES SOUTH | 500 MW | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

MASSENA_MARCY__765_MSU1 , ADIRNDCK-CHASLAKE_230_13

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ_CEDARS | 0 MW | |
| Impacts Total Transfer Capability | 270 MW | |
| TTC with All Lines In Service | 270 MW | |

MASSENA_MARCY__765_MSU1 , CHASLAKE-PORTER_230_11

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ_CEDARS | 0 MW | |
| Impacts Total Transfer Capability | 270 MW | |
| TTC with All Lines In Service | 270 MW | |

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| MOSES SOUTH | 500 MW | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

MASSENA_MARCY__765_MSU1 , MOSES__ADIRNDCK_230_MA2

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ_CEDARS | 0 MW | |
| Impacts Total Transfer Capability | 270 MW | |
| TTC with All Lines In Service | 270 MW | |

MASSENA_MARCY__765_MSU1 , MOSES__WILLIS_230_MW1

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ_CEDARS | 0 MW | |
| Impacts Total Transfer Capability | 270 MW | |
| TTC with All Lines In Service | 270 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_PLSNTVLE_345_Y87

Wed 10/14/2026 to Wed 10/14/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7795 MW
 415 MW
 8210 MW

WOOD_ST_PLSNTVLE_345_Y87

Sat 10/17/2026 to Sat 10/17/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7795 MW
 415 MW
 8210 MW

SAND_BAR-PLATSBRG_115_PV20

Wed 10/21/2026 to Thu 10/22/2026
 0601 Continuous 1600
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3625 MW
 100 MW
 3725 MW

SAND_BAR-PLATSBRG_115_PV20

Wed 10/21/2026 to Thu 10/22/2026
 0601 Continuous 1600
 Work scheduled by: ISONE

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
 270 MW
 270 MW

SAND_BAR-PLATSBRG_115_PV20 , MASSENA -MARCY___765_MSU1

Wed 10/21/2026 to Thu 10/22/2026
 0601 1600
 Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7470 MW
 740 MW
 8210 MW

ROSETON_EFISHKIL_345_RFK305

Mon 10/26/2026 to Fri 11/06/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7470 MW
 740 MW
 8210 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_8

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

STLAWRNC-MOSES_230_L34P

Thu 10/29/2026 to Fri 11/13/2026
 0900 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

ROSETON_EFISHKIL_345_RFK305

Fri 11/06/2026 to Fri 11/13/2026
 1600 Continuous 1600
 Work scheduled by: CHGE

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7470 MW
 740 MW
 8210 MW

MILLWOOD-EASTVIEW_345_W99

Mon 11/09/2026 to Mon 11/09/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
8015 MW
 195 MW
 8210 MW

SPRNBRK_345KV_RNS5

Mon 11/09/2026 to Mon 11/09/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
 1400 MW
 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES_230_L33P

Mon 11/16/2026 to Fri 11/20/2026
 0600 Continuous 1630
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

BECK_-NIAGARA_230_PA27

Mon 11/23/2026 to Fri 11/27/2026
 0630 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

2050 MW
 450 MW
 2500 MW

EDIC_-FRASER_345_EF24-40

Mon 11/30/2026 to Sun 12/06/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

3225 MW
 500 MW
 3725 MW

DUNWODIE_345KV_3

Fri 12/04/2026 to Fri 12/04/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_5

Fri 12/04/2026 to Fri 12/04/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
 800 MW
 4600 MW

DUNWODIE-MOTTHAVN_345_71

Fri 12/04/2026 to Sat 12/12/2026
 0001 Continuous 0259
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
 800 MW
 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Fri 12/04/2026 to Fri 12/04/2026
 0101 Continuous 0130
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

W49TH_ST-E13THSTA_345_M54

Thu 12/10/2026 to Thu 12/10/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_3

Sat 12/12/2026 to Sat 12/12/2026
 0230 Continuous 0259
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_5

Sat 12/12/2026 to Sat 12/12/2026
 0230 Continuous 0259
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

MILLWOOD-EASTVIEW_345_W99

Wed 12/23/2026 to Wed 12/23/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

UPNY CONED **8015 MW**
 Impacts Total Transfer Capability 195 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

SPRNBRK_345KV_RNS5

Wed 12/23/2026 to Wed 12/23/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Fri 12/25/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_8

Fri 12/25/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

STLAWRNC-MOSES_230_L34P

Fri 12/25/2026 to Fri 12/25/2026
 0800 Continuous 1600
 Work scheduled by: IESO

| | | |
|-----------------------------------|--------------|--------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

W49TH_ST-E13THSTA_345_M54

Sun 12/27/2026 to Sun 12/27/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

W49TH_ST-E13THSTA_345_M54

Wed 12/30/2026 to Wed 12/30/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Mon 02/08/2027 to Tue 02/09/2027
 0001 Continuous 0200
 Work scheduled by:

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS5

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

SPRNBK_-W49TH_ST_345_M51

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

BUCHAN_S-MILLWOOD_345_W97

Mon 03/01/2027 to Wed 03/03/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED **8175 MW**
 Impacts Total Transfer Capability 35 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Thu 03/11/2027 to Sun 03/14/2027
 0001 0100
 Work scheduled by:

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

SPRNBK_345KV_RNS5

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

SPRNBK_-W49TH_ST_345_M51

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Sun 04/04/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | UPNY CONED | 8175 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 35 MW | | |
| | TTC with All Lines In Service | 8210 MW | | |

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Wed 04/07/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | UPNY CONED | 8175 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 35 MW | | |
| | TTC with All Lines In Service | 8210 MW | | |

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | | | |
|--|-----------------------------------|-------------|--------------|--------------|
| | SCH - PJM_NEPTUNE | 0 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 660 MW | | |
| | TTC with All Lines In Service | 660 MW | | |

NEWBRDGE_345_138_BK_1

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | | | |
|--|-----------------------------------|---------------|--------------|--------------|
| | SCH - PJM_NEPTUNE | 375 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 285 MW | | |
| | TTC with All Lines In Service | 660 MW | | |

NEWBRDGE_345_138_BK_2

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | | | |
|--|-----------------------------------|---------------|--------------|--------------|
| | SCH - PJM_NEPTUNE | 375 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 285 MW | | |
| | TTC with All Lines In Service | 660 MW | | |

NEWBRDGE-DUFFYAVE_345_501

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | | | |
|--|-----------------------------------|-------------|--------------|--------------|
| | SCH - PJM_NEPTUNE | 0 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 660 MW | | |
| | TTC with All Lines In Service | 660 MW | | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|-------------|-------------|
| SCH - HQ - NY | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--|
| MOSES SOUTH | 1750 MW | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

MARCY_765_345_AT1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

| | | |
|-----------------------------------|----------------|--|
| MOSES SOUTH | 1750 MW | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

MARCY_765_345_AT2

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

| | | |
|-----------------------------------|----------------|--|
| MOSES SOUTH | 1700 MW | |
| Impacts Total Transfer Capability | 1700 MW | |
| TTC with All Lines In Service | 3400 MW | |

MASSENA-MARCY_765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|---------------|----------------|
| SCH - HQ - NY | 475 MW | 1000 MW |
| Impacts Total Transfer Capability | 1025 MW | 0 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

MASSENA-MARCY_765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--|
| CENTRAL EAST - VC | 2595 MW | |
| Impacts Total Transfer Capability | 1130 MW | |
| TTC with All Lines In Service | 3725 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 8, 2026 to Tuesday, September 7, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | | |
|-----------------------------------|---------------|--------------|--------------|
| SCH - HQ_CEDARS | 190 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 80 MW | | |
| TTC with All Lines In Service | 270 MW | | |

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | | |
|-----------------------------------|---------------|--------------|--------------|
| MOSES SOUTH | 500 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 2900 MW | | |
| TTC with All Lines In Service | 3400 MW | | |

MASSENA_MARCY__765_MSU1 , ADIRNDCK-CHASLAKE_230_13

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

| | | | |
|-----------------------------------|-------------|--------------|--------------|
| SCH - HQ_CEDARS | 0 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 270 MW | | |
| TTC with All Lines In Service | 270 MW | | |

MASSENA_MARCY__765_MSU1 , CHASLAKE-PORTER__230_11

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

| | | | |
|-----------------------------------|-------------|--------------|--------------|
| SCH - HQ_CEDARS | 0 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 270 MW | | |
| TTC with All Lines In Service | 270 MW | | |

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

| | | | |
|-----------------------------------|---------------|--------------|--------------|
| MOSES SOUTH | 500 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 2900 MW | | |
| TTC with All Lines In Service | 3400 MW | | |

MASSENA_MARCY__765_MSU1 , MOSES__ADIRNDCK_230_MA2

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

| | | | |
|-----------------------------------|-------------|--------------|--------------|
| SCH - HQ_CEDARS | 0 MW | FWD (Import) | REV (Export) |
| Impacts Total Transfer Capability | 270 MW | | |
| TTC with All Lines In Service | 270 MW | | |

