

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 2359
 Work scheduled by:

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2400 MW 2400 MW
 100 MW 250 MW
 2500 MW 2650 MW

HAVERSTK-ADIRNDCK_345_HA1

Tue 08/19/2025 to Fri 03/27/2026
 1128 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 01/21/2026 16:09

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
 1100 MW
 3400 MW

MARCY_-ADIRNDCK_345_12

Tue 08/19/2025 to Sat 03/28/2026
 1129 Continuous 1730
 Work scheduled by: NYPA

UPDATED by NYPA 11/04/2025 10:05

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
 1100 MW
 3400 MW

SCH-IMO-NYISO_LIMIT_1900

Sat 11/01/2025 to Thu 04/30/2026
 0001 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2200 MW
 300 MW
 2500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__345KV_CSC

Fri 12/05/2025 to Sat 04/04/2026
 1541 Continuous 2359
 Work scheduled by: NYPA

EXT FORCED by NYPA 03/11/2026 13:13

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
3650 MW	
75 MW	
3725 MW	

HERTELHQ-ASTANNEX_345_G180

Tue 02/10/2026 to Sun 05/31/2026
 1121 Continuous 2359
 Work scheduled by: NYISO

SCH - HQ_CHPE
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	
1250 MW	
1250 MW	

NRTH1385-NOR HBR_138_601

Thu 02/26/2026 to Fri 05/15/2026
 0600 Continuous 1500
 Work scheduled by: LI

SCH - NPX_1385
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
60 MW	60 MW
100 MW	100 MW
160 MW	160 MW

NRTH1385-NOR HBR_138_602

Thu 02/26/2026 to Fri 05/15/2026
 0600 Continuous 1500
 Work scheduled by: LI

SCH - NPX_1385
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
60 MW	60 MW
100 MW	100 MW
160 MW	160 MW

NRTH1385-NOR HBR_138_603

Thu 02/26/2026 to Fri 05/15/2026
 0600 Continuous 1500
 Work scheduled by: LI

SCH - NPX_1385
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
60 MW	60 MW
100 MW	100 MW
160 MW	160 MW

NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602

Thu 02/26/2026 to Fri 05/15/2026
 0600 1500
 Work scheduled by:

SCH - NPX_1385
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
160 MW	160 MW
160 MW	160 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603

Thu 02/26/2026 to Fri 05/15/2026
 0600 1500
 Work scheduled by:

SCH - NPX_1385	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	160 MW	160 MW
TTC with All Lines In Service	160 MW	160 MW

NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603

Thu 02/26/2026 to Fri 05/15/2026
 0600 1500
 Work scheduled by:

SCH - NPX_1385	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	160 MW	160 MW
TTC with All Lines In Service	160 MW	160 MW

NRTH1385-NRTHPORT_138_NNC

Thu 02/26/2026 to Fri 05/15/2026
 0600 Continuous 1500
 Work scheduled by: LI

SCH - NPX_1385	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	160 MW	160 MW
TTC with All Lines In Service	160 MW	160 MW

DYSINGER-STA_255_345_DH2

Mon 03/02/2026 to Sat 03/28/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

EXTENDED by NYPA 06/17/2025 15:09

DYSINGER EAST	FWD (Import)	REV (Export)
	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

WOOD_ST_PLSNTVLE_345_Y86

Tue 03/03/2026 to Fri 03/13/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7820 MW	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	8210 MW	

SCH-HQ_CEDARS-NYISO_LIMIT_40

Mon 03/09/2026 to Thu 03/26/2026
 0700 Continuous 1900
 Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	40 MW	
Impacts Total Transfer Capability	239 MW	
TTC with All Lines In Service	279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/09/2026 to Thu 03/26/2026
0700 Continuous 1900
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS		0 MW
Impacts Total Transfer Capability		100 MW
TTC with All Lines In Service		100 MW

CEDARS__ROSEMNTA_115_1/11

Mon 03/09/2026 to Mon 03/30/2026
1113 Continuous 1730
Work scheduled by: HQ

FORCED by HQ 03/09/2026 16:05

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	95 MW	100 MW
Impacts Total Transfer Capability	184 MW	0 MW
TTC with All Lines In Service	279 MW	100 MW

DENNISON-ROSEMNTA_115_1/11

Tue 03/10/2026 to Mon 03/30/2026
0600 Continuous 1730
Work scheduled by: NGrid

UPDATED by NYISO 03/05/2026 11:47

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	95 MW	100 MW
Impacts Total Transfer Capability	184 MW	0 MW
TTC with All Lines In Service	279 MW	100 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Tue 03/10/2026 to Mon 03/30/2026
0600 Continuous 1730
Work scheduled by: NGrid

UPDATED by NYISO 03/05/2026 11:47

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	80 MW	
Impacts Total Transfer Capability	199 MW	
TTC with All Lines In Service	279 MW	

FRASER__345_FRASER SVC

Tue 03/10/2026 to Fri 03/13/2026
1834 Continuous 1433
Work scheduled by: NYSEG

FORCED by NYSEG 03/11/2026 10:05

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	3655 MW	
Impacts Total Transfer Capability	70 MW	
TTC with All Lines In Service	3725 MW	

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Fri 03/13/2026 to Fri 03/13/2026
0500 Continuous 1900
Work scheduled by: NYPA

UPDATED by NYPA 01/15/2026 11:02

	FWD (Import)	REV (Export)
SCH - OH - NY	1550 MW	1450 MW
Impacts Total Transfer Capability	950 MW	400 MW
TTC with All Lines In Service	2500 MW	1850 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_900

Sat 03/14/2026 to Fri 12/31/2027
 0001 Continuous 2359
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		900 MW
TTC with All Lines In Service		100 MW
		1000 MW

BECK__-NIAGARA_345_PA302

Mon 03/16/2026 to Fri 03/20/2026
 0630 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1150 MW	1000 MW
TTC with All Lines In Service	1350 MW	850 MW
	2500 MW	1850 MW

MARCY__-FRASANX_345_UCC2-41

Wed 03/18/2026 to Thu 03/26/2026 UPDATED by NGrid 01/21/2026 15:38
 0600 Continuous 2100
 Work scheduled by: NGrid
 ARR: 19

CENTRAL EAST - VC	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	3225 MW	
TTC with All Lines In Service	500 MW	
	3725 MW	

SCH-NYISO-HQ_LIMIT_700

Mon 03/23/2026 to Wed 03/25/2026
 0500 Continuous 1800
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		300 MW
		1000 MW

WOOD_ST_PLSNTVLE_345_Y86

Wed 03/25/2026 to Tue 04/28/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	7820 MW	
TTC with All Lines In Service	390 MW	
	8210 MW	

DYSINGER-STA_255_345_DH1

Sun 03/29/2026 to Mon 04/20/2026 UPDATED by NYPA 02/23/2026 11:15
 0500 Continuous 2100
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	2850 MW	
TTC with All Lines In Service	350 MW	
	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Mon 03/30/2026 to Mon 03/30/2026
 0130 Continuous 2359
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_4

Mon 03/30/2026 to Mon 03/30/2026
 0130 Continuous 2359
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

OSWEGO_COMPLEX_AVR_O/S

Tue 03/31/2026 to Sun 09/13/2026
 0001 Continuous 2359 FORCED by NGrid 01/27/2025 10:33
 Work scheduled by: NGrid

CENTRAL EAST - VC **3640 MW**
 Impacts Total Transfer Capability 85 MW
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

SPRNBK_345KV_RNS3

Mon 04/06/2026 to Tue 04/07/2026
 0001 Continuous 2130
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

LINDN_CG-LNDVFT__345_V-3022

Mon 04/06/2026 to Sat 04/11/2026
 0800 Continuous 1500
 Work scheduled by: ConEd

SCH - PJM_VFT **0 MW** **0 MW**
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

FWD (Import) REV (Export)

SHORE_RD_345_138_BK 1

Wed 04/08/2026 to Wed 04/08/2026
 0100 Continuous 2359
 Work scheduled by: LI

CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-NIAGARA_345_PA302

Wed 04/08/2026 to Wed 04/08/2026
 0900 Continuous 1700
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	1150 MW	1000 MW
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

DYSINGER-STA_255_345_DH1 , NIAGARA_-DYSINGER_345_ND1

Thu 04/09/2026 to Thu 04/09/2026
 0500 1900
 Work scheduled by:

DYSINGER EAST	FWD (Import)	REV (Export)
	2500 MW	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	3200 MW	

NIAGARA_-DYSINGER_345_ND1

Thu 04/09/2026 to Thu 04/09/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	2700 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

FRASER__345_FRASER SVC

Mon 04/13/2026 to Fri 04/17/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3655 MW	
Impacts Total Transfer Capability	70 MW	
TTC with All Lines In Service	3725 MW	

WATRCURE-OAKDALE_345_31

Mon 04/13/2026 to Fri 05/08/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

SCH - PJ - NY	FWD (Import)	REV (Export)
	2400 MW	2400 MW
Impacts Total Transfer Capability	100 MW	250 MW
TTC with All Lines In Service	2500 MW	2650 MW

SCH-NYISO-HQ_LIMIT_700

Tue 04/14/2026 to Thu 04/16/2026
 0500 Continuous 1900
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		700 MW
Impacts Total Transfer Capability		300 MW
TTC with All Lines In Service		1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__765_345_AT2		FWD (Import)	REV (Export)
Tue 04/14/2026	to Thu 04/16/2026		
0600	Continuous 1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1700 MW
		TTC with All Lines In Service	3400 MW
<hr style="border-top: 1px dashed black;"/>			
BECK__-NIAGARA_345_PA301		FWD (Import)	REV (Export)
Tue 04/14/2026	to Tue 04/14/2026		
0900	Continuous 1700	SCH - OH - NY	1150 MW 1000 MW
Work scheduled by: IESO		Impacts Total Transfer Capability	1350 MW 850 MW
		TTC with All Lines In Service	2500 MW 1850 MW
<hr style="border-top: 1px dashed black;"/>			
BECK__-NIAGARA_345_PA301		FWD (Import)	REV (Export)
Wed 04/15/2026	to Thu 04/16/2026		
0900	Continuous 1700	SCH - OH - NY	1150 MW 1000 MW
Work scheduled by: IESO		Impacts Total Transfer Capability	1350 MW 850 MW
		TTC with All Lines In Service	2500 MW 1850 MW
<hr style="border-top: 1px dashed black;"/>			
DYSINGER-STA_255_345_DH1 , NIAGARA_-DYSINGER_345_ND2		FWD (Import)	REV (Export)
Thu 04/16/2026	to Thu 04/16/2026		
0500	1800	DYSINGER EAST	2500 MW
Work scheduled by:		Impacts Total Transfer Capability	700 MW
		TTC with All Lines In Service	3200 MW
<hr style="border-top: 1px dashed black;"/>			
NIAGARA_-DYSINGER_345_ND2		FWD (Import)	REV (Export)
Thu 04/16/2026	to Thu 04/16/2026		
0500	Continuous 1800	DYSINGER EAST	2700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	3200 MW
<hr style="border-top: 1px dashed black;"/>			
LINDN_CG-LNDVFT__345_V-3022		FWD (Import)	REV (Export)
Thu 04/16/2026	to Thu 04/16/2026		
1200	Continuous 1500	SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM		Impacts Total Transfer Capability	315 MW 315 MW
		TTC with All Lines In Service	315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-WILLIS__230_MW1 , HAVERSTK-WILLISNX_345_HW2

Sun 04/19/2026 to Sun 04/26/2026
 0700 to 1730
 Work scheduled by:

SCH - HQ_CEDARS	0 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	279 MW		
TTC with All Lines In Service	279 MW		

SPRNBK_-UNIONHBS_345_Y49

Mon 04/20/2026 to Sun 05/03/2026
 0001 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA	775 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	725 MW		
TTC with All Lines In Service	1500 MW		

UNIONDHB_345_138_AT1

Mon 04/20/2026 to Sun 05/03/2026
 0001 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA	1250 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	250 MW		
TTC with All Lines In Service	1500 MW		

UNIONDHB_345_138_AT2

Mon 04/20/2026 to Sun 05/03/2026
 0001 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA	1250 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	250 MW		
TTC with All Lines In Service	1500 MW		

SCH-NYISO-HQ_LIMIT_700

Mon 04/20/2026 to Tue 04/21/2026
 0500 Continuous 1900
 Work scheduled by: HQ

SCH - HQ - NY	700 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	300 MW		
TTC with All Lines In Service	1000 MW		

DYSINGER-STA_255_345_DH2

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST	2850 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	350 MW		
TTC with All Lines In Service	3200 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-NIAGARA_345_PA302

Tue 04/21/2026 to Wed 04/22/2026
 0900 Continuous 1700
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	1150 MW	1000 MW
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

PIERCBRK-FIVEMILE_345_37

Thu 04/23/2026 to Fri 05/08/2026
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	2300 MW	2300 MW
Impacts Total Transfer Capability	200 MW	350 MW
TTC with All Lines In Service	2500 MW	2650 MW

BECK__-NIAGARA_230_PA27

Thu 04/23/2026 to Thu 04/23/2026
 0900 Continuous 1700
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	2050 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

DUNWODIE_345KV_3

Fri 04/24/2026 to Fri 04/24/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_4

Fri 04/24/2026 to Fri 04/24/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

BECK__-NIAGARA_345_PA301

Mon 04/27/2026 to Fri 05/01/2026
 0630 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	1150 MW	1000 MW
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3	FWD (Import)	REV (Export)
Tue 04/28/2026 to Tue 04/28/2026 0130 Continuous 0200 Work scheduled by: ConEd	SPR/DUN-SOUTH 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW	
<hr style="border-top: 1px dashed #000;"/>		
DUNWODIE_345KV_4	FWD (Import)	REV (Export)
Tue 04/28/2026 to Tue 04/28/2026 0130 Continuous 0200 Work scheduled by: ConEd	SPR/DUN-SOUTH 3800 MW Impacts Total Transfer Capability 800 MW TTC with All Lines In Service 4600 MW	
<hr style="border-top: 1px dashed #000;"/>		
GOETHALS_345KV_5	FWD (Import)	REV (Export)
Sat 05/02/2026 to Fri 05/08/2026 0001 Continuous 0300 Work scheduled by: ConEd	<u>UPDATED by ConEd 03/05/2026 15:19</u> STATEN ISLAND Impacts Total Transfer Capability TTC with All Lines In Service	
<hr style="border-top: 1px dashed #000;"/>		
SHOR_NPX-SHOREHAM_138_CSC	FWD (Import)	REV (Export)
Sun 05/03/2026 to Fri 05/15/2026 0700 Continuous 1800 Work scheduled by: ISONE	<u>UPDATED by ISONE 02/18/2026 11:51</u> SCH - NPX_CSC 0 MW 0 MW Impacts Total Transfer Capability 330 MW 330 MW TTC with All Lines In Service 330 MW 330 MW	
<hr style="border-top: 1px dashed #000;"/>		
CHATGUAY-MASSENA_765_7040	FWD (Import)	REV (Export)
Sun 05/03/2026 to Wed 05/06/2026 2301 Continuous 0259 Work scheduled by: NYPA	SCH - HQ - NY 0 MW 0 MW Impacts Total Transfer Capability 1500 MW 1000 MW TTC with All Lines In Service 1500 MW 1000 MW	
<hr style="border-top: 1px dashed #000;"/>		
CHATGUAY-MASSENA_765_7040	FWD (Import)	REV (Export)
Sun 05/03/2026 to Wed 05/06/2026 2301 Continuous 0259 Work scheduled by: NYPA	MOSES SOUTH 1750 MW Impacts Total Transfer Capability 1650 MW TTC with All Lines In Service 3400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__765_345_AT1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
1750 MW	
1650 MW	
3400 MW	

MARCY__765_345_AT2

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
1700 MW	
1700 MW	
3400 MW	

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
475 MW	1000 MW
1025 MW	0 MW
1500 MW	1000 MW

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
2595 MW	
1130 MW	
3725 MW	

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
190 MW	
80 MW	
270 MW	

MASSENA_-MARCY__765_MSU1

Mon 05/04/2026 to Wed 05/06/2026
 0001 Continuous 0130
 Work scheduled by: NYPA

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
500 MW	
2900 MW	
3400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1 , ADIRNDCK-CHASLAKE_230_13				
Mon 05/04/2026	to	Wed 05/06/2026	SCH - HQ_CEDARS	FWD (Import) REV (Export)
0001		0130	Impacts Total Transfer Capability	0 MW
Work scheduled by:			TTC with All Lines In Service	270 MW
				270 MW
MASSENA_MARCY__765_MSU1 , CHASLAKE-PORTER__230_11				
Mon 05/04/2026	to	Wed 05/06/2026	SCH - HQ_CEDARS	FWD (Import) REV (Export)
0001		0130	Impacts Total Transfer Capability	0 MW
Work scheduled by:			TTC with All Lines In Service	270 MW
				270 MW
MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040				
Mon 05/04/2026	to	Wed 05/06/2026	MOSES SOUTH	FWD (Import) REV (Export)
0001		0130	Impacts Total Transfer Capability	500 MW
Work scheduled by:			TTC with All Lines In Service	2900 MW
				3400 MW
MASSENA_MARCY__765_MSU1 , MOSES__-ADIRNDCK_230_MA2				
Mon 05/04/2026	to	Wed 05/06/2026	SCH - HQ_CEDARS	FWD (Import) REV (Export)
0001		0130	Impacts Total Transfer Capability	0 MW
Work scheduled by:			TTC with All Lines In Service	270 MW
				270 MW
MASSENA_MARCY__765_MSU1 , MOSES__-WILLIS__230_MW1				
Mon 05/04/2026	to	Wed 05/06/2026	SCH - HQ_CEDARS	FWD (Import) REV (Export)
0001		0130	Impacts Total Transfer Capability	0 MW
Work scheduled by:			TTC with All Lines In Service	270 MW
				270 MW
BECK__-NIAGARA_230_PA27				
Mon 05/04/2026	to	Fri 05/08/2026	SCH - OH - NY	FWD (Import) REV (Export)
0900	Continuous	1700	Impacts Total Transfer Capability	1900 MW 1650 MW
Work scheduled by: IESO			TTC with All Lines In Service	100 MW -50 MW
				2000 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__FRASANNX_345_UCC2-41				FWD (Import)	REV (Export)
Wed 05/06/2026	to	Fri 05/29/2026	CENTRAL EAST - VC	3225 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA			ARR: 19	TTC with All Lines In Service	3725 MW
BECK__PACKARD_230_BP76				FWD (Import)	REV (Export)
Sun 05/10/2026	to	Fri 05/15/2026	SCH - OH - NY	1600 MW	1050 MW
0530	Continuous	1600	Impacts Total Transfer Capability	400 MW	550 MW
Work scheduled by: IESO			<u>UPDATED by IESO 01/21/2026 07:51</u>	TTC with All Lines In Service	2000 MW
FIVEMILE-ESTOLERD_345_29				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Thu 06/25/2026	SCH - PJ - NY	2000 MW	1050 MW
0500	Continuous	1800	Impacts Total Transfer Capability	200 MW	150 MW
Work scheduled by: NGrid			TTC with All Lines In Service	2200 MW	1200 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 05/11/2026 to Fri 05/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

DYSINGER-STA_255_345_DH1

Tue 05/12/2026 to Sun 05/31/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

MILLWOOD-EASTVIEW_345_W99

Fri 05/15/2026 to Sat 05/16/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8015 MW	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

SPRNBRK_345KV_RNS5

Fri 05/15/2026 to Fri 05/15/2026
 0201 Continuous 0230
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_W49TH_ST_345_M51

Fri 05/15/2026 to Mon 06/01/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_5

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_4

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
800 MW
 700 MW
 1500 MW

SHORE_RD_345_138_BK 1

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
 150 MW
 1500 MW

SHORE_RD_345_138_BK 2

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
 150 MW
 1500 MW

W49TH_ST_345KV_5

Mon 05/18/2026 to Mon 05/18/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

W49TH_ST_345KV_7

Mon 05/18/2026 to Mon 05/18/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL_345_RP2

Mon 05/18/2026 to Fri 05/22/2026
 0700 Continuous 1500
 Work scheduled by: RGE

DYSINGER EAST	FWD (Import)	REV (Export)
	2300 MW	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

NIAGARA_345_230_AT4

Tue 05/26/2026 to Sat 05/30/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	1900 MW	1200 MW
Impacts Total Transfer Capability	100 MW	400 MW
TTC with All Lines In Service	2000 MW	1600 MW

SPRNBK_345KV_RNS5

Mon 06/01/2026 to Mon 06/01/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

HUDSONTP-W49TH_ST_345_Y56

Mon 06/01/2026 to Fri 06/05/2026
 0600 Continuous 1600
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_7

Mon 06/01/2026 to Mon 06/01/2026
 0600 Continuous 0630
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

Mon 06/01/2026 to Mon 06/01/2026
 0600 Continuous 0630
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__345KV_CSC

Mon 06/01/2026 to Sun 06/14/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3650 MW	
Impacts Total Transfer Capability	75 MW	
TTC with All Lines In Service	3725 MW	

LEEDS__-HURLYAVE_345_301

Mon 06/01/2026 to Fri 07/03/2026
 0800 Continuous 1600
 Work scheduled by: CHGE

UPDATED by CHGE 01/16/2026 09:18

UPNY CONED	FWD (Import)	REV (Export)
	8120 MW	
Impacts Total Transfer Capability	90 MW	
TTC with All Lines In Service	8210 MW	

SAND_BAR-PLATSBRG_115_PV20

Tue 06/02/2026 to Wed 06/03/2026
 0600 Continuous 1700
 Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

SAND_BAR-PLATSBRG_115_PV20

Tue 06/02/2026 to Wed 06/03/2026
 0600 Continuous 1700
 Work scheduled by: ISONE

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3625 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

MOTHAVN-RAINEY__345_Q11

Thu 06/04/2026 to Sun 06/07/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_7

Fri 06/05/2026 to Fri 06/05/2026
 1530 Continuous 1600
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Fri 06/05/2026 to Fri 06/05/2026
 1530 Continuous 1600
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

MAINESBG-WATRCURE_345_30

Wed 06/10/2026 to Fri 06/12/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

SCH - PJ - NY	FWD (Import)	REV (Export)
	1600 MW	1050 MW
Impacts Total Transfer Capability	600 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

INGHAM_C_115_115_PAR 2

Mon 06/22/2026 to Sat 08/29/2026
 0500 Continuous 1900
 Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3605 MW	
Impacts Total Transfer Capability	120 MW	
TTC with All Lines In Service	3725 MW	

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3625 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3625 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

DYSINGER-STA_255_345_DH2

Tue 08/25/2026 to Wed 09/02/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

MARION_-FARRAGUT_345_C3403

Sat 09/05/2026 to Sat 09/05/2026
 0201 Continuous 2359
 Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

E13THSTA-FARRAGUT_345_45

Wed 09/09/2026 to Fri 09/11/2026
 0001 Continuous 1830
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

MARCY__765_345_AT1

Wed 09/09/2026 to Thu 09/10/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	1750 MW	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

W49TH_ST-E13THSTA_345_M54

Fri 09/11/2026 to Fri 09/11/2026
 0001 Continuous 1830
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__765_345_AT2

Fri 09/11/2026 to Sat 09/12/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1700 MW
 1700 MW
 3400 MW

HUDSONTP-W49TH_ST_345_Y56

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
 660 MW
 660 MW

W49TH_ST_345KV_7

Sat 09/12/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

W49TH_ST_345KV_8

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

STLAWRNC-MOSES__230_L34P

Mon 09/14/2026 to Fri 09/18/2026
 0600 Continuous 1630
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

DUNWODIE_345KV_7

Tue 09/15/2026 to Tue 09/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8

Tue 09/15/2026 to Tue 09/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

DUNWODIE-MOTTHAVN_345_72

Tue 09/15/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

BECK__-NIAGARA_230_PA27

Tue 09/15/2026 to Tue 11/17/2026
 0500 Continuous 2330
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
1900 MW	1650 MW
100 MW	-50 MW
2000 MW	1600 MW

MARCY__FRASANNX_345_UCC2-41

Tue 09/15/2026 to Tue 09/29/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
3225 MW	
500 MW	
3725 MW	

PLSNTVLY-EFISHKIL_345_F37

Wed 09/16/2026 to Thu 10/22/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
8195 MW	
15 MW	
8210 MW	

WOOD_ST-PLSNTVLE_345_Y87

Wed 09/16/2026 to Wed 09/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
7795 MW	
415 MW	
8210 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH2

Wed 09/16/2026 to Sat 10/10/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

WOOD_ST_-PLSNTVLE_345_Y87

Fri 09/18/2026 to Fri 09/18/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED	FWD (Import)	REV (Export)
	7795 MW	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

W49TH_ST_345KV_5

Sat 09/26/2026 to Thu 12/24/2026
 0201 Continuous 2359
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

GOETHALS_345KV_5

Mon 09/28/2026 to Sat 10/03/2026
 0001 Continuous 0300
 Work scheduled by: ConEd

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

PANNELL_-CLAY___345_1

Mon 09/28/2026 to Fri 10/02/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	1300 MW	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

PANNELL_-CLAY___345_2

Mon 10/05/2026 to Fri 10/09/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	1300 MW	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Sun 10/11/2026 to Wed 11/04/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

DYSINGER EAST	2850 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	350 MW		
TTC with All Lines In Service	3200 MW		

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	0 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	660 MW		
TTC with All Lines In Service	660 MW		

NEWBRDGE_345_138_BK_1

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	375 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	285 MW		
TTC with All Lines In Service	660 MW		

NEWBRDGE_345_138_BK_2

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	375 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	285 MW		
TTC with All Lines In Service	660 MW		

NEWBRDGE-DUFFYAVE_345_501

Mon 10/12/2026 to Thu 10/15/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	0 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	660 MW		
TTC with All Lines In Service	660 MW		

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

SCH - HQ - NY	0 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1500 MW		1000 MW
TTC with All Lines In Service	1500 MW		1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	1750 MW	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY_765_345_AT1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1750 MW	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY_765_345_AT2

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1700 MW	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

MASSENA -MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA -MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2595 MW	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

MASSENA -MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	190 MW	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	500 MW	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

MASSENA_MARCY__765_MSU1 , ADIRNDCK-CHASLAKE_230_13

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

MASSENA_MARCY__765_MSU1 , CHASLAKE-PORTER_230_11

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	500 MW	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

MASSENA_MARCY__765_MSU1 , MOSES__ADIRNDCK_230_MA2

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

MASSENA_MARCY__765_MSU1 , MOSES__WILLIS_230_MW1

Wed 10/14/2026 to Wed 10/28/2026
 0001 2359
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_PLSNTVLE_345_Y87

Wed 10/14/2026 to Wed 10/14/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7795 MW
 415 MW
 8210 MW

WOOD_ST_PLSNTVLE_345_Y87

Sat 10/17/2026 to Sat 10/17/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7795 MW
 415 MW
 8210 MW

SAND_BAR-PLATSBRG_115_PV20

Wed 10/21/2026 to Thu 10/22/2026
 0601 Continuous 1600
 Work scheduled by: ISONE

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3625 MW
 100 MW
 3725 MW

SAND_BAR-PLATSBRG_115_PV20

Wed 10/21/2026 to Thu 10/22/2026
 0601 Continuous 1600
 Work scheduled by: ISONE

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
 270 MW
 270 MW

SAND_BAR-PLATSBRG_115_PV20 , MASSENA -MARCY___765_MSU1

Wed 10/21/2026 to Thu 10/22/2026
 0601 1600
 Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7470 MW
 740 MW
 8210 MW

ROSETON_EFISHKIL_345_RFK305

Mon 10/26/2026 to Fri 11/06/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
7470 MW
 740 MW
 8210 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_8

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

STLAWRNC-MOSES_230_L34P

Thu 10/29/2026 to Fri 11/13/2026
 0900 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

DUNWODIE_345KV_5

Mon 11/02/2026 to Mon 11/02/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 03/11/2026 15:36

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE-MOTTHAVN_345_71

Mon 11/02/2026 to Mon 12/14/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/11/2026 15:36

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_3

Mon 11/02/2026 to Mon 11/02/2026
 0230 Continuous 0259
 Work scheduled by: ConEd

UPDATED by ConEd 03/11/2026 15:36

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT__345_V-3022

Mon 11/02/2026 to Sat 11/07/2026
 0800 Continuous 1900
 Work scheduled by: PJM

SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

ROSETON_EFISHKIL_345_RFK305

Fri 11/06/2026 to Fri 11/13/2026
 1600 Continuous 1600
 Work scheduled by: CHGE

UPNY CONED	7470 MW	
Impacts Total Transfer Capability	740 MW	
TTC with All Lines In Service	8210 MW	

MILLWOOD-EASTVIEW_345_W99

Mon 11/09/2026 to Mon 11/09/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPNY CONED	8015 MW	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

SPRNBK_345KV_RNS5

Mon 11/09/2026 to Mon 11/09/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

STLAWRNC-MOSES__230_L33P

Mon 11/16/2026 to Fri 11/20/2026
 0600 Continuous 1630
 Work scheduled by: NYPA

SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

BECK__-NIAGARA_230_PA27

Mon 11/23/2026 to Fri 11/27/2026
 0630 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY	2050 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Wed 12/23/2026 to Wed 12/23/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8015 MW	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

SPRNBK_345KV_RNS5

Wed 12/23/2026 to Wed 12/23/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

HUDSONTP-W49TH_ST_345_Y56

Fri 12/25/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

Fri 12/25/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

STLAWRNC-MOSES_230_L34P

Fri 12/25/2026 to Fri 12/25/2026
 0800 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

W49TH_ST-E13THSTA_345_M54

Sun 12/27/2026 to Sun 12/27/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Wed 12/30/2026 to Wed 12/30/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_345KV_RS3 , SPRNBRK_345KV_RS4

Mon 02/08/2027 to Tue 02/09/2027
 0001 0200
 Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_345KV_RNS5

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M51

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

BUCHAN_S-MILLWOOD_345_W97

Mon 03/01/2027 to Wed 03/03/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8175 MW	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

SPRNBRK_345KV_RS3 , SPRNBRK_345KV_RS4

Thu 03/11/2027 to Sun 03/14/2027
 0001 0100
 Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS5

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBK_-W49TH_ST_345_M51

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Sun 04/04/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8175 MW	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Wed 04/07/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8175 MW	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	1750 MW	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY__765_345_AT1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	1750 MW	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY__765_345_AT2

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	1700 MW	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

CENTRAL EAST - VC	2595 MW	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ_CEDARS	190 MW	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

MASSENA_MARCY__765_MSU1 , ADIRNDCK-CHASLAKE_230_13

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

SCH - HQ_CEDARS	0 MW	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

MASSENA_MARCY__765_MSU1 , CHASLAKE-PORTER__230_11

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

SCH - HQ_CEDARS	0 MW	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, March 13, 2026 to Sunday, September 12, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

MOSES SOUTH	500 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	2900 MW		
TTC with All Lines In Service	3400 MW		

MASSENA_MARCY__765_MSU1 , MOSES__-ADIRNDCK_230_MA2

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

SCH - HQ_CEDARS	0 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	270 MW		
TTC with All Lines In Service	270 MW		

MASSENA_MARCY__765_MSU1 , MOSES__-WILLIS__230_MW1

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

SCH - HQ_CEDARS	0 MW	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	270 MW		
TTC with All Lines In Service	270 MW		