

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 Continuous 2359  
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 Continuous 2359  
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 2359  
 Work scheduled by:

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2400 MW 2400 MW**  
 100 MW 250 MW  
 2500 MW 2650 MW

**HAVERSTK-ADIRNDCK\_345\_HA1**

Tue 08/19/2025 to Fri 03/27/2026  
 1128 Continuous 1730  
 Work scheduled by: NYPA

UPDATED by NYPA 01/21/2026 16:09

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
 1100 MW  
 3400 MW

**MARCY\_-ADIRNDCK\_345\_12**

Tue 08/19/2025 to Sat 03/28/2026  
 1129 Continuous 1730  
 Work scheduled by: NYPA

UPDATED by NYPA 11/04/2025 10:05

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
 1100 MW  
 3400 MW

**SCH-IMO-NYISO\_LIMIT\_1900**

Sat 11/01/2025 to Thu 04/30/2026  
 0001 Continuous 2359  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2200 MW**  
 300 MW  
 2500 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY\_\_345KV\_CSC**

Fri 12/05/2025 to Sat 04/04/2026  
 1541 Continuous 2359  
 Work scheduled by: NYPA

EXT FORCED by NYPA 03/11/2026 13:13

CENTRAL EAST - VC **3650 MW**  
 Impacts Total Transfer Capability 75 MW  
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**HERTELHQ-ASTANNEX\_345\_G180**

Tue 02/10/2026 to Sun 05/31/2026  
 1121 Continuous 2359  
 Work scheduled by: NYISO

SCH - HQ\_CHPE **0 MW**  
 Impacts Total Transfer Capability 1250 MW  
 TTC with All Lines In Service 1250 MW

FWD (Import) REV (Export)

**NRTH1385-NOR HBR\_138\_601**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385 **60 MW 60 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 160 MW 160 MW

FWD (Import) REV (Export)

**NRTH1385-NOR HBR\_138\_602**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385 **60 MW 60 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 160 MW 160 MW

FWD (Import) REV (Export)

**NRTH1385-NOR HBR\_138\_603**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385 **60 MW 60 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 160 MW 160 MW

FWD (Import) REV (Export)

**NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_602**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 1500  
 Work scheduled by:

SCH - NPX\_1385 **0 MW 0 MW**  
 Impacts Total Transfer Capability 160 MW 160 MW  
 TTC with All Lines In Service 160 MW 160 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603</b>				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import)    REV (Export)
0600		1500	Impacts Total Transfer Capability	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:			TTC with All Lines In Service	160 MW        160 MW
<b>NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603</b>				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import)    REV (Export)
0600		1500	Impacts Total Transfer Capability	<b>0 MW</b> <b>0 MW</b>
Work scheduled by:			TTC with All Lines In Service	160 MW        160 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import)    REV (Export)
0600	Continuous	1500	Impacts Total Transfer Capability	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: LI			TTC with All Lines In Service	160 MW        160 MW
<b>DYSINGER-STA_255_345_DH2</b>				
Mon 03/02/2026	to	Sat 03/28/2026	DYSINGER EAST	FWD (Import)    REV (Export)
0500	Continuous	1900	Impacts Total Transfer Capability	<b>2850 MW</b>
Work scheduled by: NYPA			TTC with All Lines In Service	350 MW        3200 MW
			<u>EXTENDED by NYPA 06/17/2025 15:09</u>	
<b>SCH-HQ_CEDARS-NYISO_LIMIT_40</b>				
Mon 03/09/2026	to	Thu 03/26/2026	SCH - HQ_CEDARS	FWD (Import)    REV (Export)
0700	Continuous	1900	Impacts Total Transfer Capability	<b>40 MW</b>
Work scheduled by: HQ			TTC with All Lines In Service	239 MW        279 MW
<b>SCH-NYISO-HQ_CEDARS_LIMIT_0</b>				
Mon 03/09/2026	to	Thu 03/26/2026	SCH - HQ_CEDARS	FWD (Import)    REV (Export)
0700	Continuous	1900	Impacts Total Transfer Capability	<b>0 MW</b>
Work scheduled by: HQ			TTC with All Lines In Service	100 MW        100 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CEDARS\_-ROSEMNTA\_115\_1/11**

Mon 03/09/2026 to Mon 03/30/2026  
 1113 Continuous 1730  
 Work scheduled by: HQ

FORCED by HQ\_03/09/2026 16:05

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 100 MW**

184 MW 0 MW

279 MW 100 MW

**DENNISON-ROSEMNTA\_115\_1/11**

Tue 03/10/2026 to Mon 03/30/2026  
 0600 Continuous 1730  
 Work scheduled by: NGrid

UPDATED by NYISO\_03/05/2026 11:47

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 100 MW**

184 MW 0 MW

279 MW 100 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

Tue 03/10/2026 to Mon 03/30/2026  
 0600 Continuous 1730  
 Work scheduled by: NGrid

UPDATED by NYISO\_03/05/2026 11:47

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**80 MW**

199 MW

279 MW

**SCH-NYISO-HQ\_LIMIT\_900**

Sat 03/14/2026 to Fri 12/31/2027  
 0001 Continuous 2359  
 Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**900 MW**

100 MW

1000 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Mon 03/16/2026 to Fri 03/27/2026  
 0600 Continuous 1600  
 Work scheduled by: PJM

FORCED by PJM\_03/15/2026 10:46

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**

660 MW

660 MW

**BECK\_-NIAGARA\_345\_PA302**

Mon 03/16/2026 to Fri 03/20/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1150 MW 1000 MW**

1350 MW 850 MW

2500 MW 1850 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY\_\_FRASANNX\_345\_UCC2-41**

Wed 03/18/2026 to Thu 03/26/2026  
 0600 Continuous 2100  
 Work scheduled by: NGrid

UPDATED by NGrid 01/21/2026 15:38

ARR: 19

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
 500 MW  
 3725 MW

**SCH-NYISO-HQ\_LIMIT\_700**

Mon 03/23/2026 to Wed 03/25/2026  
 0500 Continuous 1800  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
 300 MW  
 1000 MW

**WOOD\_ST\_PLSNTVLE\_345\_Y86**

Wed 03/25/2026 to Tue 04/28/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**7820 MW**  
 390 MW  
 8210 MW

**DYSINGER-STA\_255\_345\_DH1**

Sun 03/29/2026 to Mon 04/20/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:15

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
 350 MW  
 3200 MW

**DUNWODIE\_345KV\_3**

Mon 03/30/2026 to Mon 03/30/2026  
 0130 Continuous 2359  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_4**

Mon 03/30/2026 to Mon 03/30/2026  
 0130 Continuous 2359  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**OSWEGO\_COMPLEX\_AVR\_O/S**

Tue 03/31/2026 to Sun 09/13/2026  
 0001 Continuous 2359  
 Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3640 MW</b>	
85 MW	
3725 MW	

**SPRNBRK\_345KV\_RNS3**

Mon 04/06/2026 to Tue 04/07/2026  
 0001 Continuous 2130  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**LINDN\_CG-LNDVFT\_345\_V-3022**

Mon 04/06/2026 to Sat 04/11/2026  
 0800 Continuous 1500  
 Work scheduled by: ConEd

SCH - PJM\_VFT  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
315 MW	315 MW
315 MW	315 MW

**SHORE\_RD\_345\_138\_BK 1**

Wed 04/08/2026 to Wed 04/08/2026  
 0100 Continuous 2359  
 Work scheduled by: LI

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1350 MW</b>	
150 MW	
1500 MW	

**BECK\_\_-NIAGARA\_345\_PA302**

Wed 04/08/2026 to Wed 04/08/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1150 MW</b>	<b>1000 MW</b>
1350 MW	850 MW
2500 MW	1850 MW

**DYSINGER-STA\_255\_345\_DH1 , NIAGARA\_-DYSINGER\_345\_ND1**

Thu 04/09/2026 to Thu 04/09/2026  
 0500 1900  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2500 MW</b>	
700 MW	
3200 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NIAGARA\_-DYSINGER\_345\_ND1**

Thu 04/09/2026 to Thu 04/09/2026  
 0500 Continuous 1900  
 Work scheduled by: NYPA

DYSINGER EAST	<b>2700 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	500 MW		
TTC with All Lines In Service	3200 MW		

**FRASER\_\_345\_FRASER SVC**

Mon 04/13/2026 to Fri 04/17/2026  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

CENTRAL EAST - VC	<b>3655 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	70 MW		
TTC with All Lines In Service	3725 MW		

**WATRCURE-OAKDALE\_345\_31**

Mon 04/13/2026 to Fri 05/08/2026  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

SCH - PJ - NY	<b>2400 MW</b>	<b>2400 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	100 MW	250 MW		
TTC with All Lines In Service	2500 MW	2650 MW		

**SCH-NYISO-HQ\_LIMIT\_700**

Tue 04/14/2026 to Thu 04/16/2026  
 0500 Continuous 1900  
 Work scheduled by: HQ

SCH - HQ - NY	<b>700 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability			300 MW
TTC with All Lines In Service			1000 MW

**MARCY\_\_765\_345\_AT2**

Tue 04/14/2026 to Thu 04/16/2026  
 0600 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	<b>1700 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1700 MW		
TTC with All Lines In Service	3400 MW		

**BECK\_\_-NIAGARA\_345\_PA301**

Tue 04/14/2026 to Tue 04/14/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY	<b>1150 MW</b>	<b>1000 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1350 MW	850 MW		
TTC with All Lines In Service	2500 MW	1850 MW		

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BECK\_\_-NIAGARA\_345\_PA301**

Wed 04/15/2026 to Thu 04/16/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1150 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

**DYSINGER-STA\_255\_345\_DH1 , NIAGARA\_-DYSINGER\_345\_ND2**

Thu 04/16/2026 to Thu 04/16/2026  
 0500 1800  
 Work scheduled by:

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2500 MW</b>	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	3200 MW	

**NIAGARA\_-DYSINGER\_345\_ND2**

Thu 04/16/2026 to Thu 04/16/2026  
 0500 Continuous 1800  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2700 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Thu 04/16/2026 to Thu 04/16/2026  
 1200 Continuous 1500  
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

**MOSES\_\_-WILLIS\_\_230\_MW1 , HAVERSTK-WILLISNX\_345\_HW2**

Sun 04/19/2026 to Sun 04/26/2026  
 0700 1730  
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>0 MW</b>	
Impacts Total Transfer Capability	279 MW	
TTC with All Lines In Service	279 MW	

**SPRNBRK\_-UNIONHBS\_345\_Y49**

Mon 04/20/2026 to Sun 05/03/2026  
 0001 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

	FWD (Import)	REV (Export)
CONED - LIPA	<b>775 MW</b>	
Impacts Total Transfer Capability	725 MW	
TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**UNIONDHB\_345\_138\_AT1**

Mon 04/20/2026 to Sun 05/03/2026  
 0001 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1250 MW</b>	
250 MW	
1500 MW	

**UNIONDHB\_345\_138\_AT2**

Mon 04/20/2026 to Sun 05/03/2026  
 0001 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1250 MW</b>	
250 MW	
1500 MW	

**SCH-NYISO-HQ\_LIMIT\_700**

Mon 04/20/2026 to Tue 04/21/2026  
 0500 Continuous 1900  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
	<b>700 MW</b>
	300 MW
	1000 MW

**DYSINGER-STA\_255\_345\_DH2**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

**BECK\_\_-NIAGARA\_345\_PA302**

Tue 04/21/2026 to Wed 04/22/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1150 MW</b>	<b>1000 MW</b>
1350 MW	850 MW
2500 MW	1850 MW

**PIERCBRK-FIVEMILE\_345\_37**

Thu 04/23/2026 to Fri 05/08/2026  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2300 MW</b>	<b>2300 MW</b>
200 MW	350 MW
2500 MW	2650 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BECK\_\_-NIAGARA\_230\_PA27**

Thu 04/23/2026 to Thu 04/23/2026  
0900 Continuous 1700  
Work scheduled by: IESO

SCH - OH - NY **2050 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 2500 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_3**

Fri 04/24/2026 to Fri 04/24/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_4**

Fri 04/24/2026 to Fri 04/24/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**BECK\_\_-NIAGARA\_345\_PA301**

Mon 04/27/2026 to Fri 05/01/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY **1150 MW** **1000 MW**  
Impacts Total Transfer Capability 1350 MW 850 MW  
TTC with All Lines In Service 2500 MW 1850 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_3**

Tue 04/28/2026 to Tue 04/28/2026  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_4**

Tue 04/28/2026 to Tue 04/28/2026  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**GOETHALS\_345KV\_5**

Sat 05/02/2026 to Fri 05/08/2026  
 0001 Continuous 0300  
 Work scheduled by: ConEd

UPDATED by ConEd 03/05/2026 15:19

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Sun 05/03/2026 to Fri 05/15/2026  
 0700 Continuous 1800  
 Work scheduled by: ISONE

UPDATED by ISONE 02/18/2026 11:51

SCH - NPX\_CSC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**0 MW**    **0 MW**  
 330 MW    330 MW  
 330 MW    330 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 05/03/2026 to Wed 05/06/2026  
 2301 Continuous 0259  
 Work scheduled by: NYPA

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**0 MW**    **0 MW**  
 1500 MW    1000 MW  
 1500 MW    1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 05/03/2026 to Wed 05/06/2026  
 2301 Continuous 0259  
 Work scheduled by: NYPA

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**1750 MW**  
 1650 MW  
 3400 MW

**MARCY\_\_765\_345\_AT1**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 Continuous 0130  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**1750 MW**  
 1650 MW  
 3400 MW

**MARCY\_\_765\_345\_AT2**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 Continuous 0130  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**1700 MW**  
 1700 MW  
 3400 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 Continuous 0130  
 Work scheduled by: NYPA

SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

FWD (Import)    REV (Export)

**MASSENA\_MARCY\_\_765\_MSU1**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 Continuous 0130  
 Work scheduled by: NYPA

CENTRAL EAST - VC	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

FWD (Import)    REV (Export)

**MASSENA\_MARCY\_\_765\_MSU1**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 Continuous 0130  
 Work scheduled by: NYPA

SCH - HQ_CEDARS	<b>190 MW</b>	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

FWD (Import)    REV (Export)

**MASSENA\_MARCY\_\_765\_MSU1**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 Continuous 0130  
 Work scheduled by: NYPA

MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

FWD (Import)    REV (Export)

**MASSENA\_MARCY\_\_765\_MSU1 , ADIRNDCK-CHASLAKE\_230\_13**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 0130  
 Work scheduled by:

SCH - HQ_CEDARS	<b>0 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

FWD (Import)    REV (Export)

**MASSENA\_MARCY\_\_765\_MSU1 , CHASLAKE-PORTER\_\_230\_11**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 0130  
 Work scheduled by:

SCH - HQ_CEDARS	<b>0 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

FWD (Import)    REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 0130  
 Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 0130  
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_-WILLIS\_230\_MW1**

Mon 05/04/2026 to Wed 05/06/2026  
 0001 0130  
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

**BECK\_\_-NIAGARA\_230\_PA27**

Mon 05/04/2026 to Fri 05/08/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1900 MW</b>	<b>1650 MW</b>
Impacts Total Transfer Capability	100 MW	-50 MW
TTC with All Lines In Service	2000 MW	1600 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Wed 05/06/2026 to Fri 05/29/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3225 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

**BECK\_\_-PACKARD\_230\_BP76**

Sun 05/10/2026 to Fri 05/15/2026  
 0530 Continuous 1600  
 Work scheduled by: IESO

UPDATED by IESO 01/21/2026 07:51

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1600 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	400 MW	550 MW
TTC with All Lines In Service	2000 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**FIVEMILE-ESTOLERD\_345\_29**

Mon 05/11/2026 to Thu 06/25/2026  
 0500 Continuous 1800  
 Work scheduled by: NGrid

	SCH - PJ - NY	FWD (Import)	REV (Export)
		<b>2000 MW</b>	<b>1050 MW</b>
	Impacts Total Transfer Capability	200 MW	150 MW
	TTC with All Lines In Service	2200 MW	1200 MW

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		<b>0 MW</b>	
	Impacts Total Transfer Capability	660 MW	
	TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		<b>375 MW</b>	
	Impacts Total Transfer Capability	285 MW	
	TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		<b>375 MW</b>	
	Impacts Total Transfer Capability	285 MW	
	TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		<b>0 MW</b>	
	Impacts Total Transfer Capability	660 MW	
	TTC with All Lines In Service	660 MW	

**DYSINGER-STA\_255\_345\_DH1**

Tue 05/12/2026 to Sun 05/31/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

	DYSINGER EAST	FWD (Import)	REV (Export)
		<b>2850 MW</b>	
	Impacts Total Transfer Capability	350 MW	
	TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MILLWOOD-EASTVIEW\_345\_W99**

Fri 05/15/2026 to Sat 05/16/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED **8015 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Fri 05/15/2026 to Fri 05/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_7**

Fri 05/15/2026 to Fri 05/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**SPRNBRK\_345KV\_RNS5**

Fri 05/15/2026 to Fri 05/15/2026  
 0201 Continuous 0230  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBRK\_W49TH\_ST\_345\_M51**

Fri 05/15/2026 to Mon 06/01/2026  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Fri 05/15/2026 to Fri 05/15/2026  
 1430 Continuous 1500  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>W49TH_ST_345KV_7</b>						
Fri 05/15/2026	to	Fri 05/15/2026		SCH - PJM_HTP	<b>300 MW</b>	FWD (Import)    REV (Export)
1430	Continuous	1500		Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	
<hr style="border-top: 1px dashed black;"/>						
<b>W49TH_ST_345KV_5</b>						
Sat 05/16/2026	to	Sat 05/16/2026		SCH - PJM_HTP	<b>300 MW</b>	FWD (Import)    REV (Export)
0001	Continuous	0030		Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	
<hr style="border-top: 1px dashed black;"/>						
<b>W49TH_ST_345KV_7</b>						
Sat 05/16/2026	to	Sat 05/16/2026		SCH - PJM_HTP	<b>300 MW</b>	FWD (Import)    REV (Export)
0001	Continuous	0030		Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	
<hr style="border-top: 1px dashed black;"/>						
<b>DUNWODIE_345KV_4</b>						
Sat 05/16/2026	to	Thu 05/28/2026	<u>UPDATED by ConEd 03/01/2026 10:07</u>	SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import)    REV (Export)
0201	Continuous	0200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<hr style="border-top: 1px dashed black;"/>						
<b>DUNWODIE_345KV_6</b>						
Sat 05/16/2026	to	Thu 05/28/2026	<u>UPDATED by ConEd 03/01/2026 10:07</u>	SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import)    REV (Export)
0201	Continuous	0200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<hr style="border-top: 1px dashed black;"/>						
<b>DUNWODIE-SHORE_RD_345_Y50</b>						
Sat 05/16/2026	to	Thu 05/28/2026	<u>UPDATED by ConEd 03/01/2026 10:07</u>	CONED - LIPA	<b>800 MW</b>	FWD (Import)    REV (Export)
0201	Continuous	0200		Impacts Total Transfer Capability	700 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SHORE\_RD\_345\_138\_BK 1**

Sat 05/16/2026 to Thu 05/28/2026  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1350 MW</b>	
150 MW	
1500 MW	

**SHORE\_RD\_345\_138\_BK 2**

Sat 05/16/2026 to Thu 05/28/2026  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1350 MW</b>	
150 MW	
1500 MW	

**W49TH\_ST\_345KV\_5**

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>300 MW</b>	
360 MW	
660 MW	

**W49TH\_ST\_345KV\_7**

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>300 MW</b>	
360 MW	
660 MW	

**ROCHESTR-PANNELL\_345\_RP2**

Mon 05/18/2026 to Fri 05/22/2026  
0700 Continuous 1500  
Work scheduled by: RGE

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2300 MW</b>	
900 MW	
3200 MW	

**NIAGARA\_345\_230\_AT4**

Tue 05/26/2026 to Sat 05/30/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1900 MW</b>	<b>1200 MW</b>
100 MW	400 MW
2000 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBK\_345KV\_RNS5**

Mon 06/01/2026 to Mon 06/01/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**HUDSONTP-W49TH\_ST\_345\_Y56**

Mon 06/01/2026 to Fri 06/05/2026  
 0600 Continuous 1600  
 Work scheduled by: ConEd

SCH - PJM\_HTP **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_7**

Mon 06/01/2026 to Mon 06/01/2026  
 0600 Continuous 0630  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_8**

Mon 06/01/2026 to Mon 06/01/2026  
 0600 Continuous 0630  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**MARCY\_345KV\_CSC**

Mon 06/01/2026 to Sun 06/14/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

CENTRAL EAST - VC **3650 MW**  
 Impacts Total Transfer Capability 75 MW  
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**LEEDS\_-HURLYAVE\_345\_301**

Mon 06/01/2026 to Fri 07/03/2026  
 0800 Continuous 1600  
 Work scheduled by: CHGE

UPDATED by CHGE 01/16/2026 09:18

UPNY CONED **8120 MW**  
 Impacts Total Transfer Capability 90 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 06/02/2026 to Wed 06/03/2026  
 0600 Continuous 1700  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 06/02/2026 to Wed 06/03/2026  
 0600 Continuous 1700  
 Work scheduled by: ISONE

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3625 MW**  
 100 MW  
 3725 MW

**MOTTHAVN-RAINEY\_345\_Q11**

Thu 06/04/2026 to Sun 06/07/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**W49TH\_ST\_345KV\_7**

Fri 06/05/2026 to Fri 06/05/2026  
 1530 Continuous 1600  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
 360 MW  
 660 MW

**W49TH\_ST\_345KV\_8**

Fri 06/05/2026 to Fri 06/05/2026  
 1530 Continuous 1600  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
 360 MW  
 660 MW

**MAINESBG-WATRCURE\_345\_30**

Wed 06/10/2026 to Fri 06/12/2026  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1600 MW** **1050 MW**  
 600 MW 150 MW  
 2200 MW 1200 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**INGHAM\_C\_115\_115\_PAR 2**

Mon 06/22/2026 to Sat 08/29/2026  
0500 Continuous 1900  
Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3605 MW</b>	
Impacts Total Transfer Capability	120 MW	
TTC with All Lines In Service	3725 MW	

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3625 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3625 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

**DYSINGER-STA\_255\_345\_DH2**

Tue 08/25/2026 to Wed 09/02/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARION\_-FARRAGUT\_345\_C3403**

Sat 09/05/2026 to Sat 09/05/2026  
 0201 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**E13THSTA-FARRAGUT\_345\_45**

Wed 09/09/2026 to Fri 09/11/2026  
 0001 Continuous 1830  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**MARCY\_\_765\_345\_AT1**

Wed 09/09/2026 to Thu 09/10/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1750 MW**  
 1650 MW  
 3400 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Fri 09/11/2026 to Fri 09/11/2026  
 0001 Continuous 1830  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**MARCY\_\_765\_345\_AT2**

Fri 09/11/2026 to Sat 09/12/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**  
 1700 MW  
 3400 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sat 09/12/2026 to Sat 09/26/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**  
 660 MW  
 660 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_7**

Sat 09/12/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**W49TH\_ST\_345KV\_8**

Sat 09/12/2026 to Sat 09/26/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**STLAWRNC-MOSES\_230\_L34P**

Mon 09/14/2026 to Fri 09/18/2026  
 0600 Continuous 1630  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**DUNWODIE\_345KV\_7**

Tue 09/15/2026 to Tue 09/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_8**

Tue 09/15/2026 to Tue 09/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE-MOTTHAVN\_345\_72**

Tue 09/15/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BECK\_\_-NIAGARA\_230\_PA27**

Tue 09/15/2026 to Tue 11/17/2026  
 0500 Continuous 2330  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1900 MW</b>	<b>1650 MW</b>
100 MW	-50 MW
2000 MW	1600 MW

**MARCY\_\_-FRASANX\_345\_UCC2-41**

Tue 09/15/2026 to Tue 09/29/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA  
 ARR: 19

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3225 MW</b>	
500 MW	
3725 MW	

**PLSNTVLY-EFISHKIL\_345\_F37**

Wed 09/16/2026 to Thu 10/22/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd  
UPDATED by ConEd 01/21/2026 13:57

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>8195 MW</b>	
15 MW	
8210 MW	

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Wed 09/16/2026 to Wed 09/16/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd  
UPDATED by ConEd 01/21/2026 13:57

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>7795 MW</b>	
415 MW	
8210 MW	

**DYSINGER-STA\_255\_345\_DH2**

Wed 09/16/2026 to Sat 10/10/2026  
 0500 Continuous 1900  
 Work scheduled by: NYPA

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Fri 09/18/2026 to Fri 09/18/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd  
UPDATED by ConEd 01/21/2026 13:57

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>7795 MW</b>	
415 MW	
8210 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_5**

Sat 09/26/2026 to Thu 12/24/2026  
 0201 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
 360 MW  
 660 MW

**GOETHALS\_345KV\_5**

Mon 09/28/2026 to Sat 10/03/2026  
 0001 Continuous 0300  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**PANNELL\_-CLAY\_\_\_345\_1**

Mon 09/28/2026 to Fri 10/02/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
 950 MW  
 2250 MW

**PANNELL\_-CLAY\_\_\_345\_2**

Mon 10/05/2026 to Fri 10/09/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
 950 MW  
 2250 MW

**DYSINGER-STA\_255\_345\_DH1**

Sun 10/11/2026 to Wed 11/04/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
 350 MW  
 3200 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 10/12/2026 to Thu 10/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 660 MW  
 660 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>NEWBRDGE_345_138_BK_1</b>									
Mon 10/12/2026	to	Thu 10/15/2026		SCH - PJM_NEPTUNE		FWD (Import)		REV (Export)	
0600	Continuous	1600		Impacts Total Transfer Capability		<b>375 MW</b>			
Work scheduled by: LI				TTC with All Lines In Service		660 MW			
<b>NEWBRDGE_345_138_BK_2</b>									
Mon 10/12/2026	to	Thu 10/15/2026		SCH - PJM_NEPTUNE		FWD (Import)		REV (Export)	
0600	Continuous	1600		Impacts Total Transfer Capability		<b>375 MW</b>			
Work scheduled by: LI				TTC with All Lines In Service		660 MW			
<b>NEWBRDGE-DUFFYAVE_345_501</b>									
Mon 10/12/2026	to	Thu 10/15/2026		SCH - PJM_NEPTUNE		FWD (Import)		REV (Export)	
0600	Continuous	1600		Impacts Total Transfer Capability		<b>0 MW</b>			
Work scheduled by: LI				TTC with All Lines In Service		660 MW			
<b>CHATGUAY-MASSENA_765_7040</b>									
Wed 10/14/2026	to	Wed 10/28/2026		SCH - HQ - NY		FWD (Import)		REV (Export)	
0001	Continuous	2359		Impacts Total Transfer Capability		<b>0 MW</b>		<b>0 MW</b>	
Work scheduled by: NYPA				TTC with All Lines In Service		1500 MW		1000 MW	
						1500 MW		1000 MW	
<b>CHATGUAY-MASSENA_765_7040</b>									
Wed 10/14/2026	to	Wed 10/28/2026		MOSES SOUTH		FWD (Import)		REV (Export)	
0001	Continuous	2359		Impacts Total Transfer Capability		<b>1750 MW</b>			
Work scheduled by: NYPA				TTC with All Lines In Service		1650 MW			
						3400 MW			
<b>MARCY__765_345_AT1</b>									
Wed 10/14/2026	to	Wed 10/28/2026		MOSES SOUTH		FWD (Import)		REV (Export)	
0001	Continuous	2359		Impacts Total Transfer Capability		<b>1750 MW</b>			
Work scheduled by: NYPA				TTC with All Lines In Service		1650 MW			
						3400 MW			

ARR: 19

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY\_\_765\_345\_AT2**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1700 MW</b>	
1700 MW	
3400 MW	

**MASSENA\_-MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>475 MW</b>	<b>1000 MW</b>
1025 MW	0 MW
1500 MW	1000 MW

**MASSENA\_-MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2595 MW</b>	
1130 MW	
3725 MW	

**MASSENA\_-MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>190 MW</b>	
80 MW	
270 MW	

**MASSENA\_-MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>500 MW</b>	
2900 MW	
3400 MW	

**MASSENA\_-MARCY\_\_765\_MSU1 , ADIRNDCK-CHASLAKE\_230\_13**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by:

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	
270 MW	
270 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1 , CHASLAKE-PORTER\_\_230\_11**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

SCH - HQ_CEDARS	<b>0 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

MOSES SOUTH	<b>500 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_ADIRNDCK\_230\_MA2**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

SCH - HQ_CEDARS	<b>0 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_WILLIS\_\_230\_MW1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

SCH - HQ_CEDARS	<b>0 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

**WOOD\_ST\_PLSNTVLE\_345\_Y87**

Wed 10/14/2026 to Wed 10/14/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED	<b>7795 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

**WOOD\_ST\_PLSNTVLE\_345\_Y87**

Sat 10/17/2026 to Sat 10/17/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 01/21/2026 13:57

UPNY CONED	<b>7795 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SAND\_BAR-PLATSBRG\_115\_PV20**

Wed 10/21/2026 to Thu 10/22/2026  
 0601 Continuous 1600  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**SAND\_BAR-PLATSBRG\_115\_PV20**

Wed 10/21/2026 to Thu 10/22/2026  
 0601 Continuous 1600  
 Work scheduled by: ISONE

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3625 MW**  
 100 MW  
 3725 MW

**SAND\_BAR-PLATSBRG\_115\_PV20 , MASSENA\_-MARCY\_\_\_765\_MSU1**

Wed 10/21/2026 to Thu 10/22/2026  
 0601 1600  
 Work scheduled by:

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**  
 270 MW  
 270 MW

**ROSETON\_-EFISHKIL\_345\_RFK305**

Mon 10/26/2026 to Fri 11/06/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**7470 MW**  
 740 MW  
 8210 MW

**DUNWODIE\_345KV\_7**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_8**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**STLAWRNC-MOSES\_\_230\_L34P**

Thu 10/29/2026 to Fri 11/13/2026  
 0900 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_5**

Mon 11/02/2026 to Mon 11/02/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 03/11/2026 15:36

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 11/02/2026 to Mon 12/14/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/11/2026 15:36

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_3**

Mon 11/02/2026 to Mon 11/02/2026  
 0230 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by ConEd 03/11/2026 15:36

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Mon 11/02/2026 to Sat 11/07/2026  
 0800 Continuous 1900  
 Work scheduled by: PJM

SCH - PJM\_VFT  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW** **0 MW**  
 315 MW 315 MW  
 315 MW 315 MW

**ROSETON\_EFISHKIL\_345\_RFK305**

Fri 11/06/2026 to Fri 11/13/2026  
 1600 Continuous 1600  
 Work scheduled by: CHGE

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**7470 MW**  
 740 MW  
 8210 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MILLWOOD-EASTVIEW\_345\_W99**

Mon 11/09/2026 to Mon 11/09/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8015 MW</b>	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

**SPRNBRK\_345KV\_RNS5**

Mon 11/09/2026 to Mon 11/09/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**STLAWRNC-MOSES\_230\_L33P**

Mon 11/16/2026 to Fri 11/20/2026  
 0600 Continuous 1630  
 Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**BECK\_\_-NIAGARA\_230\_PA27**

Mon 11/23/2026 to Fri 11/27/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>2050 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

**EDIC\_\_-FRASER\_345\_EF24-40**

Mon 11/30/2026 to Sun 12/06/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3225 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

**DUNWODIE\_345KV\_3**

Fri 12/04/2026 to Fri 12/04/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 03/11/2026 15:36

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

W49TH_ST-E13THSTA_345_M54	FWD (Import)	REV (Export)
Fri 12/04/2026 to Fri 12/04/2026 0101 Continuous 0130 Work scheduled by: ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	<b>3800 MW</b> 800 MW 4600 MW
Thu 12/10/2026 to Thu 12/10/2026 0030 Continuous 0100 Work scheduled by: ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) REV (Export) <b>3800 MW</b> 800 MW 4600 MW
Sat 12/12/2026 to Mon 12/14/2026 0001 Continuous 0200 Work scheduled by: ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) REV (Export) <b>3800 MW</b> 800 MW 4600 MW
Sat 12/12/2026 to Mon 12/14/2026 0001 Continuous 0200 Work scheduled by: ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) REV (Export) <b>3800 MW</b> 800 MW 4600 MW
Wed 12/23/2026 to Wed 12/23/2026 2130 Continuous 2200 Work scheduled by: ConEd	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) REV (Export) <b>8015 MW</b> 195 MW 8210 MW
Wed 12/23/2026 to Wed 12/23/2026 2130 Continuous 2200 Work scheduled by: ConEd	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) REV (Export) <b>3200 MW</b> 1400 MW 4600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HUDSONTP-W49TH\_ST\_345\_Y56**

Fri 12/25/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**W49TH\_ST\_345KV\_8**

Fri 12/25/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**STLAWRNC-MOSES\_230\_L34P**

Fri 12/25/2026 to Fri 12/25/2026  
 0800 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**W49TH\_ST-E13THSTA\_345\_M54**

Sun 12/27/2026 to Sun 12/27/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**W49TH\_ST-E13THSTA\_345\_M54**

Wed 12/30/2026 to Wed 12/30/2026  
 0030 Continuous 0100  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4**

Mon 02/08/2027 to Tue 02/09/2027  
 0001 Continuous 0200  
 Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>SPRNBK_345KV_RNS5</b>		FWD (Import)	REV (Export)
Tue 02/09/2027	to	Fri 02/19/2027	
0201	Continuous	0200	
Work scheduled by: ConEd		SPR/DUN-SOUTH	<b>3200 MW</b>
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
-----			
<b>SPRNBK_-W49TH_ST_345_M51</b>		FWD (Import)	REV (Export)
Tue 02/09/2027	to	Fri 02/19/2027	
0201	Continuous	0200	
Work scheduled by: ConEd		SPR/DUN-SOUTH	<b>3200 MW</b>
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
-----			
<b>BUCHAN_S-MILLWOOD_345_W97</b>		FWD (Import)	REV (Export)
Mon 03/01/2027	to	Wed 03/03/2027	
0001	Continuous	0200	
Work scheduled by: ConEd		UPNY CONED	<b>8175 MW</b>
		Impacts Total Transfer Capability	35 MW
		TTC with All Lines In Service	8210 MW
-----			
<b>SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4</b>		FWD (Import)	REV (Export)
Thu 03/11/2027	to	Sun 03/14/2027	
0001		0100	
Work scheduled by:		SPR/DUN-SOUTH	<b>3800 MW</b>
		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	4600 MW
-----			
<b>SPRNBK_345KV_RNS5</b>		FWD (Import)	REV (Export)
Sun 03/14/2027	to	Wed 03/17/2027	
0101	Continuous	0200	
Work scheduled by: ConEd		SPR/DUN-SOUTH	<b>3200 MW</b>
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW
-----			
<b>SPRNBK_-W49TH_ST_345_M51</b>		FWD (Import)	REV (Export)
Sun 03/14/2027	to	Wed 03/17/2027	
0101	Continuous	0200	
Work scheduled by: ConEd		SPR/DUN-SOUTH	<b>3200 MW</b>
		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

				FWD (Import)	REV (Export)
<b>BUCHAN_S-MILLWOOD_345_W97</b>					
Sun 04/04/2027	to	Sun 04/04/2027	UPNY CONED	<b>8175 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8210 MW	
<hr/>					
<b>BUCHAN_S-MILLWOOD_345_W97</b>					
Sun 04/04/2027	to	Wed 04/07/2027	UPNY CONED	<b>8175 MW</b>	
0201	Continuous	0200	Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8210 MW	
<hr/>					
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					
Mon 05/10/2027	to	Fri 05/14/2027	SCH - PJM_NEPTUNE	<b>0 MW</b>	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
<hr/>					
<b>NEWBRDGE_345_138_BK_1</b>					
Mon 05/10/2027	to	Fri 05/14/2027	SCH - PJM_NEPTUNE	<b>375 MW</b>	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
<hr/>					
<b>NEWBRDGE_345_138_BK_2</b>					
Mon 05/10/2027	to	Fri 05/14/2027	SCH - PJM_NEPTUNE	<b>375 MW</b>	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
<hr/>					
<b>NEWBRDGE-DUFFYAVE_345_501</b>					
Mon 05/10/2027	to	Fri 05/14/2027	SCH - PJM_NEPTUNE	<b>0 MW</b>	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHATGUAY-MASSENA\_765\_7040**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

MOSES SOUTH	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_765\_345\_AT1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_765\_345\_AT2**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	<b>1700 MW</b>	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA-MARCY\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA-MARCY\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

CENTRAL EAST - VC	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Sunday, March 15, 2026 to Tuesday, September 14, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>190 MW</b>	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , ADIRNDCK-CHASLAKE\_230\_13**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 0130  
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>0 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , CHASLAKE-PORTER\_\_230\_11**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 0130  
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>0 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 0130  
 Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_ADIRNDCK\_230\_MA2**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 0130  
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>0 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	270 MW	

