

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 2359
 Work scheduled by:

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2400 MW 2400 MW
 100 MW 250 MW
 2500 MW 2650 MW

SCH-IMO-NYISO_LIMIT_1900

Sat 11/01/2025 to Thu 04/30/2026
 0001 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2200 MW
 300 MW
 2500 MW

HERTELHQ-ASTANNEX_345_G180

Tue 02/10/2026 to Sun 05/31/2026
 1121 Continuous 2359
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:34

SCH - HQ_CHPE
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
 1250 MW
 1250 MW

DYSINGER-BYRON_345_DB2

Tue 02/10/2026 to Tue 04/21/2026
 1122 Continuous 0459
 Work scheduled by: NYISO

FORCED by NYISO 04/14/2026 16:02

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
 350 MW
 3200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-BYRON__345_DB2 , DYSINGER-GRAHAM__345_DG1

Tue 02/10/2026 to Tue 04/21/2026
 1122 0459
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

DYSINGER-BYRON__345_DB2 , GRAHAM__STA_255_345_GH1-43

Tue 02/10/2026 to Tue 04/21/2026
 1122 0459
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

DYSINGER-GRAHAM__345_DG1

Tue 02/10/2026 to Sun 05/31/2026
 1122 Continuous 2100
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

GRAHAM__STA_255_345_GH1-43

Tue 02/10/2026 to Sun 05/31/2026
 1122 Continuous 2100
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

STA_255_-BYRON__345_BH2-50

Tue 02/10/2026 to Tue 04/21/2026
 1122 Continuous 0459
 Work scheduled by: NYISO

FORCED by NYISO 04/14/2026 16:02

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
 350 MW
 3200 MW

STA_255_-BYRON__345_BH2-50 , DYSINGER-GRAHAM__345_DG1

Tue 02/10/2026 to Tue 04/21/2026
 1122 0459
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STA_255_BYRON_345_BH2-50 , GRAHAM_-STA_255_345_GH1-43				
Tue 02/10/2026	to	Tue 04/21/2026	DYSINGER EAST	FWD (Import) REV (Export)
1122		0459	Impacts Total Transfer Capability	
Work scheduled by:			TTC with All Lines In Service	
NRTH1385-NOR HBR_138_601				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import) REV (Export)
0600	Continuous	1500	Impacts Total Transfer Capability	60 MW 60 MW
Work scheduled by: LI			TTC with All Lines In Service	100 MW 100 MW
				160 MW 160 MW
NRTH1385-NOR HBR_138_602				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import) REV (Export)
0600	Continuous	1500	Impacts Total Transfer Capability	60 MW 60 MW
Work scheduled by: LI			TTC with All Lines In Service	100 MW 100 MW
				160 MW 160 MW
NRTH1385-NOR HBR_138_603				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import) REV (Export)
0600	Continuous	1500	Impacts Total Transfer Capability	60 MW 60 MW
Work scheduled by: LI			TTC with All Lines In Service	100 MW 100 MW
				160 MW 160 MW
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import) REV (Export)
0600		1500	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	160 MW 160 MW
				160 MW 160 MW
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603				
Thu 02/26/2026	to	Fri 05/15/2026	SCH - NPX_1385	FWD (Import) REV (Export)
0600		1500	Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	160 MW 160 MW
				160 MW 160 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603

Thu 02/26/2026 to Fri 05/15/2026
 0600 1500
 Work scheduled by:

SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	160 MW	160 MW
TTC with All Lines In Service	160 MW	160 MW

NRTH1385-NRTHPORT_138_NNC

Thu 02/26/2026 to Fri 05/15/2026
 0600 Continuous 1500
 Work scheduled by: LI

SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	160 MW	160 MW
TTC with All Lines In Service	160 MW	160 MW

MARCY__FRASANX_345_UCC2-41

Thu 03/26/2026 to Sat 05/02/2026
 2101 Continuous 0800
 Work scheduled by: NYISO

ARR: 19

CENTRAL EAST - VC	3225 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

WOOD_ST_PLSNTVLE_345_Y86

Mon 03/30/2026 to Sun 04/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/30/2026 11:34

UPNY CONED	7820 MW	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	8210 MW	

OSWEGO_COMPLEX_AVR_O/S

Sat 04/04/2026 to Sun 09/13/2026
 0800 Continuous 0000
 Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC	3640 MW	
Impacts Total Transfer Capability	85 MW	
TTC with All Lines In Service	3725 MW	

WATRCURE-OAKDALE_345_31

Wed 04/15/2026 to Fri 05/15/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

EXTENDED by NYSEG 04/09/2026 10:23

SCH - PJ - NY	2400 MW	2400 MW
Impacts Total Transfer Capability	100 MW	250 MW
TTC with All Lines In Service	2500 MW	2650 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-PJM-NYISO_LIMIT_1500

Fri 04/17/2026 to Fri 05/15/2026
 0001 Continuous 1500
 Work scheduled by: NYSEG

EXTENDED by NYSEG 04/09/2026 10:23

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
1800 MW	
700 MW	
2500 MW	

SCH-NYISO-HQ_CEDARS_LIMIT_0

Fri 04/17/2026 to Mon 04/27/2026
 1900 Continuous 1700
 Work scheduled by: HQ

EXT FORCED by HQ 04/20/2026 16:32

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
	0 MW
	100 MW
	100 MW

W49TH_ST_345KV_5

Sat 04/18/2026 to Tue 05/05/2026
 0021 Continuous 2359
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
175 MW	
485 MW	
660 MW	

W49TH_ST_345KV_7

Sat 04/18/2026 to Tue 05/05/2026
 0021 Continuous 2359
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
175 MW	
485 MW	
660 MW	

HOMRC_NY-MAINS_NY_345_47

Sat 04/18/2026 to Fri 04/24/2026
 1440 Continuous 2359
 Work scheduled by: PJM

FORCED by PJM 04/20/2026 11:37

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
2400 MW	2400 MW
100 MW	250 MW
2500 MW	2650 MW

SCH-IMO-NYISO_LIMIT_1700

Sun 04/19/2026 to Fri 05/01/2026
 0630 Continuous 1600
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import)	REV (Export)
2000 MW	
500 MW	
2500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1400

Sun 04/19/2026 to Fri 05/01/2026
 0630 Continuous 1600
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1700 MW
 150 MW
 1850 MW

SPRNBK_-UNIONHBS_345_Y49

Mon 04/20/2026 to Sun 05/03/2026
 0101 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
775 MW
 725 MW
 1500 MW

UNIONDHB_345_138_AT1

Mon 04/20/2026 to Sun 05/03/2026
 0101 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

UNIONDHB_345_138_AT2

Mon 04/20/2026 to Sun 05/03/2026
 0101 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

SCH-NYISO-HQ_LIMIT_700

Mon 04/20/2026 to Tue 04/21/2026
 0500 Continuous 1900
 Work scheduled by: HQ

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
700 MW
 300 MW
 1000 MW

BECK_-NIAGARA_345_PA302

Mon 04/20/2026 to Thu 04/23/2026
 0700 Continuous 2100
 Work scheduled by: IESO

EXTENDED by IESO 04/21/2026 16:46

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1150 MW 1000 MW
 1350 MW 850 MW
 2500 MW 1850 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_500

Mon 04/20/2026 to Thu 04/23/2026
 0700 Continuous 2100
 Work scheduled by: IESO

EXTENDED by IESO 04/21/2026 16:46

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
800 MW
 1700 MW
 2500 MW

DYSINGER-BYRON__345_DB2

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
 350 MW
 3200 MW

DYSINGER-BYRON__345_DB2 , DYSINGER-GRAHAM__345_DG1

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 350 MW
 3200 MW

DYSINGER-BYRON__345_DB2 , GRAHAM__STA_255__345_GH1-43

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 350 MW
 3200 MW

STA_255_-BYRON__345_BH2-50

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
 350 MW
 3200 MW

STA_255_-BYRON__345_BH2-50 , DYSINGER-GRAHAM__345_DG1

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
 350 MW
 3200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STA_255_BYRON_345_BH2-50 , GRAHAM_STA_255_345_GH1-43

Tue 04/21/2026 to Sun 05/03/2026
 0500 2100
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

SCH-HQ_CEDARS-NYISO_LIMIT_220

Tue 04/21/2026 to Mon 04/27/2026
 1900 Continuous 1700
 Work scheduled by: HQ

EXT FORCED by HQ 04/20/2026 16:32

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

220 MW
 59 MW
 279 MW

SCH-NYISO-IMO_NIAGARA_CB_3102

Wed 04/22/2026 to Wed 04/22/2026
 0500 Continuous 1600
 Work scheduled by: NYPA

CANCELLED by TO 04/21/2026 16:42

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

2300 MW **1700 MW**
 200 MW 150 MW
 2500 MW 1850 MW

SCH-NYISO-IMO_NIAGARA_CB_3108

Thu 04/23/2026 to Thu 04/23/2026
 0500 Continuous 1600
 Work scheduled by: NYPA

CANCELLED by TO 04/21/2026 16:42

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

2450 MW **1750 MW**
 50 MW 100 MW
 2500 MW 1850 MW

BECK_NIAGARA_230_PA27

Thu 04/23/2026 to Thu 04/23/2026
 0900 Continuous 1700
 Work scheduled by: IESO

CANCELLED by TO 04/21/2026 16:38

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

2050 MW
 450 MW
 2500 MW

BECK_NIAGARA_230_PA27 , BECK_NIAGARA_345_PA302

Thu 04/23/2026 to Thu 04/23/2026
 0900 1700
 Work scheduled by:

WESTERN_NY_EXPORT
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

1100 MW
 1200 MW
 2300 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1500

Thu 04/23/2026 to Thu 04/23/2026
0900 Continuous 1600
Work scheduled by: NYPA

CANCELLED by TO 04/21/2026 16:42

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1800 MW	
700 MW	
2500 MW	

SCH-NYISO-IMO_LIMIT_1300

Thu 04/23/2026 to Thu 04/23/2026
0900 Continuous 1600
Work scheduled by: NYPA

CANCELLED by TO 04/21/2026 16:42

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1600 MW	
250 MW	
1850 MW	

DUNWODIE_345KV_3

Fri 04/24/2026 to Fri 04/24/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

DUNWODIE_345KV_4

Fri 04/24/2026 to Fri 04/24/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

BECK__-NIAGARA_230_PA27

Fri 04/24/2026 to Fri 04/24/2026
1000 Continuous 1300
Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2050 MW	
450 MW	
2500 MW	

BECK__-NIAGARA_345_PA301

Mon 04/27/2026 to Fri 05/01/2026
0630 Continuous 1600
Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1150 MW	1000 MW
1350 MW	850 MW
2500 MW	1850 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PIERCBRK-FIVEMILE_345_37

Tue 04/28/2026 to Wed 05/13/2026
 0800 Continuous 1600
 Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	2300 MW	2300 MW
Impacts Total Transfer Capability	200 MW	350 MW
TTC with All Lines In Service	2500 MW	2650 MW

DUNWODIE_345KV_3

Sat 05/02/2026 to Sat 05/02/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_4

Sat 05/02/2026 to Sat 05/02/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

SCH-NYISO-HQ_LIMIT_0

Sat 05/02/2026 to Sat 05/02/2026
 0500 Continuous 2000
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		0 MW
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1000 MW

CHAT_DC_GC1

Sun 05/03/2026 to Wed 05/06/2026
 0100 Continuous 2000
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 05/03/2026 to Wed 05/06/2026
 0100 Continuous 2000
 Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	1370 MW	0 MW
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	to	Work Scheduled	Impacts	FWD (Import)	REV (Export)
<hr style="border-top: 1px dashed black;"/>					
CHAT_DC_GC2					
Sun 05/03/2026	to	Wed 05/06/2026	SCH - HQ - NY		
0100	Continuous	2000	Impacts Total Transfer Capability		500 MW
Work scheduled by: HQ			TTC with All Lines In Service		1000 MW
<hr style="border-top: 1px dashed black;"/>					
CHATGUAY-MASSENA_765_7040					
Sun 05/03/2026	to	Wed 05/06/2026	SCH - HQ - NY		
0100	Continuous	0200	Impacts Total Transfer Capability	0 MW	0 MW
Work scheduled by: NYPA			TTC with All Lines In Service	1500 MW	1000 MW
				1500 MW	1000 MW
<hr style="border-top: 1px dashed black;"/>					
CHATGUAY-MASSENA_765_7040					
Sun 05/03/2026	to	Wed 05/06/2026	MOSES SOUTH		
0100	Continuous	0200	Impacts Total Transfer Capability	1750 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	1650 MW	
				3400 MW	
<hr style="border-top: 1px dashed black;"/>					
DUNWODIE_345KV_7					
Sun 05/03/2026	to	Sun 05/03/2026	SPR/DUN-SOUTH		
0100	Continuous	0200	Impacts Total Transfer Capability	3800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	800 MW	
				4600 MW	
<hr style="border-top: 1px dashed black;"/>					
SCH-HQ-NYISO_LIMIT_900					
Sun 05/03/2026	to	Wed 05/06/2026	SCH - HQ - NY		
0100	Continuous	2000	Impacts Total Transfer Capability	900 MW	
Work scheduled by: HQ			TTC with All Lines In Service	600 MW	
				1500 MW	
<hr style="border-top: 1px dashed black;"/>					
SCH-NYISO-HQ_LIMIT_0					
Sun 05/03/2026	to	Wed 05/06/2026	SCH - HQ - NY		
0100	Continuous	2000	Impacts Total Transfer Capability		0 MW
Work scheduled by: HQ			TTC with All Lines In Service		1000 MW
					1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC

Sun 05/03/2026 to Fri 05/15/2026
0700 Continuous 1800
Work scheduled by: ISONE

UPDATED by ISONE 02/18/2026 11:51

SCH - NPX_CSC

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
330 MW	330 MW
330 MW	330 MW

MILLWOOD-EASTVIEW_345_W82

Mon 05/04/2026 to Mon 05/04/2026
0001 Continuous 2200
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
8015 MW	
195 MW	
8210 MW	

SPRNBK_345KV_RNS4

Mon 05/04/2026 to Mon 05/04/2026
0001 Continuous 0030
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3200 MW	
1400 MW	
4600 MW	

BECK__-NIAGARA_230_PA27

Mon 05/04/2026 to Fri 05/08/2026
0900 Continuous 1700
Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1900 MW	
100 MW	
2000 MW	

SPRNBK_345KV_RNS4

Mon 05/04/2026 to Mon 05/04/2026
2130 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3200 MW	
1400 MW	
4600 MW	

RAMAPO_-BUCHAN_N_345_Y94

Tue 05/05/2026 to Tue 05/05/2026
0031 Continuous 2359
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
7795 MW	
415 MW	
8210 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__FRASANNX_345_UCC2-41				
Wed 05/06/2026	to	Fri 05/29/2026	CENTRAL EAST - VC	FWD (Import) REV (Export)
0700	Continuous	1530	Impacts Total Transfer Capability	3225 MW 500 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW

HOPATCON-RAMAPO__500_5018				
Thu 05/07/2026	to	Sat 05/09/2026	SCH - PJ - NY	FWD (Import) REV (Export)
0001	Continuous	1800	Impacts Total Transfer Capability	1000 MW 1050 MW
Work scheduled by: ConEd			TTC with All Lines In Service	1200 MW 150 MW

HOPATCON-RAMAPO__500_5018				
Thu 05/07/2026	to	Sat 05/09/2026	UPNY CONED	FWD (Import) REV (Export)
0001	Continuous	1800	Impacts Total Transfer Capability	8015 MW 195 MW
Work scheduled by: ConEd			TTC with All Lines In Service	8210 MW

HOPATCON-RAMAPO__500_5018				
Thu 05/07/2026	to	Sat 05/09/2026	TOTAL EAST	FWD (Import) REV (Export)
0001	Continuous	1800	Impacts Total Transfer Capability	6800 MW 750 MW
Work scheduled by: ConEd			TTC with All Lines In Service	7550 MW

RAMAPO__345_345_PAR3500				
Thu 05/07/2026	to	Sat 05/09/2026	SCH - PJ - NY	FWD (Import) REV (Export)
0001	Continuous	1800	Impacts Total Transfer Capability	1350 MW 1050 MW
Work scheduled by: ConEd			TTC with All Lines In Service	850 MW 150 MW

RAMAPO__345_345_PAR4500				
Thu 05/07/2026	to	Sat 05/09/2026	SCH - PJ - NY	FWD (Import) REV (Export)
0001	Continuous	1800	Impacts Total Transfer Capability	1350 MW 1050 MW
Work scheduled by: ConEd			TTC with All Lines In Service	850 MW 150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__500_345_BK_1500

Thu 05/07/2026 to Sat 05/09/2026
 0001 Continuous 1800
 Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	1000 MW	1050 MW
Impacts Total Transfer Capability	1200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

RAMAPO__500_345_BK_1500

Thu 05/07/2026 to Sat 05/09/2026
 0001 Continuous 1800
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8015 MW	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

RAMAPO_-BUCHAN_N_345_Y94

Sat 05/09/2026 to Sat 05/09/2026
 1930 Continuous 2000
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7795 MW	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

BECK__-PACKARD_230_BP76

Sun 05/10/2026 to Fri 05/15/2026
 0530 Continuous 1600
 Work scheduled by: IESO

UPDATED by NGrid 04/20/2026 11:53

SCH - OH - NY	FWD (Import)	REV (Export)
	1600 MW	1050 MW
Impacts Total Transfer Capability	400 MW	550 MW
TTC with All Lines In Service	2000 MW	1600 MW

FIVEMILE-LIMELAKE_345_49

Mon 05/11/2026 to Thu 06/25/2026
 0500 Continuous 1800
 Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	2000 MW	1050 MW
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

LIMELAKE-ESTOLERD_345_29

Mon 05/11/2026 to Thu 06/25/2026
 0500 Continuous 1800
 Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	2000 MW	1050 MW
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_345_230_AT4

Mon 05/11/2026 to Sat 05/30/2026
 0500 Continuous 1900
 Work scheduled by: NYPA

	SCH - OH - NY	FWD (Import)	REV (Export)
		1900 MW	1200 MW
	Impacts Total Transfer Capability	100 MW	400 MW
	TTC with All Lines In Service	2000 MW	1600 MW

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026
 0600 Continuous 1600
 Work scheduled by: LI
CANCELLED by TO 04/20/2026 11:47

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		0 MW	
	Impacts Total Transfer Capability	660 MW	
	TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

Mon 05/11/2026 to Fri 05/15/2026
 0600 Continuous 1600
 Work scheduled by: LI
CANCELLED by TO 04/20/2026 11:47

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		375 MW	
	Impacts Total Transfer Capability	285 MW	
	TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_2

Mon 05/11/2026 to Fri 05/15/2026
 0600 Continuous 1600
 Work scheduled by: LI
CANCELLED by TO 04/20/2026 11:47

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		375 MW	
	Impacts Total Transfer Capability	285 MW	
	TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 05/11/2026 to Fri 05/15/2026
 0600 Continuous 1600
 Work scheduled by: LI
CANCELLED by TO 04/20/2026 11:47

	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
		0 MW	
	Impacts Total Transfer Capability	660 MW	
	TTC with All Lines In Service	660 MW	

DYSINGER-STA_255_345_DH1

Tue 05/12/2026 to Sun 05/31/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

	DYSINGER EAST	FWD (Import)	REV (Export)
		2850 MW	
	Impacts Total Transfer Capability	350 MW	
	TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Thu 05/14/2026 to Thu 05/14/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

	UPNY CONED	8015 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	195 MW		
	TTC with All Lines In Service	8210 MW		

SPRNBRK_345KV_RNS3

Thu 05/14/2026 to Thu 05/14/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

	SPR/DUN-SOUTH	3800 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	800 MW		
	TTC with All Lines In Service	4600 MW		

SPRNBRK_345KV_RNS3

Thu 05/14/2026 to Thu 05/14/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

	SPR/DUN-SOUTH	3800 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	800 MW		
	TTC with All Lines In Service	4600 MW		

MILLWOOD-EASTVIEW_345_W99

Fri 05/15/2026 to Sat 05/16/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

	UPNY CONED	8015 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	195 MW		
	TTC with All Lines In Service	8210 MW		

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

	SCH - PJM_HTP	300 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	360 MW		
	TTC with All Lines In Service	660 MW		

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

	SCH - PJM_HTP	300 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	360 MW		
	TTC with All Lines In Service	660 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_345KV_RNS5

Fri 05/15/2026 to Fri 05/15/2026
 0201 Continuous 0230
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

SPRNBRK_-W49TH_ST_345_M51

Fri 05/15/2026 to Mon 06/01/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_5

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4	FWD (Import)	REV (Export)
Sat 05/16/2026 to Thu 05/28/2026 0201 Continuous 0200 Work scheduled by: ConEd	<u>UPDATED by ConEd 03/01/2026 10:07</u> SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	3800 MW 800 MW 4600 MW
Sat 05/16/2026 to Thu 05/28/2026 0201 Continuous 0200 Work scheduled by: ConEd	<u>UPDATED by ConEd 03/01/2026 10:07</u> SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	3800 MW 800 MW 4600 MW
Sat 05/16/2026 to Thu 05/28/2026 0201 Continuous 0200 Work scheduled by: ConEd	<u>UPDATED by ConEd 03/01/2026 10:07</u> CONED - LIPA Impacts Total Transfer Capability TTC with All Lines In Service	800 MW 700 MW 1500 MW
Sat 05/16/2026 to Thu 05/28/2026 0201 Continuous 0200 Work scheduled by: ConEd	<u>UPDATED by ConEd 03/01/2026 10:07</u> CONED - LIPA Impacts Total Transfer Capability TTC with All Lines In Service	1350 MW 150 MW 1500 MW
Sat 05/16/2026 to Thu 05/28/2026 0201 Continuous 0200 Work scheduled by: ConEd	<u>UPDATED by ConEd 03/01/2026 10:07</u> CONED - LIPA Impacts Total Transfer Capability TTC with All Lines In Service	1350 MW 150 MW 1500 MW
Mon 05/18/2026 to Mon 05/18/2026 0030 Continuous 0100 Work scheduled by: ConEd	SCH - PJM_HTP Impacts Total Transfer Capability TTC with All Lines In Service	300 MW 360 MW 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Mon 05/18/2026 to Mon 05/18/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

BEAR SWP-EASTOVER_230_E205W

Mon 05/18/2026 to Sat 05/23/2026
 0630 Continuous 1800
 Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

ROCHESTR-PANNELL_345_RP2

Mon 05/18/2026 to Fri 05/22/2026
 0700 Continuous 1500
 Work scheduled by: RGE

DYSINGER EAST

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
 900 MW
 3200 MW

GOETHALS_345KV_5

Sun 05/24/2026 to Sat 05/30/2026
 0001 Continuous 0300
 Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

SPRNBK_345KV_RNS5

Mon 06/01/2026 to Mon 06/01/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
 1400 MW
 4600 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 06/01/2026 to Fri 06/05/2026
 0600 Continuous 1600
 Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
 660 MW
 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Mon 06/01/2026 to Mon 06/01/2026
0600 Continuous 0630
Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import) REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_8

Mon 06/01/2026 to Mon 06/01/2026
0600 Continuous 0630
Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import) REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

MARCY__345KV_CSC

Mon 06/01/2026 to Sun 06/14/2026
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import) REV (Export)

3650 MW

Impacts Total Transfer Capability

75 MW

TTC with All Lines In Service

3725 MW

LEEDS__HURLYAVE_345_301

Mon 06/01/2026 to Fri 07/03/2026
0800 Continuous 1600
Work scheduled by: CHGE

UPDATED by CHGE 01/16/2026 09:18

UPNY CONED

FWD (Import) REV (Export)

8120 MW

Impacts Total Transfer Capability

90 MW

TTC with All Lines In Service

8210 MW

SAND_BAR-PLATSBRG_115_PV20

Tue 06/02/2026 to Wed 06/03/2026
0600 Continuous 1700
Work scheduled by: ISONE

CANCELLED by TO 04/17/2026 12:44

SCH - NE - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

SAND_BAR-PLATSBRG_115_PV20

Tue 06/02/2026 to Wed 06/03/2026
0600 Continuous 1700
Work scheduled by: ISONE

CANCELLED by TO 04/17/2026 12:44

CENTRAL EAST - VC

FWD (Import) REV (Export)

3625 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY__345_Q11

Thu 06/04/2026 to Sun 06/07/2026
0001 Continuous 0200
Work scheduled by: ConEd

EXTENDED by ConEd 04/20/2026 11:31

SPR/DUN-SOUTH

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

W49TH_ST_345KV_7

Fri 06/05/2026 to Fri 06/05/2026
1530 Continuous 1600
Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
300 MW	
360 MW	
660 MW	

W49TH_ST_345KV_8

Fri 06/05/2026 to Fri 06/05/2026
1530 Continuous 1600
Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
300 MW	
360 MW	
660 MW	

MAINESBG-WATRCURE_345_30

Wed 06/10/2026 to Fri 06/12/2026
0700 Continuous 1500
Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1600 MW	1050 MW
600 MW	150 MW
2200 MW	1200 MW

INGHAM_C_115_115_PAR 2

Mon 06/22/2026 to Sat 08/29/2026
0500 Continuous 1900
Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3605 MW	
120 MW	
3725 MW	

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
0900 Continuous 1630
Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

CENTRAL EAST - VC
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

CENTRAL EAST - VC
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

FIVEMILE-LIMELAKE_345_49

Thu 07/09/2026 to Fri 10/02/2026
 0700 Continuous 1700
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability 200 MW 150 MW
 TTC with All Lines In Service 2200 MW 1200 MW

FWD (Import) REV (Export)

LIMELAKE-ESTOLERD_345_29

Thu 07/09/2026 to Fri 10/02/2026
 0700 Continuous 1700
 Work scheduled by: NGrid

SCH - PJ - NY
 Impacts Total Transfer Capability 200 MW 150 MW
 TTC with All Lines In Service 2200 MW 1200 MW

FWD (Import) REV (Export)

GOETHALS_345KV_5

Sat 08/15/2026 to Sat 08/15/2026
 0301 Continuous 0330
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Mon 08/17/2026 to Mon 08/17/2026
0630 Continuous 0700
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Sat 09/05/2026 to Sat 09/05/2026
0201 Continuous 2359
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

E13THSTA-FARRAGUT_345_45

Wed 09/09/2026 to Fri 09/11/2026
0001 Continuous 1830
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

MARCY__765_345_AT1

Wed 09/09/2026 to Thu 09/10/2026
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1750 MW
1650 MW
3400 MW

W49TH_ST-E13THSTA_345_M54

Fri 09/11/2026 to Fri 09/11/2026
0001 Continuous 1830
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

MARCY__765_345_AT2

Fri 09/11/2026 to Sat 09/12/2026
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1700 MW
1700 MW
3400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP	0 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_7

Sat 09/12/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP	300 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP	300 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

DUNWODIE_345KV_7

Mon 09/14/2026 to Tue 09/15/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	3800 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_8

Mon 09/14/2026 to Tue 09/15/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	3800 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE-MOTTHAVN_345_72

Mon 09/14/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	3800 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES__230_L34P

Mon 09/14/2026 to Fri 09/18/2026
 0600 Continuous 1630
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

BECK__-NIAGARA_230_PA27

Tue 09/15/2026 to Tue 11/17/2026
 0500 Continuous 2330
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

1900 MW
 100 MW
 2000 MW

MARCY__-FRASANX_345_UCC2-41

Tue 09/15/2026 to Tue 09/29/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

3225 MW
 500 MW
 3725 MW

W49TH_ST_345KV_5

Sat 09/26/2026 to Thu 12/24/2026
 0201 Continuous 2359
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

300 MW
 360 MW
 660 MW

GOETHALS_345KV_5

Mon 09/28/2026 to Sat 10/03/2026
 0001 Continuous 0300
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

PANNELL_-CLAY__345_1

Mon 09/28/2026 to Fri 10/02/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

1300 MW
 950 MW
 2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_345_2

Mon 10/05/2026 to Fri 10/09/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH1

Sun 10/11/2026 to Wed 11/04/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/12/2026 to Fri 10/16/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NEWBRDGE_345_138_BK_1

Mon 10/12/2026 to Fri 10/16/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NEWBRDGE_345_138_BK_2

Mon 10/12/2026 to Fri 10/16/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NEWBRDGE-DUFFYAVE_345_501

Mon 10/12/2026 to Fri 10/16/2026
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	1750 MW	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY_765_345_AT1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1750 MW	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY_765_345_AT2

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1700 MW	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

MASSENA -MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA -MARCY_765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2595 MW	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ_CEDARS **190 MW**
Impacts Total Transfer Capability 80 MW
TTC with All Lines In Service 270 MW

FWD (Import) REV (Export)

MASSENA_MARCY__765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2900 MW
TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
0001 2359
Work scheduled by:

MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2900 MW
TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Wed 10/21/2026 to Thu 10/22/2026
0601 Continuous 1600
Work scheduled by: ISONE

CANCELLED by TO 04/17/2026 12:46

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Wed 10/21/2026 to Thu 10/22/2026
0601 Continuous 1600
Work scheduled by: ISONE

CANCELLED by TO 04/17/2026 12:46

CENTRAL EAST - VC **3625 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

ROSETON_EFISHKIL_345_RFK305

Mon 10/26/2026 to Fri 11/06/2026
0700 Continuous 1530
Work scheduled by: NYPA

UPNY CONED **7470 MW**
Impacts Total Transfer Capability 740 MW
TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_8

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

STLAWRNC-MOSES_230_L34P

Thu 10/29/2026 to Fri 11/13/2026
 0900 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

DUNWODIE_345KV_3

Mon 11/02/2026 to Mon 11/02/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_5

Mon 11/02/2026 to Mon 11/02/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE-MOTTHAVN_345_71

Mon 11/02/2026 to Mon 12/14/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT__345_V-3022

Mon 11/02/2026 to Sat 11/07/2026
0800 Continuous 1900
Work scheduled by: PJM

SCH - PJM_VFT	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

ROSETON_EFISHKIL_345_RFK305

Fri 11/06/2026 to Fri 11/13/2026
1600 Continuous 1600
Work scheduled by: CHGE

UPNY CONED	FWD (Import)	REV (Export)
	7470 MW	
Impacts Total Transfer Capability	740 MW	
TTC with All Lines In Service	8210 MW	

MILLWOOD-EASTVIEW_345_W99

Mon 11/09/2026 to Mon 11/09/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8015 MW	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

SPRNBK_345KV_RNS5

Mon 11/09/2026 to Mon 11/09/2026
0001 Continuous 0030
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

BUCHAN_S-MILLWOOD_345_W97

Mon 11/16/2026 to Sat 11/28/2026
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8175 MW	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

BUCHAN_S-MILLWOOD_345_W98

Mon 11/16/2026 to Sat 11/28/2026
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	8175 MW	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LOVETT_-BUCHAN_S_345_Y88

Mon 11/16/2026 to Sat 11/28/2026
0001 Continuous 2330
Work scheduled by: ConEd

UPNY CONED **7960 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

STLAWRNC-MOSES__230_L33P

Mon 11/16/2026 to Fri 11/20/2026
0600 Continuous 1630
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

BECK_-NIAGARA_230_PA27

Mon 11/23/2026 to Fri 11/27/2026
0630 Continuous 1600
Work scheduled by: IESO

SCH - OH - NY **2050 MW**
Impacts Total Transfer Capability 450 MW
TTC with All Lines In Service 2500 MW

FWD (Import) REV (Export)

EDIC_-FRASER_345_EF24-40

Mon 11/30/2026 to Sun 12/06/2026
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC **3225 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_3

Fri 12/04/2026 to Fri 12/04/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

W49TH_ST-E13THSTA_345_M54

Fri 12/04/2026 to Fri 12/04/2026
0101 Continuous 0130
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Thu 12/10/2026 to Thu 12/10/2026
0030 Continuous 0100
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_3

Sat 12/12/2026 to Mon 12/14/2026
0001 Continuous 0200 UPDATED by ConEd 03/27/2026 13:56
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_5

Sat 12/12/2026 to Mon 12/14/2026
0001 Continuous 0200 UPDATED by ConEd 03/27/2026 13:56
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

MILLWOOD-EASTVIEW_345_W99

Wed 12/23/2026 to Wed 12/23/2026
2130 Continuous 2200
Work scheduled by: ConEd

UPNY CONED **8015 MW**
Impacts Total Transfer Capability 195 MW
TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

SPRNBK_345KV_RNS5

Wed 12/23/2026 to Wed 12/23/2026
2130 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

HUDSONTP-W49TH_ST_345_Y56

Fri 12/25/2026 to Tue 01/12/2027
0001 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Fri 12/25/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

STLAWRNC-MOSES__230_L34P

Fri 12/25/2026 to Fri 12/25/2026
 0800 Continuous 1600
 Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

W49TH_ST-E13THSTA_345_M54

Sun 12/27/2026 to Sun 12/27/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST-E13THSTA_345_M54

Wed 12/30/2026 to Wed 12/30/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Mon 02/08/2027 to Tue 02/09/2027
 0001 Continuous 0200
 Work scheduled by:

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

SPRNBK_345KV_RNS5

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_W49TH_ST_345_M51

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

BUCHAN_S-MILLWOOD_345_W97

Mon 03/01/2027 to Wed 03/03/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED **8175 MW**
 Impacts Total Transfer Capability 35 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Thu 03/11/2027 to Sun 03/14/2027
 0001 0100
 Work scheduled by:

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

SPRNBK_345KV_RNS5

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

SPRNBK_W49TH_ST_345_M51

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Sun 04/04/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED **8175 MW**
 Impacts Total Transfer Capability 35 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Wed 04/07/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED	8175 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	0 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	375 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_2

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	375 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	0 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

SCH - HQ - NY	0 MW	FWD (Import) REV (Export)
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

	MOSES SOUTH	1750 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	1650 MW		
	TTC with All Lines In Service	3400 MW		

MARCY_765_345_AT1

Tue 05/25/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

ARR: 19

	MOSES SOUTH	1750 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	1650 MW		
	TTC with All Lines In Service	3400 MW		

MARCY_765_345_AT2

Tue 05/25/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

ARR: 19

	MOSES SOUTH	1700 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	1700 MW		
	TTC with All Lines In Service	3400 MW		

MASSENA -MARCY_765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

	SCH - HQ - NY	475 MW	1000 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	1025 MW	0 MW		
	TTC with All Lines In Service	1500 MW	1000 MW		

MASSENA -MARCY_765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

	CENTRAL EAST - VC	2595 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	1130 MW		
	TTC with All Lines In Service	3725 MW		

MASSENA -MARCY_765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

	SCH - HQ_CEDARS	190 MW	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	80 MW		
	TTC with All Lines In Service	270 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

BUCHAN_S-MILLWOOD_345_W97

Mon 09/20/2027 to Mon 09/20/2027
 0001 Continuous 0030
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	8175 MW	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

BUCHAN_S-MILLWOOD_345_W97

Tue 09/21/2027 to Tue 09/21/2027
 0130 Continuous 0200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	8175 MW	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

WOOD_ST_PLSNTVLE_345_Y87

Mon 10/04/2027 to Sat 10/16/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	7795 MW	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

SPRNBRK_UNIONHBS_345_Y49

Mon 10/04/2027 to Fri 05/26/2028
 0800 Continuous 1530
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CONED - LIPA	775 MW	
Impacts Total Transfer Capability	725 MW	
TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 21, 2026 to Wednesday, October 20, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

UNIONDHB_345_138_AT1

Mon 10/04/2027 to Fri 05/26/2028
 0800 Continuous 1530
 Work scheduled by: NYPA

CONED - LIPA	FWD (Import)	REV (Export)
	1250 MW	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

UNIONDHB_345_138_AT2

Mon 10/04/2027 to Fri 05/26/2028
 0800 Continuous 1530
 Work scheduled by: NYPA

CONED - LIPA	FWD (Import)	REV (Export)
	1250 MW	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_2

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	