

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 Continuous 2359  
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 Continuous 2359  
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 2359  
 Work scheduled by:

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)  
**2400 MW    2400 MW**  
 100 MW    250 MW  
 2500 MW    2650 MW

**SCH-IMO-NYISO\_LIMIT\_1900**

Sat 11/01/2025 to Thu 04/30/2026  
 0001 Continuous 2359  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)  
**2200 MW**  
 300 MW  
 2500 MW

**HERTELHQ-ASTANNEX\_345\_G180**

Tue 02/10/2026 to Sun 05/31/2026  
 1121 Continuous 2359  
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:34

SCH - HQ\_CHPE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)  
**0 MW**  
 1250 MW  
 1250 MW

**DYSINGER-GRAHAM\_345\_DG1**

Tue 02/10/2026 to Sun 05/31/2026  
 1122 Continuous 2100  
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**GRAHAM \_STA\_255\_345\_GH1-43**

Tue 02/10/2026 to Sun 05/31/2026  
 1122 Continuous 2100  
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**NRTH1385-NOR HBR\_138\_601**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**60 MW    60 MW**  
 100 MW    100 MW  
 160 MW    160 MW

**NRTH1385-NOR HBR\_138\_602**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**60 MW    60 MW**  
 100 MW    100 MW  
 160 MW    160 MW

**NRTH1385-NOR HBR\_138\_603**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**60 MW    60 MW**  
 100 MW    100 MW  
 160 MW    160 MW

**NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_602**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by:

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**0 MW    0 MW**  
 160 MW    160 MW  
 160 MW    160 MW

**NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_603**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by:

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**0 MW    0 MW**  
 160 MW    160 MW  
 160 MW    160 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NRTH1385-NORHBR\_138\_602 , NRTH1385-NORHBR\_138\_603**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 1500

Work scheduled by:

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW 0 MW**

160 MW 160 MW

160 MW 160 MW

**NRTH1385-NRTHPORT\_138\_NNC**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500

Work scheduled by: LI

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW 0 MW**

160 MW 160 MW

160 MW 160 MW

**MARCY\_\_FRASANX\_345\_UCC2-41**

Thu 03/26/2026 to Sat 05/02/2026  
 2101 Continuous 0800

Work scheduled by: NYISO

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3225 MW**

500 MW

3725 MW

**WOOD\_ST\_PLSNTVLE\_345\_Y86**

Mon 03/30/2026 to Sun 04/26/2026  
 0001 Continuous 0200

Work scheduled by: ConEd

EXT FORCED by ConEd 03/30/2026 11:34

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**7820 MW**

390 MW

8210 MW

**OSWEGO\_COMPLEX\_AVR\_O/S**

Sat 04/04/2026 to Sun 09/13/2026  
 0800 Continuous 0000

Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3640 MW**

85 MW

3725 MW

**WATRCURE-OAKDALE\_345\_31**

Wed 04/15/2026 to Fri 05/15/2026  
 0700 Continuous 1500

Work scheduled by: NYSEG

EXTENDED by NYSEG 04/09/2026 10:23

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2400 MW 2400 MW**

100 MW 250 MW

2500 MW 2650 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SCH-PJM-NYISO\_LIMIT\_1500**

Fri 04/17/2026 to Fri 05/15/2026  
 0001 Continuous 1500  
 Work scheduled by: NYSEG

EXTENDED by NYSEG 04/09/2026 10:23

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1800 MW</b>	
700 MW	
2500 MW	

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

Fri 04/17/2026 to Sat 05/30/2026  
 1900 Continuous 1700  
 Work scheduled by: HQ

EXT FORCED by HQ 04/22/2026 14:24

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
	<b>0 MW</b>
	100 MW
	100 MW

**W49TH\_ST\_345KV\_5**

Sat 04/18/2026 to Tue 05/05/2026  
 0021 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>200 MW</b>	
460 MW	
660 MW	

**W49TH\_ST\_345KV\_7**

Sat 04/18/2026 to Tue 05/05/2026  
 0021 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>200 MW</b>	
460 MW	
660 MW	

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sat 04/18/2026 to Fri 04/24/2026  
 1440 Continuous 2359  
 Work scheduled by: PJM

FORCED by PJM 04/20/2026 11:37

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2400 MW</b>	<b>2400 MW</b>
100 MW	250 MW
2500 MW	2650 MW

**SCH-IMO-NYISO\_LIMIT\_1700**

Sun 04/19/2026 to Fri 05/01/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2000 MW</b>	
500 MW	
2500 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SCH-NYISO-IMO\_LIMIT\_1400**

Sun 04/19/2026 to Fri 05/01/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
 150 MW  
 1850 MW

**SPRNBK\_-UNIONHBS\_345\_Y49**

Mon 04/20/2026 to Sun 05/03/2026  
 0101 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**775 MW**  
 725 MW  
 1500 MW

**UNIONDHB\_345\_138\_AT1**

Mon 04/20/2026 to Sun 05/03/2026  
 0101 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1250 MW**  
 250 MW  
 1500 MW

**UNIONDHB\_345\_138\_AT2**

Mon 04/20/2026 to Sun 05/03/2026  
 0101 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1250 MW**  
 250 MW  
 1500 MW

**BECK\_-NIAGARA\_345\_PA302**

Mon 04/20/2026 to Thu 04/23/2026  
 0700 Continuous 2100  
 Work scheduled by: IESO

EXTENDED by IESO 04/21/2026 16:46

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1150 MW 1000 MW**  
 1350 MW 850 MW  
 2500 MW 1850 MW

**SCH-IMO-NYISO\_LIMIT\_500**

Mon 04/20/2026 to Thu 04/23/2026  
 0700 Continuous 2100  
 Work scheduled by: IESO

EXTENDED by IESO 04/21/2026 16:46

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
 1700 MW  
 2500 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DYSINGER-BYRON\_\_345\_DB2**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
 350 MW  
 3200 MW

**DYSINGER-BYRON\_\_345\_DB2 , DYSINGER-GRAHAM\_\_345\_DG1**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**DYSINGER-BYRON\_\_345\_DB2 , GRAHAM\_\_STA\_255\_345\_GH1-43**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**STA\_255\_-BYRON\_\_345\_BH2-50**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
 350 MW  
 3200 MW

**STA\_255\_-BYRON\_\_345\_BH2-50 , DYSINGER-GRAHAM\_\_345\_DG1**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**STA\_255\_-BYRON\_\_345\_BH2-50 , GRAHAM\_\_STA\_255\_345\_GH1-43**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_220**

Tue 04/21/2026 to Sat 05/30/2026  
 1900 Continuous 1700  
 Work scheduled by: HQ

EXT FORCED by HQ 04/22/2026 14:24

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>220 MW</b>	
59 MW	
279 MW	

**SCH-NYISO-IMO\_NIAGARA\_CB\_3108**

Thu 04/23/2026 to Thu 04/23/2026  
 0500 Continuous 1600  
 Work scheduled by: NYPA

CANCELLED by TO 04/21/2026 16:42

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2450 MW</b>	<b>1750 MW</b>
50 MW	100 MW
2500 MW	1850 MW

**BECK\_\_-NIAGARA\_230\_PA27**

Thu 04/23/2026 to Thu 04/23/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

CANCELLED by TO 04/21/2026 16:38

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2050 MW</b>	
450 MW	
2500 MW	

**BECK\_\_-NIAGARA\_230\_PA27 , BECK\_\_-NIAGARA\_345\_PA302**

Thu 04/23/2026 to Thu 04/23/2026  
 0900 Continuous 1700  
 Work scheduled by:

WESTERN\_NY\_EXPORT  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1100 MW</b>	
1200 MW	
2300 MW	

**SCH-IMO-NYISO\_LIMIT\_1500**

Thu 04/23/2026 to Thu 04/23/2026  
 0900 Continuous 1600  
 Work scheduled by: NYPA

CANCELLED by TO 04/21/2026 16:42

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1800 MW</b>	
700 MW	
2500 MW	

**SCH-NYISO-IMO\_LIMIT\_1300**

Thu 04/23/2026 to Thu 04/23/2026  
 0900 Continuous 1600  
 Work scheduled by: NYPA

CANCELLED by TO 04/21/2026 16:42

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1600 MW</b>	
250 MW	
1850 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BECK\_\_-NIAGARA\_230\_PA27**

Fri 04/24/2026 to Fri 04/24/2026  
 1000 Continuous 1300  
 Work scheduled by: IESO

SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 450 MW  
 TTC with All Lines In Service 2500 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_3**

Sun 04/26/2026 to Sun 04/26/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_4**

Sun 04/26/2026 to Sun 04/26/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

Sun 04/26/2026 to Sat 05/02/2026  
 0201 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

UPNY CONED **7820 MW**  
 Impacts Total Transfer Capability 390 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**BECK\_\_-NIAGARA\_345\_PA301**

Mon 04/27/2026 to Fri 05/01/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY **1150 MW** **1000 MW**  
 Impacts Total Transfer Capability 1350 MW 850 MW  
 TTC with All Lines In Service 2500 MW 1850 MW

FWD (Import) REV (Export)

**PIERCBRK-FIVEMILE\_345\_37**

Tue 04/28/2026 to Wed 05/13/2026  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY **2300 MW** **2300 MW**  
 Impacts Total Transfer Capability 200 MW 350 MW  
 TTC with All Lines In Service 2500 MW 2650 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DUNWODIE\_345KV\_3**

Sat 05/02/2026 to Sat 05/02/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_4**

Sat 05/02/2026 to Sat 05/02/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**SCH-NYISO-HQ\_LIMIT\_0**

Sat 05/02/2026 to Sat 05/02/2026  
 0500 Continuous 2000  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 1000 MW  
 1000 MW

**CHAT\_DC\_GC1**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
 500 MW  
 1000 MW

**CHAT\_DC\_GC1 , CHAT\_DC\_GC2**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by:

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1370 MW 0 MW**  
 130 MW 1000 MW  
 1500 MW 1000 MW

**CHAT\_DC\_GC2**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
 500 MW  
 1000 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHATGUAY-MASSENA\_765\_7040**

Sun 05/03/2026 to Wed 05/06/2026  
0100 Continuous 0200  
Work scheduled by: NYPA

UPDATED by HQ\_03/31/2026 08:32

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
1500 MW	1000 MW
1500 MW	1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 05/03/2026 to Wed 05/06/2026  
0100 Continuous 0200  
Work scheduled by: NYPA

UPDATED by HQ\_03/31/2026 08:32

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1750 MW</b>	
1650 MW	
3400 MW	

**DUNWODIE\_345KV\_7**

Sun 05/03/2026 to Sun 05/03/2026  
0100 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**SCH-HQ-NYISO\_LIMIT\_900**

Sun 05/03/2026 to Wed 05/06/2026  
0100 Continuous 2000  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>900 MW</b>	
600 MW	
1500 MW	

**SCH-NYISO-HQ\_LIMIT\_0**

Sun 05/03/2026 to Wed 05/06/2026  
0100 Continuous 2000  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
	<b>0 MW</b>
	1000 MW
	1000 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Sun 05/03/2026 to Fri 05/15/2026  
0700 Continuous 1800  
Work scheduled by: ISONE

UPDATED by ISONE\_02/18/2026 11:51

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
330 MW	330 MW
330 MW	330 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MILLWOOD-EASTVIEW\_345\_W82**

Mon 05/04/2026 to Mon 05/04/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED	<b>8015 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

**SPRNBK\_345KV\_RNS4**

Mon 05/04/2026 to Mon 05/04/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>3200 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**BECK\_\_-NIAGARA\_230\_PA27**

Mon 05/04/2026 to Fri 05/08/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY	<b>1900 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	2000 MW	

**SPRNBK\_345KV\_RNS4**

Mon 05/04/2026 to Mon 05/04/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>3200 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

Tue 05/05/2026 to Tue 05/05/2026  
 0031 Continuous 2359  
 Work scheduled by: ConEd

UPNY CONED	<b>7795 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

**HOPATCON-RAMAPO\_500\_5018**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	<b>1000 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	1200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HOPATCON-RAMAPO\_\_500\_5018**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

UPNY CONED	<b>8015 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	195 MW		
TTC with All Lines In Service	8210 MW		

**HOPATCON-RAMAPO\_\_500\_5018**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

TOTAL EAST	<b>6800 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	750 MW		
TTC with All Lines In Service	7550 MW		

**RAMAPO\_\_345\_345\_PAR3500**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	<b>1350 MW</b>	<b>1050 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	850 MW	150 MW		
TTC with All Lines In Service	2200 MW	1200 MW		

**RAMAPO\_\_345\_345\_PAR4500**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	<b>1350 MW</b>	<b>1050 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	850 MW	150 MW		
TTC with All Lines In Service	2200 MW	1200 MW		

**RAMAPO\_\_500\_345\_BK 1500**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	<b>1000 MW</b>	<b>1050 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1200 MW	150 MW		
TTC with All Lines In Service	2200 MW	1200 MW		

**RAMAPO\_\_500\_345\_BK 1500**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

UPNY CONED	<b>8015 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	195 MW		
TTC with All Lines In Service	8210 MW		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>MARCY__-FRASANNX_345_UCC2-41</b>		FWD (Import)	REV (Export)
Thu 05/07/2026	to Sat 05/30/2026	CENTRAL EAST - VC	<b>3225 MW</b>
0700	Continuous 1530	Impacts Total Transfer Capability	500 MW
Work scheduled by: NYPA	ARR: 19	TTC with All Lines In Service	3725 MW
<hr style="border-top: 1px dashed black;"/>			
<b>RAMAPO_-BUCHAN_N_345_Y94</b>		FWD (Import)	REV (Export)
Sat 05/09/2026	to Sat 05/09/2026	UPNY CONED	<b>7795 MW</b>
1930	Continuous 2000	Impacts Total Transfer Capability	415 MW
Work scheduled by: ConEd		TTC with All Lines In Service	8210 MW
<hr style="border-top: 1px dashed black;"/>			
<b>BECK__-PACKARD_230_BP76</b>		FWD (Import)	REV (Export)
Sun 05/10/2026	to Fri 05/15/2026	SCH - OH - NY	<b>1600 MW 1050 MW</b>
0530	Continuous 1600	Impacts Total Transfer Capability	400 MW 550 MW
Work scheduled by: IESO	<u>UPDATED by NGrid 04/20/2026 11:53</u>	TTC with All Lines In Service	2000 MW 1600 MW
<hr style="border-top: 1px dashed black;"/>			
<b>FIVEMILE-LIMELAKE_345_49</b>		FWD (Import)	REV (Export)
Mon 05/11/2026	to Thu 06/25/2026	SCH - PJ - NY	<b>2000 MW 1050 MW</b>
0500	Continuous 1800	Impacts Total Transfer Capability	200 MW 150 MW
Work scheduled by: NGrid		TTC with All Lines In Service	2200 MW 1200 MW
<hr style="border-top: 1px dashed black;"/>			
<b>LIMELAKE-ESTOLERD_345_29</b>		FWD (Import)	REV (Export)
Mon 05/11/2026	to Thu 06/25/2026	SCH - PJ - NY	<b>2000 MW 1050 MW</b>
0500	Continuous 1800	Impacts Total Transfer Capability	200 MW 150 MW
Work scheduled by: NGrid		TTC with All Lines In Service	2200 MW 1200 MW
<hr style="border-top: 1px dashed black;"/>			
<b>NIAGARA_345_230_AT4</b>		FWD (Import)	REV (Export)
Mon 05/11/2026	to Sat 05/30/2026	SCH - OH - NY	<b>1900 MW 1200 MW</b>
0500	Continuous 1900	Impacts Total Transfer Capability	100 MW 400 MW
Work scheduled by: NYPA		TTC with All Lines In Service	2000 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

CANCELLED by TO 04/20/2026 11:47

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 660 MW  
 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

CANCELLED by TO 04/20/2026 11:47

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
 285 MW  
 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

CANCELLED by TO 04/20/2026 11:47

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
 285 MW  
 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

CANCELLED by TO 04/20/2026 11:47

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 660 MW  
 660 MW

**DYSINGER-STA\_255\_345\_DH1**

Tue 05/12/2026 to Sun 05/31/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
 350 MW  
 3200 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Thu 05/14/2026 to Thu 05/14/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**8015 MW**  
 195 MW  
 8210 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBRK\_345KV\_RNS3**

Thu 05/14/2026 to Thu 05/14/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBRK\_345KV\_RNS3**

Thu 05/14/2026 to Thu 05/14/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**MILLWOOD-EASTVIEW\_345\_W99**

Fri 05/15/2026 to Sat 05/16/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED **8015 MW**  
 Impacts Total Transfer Capability 195 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Fri 05/15/2026 to Fri 05/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_7**

Fri 05/15/2026 to Fri 05/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**SPRNBRK\_345KV\_RNS5**

Fri 05/15/2026 to Fri 05/15/2026  
 0201 Continuous 0230  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBRK\_W49TH\_ST\_345\_M51**

Fri 05/15/2026 to Mon 06/01/2026  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Fri 05/15/2026 to Fri 05/15/2026  
 1430 Continuous 1500  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_7**

Fri 05/15/2026 to Fri 05/15/2026  
 1430 Continuous 1500  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Sat 05/16/2026 to Sat 05/16/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_7**

Sat 05/16/2026 to Sat 05/16/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_4**

Sat 05/16/2026 to Thu 05/28/2026  
 0201 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DUNWODIE\_345KV\_6**

Sat 05/16/2026 to Thu 05/28/2026  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Sat 05/16/2026 to Thu 05/28/2026  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
700 MW  
1500 MW

**SHORE\_RD\_345\_138\_BK 1**

Sat 05/16/2026 to Thu 05/28/2026  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1350 MW**  
150 MW  
1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Sat 05/16/2026 to Thu 05/28/2026  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1350 MW**  
150 MW  
1500 MW

**W49TH\_ST\_345KV\_5**

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

**W49TH\_ST\_345KV\_7**

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BEAR SWP-EASTOVER\_230\_E205W**

Mon 05/18/2026 to Sat 05/23/2026  
 0630 Continuous 1800  
 Work scheduled by: NGrid

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**ROCHESTR-PANNELL\_345\_RP2**

Mon 05/18/2026 to Fri 05/22/2026  
 0700 Continuous 1500  
 Work scheduled by: RGE

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2300 MW**  
 900 MW  
 3200 MW

**GOETHALS\_345KV\_5**

Sun 05/24/2026 to Sat 05/30/2026  
 0001 Continuous 0300  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**SPRNBK\_345KV\_RNS5**

Mon 06/01/2026 to Mon 06/01/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3200 MW**  
 1400 MW  
 4600 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Mon 06/01/2026 to Fri 06/05/2026  
 0600 Continuous 1600  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**  
 660 MW  
 660 MW

**W49TH\_ST\_345KV\_7**

Mon 06/01/2026 to Mon 06/01/2026  
 0600 Continuous 0630  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
 360 MW  
 660 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_8**

Mon 06/01/2026 to Mon 06/01/2026  
0600 Continuous 0630  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**MARCY\_\_345KV\_CSC**

Mon 06/01/2026 to Sun 06/14/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>3650 MW</b>	
Impacts Total Transfer Capability	75 MW	
TTC with All Lines In Service	3725 MW	

**LEEDS\_-HURLYAVE\_345\_301**

Mon 06/01/2026 to Fri 07/03/2026  
0800 Continuous 1600  
Work scheduled by: CHGE

UPDATED by CHGE 01/16/2026 09:18

	FWD (Import)	REV (Export)
UPNY CONED	<b>8120 MW</b>	
Impacts Total Transfer Capability	90 MW	
TTC with All Lines In Service	8210 MW	

**MOTTHAVN-RAINEY\_\_345\_Q11**

Thu 06/04/2026 to Sun 06/07/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 04/20/2026 11:31

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**W49TH\_ST\_345KV\_7**

Fri 06/05/2026 to Fri 06/05/2026  
1530 Continuous 1600  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**W49TH\_ST\_345KV\_8**

Fri 06/05/2026 to Fri 06/05/2026  
1530 Continuous 1600  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MAINESBG-WATRCURE\_345\_30**

Wed 06/10/2026 to Fri 06/12/2026  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1600 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	600 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**INGHAM\_C\_115\_115\_PAR 2**

Mon 06/22/2026 to Sat 08/29/2026  
 0500 Continuous 1900  
 Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3605 MW</b>	
Impacts Total Transfer Capability	120 MW	
TTC with All Lines In Service	3725 MW	

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3625 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3625 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**FIVEMILE-LIMELAKE\_345\_49**

Thu 07/09/2026 to Fri 10/02/2026  
 0700 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**LIMELAKE-ESTOLERD\_345\_29**

Thu 07/09/2026 to Fri 10/02/2026  
 0700 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/21/2026 to Tue 07/21/2026  
 1200 Continuous 1600  
 Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/21/2026 to Tue 07/21/2026  
 1200 Continuous 1600  
 Work scheduled by: ISONE

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3625 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

**GOETHALS\_345KV\_5**

Sat 08/15/2026 to Sat 08/15/2026  
 0301 Continuous 0330  
 Work scheduled by: ConEd

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**GOETHALS\_345KV\_5**

Mon 08/17/2026 to Mon 08/17/2026  
 0630 Continuous 0700  
 Work scheduled by: ConEd

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARION\_-FARRAGUT\_345\_C3403**

Sat 09/05/2026 to Sat 09/05/2026  
 0201 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**E13THSTA-FARRAGUT\_345\_45**

Wed 09/09/2026 to Fri 09/11/2026  
 0001 Continuous 1830  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**MARCY\_\_765\_345\_AT1**

Wed 09/09/2026 to Thu 09/10/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1750 MW**  
 1650 MW  
 3400 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Fri 09/11/2026 to Fri 09/11/2026  
 0001 Continuous 1830  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**MARCY\_\_765\_345\_AT2**

Fri 09/11/2026 to Sat 09/12/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**  
 1700 MW  
 3400 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sat 09/12/2026 to Sat 09/26/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**  
 660 MW  
 660 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_7**

Sat 09/12/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	<b>300 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**W49TH\_ST\_345KV\_8**

Sat 09/12/2026 to Sat 09/26/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	<b>300 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**DUNWODIE\_345KV\_7**

Mon 09/14/2026 to Tue 09/15/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_8**

Mon 09/14/2026 to Tue 09/15/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE-MOTTHAVN\_345\_72**

Mon 09/14/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**STLAWRNC-MOSES\_230\_L34P**

Mon 09/14/2026 to Fri 09/18/2026  
 0600 Continuous 1630  
 Work scheduled by: NYPA

SCH - OH - NY		FWD (Import) REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BECK\_\_-NIAGARA\_230\_PA27**

Tue 09/15/2026 to Tue 11/17/2026  
 0500 Continuous 2330  
 Work scheduled by: NYPA

SCH - OH - NY **1900 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 2000 MW

FWD (Import) REV (Export)

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

Tue 09/15/2026 to Tue 09/29/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **3225 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Sat 09/26/2026 to Thu 12/24/2026  
 0201 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**GOETHALS\_345KV\_5**

Mon 09/28/2026 to Sat 10/03/2026  
 0001 Continuous 0300  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**PANNELL\_-CLAY\_\_345\_1**

Mon 09/28/2026 to Fri 10/02/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

**PANNELL\_-CLAY\_\_345\_2**

Mon 10/05/2026 to Fri 10/09/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DYSINGER-STA\_255\_345\_DH1**

Sun 10/11/2026 to Wed 11/04/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST	<b>2850 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	350 MW		
TTC with All Lines In Service	3200 MW		

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>0 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	660 MW		
TTC with All Lines In Service	660 MW		

**NEWBRDGE\_345\_138\_BK\_1**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>375 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	285 MW		
TTC with All Lines In Service	660 MW		

**NEWBRDGE\_345\_138\_BK\_2**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>375 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	285 MW		
TTC with All Lines In Service	660 MW		

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>0 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	660 MW		
TTC with All Lines In Service	660 MW		

**CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

SCH - HQ - NY	<b>0 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1500 MW		1000 MW
TTC with All Lines In Service	1500 MW		1000 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_765\_345\_AT1**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_765\_345\_AT2**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1700 MW</b>	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA -MARCY\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA -MARCY\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

**MASSENA -MARCY\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>190 MW</b>	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**ROSETON\_EFISHKIL\_345\_RFK305**

Mon 10/26/2026 to Fri 11/06/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
UPNY CONED	<b>7470 MW</b>	
Impacts Total Transfer Capability	740 MW	
TTC with All Lines In Service	8210 MW	

**DUNWODIE\_345KV\_7**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_8**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**STLAWRNC-MOSES\_\_230\_L34P**

Thu 10/29/2026 to Fri 11/13/2026  
 0900 Continuous 1600  
 Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DUNWODIE\_345KV\_3**

Mon 11/02/2026 to Mon 11/02/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**DUNWODIE\_345KV\_5**

Mon 11/02/2026 to Mon 11/02/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 11/02/2026 to Mon 12/14/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**LINDN\_CG-LNDVFT\_345\_V-3022**

Mon 11/02/2026 to Sat 11/07/2026  
 0800 Continuous 1900  
 Work scheduled by: PJM

SCH - PJM\_VFT  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
315 MW	315 MW
315 MW	315 MW

**ROSETON\_EFISHKIL\_345\_RFK305**

Fri 11/06/2026 to Fri 11/13/2026  
 1600 Continuous 1600  
 Work scheduled by: CHGE

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>7470 MW</b>	
740 MW	
8210 MW	

**MILLWOOD-EASTVIEW\_345\_W99**

Mon 11/09/2026 to Mon 11/09/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>8015 MW</b>	
195 MW	
8210 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBK\_345KV\_RNS5**

Mon 11/09/2026 to Mon 11/09/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 11/16/2026 to Sat 11/28/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**BUCHAN\_S-MILLWOOD\_345\_W98**

Mon 11/16/2026 to Sat 11/28/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**LOVETT\_-BUCHAN\_S\_345\_Y88**

Mon 11/16/2026 to Sat 11/28/2026  
 0001 Continuous 2330  
 Work scheduled by: ConEd

UPNY CONED **7960 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**STLAWRNC-MOSES\_230\_L33P**

Mon 11/16/2026 to Fri 11/20/2026  
 0600 Continuous 1630  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**BECK\_-NIAGARA\_230\_PA27**

Mon 11/23/2026 to Fri 11/27/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY **2050 MW**  
 Impacts Total Transfer Capability 450 MW  
 TTC with All Lines In Service 2500 MW

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MILLWOOD-EASTVIEW\_345\_W99**

Wed 12/23/2026 to Wed 12/23/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8015 MW</b>	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

**SPRNBRK\_345KV\_RNS5**

Wed 12/23/2026 to Wed 12/23/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**HUDSONTP-W49TH\_ST\_345\_Y56**

Fri 12/25/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**W49TH\_ST\_345KV\_8**

Fri 12/25/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**STLAWRNC-MOSES\_230\_L34P**

Fri 12/25/2026 to Fri 12/25/2026  
 0800 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**W49TH\_ST-E13THSTA\_345\_M54**

Sun 12/27/2026 to Sun 12/27/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST-E13THSTA\_345\_M54**

Wed 12/30/2026 to Wed 12/30/2026  
 0030 Continuous 0100  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**SPRNBRK\_345KV\_RS3 , SPRNBRK\_345KV\_RS4**

Mon 02/08/2027 to Tue 02/09/2027  
 0001 0200  
 Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**SPRNBRK\_345KV\_RNS5**

Tue 02/09/2027 to Fri 02/19/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**SPRNBRK\_-W49TH\_ST\_345\_M51**

Tue 02/09/2027 to Fri 02/19/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 03/01/2027 to Wed 03/03/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8175 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

**SPRNBRK\_345KV\_RS3 , SPRNBRK\_345KV\_RS4**

Thu 03/11/2027 to Sun 03/14/2027  
 0001 0100  
 Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBK\_345KV\_RNS5**

Sun 03/14/2027 to Wed 03/17/2027  
 0101 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**SPRNBK\_-W49TH\_ST\_345\_M51**

Sun 03/14/2027 to Wed 03/17/2027  
 0101 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sun 04/04/2027 to Sun 04/04/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8175 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sun 04/04/2027 to Wed 04/07/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8175 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**CHATGUAY-MASSENA\_765\_7040**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_\_765\_345\_AT1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_\_765\_345\_AT2**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1700 MW</b>	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA\_MARCY\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

CENTRAL EAST - VC	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

**MASSENA\_MARCY\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

SCH - HQ_CEDARS	<b>190 MW</b>	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Tue 05/25/2027 to Sat 05/29/2027  
 0001 0130  
 Work scheduled by:

MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 09/20/2027 to Mon 09/20/2027  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPNY CONED	<b>8175 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BUCHAN\_S-MILLWOOD\_345\_W97**

Tue 09/21/2027 to Tue 09/21/2027  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Mon 10/04/2027 to Sat 10/16/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **7795 MW**  
 Impacts Total Transfer Capability 415 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**SPRNBK\_-UNIONHBS\_345\_Y49**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA **775 MW**  
 Impacts Total Transfer Capability 725 MW  
 TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

**UNIONDHB\_345\_138\_AT1**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

**UNIONDHB\_345\_138\_AT2**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Thursday, April 23, 2026 to Friday, October 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NEWBRDGE\_345\_138\_BK\_1**

Mon 10/11/2027                      to                      Thu 10/14/2027  
 0600                                      Continuous                      1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 10/11/2027                      to                      Thu 10/14/2027  
 0600                                      Continuous                      1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 10/11/2027                      to                      Thu 10/14/2027  
 0600                                      Continuous                      1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	