

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 Continuous 2359  
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**MARION\_-FARRAGUT\_345\_C3403**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 Continuous 2359  
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402**

Mon 01/15/2018 to Sat 08/01/2026  
 0001 2359  
 Work scheduled by:

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2400 MW 2400 MW**  
 100 MW 250 MW  
 2500 MW 2650 MW

**SCH-IMO-NYISO\_LIMIT\_1900**

Sat 11/01/2025 to Thu 04/30/2026  
 0001 Continuous 2359  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2200 MW**  
 300 MW  
 2500 MW

**HERTELHQ-ASTANNEX\_345\_G180**

Tue 02/10/2026 to Sun 05/31/2026  
 1121 Continuous 2359  
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:34

SCH - HQ\_CHPE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 1250 MW  
 1250 MW

**DYSINGER-GRAHAM\_345\_DG1**

Tue 02/10/2026 to Sun 05/31/2026  
 1122 Continuous 2100  
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**GRAHAM\_-STA\_255\_345\_GH1-43**

Tue 02/10/2026 to Sun 05/31/2026  
 1122 Continuous 2100  
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**NRTH1385-NOR HBR\_138\_601**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**60 MW 60 MW**  
 100 MW 100 MW  
 160 MW 160 MW

**NRTH1385-NOR HBR\_138\_602**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**60 MW 60 MW**  
 100 MW 100 MW  
 160 MW 160 MW

**NRTH1385-NOR HBR\_138\_603**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous 1500  
 Work scheduled by: LI

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**60 MW 60 MW**  
 100 MW 100 MW  
 160 MW 160 MW

**NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_602**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 1500  
 Work scheduled by:

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW 0 MW**  
 160 MW 160 MW  
 160 MW 160 MW

**NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_603**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 1500  
 Work scheduled by:

SCH - NPX\_1385  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW 0 MW**  
 160 MW 160 MW  
 160 MW 160 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NRTH1385-NORHBR\_138\_602 , NRTH1385-NORHBR\_138\_603**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 to 1500  
 Work scheduled by:

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	160 MW	160 MW
TTC with All Lines In Service	160 MW	160 MW

**NRTH1385-NRTHPORT\_138\_NNC**

Thu 02/26/2026 to Fri 05/15/2026  
 0600 Continuous to 1500  
 Work scheduled by: LI

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	160 MW	160 MW
TTC with All Lines In Service	160 MW	160 MW

**MARCY\_\_FRASANNX\_345\_UCC2-41**

Thu 03/26/2026 to Sat 05/02/2026  
 2101 Continuous to 0800  
 Work scheduled by: NYISO

ARR: 19

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3225 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

**WOOD\_ST\_PLSNTVLE\_345\_Y86**

Mon 03/30/2026 to Sun 04/26/2026  
 0001 Continuous to 0200  
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/30/2026 11:34

UPNY CONED	FWD (Import)	REV (Export)
	<b>7820 MW</b>	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	8210 MW	

**OSWEGO\_COMPLEX\_AVR\_O/S**

Sat 04/04/2026 to Sun 09/13/2026  
 0800 Continuous to 0000  
 Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3640 MW</b>	
Impacts Total Transfer Capability	85 MW	
TTC with All Lines In Service	3725 MW	

**WATRCURE-OAKDALE\_345\_31**

Wed 04/15/2026 to Fri 05/15/2026  
 0700 Continuous to 1500  
 Work scheduled by: NYSEG

EXTENDED by NYSEG 04/09/2026 10:23

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2400 MW</b>	<b>2400 MW</b>
Impacts Total Transfer Capability	100 MW	250 MW
TTC with All Lines In Service	2500 MW	2650 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SCH-PJM-NYISO\_LIMIT\_1500**

Fri 04/17/2026 to Fri 05/15/2026  
 0001 Continuous 1500  
 Work scheduled by: NYSEG

EXTENDED by NYSEG 04/09/2026 10:23

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1800 MW**  
 700 MW  
 2500 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

Fri 04/17/2026 to Sat 05/30/2026  
 1900 Continuous 1700  
 Work scheduled by: HQ

EXT FORCED by HQ 04/22/2026 14:24

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 100 MW  
 100 MW

**W49TH\_ST\_345KV\_5**

Sat 04/18/2026 to Tue 05/05/2026  
 0021 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**200 MW**  
 460 MW  
 660 MW

**W49TH\_ST\_345KV\_7**

Sat 04/18/2026 to Tue 05/05/2026  
 0021 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**200 MW**  
 460 MW  
 660 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Sat 04/18/2026 to Fri 04/24/2026  
 1440 Continuous 2359  
 Work scheduled by: PJM

FORCED by PJM 04/20/2026 11:37

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2400 MW** **2400 MW**  
 100 MW 250 MW  
 2500 MW 2650 MW

**SCH-IMO-NYISO\_LIMIT\_1700**

Sun 04/19/2026 to Fri 05/01/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2000 MW**  
 500 MW  
 2500 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SCH-NYISO-IMO\_LIMIT\_1400**

Sun 04/19/2026 to Fri 05/01/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
 150 MW  
 1850 MW

**SPRNBKR\_-UNIONHBS\_345\_Y49**

Mon 04/20/2026 to Sun 05/03/2026  
 0101 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**775 MW**  
 725 MW  
 1500 MW

**UNIONDHB\_345\_138\_AT1**

Mon 04/20/2026 to Sun 05/03/2026  
 0101 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1250 MW**  
 250 MW  
 1500 MW

**UNIONDHB\_345\_138\_AT2**

Mon 04/20/2026 to Sun 05/03/2026  
 0101 Continuous 0259  
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1250 MW**  
 250 MW  
 1500 MW

**DYSINGER-BYRON\_\_\_345\_DB2**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
 350 MW  
 3200 MW

**DYSINGER-BYRON\_\_\_345\_DB2 , DYSINGER-GRAHAM\_\_\_345\_DG1**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DYSINGER-BYRON\_\_345\_DB2 , GRAHAM\_-STA\_255\_345\_GH1-43**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**STA\_255\_-BYRON\_\_345\_BH2-50**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**  
 350 MW  
 3200 MW

**STA\_255\_-BYRON\_\_345\_BH2-50 , DYSINGER-GRAHAM\_\_345\_DG1**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**STA\_255\_-BYRON\_\_345\_BH2-50 , GRAHAM\_-STA\_255\_345\_GH1-43**

Tue 04/21/2026 to Sun 05/03/2026  
 0500 2100  
 Work scheduled by:

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_220**

Tue 04/21/2026 to Sat 05/30/2026  
 1900 Continuous 1700  
 Work scheduled by: HQ

EXT FORCED by HQ, 04/22/2026 14:24

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**220 MW**  
 59 MW  
 279 MW

**BECK\_-NIAGARA\_230\_PA27**

Fri 04/24/2026 to Fri 04/24/2026  
 1000 Continuous 1300  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2050 MW**  
 450 MW  
 2500 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DUNWODIE\_345KV\_3**

Sun 04/26/2026 to Sun 04/26/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_4**

Sun 04/26/2026 to Sun 04/26/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**WOOD\_ST\_PLSNTVLE\_345\_Y86**

Sun 04/26/2026 to Sat 05/02/2026  
 0201 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**7820 MW**  
 390 MW  
 8210 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_180**

Mon 04/27/2026 to Tue 04/28/2026  
 0600 Continuous 1900  
 Work scheduled by: HQ

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**180 MW**  
 99 MW  
 279 MW

**BECK\_\_-NIAGARA\_345\_PA301**

Mon 04/27/2026 to Fri 05/01/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1150 MW 1000 MW**  
 1350 MW 850 MW  
 2500 MW 1850 MW

**PIERCBRK-FIVEMILE\_345\_37**

Tue 04/28/2026 to Wed 05/13/2026  
 0800 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW 2300 MW**  
 200 MW 350 MW  
 2500 MW 2650 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_180**

Wed 04/29/2026 to Thu 04/30/2026  
 0600 Continuous 1900  
 Work scheduled by: HQ

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**180 MW**  
 99 MW  
 279 MW

**DUNWODIE\_345KV\_3**

Sat 05/02/2026 to Sat 05/02/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_4**

Sat 05/02/2026 to Sat 05/02/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/29/2026 13:51

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**SCH-NYISO-HQ\_LIMIT\_0**

Sat 05/02/2026 to Sat 05/02/2026  
 0500 Continuous 2000  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 1000 MW  
 1000 MW

**CHAT\_DC\_GC1**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
 500 MW  
 1000 MW

**CHAT\_DC\_GC1 , CHAT\_DC\_GC2**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by:

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1370 MW 0 MW**  
 130 MW 1000 MW  
 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHAT\_DC\_GC2**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		<b>500 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 0200  
 Work scheduled by: NYPA

UPDATED by HQ, 03/31/2026 08:32

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 0200  
 Work scheduled by: NYPA

UPDATED by HQ, 03/31/2026 08:32

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**DUNWODIE\_345KV\_7**

Sun 05/03/2026 to Sun 05/03/2026  
 0100 Continuous 0200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**SCH-HQ-NYISO\_LIMIT\_900**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>900 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1500 MW	

**SCH-NYISO-HQ\_LIMIT\_0**

Sun 05/03/2026 to Wed 05/06/2026  
 0100 Continuous 2000  
 Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		<b>0 MW</b>
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1000 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Sun 05/03/2026 to Fri 05/15/2026  
 0700 Continuous 1800  
 Work scheduled by: ISONE

UPDATED by ISONE 02/18/2026 11:51

SCH - NPX\_CSC

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
330 MW	330 MW
330 MW	330 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Mon 05/04/2026 to Mon 05/04/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

CANCELLED by TO 04/24/2026 15:05

UPNY CONED

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>8015 MW</b>	
195 MW	
8210 MW	

**SPRNBK\_345KV\_RNS4**

Mon 05/04/2026 to Mon 05/04/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

CANCELLED by TO 04/24/2026 15:05

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3200 MW</b>	
1400 MW	
4600 MW	

**BECK\_\_-NIAGARA\_230\_PA27**

Mon 05/04/2026 to Fri 05/08/2026  
 0900 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1900 MW</b>	
100 MW	
2000 MW	

**SPRNBK\_345KV\_RNS4**

Mon 05/04/2026 to Mon 05/04/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

CANCELLED by TO 04/24/2026 15:05

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3200 MW</b>	
1400 MW	
4600 MW	

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

Tue 05/05/2026 to Tue 05/05/2026  
 0031 Continuous 2359  
 Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>7795 MW</b>	
415 MW	
8210 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HOPATCON-RAMAPO\_\_500\_5018**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	1200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**HOPATCON-RAMAPO\_\_500\_5018**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8015 MW</b>	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

**HOPATCON-RAMAPO\_\_500\_5018**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

TOTAL EAST	FWD (Import)	REV (Export)
	<b>6800 MW</b>	
Impacts Total Transfer Capability	750 MW	
TTC with All Lines In Service	7550 MW	

**RAMAPO\_\_345\_345\_PAR3500**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1350 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	850 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**RAMAPO\_\_345\_345\_PAR4500**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1350 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	850 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**RAMAPO\_\_500\_345\_BK 1500**

Thu 05/07/2026 to Sat 05/09/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	1200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**RAMAPO\_\_500\_345\_BK 1500**

Thu 05/07/2026 to Sat 05/09/2026  
0001 Continuous 1800  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8015 MW</b>	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

**MARCY\_\_FRASANNX\_345\_UCC2-41**

Thu 05/07/2026 to Sat 05/30/2026  
0700 Continuous 1530  
Work scheduled by: NYPA  
ARR: 19

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3225 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

Sat 05/09/2026 to Sat 05/09/2026  
1930 Continuous 2000  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7795 MW</b>	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

**BECK\_\_PACKARD\_230\_BP76**

Sun 05/10/2026 to Fri 05/15/2026  
0530 Continuous 1600  
Work scheduled by: IESO  
UPDATED by NGrid 04/20/2026 11:53

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1600 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	400 MW	550 MW
TTC with All Lines In Service	2000 MW	1600 MW

**FIVEMILE-LIMELAKE\_345\_49**

Mon 05/11/2026 to Thu 06/25/2026  
0500 Continuous 1800  
Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**LIMELAKE-ESTOLERD\_345\_29**

Mon 05/11/2026 to Thu 06/25/2026  
0500 Continuous 1800  
Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NIAGARA\_345\_230\_AT4**

Mon 05/11/2026 to Sat 05/30/2026  
 0500 Continuous 1900  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	100 MW	400 MW
TTC with All Lines In Service	2000 MW	1600 MW

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI  
CANCELLED by TO 04/20/2026 11:47

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI  
CANCELLED by TO 04/20/2026 11:47

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI  
CANCELLED by TO 04/20/2026 11:47

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI  
CANCELLED by TO 04/20/2026 11:47

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**DYSINGER-STA\_255\_345\_DH1**

Tue 05/12/2026 to Sun 05/31/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MILLWOOD-EASTVIEW\_345\_W85**

Thu 05/14/2026 to Thu 05/14/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	UPNY CONED	<b>8015 MW</b>	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	195 MW		
	TTC with All Lines In Service	8210 MW		

**SPRNBRK\_345KV\_RNS3**

Thu 05/14/2026 to Thu 05/14/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

	SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	800 MW		
	TTC with All Lines In Service	4600 MW		

**SPRNBRK\_345KV\_RNS3**

Thu 05/14/2026 to Thu 05/14/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

	SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	800 MW		
	TTC with All Lines In Service	4600 MW		

**MILLWOOD-EASTVIEW\_345\_W99**

Fri 05/15/2026 to Sat 05/16/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	UPNY CONED	<b>8015 MW</b>	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	195 MW		
	TTC with All Lines In Service	8210 MW		

**W49TH\_ST\_345KV\_5**

Fri 05/15/2026 to Fri 05/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

	SCH - PJM_HTP	<b>300 MW</b>	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	360 MW		
	TTC with All Lines In Service	660 MW		

**W49TH\_ST\_345KV\_7**

Fri 05/15/2026 to Fri 05/15/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

	SCH - PJM_HTP	<b>300 MW</b>	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability	360 MW		
	TTC with All Lines In Service	660 MW		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBRK\_345KV\_RNS5**

Fri 05/15/2026 to Fri 05/15/2026  
 0201 Continuous 0230  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBRK\_-W49TH\_ST\_345\_M51**

Fri 05/15/2026 to Mon 06/01/2026  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Fri 05/15/2026 to Fri 05/15/2026  
 1430 Continuous 1500  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_7**

Fri 05/15/2026 to Fri 05/15/2026  
 1430 Continuous 1500  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_5**

Sat 05/16/2026 to Sat 05/16/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**W49TH\_ST\_345KV\_7**

Sat 05/16/2026 to Sat 05/16/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

DUNWODIE_345KV_4	FWD (Import)	REV (Export)																												
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sat 05/16/2026</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Thu 05/28/2026</td> <td style="width: 25%;"></td> <td style="width: 35%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0201</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td style="text-align: center;"><u>UPDATED by ConEd 03/01/2026 10:07</u></td> <td>SPR/DUN-SOUTH</td> <td style="text-align: right;"><b>3800 MW</b></td> <td></td> </tr> <tr> <td colspan="4">Work scheduled by: ConEd</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">800 MW</td> <td></td> </tr> <tr> <td colspan="4"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">4600 MW</td> <td></td> </tr> </table>	Sat 05/16/2026	to	Thu 05/28/2026					0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	SPR/DUN-SOUTH	<b>3800 MW</b>		Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW						TTC with All Lines In Service	4600 MW			
Sat 05/16/2026	to	Thu 05/28/2026																												
0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	SPR/DUN-SOUTH	<b>3800 MW</b>																									
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW																									
				TTC with All Lines In Service	4600 MW																									
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sat 05/16/2026</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Thu 05/28/2026</td> <td style="width: 25%;"></td> <td style="width: 35%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0201</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td style="text-align: center;"><u>UPDATED by ConEd 03/01/2026 10:07</u></td> <td>SPR/DUN-SOUTH</td> <td style="text-align: right;"><b>3800 MW</b></td> <td></td> </tr> <tr> <td colspan="4">Work scheduled by: ConEd</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">800 MW</td> <td></td> </tr> <tr> <td colspan="4"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">4600 MW</td> <td></td> </tr> </table>	Sat 05/16/2026	to	Thu 05/28/2026					0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	SPR/DUN-SOUTH	<b>3800 MW</b>		Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW						TTC with All Lines In Service	4600 MW			
Sat 05/16/2026	to	Thu 05/28/2026																												
0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	SPR/DUN-SOUTH	<b>3800 MW</b>																									
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW																									
				TTC with All Lines In Service	4600 MW																									
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sat 05/16/2026</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Thu 05/28/2026</td> <td style="width: 25%;"></td> <td style="width: 35%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0201</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td style="text-align: center;"><u>UPDATED by ConEd 03/01/2026 10:07</u></td> <td>CONED - LIPA</td> <td style="text-align: right;"><b>800 MW</b></td> <td></td> </tr> <tr> <td colspan="4">Work scheduled by: ConEd</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">700 MW</td> <td></td> </tr> <tr> <td colspan="4"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td></td> </tr> </table>	Sat 05/16/2026	to	Thu 05/28/2026					0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	CONED - LIPA	<b>800 MW</b>		Work scheduled by: ConEd				Impacts Total Transfer Capability	700 MW						TTC with All Lines In Service	1500 MW			
Sat 05/16/2026	to	Thu 05/28/2026																												
0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	CONED - LIPA	<b>800 MW</b>																									
Work scheduled by: ConEd				Impacts Total Transfer Capability	700 MW																									
				TTC with All Lines In Service	1500 MW																									
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sat 05/16/2026</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Thu 05/28/2026</td> <td style="width: 25%;"></td> <td style="width: 35%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0201</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td style="text-align: center;"><u>UPDATED by ConEd 03/01/2026 10:07</u></td> <td>CONED - LIPA</td> <td style="text-align: right;"><b>1350 MW</b></td> <td></td> </tr> <tr> <td colspan="4">Work scheduled by: ConEd</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">150 MW</td> <td></td> </tr> <tr> <td colspan="4"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td></td> </tr> </table>	Sat 05/16/2026	to	Thu 05/28/2026					0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	CONED - LIPA	<b>1350 MW</b>		Work scheduled by: ConEd				Impacts Total Transfer Capability	150 MW						TTC with All Lines In Service	1500 MW			
Sat 05/16/2026	to	Thu 05/28/2026																												
0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	CONED - LIPA	<b>1350 MW</b>																									
Work scheduled by: ConEd				Impacts Total Transfer Capability	150 MW																									
				TTC with All Lines In Service	1500 MW																									
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Sat 05/16/2026</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Thu 05/28/2026</td> <td style="width: 25%;"></td> <td style="width: 35%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0201</td> <td style="text-align: center;">Continuous</td> <td>0200</td> <td style="text-align: center;"><u>UPDATED by ConEd 03/01/2026 10:07</u></td> <td>CONED - LIPA</td> <td style="text-align: right;"><b>1350 MW</b></td> <td></td> </tr> <tr> <td colspan="4">Work scheduled by: ConEd</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">150 MW</td> <td></td> </tr> <tr> <td colspan="4"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">1500 MW</td> <td></td> </tr> </table>	Sat 05/16/2026	to	Thu 05/28/2026					0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	CONED - LIPA	<b>1350 MW</b>		Work scheduled by: ConEd				Impacts Total Transfer Capability	150 MW						TTC with All Lines In Service	1500 MW			
Sat 05/16/2026	to	Thu 05/28/2026																												
0201	Continuous	0200	<u>UPDATED by ConEd 03/01/2026 10:07</u>	CONED - LIPA	<b>1350 MW</b>																									
Work scheduled by: ConEd				Impacts Total Transfer Capability	150 MW																									
				TTC with All Lines In Service	1500 MW																									
<table border="0" style="width: 100%;"> <tr> <td style="width: 15%;">Mon 05/18/2026</td> <td style="width: 10%; text-align: center;">to</td> <td style="width: 15%;">Mon 05/18/2026</td> <td style="width: 25%;"></td> <td style="width: 35%;"></td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> </tr> <tr> <td>0030</td> <td style="text-align: center;">Continuous</td> <td>0100</td> <td style="text-align: center;"></td> <td>SCH - PJM_HTP</td> <td style="text-align: right;"><b>300 MW</b></td> <td></td> </tr> <tr> <td colspan="4">Work scheduled by: ConEd</td> <td>Impacts Total Transfer Capability</td> <td style="text-align: right;">360 MW</td> <td></td> </tr> <tr> <td colspan="4"></td> <td>TTC with All Lines In Service</td> <td style="text-align: right;">660 MW</td> <td></td> </tr> </table>	Mon 05/18/2026	to	Mon 05/18/2026					0030	Continuous	0100		SCH - PJM_HTP	<b>300 MW</b>		Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW						TTC with All Lines In Service	660 MW			
Mon 05/18/2026	to	Mon 05/18/2026																												
0030	Continuous	0100		SCH - PJM_HTP	<b>300 MW</b>																									
Work scheduled by: ConEd				Impacts Total Transfer Capability	360 MW																									
				TTC with All Lines In Service	660 MW																									

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_7**

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

**BEAR SWP-EASTOVER\_230\_E205W**

Mon 05/18/2026 to Sat 05/23/2026  
0630 Continuous 1800  
Work scheduled by: NGrid

UPDATED by NGrid 04/24/2026 15:05

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**ROCHESTR-PANNELL\_345\_RP2**

Mon 05/18/2026 to Fri 05/22/2026  
0700 Continuous 1500  
Work scheduled by: RGE

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
900 MW  
3200 MW

**GOETHALS\_345KV\_5**

Sun 05/24/2026 to Sat 05/30/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**SPRNBK\_345KV\_RNS5**

Mon 06/01/2026 to Mon 06/01/2026  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Mon 06/01/2026 to Fri 06/05/2026  
0600 Continuous 1600  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_7**

Mon 06/01/2026 to Mon 06/01/2026  
0600 Continuous 0630  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**W49TH\_ST\_345KV\_8**

Mon 06/01/2026 to Mon 06/01/2026  
0600 Continuous 0630  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

**MARCY\_\_345KV\_CSC**

Mon 06/01/2026 to Sun 06/14/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3650 MW</b>	
Impacts Total Transfer Capability	75 MW	
TTC with All Lines In Service	3725 MW	

**LEEDS\_\_HURLYAVE\_345\_301**

Mon 06/01/2026 to Fri 07/03/2026  
0800 Continuous 1600  
Work scheduled by: CHGE

UPDATED by CHGE 01/16/2026 09:18

UPNY CONED	FWD (Import)	REV (Export)
	<b>8120 MW</b>	
Impacts Total Transfer Capability	90 MW	
TTC with All Lines In Service	8210 MW	

**MOTTHAVN-RAINEY\_\_345\_Q11**

Thu 06/04/2026 to Sun 06/07/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 04/20/2026 11:31

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**W49TH\_ST\_345KV\_7**

Fri 06/05/2026 to Fri 06/05/2026  
1530 Continuous 1600  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_8**

Fri 06/05/2026 to Fri 06/05/2026  
 1530 Continuous 1600  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
 360 MW  
 660 MW

**MAINESBG-WATRCURE\_345\_30**

Wed 06/10/2026 to Fri 06/12/2026  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1600 MW 1050 MW**  
 600 MW 150 MW  
 2200 MW 1200 MW

**INGHAM\_C\_115\_115\_PAR 2**

Mon 06/22/2026 to Sat 08/29/2026  
 0500 Continuous 1900  
 Work scheduled by: NGrid

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3605 MW**  
 120 MW  
 3725 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3625 MW**  
 100 MW  
 3725 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3625 MW**  
 100 MW  
 3725 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3625 MW**  
 100 MW  
 3725 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3625 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

**FIVEMILE-LIMELAKE\_345\_49**

Thu 07/09/2026 to Fri 10/02/2026  
 0700 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**LIMELAKE-ESTOLERD\_345\_29**

Thu 07/09/2026 to Fri 10/02/2026  
 0700 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/21/2026 to Tue 07/21/2026  
 1200 Continuous 1600  
 Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/21/2026 to Tue 07/21/2026  
 1200 Continuous 1600  
 Work scheduled by: ISONE

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3625 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

**GOETHALS\_345KV\_5**

Sat 08/15/2026 to Sat 08/15/2026  
 0301 Continuous 0330  
 Work scheduled by: ConEd

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**GOETHALS\_345KV\_5**

Mon 08/17/2026 to Mon 08/17/2026  
0630 Continuous 0700  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**MARION\_-FARRAGUT\_345\_C3403**

Sat 09/05/2026 to Sat 09/05/2026  
0201 Continuous 2359  
Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**E13THSTA-FARRAGUT\_345\_45**

Wed 09/09/2026 to Fri 09/11/2026  
0001 Continuous 1830  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

**MARCY\_\_765\_345\_AT1**

Wed 09/09/2026 to Thu 09/10/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1650 MW  
3400 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Fri 09/11/2026 to Fri 09/11/2026  
0001 Continuous 1830  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

**MARCY\_\_765\_345\_AT2**

Fri 09/11/2026 to Sat 09/12/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1700 MW  
3400 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sat 09/12/2026 to Sat 09/26/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	<b>0 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	660 MW		
TTC with All Lines In Service	660 MW		

**W49TH\_ST\_345KV\_7**

Sat 09/12/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	<b>300 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	360 MW		
TTC with All Lines In Service	660 MW		

**W49TH\_ST\_345KV\_8**

Sat 09/12/2026 to Sat 09/26/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	<b>300 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	360 MW		
TTC with All Lines In Service	660 MW		

**DUNWODIE\_345KV\_7**

Mon 09/14/2026 to Tue 09/15/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	800 MW		
TTC with All Lines In Service	4600 MW		

**DUNWODIE\_345KV\_8**

Mon 09/14/2026 to Tue 09/15/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	800 MW		
TTC with All Lines In Service	4600 MW		

**DUNWODIE-MOTTHAVN\_345\_72**

Mon 09/14/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	800 MW		
TTC with All Lines In Service	4600 MW		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**STLAWRNC-MOSES\_230\_L34P**

Mon 09/14/2026 to Fri 09/18/2026  
 0600 Continuous 1630  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**BECK\_-NIAGARA\_230\_PA27**

Tue 09/15/2026 to Tue 11/17/2026  
 0500 Continuous 2330  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1900 MW**  
 100 MW  
 2000 MW

**MARCY\_-FRASANX\_345\_UCC2-41**

Tue 09/15/2026 to Tue 09/29/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3225 MW**  
 500 MW  
 3725 MW

**W49TH\_ST\_345KV\_5**

Sat 09/26/2026 to Thu 12/24/2026  
 0201 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
 360 MW  
 660 MW

**GOETHALS\_345KV\_5**

Mon 09/28/2026 to Sat 10/03/2026  
 0001 Continuous 0300  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**PANNELL\_-CLAY\_345\_1**

Mon 09/28/2026 to Fri 10/02/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1300 MW**  
 950 MW  
 2250 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**PANNELL -CLAY\_345\_2**

Mon 10/05/2026 to Fri 10/09/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

**DYSINGER-STA\_255\_345\_DH1**

Sun 10/11/2026 to Wed 11/04/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

**NEPTUNE -DUFFYAVE\_345\_NEPTUNE**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_765\_345\_AT1**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

**MARCY\_765\_345\_AT2**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1700 MW</b>	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA-MARCY\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA-MARCY\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

SCH - HQ_CEDARS	<b>FWD (Import)</b>	REV (Export)
	<b>190 MW</b>	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

MOSES SOUTH	<b>FWD (Import)</b>	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

MOSES SOUTH	<b>FWD (Import)</b>	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**ROSETON\_EFISHKIL\_345\_RFK305**

Mon 10/26/2026 to Fri 11/06/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

UPNY CONED	<b>FWD (Import)</b>	REV (Export)
	<b>7470 MW</b>	
Impacts Total Transfer Capability	740 MW	
TTC with All Lines In Service	8210 MW	

**DUNWODIE\_345KV\_7**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>FWD (Import)</b>	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_8**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	<b>FWD (Import)</b>	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**STLAWRNC-MOSES\_\_230\_L34P**

Thu 10/29/2026 to Fri 11/13/2026  
 0900 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_3**

Mon 11/02/2026 to Mon 11/02/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_5**

Mon 11/02/2026 to Mon 11/02/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 11/02/2026 to Mon 12/14/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Mon 11/02/2026 to Sat 11/07/2026  
 0800 Continuous 1900  
 Work scheduled by: PJM

SCH - PJM\_VFT  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW** **0 MW**  
 315 MW 315 MW  
 315 MW 315 MW

**ROSETON\_EFISHKIL\_345\_RFK305**

Fri 11/06/2026 to Fri 11/13/2026  
 1600 Continuous 1600  
 Work scheduled by: CHGE

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**7470 MW**  
 740 MW  
 8210 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MILLWOOD-EASTVIEW\_345\_W99**

Mon 11/09/2026 to Mon 11/09/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

	UPNY CONED	FWD (Import)	REV (Export)
		<b>8015 MW</b>	
	Impacts Total Transfer Capability	195 MW	
	TTC with All Lines In Service	8210 MW	

**SPRNBK\_345KV\_RNS5**

Mon 11/09/2026 to Mon 11/09/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

	SPR/DUN-SOUTH	FWD (Import)	REV (Export)
		<b>3200 MW</b>	
	Impacts Total Transfer Capability	1400 MW	
	TTC with All Lines In Service	4600 MW	

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 11/16/2026 to Sat 11/28/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

	UPNY CONED	FWD (Import)	REV (Export)
		<b>8175 MW</b>	
	Impacts Total Transfer Capability	35 MW	
	TTC with All Lines In Service	8210 MW	

**BUCHAN\_S-MILLWOOD\_345\_W98**

Mon 11/16/2026 to Sat 11/28/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

	UPNY CONED	FWD (Import)	REV (Export)
		<b>8175 MW</b>	
	Impacts Total Transfer Capability	35 MW	
	TTC with All Lines In Service	8210 MW	

**LOVETT\_-BUCHAN\_S\_345\_Y88**

Mon 11/16/2026 to Sat 11/28/2026  
 0001 Continuous 2330  
 Work scheduled by: ConEd

	UPNY CONED	FWD (Import)	REV (Export)
		<b>7960 MW</b>	
	Impacts Total Transfer Capability	250 MW	
	TTC with All Lines In Service	8210 MW	

**STLAWRNC-MOSES\_230\_L33P**

Mon 11/16/2026 to Fri 11/20/2026  
 0600 Continuous 1630  
 Work scheduled by: NYPA

	SCH - OH - NY	FWD (Import)	REV (Export)
	Impacts Total Transfer Capability		
	TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BECK\_\_-NIAGARA\_230\_PA27**

Mon 11/23/2026 to Fri 11/27/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY	<b>2050 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

**EDIC\_\_-FRASER\_345\_EF24-40**

Mon 11/30/2026 to Sun 12/06/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC	<b>3225 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

**DUNWODIE\_345KV\_3**

Fri 12/04/2026 to Fri 12/04/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**W49TH\_ST-E13THSTA\_345\_M54**

Fri 12/04/2026 to Fri 12/04/2026  
0101 Continuous 0130  
Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**W49TH\_ST-E13THSTA\_345\_M54**

Thu 12/10/2026 to Thu 12/10/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_3**

Sat 12/12/2026 to Mon 12/14/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DUNWODIE\_345KV\_5**

Sat 12/12/2026 to Mon 12/14/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Wed 12/23/2026 to Wed 12/23/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**8015 MW**  
 195 MW  
 8210 MW

**SPRNBK\_345KV\_RNS5**

Wed 12/23/2026 to Wed 12/23/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
 1400 MW  
 4600 MW

**HUDSONTP-W49TH\_ST\_345\_Y56**

Fri 12/25/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
 660 MW  
 660 MW

**W49TH\_ST\_345KV\_8**

Fri 12/25/2026 to Tue 01/12/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
 360 MW  
 660 MW

**STLAWRNC-MOSES\_230\_L34P**

Fri 12/25/2026 to Fri 12/25/2026  
 0800 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST-E13THSTA\_345\_M54**

Sun 12/27/2026 to Sun 12/27/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**W49TH\_ST-E13THSTA\_345\_M54**

Wed 12/30/2026 to Wed 12/30/2026  
 0030 Continuous 0100  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4**

Mon 02/08/2027 to Tue 02/09/2027  
 0001 0200  
 Work scheduled by:

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBK\_345KV\_RNS5**

Tue 02/09/2027 to Fri 02/19/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBK\_W49TH\_ST\_345\_M51**

Tue 02/09/2027 to Fri 02/19/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 03/01/2027 to Wed 03/03/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4**

Thu 03/11/2027 to Sun 03/14/2027  
 0001 0100  
 Work scheduled by:

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBK\_345KV\_RNS5**

Sun 03/14/2027 to Wed 03/17/2027  
 0101 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBK\_-W49TH\_ST\_345\_M51**

Sun 03/14/2027 to Wed 03/17/2027  
 0101 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sun 04/04/2027 to Sun 04/04/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sun 04/04/2027 to Wed 04/07/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>NEWBRDGE_345_138_BK_1</b>					
Mon 05/10/2027	to	Fri 05/14/2027	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
0600	Continuous	1600	Impacts Total Transfer Capability	<b>375 MW</b>	
Work scheduled by: LI			TTC with All Lines In Service	285 MW	
				660 MW	
<b>NEWBRDGE_345_138_BK_2</b>					
Mon 05/10/2027	to	Fri 05/14/2027	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
0600	Continuous	1600	Impacts Total Transfer Capability	<b>375 MW</b>	
Work scheduled by: LI			TTC with All Lines In Service	285 MW	
				660 MW	
<b>NEWBRDGE-DUFFYAVE_345_501</b>					
Mon 05/10/2027	to	Fri 05/14/2027	SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
0600	Continuous	1600	Impacts Total Transfer Capability	<b>0 MW</b>	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
				660 MW	
<b>CHATGUAY-MASSENA_765_7040</b>					
Tue 05/25/2027	to	Sat 05/29/2027	SCH - HQ - NY	FWD (Import)	REV (Export)
0001	Continuous	0130	Impacts Total Transfer Capability	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA			TTC with All Lines In Service	1500 MW	1000 MW
				1500 MW	1000 MW
<b>CHATGUAY-MASSENA_765_7040</b>					
Tue 05/25/2027	to	Sat 05/29/2027	MOSES SOUTH	FWD (Import)	REV (Export)
0001	Continuous	0130	Impacts Total Transfer Capability	<b>1750 MW</b>	
Work scheduled by: NYPA			TTC with All Lines In Service	1650 MW	
				3400 MW	
<b>MARCY__765_345_AT1</b>					
Tue 05/25/2027	to	Sat 05/29/2027	MOSES SOUTH	FWD (Import)	REV (Export)
0001	Continuous	0130	Impacts Total Transfer Capability	<b>1750 MW</b>	
Work scheduled by: NYPA			TTC with All Lines In Service	1650 MW	
				3400 MW	

ARR: 19

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY\_\_\_765\_345\_AT2**

Tue 05/25/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1700 MW</b>	
1700 MW	
3400 MW	

**MASSENA\_-MARCY\_\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>475 MW</b>	<b>1000 MW</b>
1025 MW	0 MW
1500 MW	1000 MW

**MASSENA\_-MARCY\_\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2595 MW</b>	
1130 MW	
3725 MW	

**MASSENA\_-MARCY\_\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>190 MW</b>	
80 MW	
270 MW	

**MASSENA\_-MARCY\_\_\_765\_MSU1**

Tue 05/25/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>500 MW</b>	
2900 MW	
3400 MW	

**MASSENA\_-MARCY\_\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Tue 05/25/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>500 MW</b>	
2900 MW	
3400 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 09/20/2027 to Mon 09/20/2027  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPNY CONED	<b>8175 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	35 MW		
TTC with All Lines In Service	8210 MW		

**BUCHAN\_S-MILLWOOD\_345\_W97**

Tue 09/21/2027 to Tue 09/21/2027  
 0130 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	<b>8175 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	35 MW		
TTC with All Lines In Service	8210 MW		

**WOOD\_ST-PLSNTVLE\_345\_Y87**

Mon 10/04/2027 to Sat 10/16/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	<b>7795 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	415 MW		
TTC with All Lines In Service	8210 MW		

**SPRNBK\_-UNIONHBS\_345\_Y49**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA	<b>775 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	725 MW		
TTC with All Lines In Service	1500 MW		

**UNIONDHB\_345\_138\_AT1**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA	<b>1250 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	250 MW		
TTC with All Lines In Service	1500 MW		

**UNIONDHB\_345\_138\_AT2**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA	<b>1250 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	250 MW		
TTC with All Lines In Service	1500 MW		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Friday, April 24, 2026 to Saturday, October 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	