

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 08/01/2026
 0001 Continuous 2359
 Work scheduled by:

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2400 MW 2400 MW
 100 MW 250 MW
 2500 MW 2650 MW

SCH-IMO-NYISO_LIMIT_1900

Sat 11/01/2025 to Thu 04/30/2026
 0001 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2200 MW
 300 MW
 2500 MW

DYSINGER-GRAHAM__345_DG1

Tue 02/10/2026 to Sun 05/31/2026
 1122 Continuous 2100
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

GRAHAM_-STA_255_345_GH1-43

Tue 02/10/2026 to Sun 05/31/2026
 1122 Continuous 2100
 Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| NRTH1385-NOR HBR_138_601 | | | | | | | | | |
|--|------------|----------------|--|-----------------------------------|--|--|--------------|--------------|--|
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | | FWD (Import) | REV (Export) | |
| 0600 | Continuous | 1500 | | Impacts Total Transfer Capability | | | 60 MW | 60 MW | |
| Work scheduled by: LI | | | | TTC with All Lines In Service | | | 100 MW | 100 MW | |
| | | | | | | | 160 MW | 160 MW | |
| NRTH1385-NOR HBR_138_602 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | | FWD (Import) | REV (Export) | |
| 0600 | Continuous | 1500 | | Impacts Total Transfer Capability | | | 60 MW | 60 MW | |
| Work scheduled by: LI | | | | TTC with All Lines In Service | | | 100 MW | 100 MW | |
| | | | | | | | 160 MW | 160 MW | |
| NRTH1385-NOR HBR_138_603 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | | FWD (Import) | REV (Export) | |
| 0600 | Continuous | 1500 | | Impacts Total Transfer Capability | | | 60 MW | 60 MW | |
| Work scheduled by: LI | | | | TTC with All Lines In Service | | | 100 MW | 100 MW | |
| | | | | | | | 160 MW | 160 MW | |
| NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | | FWD (Import) | REV (Export) | |
| 0600 | | 1500 | | Impacts Total Transfer Capability | | | 0 MW | 0 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | | | 160 MW | 160 MW | |
| | | | | | | | 160 MW | 160 MW | |
| NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | | FWD (Import) | REV (Export) | |
| 0600 | | 1500 | | Impacts Total Transfer Capability | | | 0 MW | 0 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | | | 160 MW | 160 MW | |
| | | | | | | | 160 MW | 160 MW | |
| NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603 | | | | | | | | | |
| Thu 02/26/2026 | to | Fri 05/15/2026 | | SCH - NPX_1385 | | | FWD (Import) | REV (Export) | |
| 0600 | | 1500 | | Impacts Total Transfer Capability | | | 0 MW | 0 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | | | 160 MW | 160 MW | |
| | | | | | | | 160 MW | 160 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NRTHPORT_138_NNC

Thu 02/26/2026 to Fri 05/15/2026
 0600 Continuous 1500
 Work scheduled by: LI

| | | |
|-----------------------------------|-------------|-------------|
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 160 MW | 160 MW |
| TTC with All Lines In Service | 160 MW | 160 MW |

MARCY__FRASANX_345_UCC2-41

Thu 03/26/2026 to Thu 04/30/2026 UPDATED by NYISO 04/28/2026 15:28
 2101 Continuous 0659 ARR: 19
 Work scheduled by: NYISO

| | | |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | 3225 MW | REV (Export) |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3725 MW | |

WOOD_ST_PLSNTVLE_345_Y86

Mon 03/30/2026 to Sun 05/03/2026 EXTENDED by ConEd 04/25/2026 14:09
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | 7820 MW | REV (Export) |
| Impacts Total Transfer Capability | 390 MW | |
| TTC with All Lines In Service | 8210 MW | |

OSWEGO_COMPLEX_AVR_O/S

Sat 04/04/2026 to Sun 09/13/2026 FORCED by NGrid 01/27/2025 10:33
 0800 Continuous 0000
 Work scheduled by: NGrid

| | | |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | 3640 MW | REV (Export) |
| Impacts Total Transfer Capability | 85 MW | |
| TTC with All Lines In Service | 3725 MW | |

WATRCURE-OAKDALE_345_31

Wed 04/15/2026 to Fri 05/15/2026 EXTENDED by NYSEG 04/09/2026 10:23
 0700 Continuous 1500
 Work scheduled by: NYSEG

| | | |
|-----------------------------------|----------------|----------------|
| SCH - PJ - NY | 2400 MW | 2400 MW |
| Impacts Total Transfer Capability | 100 MW | 250 MW |
| TTC with All Lines In Service | 2500 MW | 2650 MW |

SCH-PJM-NYISO_LIMIT_1500

Fri 04/17/2026 to Fri 05/15/2026 EXTENDED by NYSEG 04/09/2026 10:23
 0001 Continuous 1500
 Work scheduled by: NYSEG

| | | |
|-----------------------------------|----------------|--------------|
| SCH - PJ - NY | 1800 MW | REV (Export) |
| Impacts Total Transfer Capability | 700 MW | |
| TTC with All Lines In Service | 2500 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Fri 04/17/2026 to Sat 05/30/2026
 1900 Continuous 1700
 Work scheduled by: HQ

EXT FORCED by HQ 04/22/2026 14:24

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|--------------|
| FWD (Import) | REV (Export) |
| | 0 MW |
| | 100 MW |
| | 100 MW |

W49TH_ST_345KV_5

Sat 04/18/2026 to Tue 05/05/2026
 0021 Continuous 2359
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|---------------|
| FWD (Import) | REV (Export) |
| | 200 MW |
| | 460 MW |
| | 660 MW |

W49TH_ST_345KV_7

Sat 04/18/2026 to Tue 05/05/2026
 0021 Continuous 2359
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|---------------|
| FWD (Import) | REV (Export) |
| | 200 MW |
| | 460 MW |
| | 660 MW |

SCH-IMO-NYISO_LIMIT_1700

Sun 04/19/2026 to Fri 05/01/2026
 0630 Continuous 1600
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|----------------|
| FWD (Import) | REV (Export) |
| | 2000 MW |
| | 500 MW |
| | 2500 MW |

SCH-NYISO-IMO_LIMIT_1400

Sun 04/19/2026 to Fri 05/01/2026
 0630 Continuous 1600
 Work scheduled by: IESO

UPDATED by IESO 04/16/2026 10:25

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|----------------|
| FWD (Import) | REV (Export) |
| | 1700 MW |
| | 150 MW |
| | 1850 MW |

SPRNBRK_UNIONHBS_345_Y49

Mon 04/20/2026 to Sun 05/03/2026
 0101 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|---------------|
| FWD (Import) | REV (Export) |
| | 775 MW |
| | 725 MW |
| | 1500 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

UNIONDHB_345_138_AT1

Mon 04/20/2026 to Sun 05/03/2026
 0101 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

UNIONDHB_345_138_AT2

Mon 04/20/2026 to Sun 05/03/2026
 0101 Continuous 0259
 Work scheduled by: ConEd

UPDATED by LI 01/28/2026 15:52

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
 250 MW
 1500 MW

DYSINGER-BYRON__345_DB2

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
 350 MW
 3200 MW

DYSINGER-BYRON__345_DB2 , DYSINGER-GRAHAM__345_DG1

Tue 04/21/2026 to Sun 05/03/2026
 0500 2100
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

DYSINGER-BYRON__345_DB2 , GRAHAM_-STA_255_345_GH1-43

Tue 04/21/2026 to Sun 05/03/2026
 0500 2100
 Work scheduled by:

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

STA_255_-BYRON__345_BH2-50

Tue 04/21/2026 to Sun 05/03/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

UPDATED by NYPA 02/23/2026 11:10

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
 350 MW
 3200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | |
|---|---|----------------|----------------|
| STA_255_-BYRON_345_BH2-50 , DYSINGER-GRAHAM_345_DG1 | | FWD (Import) | REV (Export) |
| Tue 04/21/2026 to Sun 05/03/2026 | DYSINGER EAST | | |
| 0500 to 2100 | Impacts Total Transfer Capability | | |
| Work scheduled by: | TTC with All Lines In Service | | |
| <hr style="border-top: 1px dashed black;"/> | | | |
| STA_255_-BYRON_345_BH2-50 , GRAHAM_-STA_255_345_GH1-43 | | FWD (Import) | REV (Export) |
| Tue 04/21/2026 to Sun 05/03/2026 | DYSINGER EAST | | |
| 0500 to 2100 | Impacts Total Transfer Capability | | |
| Work scheduled by: | TTC with All Lines In Service | | |
| <hr style="border-top: 1px dashed black;"/> | | | |
| SCH-HQ_CEDARS-NYISO_LIMIT_220 | | FWD (Import) | REV (Export) |
| Tue 04/21/2026 to Sat 05/30/2026 | SCH - HQ_CEDARS | | |
| 1900 Continuous 1700 | Impacts Total Transfer Capability | 220 MW | |
| Work scheduled by: HQ | TTC with All Lines In Service | 59 MW | |
| | | 279 MW | |
| | <u>EXT FORCED by HQ, 04/22/2026 14:24</u> | | |
| <hr style="border-top: 1px dashed black;"/> | | | |
| SCH-HQ_CEDARS-NYISO_LIMIT_180 | | FWD (Import) | REV (Export) |
| Mon 04/27/2026 to Tue 04/28/2026 | SCH - HQ_CEDARS | | |
| 0600 Continuous 1900 | Impacts Total Transfer Capability | 180 MW | |
| Work scheduled by: HQ | TTC with All Lines In Service | 99 MW | |
| | | 279 MW | |
| <hr style="border-top: 1px dashed black;"/> | | | |
| BECK_-NIAGARA_345_PA301 | | FWD (Import) | REV (Export) |
| Mon 04/27/2026 to Fri 05/01/2026 | SCH - OH - NY | | |
| 0630 Continuous 1600 | Impacts Total Transfer Capability | 1150 MW | 1000 MW |
| Work scheduled by: IESO | TTC with All Lines In Service | 1350 MW | 850 MW |
| | | 2500 MW | 1850 MW |
| | <u>UPDATED by IESO 04/16/2026 10:25</u> | | |
| <hr style="border-top: 1px dashed black;"/> | | | |
| PIERCBRK-FIVEMILE_345_37 | | FWD (Import) | REV (Export) |
| Tue 04/28/2026 to Wed 05/13/2026 | SCH - PJ - NY | | |
| 0800 Continuous 1600 | Impacts Total Transfer Capability | 2300 MW | 2300 MW |
| Work scheduled by: PJM | TTC with All Lines In Service | 200 MW | 350 MW |
| | | 2500 MW | 2650 MW |
| | <u>CANCELLED by TO 04/27/2026 14:04</u> | | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_180

Wed 04/29/2026 to Thu 04/30/2026
 0600 Continuous 1900
 Work scheduled by: HQ

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
180 MW
 99 MW
 279 MW

VOLNEY_-MARCY__345_19

Thu 04/30/2026 to Thu 04/30/2026
 0700 Daily(No Weekends) 1300
 Work scheduled by: NGrid ARR: 19

OSWEGO EXPORT
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
5250 MW
 0 MW
 5250 MW

VOLNEY_-MARCY__345_19

Thu 04/30/2026 to Thu 04/30/2026
 0700 Daily(No Weekends) 1300
 Work scheduled by: NGrid ARR: 19

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3525 MW
 200 MW
 3725 MW

MARCY_-FRASANNX_345_UCC2-41

Thu 04/30/2026 to Sat 05/02/2026
 1301 Continuous 0800
 Work scheduled by: NYISO UPDATED by NYISO 04/28/2026 15:28 ARR: 19

CENTRAL EAST - VC
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3225 MW
 500 MW
 3725 MW

SCH-NYISO-HQ_LIMIT_0

Sat 05/02/2026 to Sat 05/02/2026
 0500 Continuous 2000
 Work scheduled by: HQ

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
 1000 MW
 1000 MW

DUNWODIE_345KV_3

Sun 05/03/2026 to Sun 05/03/2026
 0001 Continuous 0030
 Work scheduled by: ConEd EXTENDED by ConEd 04/25/2026 14:38

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

Sun 05/03/2026 to Sun 05/03/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

EXTENDED by ConEd 04/25/2026 14:38

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 3800 MW | |
| 800 MW | |
| 4600 MW | |

CHAT_DC_GC1

Sun 05/03/2026 to Wed 05/06/2026
 0100 Continuous 2000
 Work scheduled by: HQ

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|---------------|
| FWD (Import) | REV (Export) |
| | 500 MW |
| | 500 MW |
| | 1000 MW |

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 05/03/2026 to Wed 05/06/2026
 0100 Continuous 2000
 Work scheduled by:

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 1370 MW | 0 MW |
| 130 MW | 1000 MW |
| 1500 MW | 1000 MW |

CHAT_DC_GC2

Sun 05/03/2026 to Wed 05/06/2026
 0100 Continuous 2000
 Work scheduled by: HQ

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|---------------|
| FWD (Import) | REV (Export) |
| | 500 MW |
| | 500 MW |
| | 1000 MW |

CHATGUAY-MASSENA_765_7040

Sun 05/03/2026 to Wed 05/06/2026
 0100 Continuous 0200
 Work scheduled by: NYPA

UPDATED by HQ, 03/31/2026 08:32

SCH - HQ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|--------------|
| FWD (Import) | REV (Export) |
| 0 MW | 0 MW |
| 1500 MW | 1000 MW |
| 1500 MW | 1000 MW |

CHATGUAY-MASSENA_765_7040

Sun 05/03/2026 to Wed 05/06/2026
 0100 Continuous 0200
 Work scheduled by: NYPA

UPDATED by HQ, 03/31/2026 08:32

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 1750 MW | |
| 1650 MW | |
| 3400 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7

Sun 05/03/2026 to Sun 05/03/2026
0100 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

SCH-HQ-NYISO_LIMIT_900

Sun 05/03/2026 to Wed 05/06/2026
0100 Continuous 2000
Work scheduled by: HQ

SCH - HQ - NY **900 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

SCH-NYISO-HQ_LIMIT_0

Sun 05/03/2026 to Wed 05/06/2026
0100 Continuous 2000
Work scheduled by: HQ

SCH - HQ - NY **0 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 1000 MW

FWD (Import) REV (Export)

WOOD_ST_PLSNTVLE_345_Y86

Sun 05/03/2026 to Sat 05/09/2026
0201 Continuous 0200 EXTENDED by ConEd 04/25/2026 14:38
Work scheduled by: ConEd

UPNY CONED **7820 MW**
Impacts Total Transfer Capability 390 MW
TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

SHOR_NPX-SHOREHAM_138_CSC

Sun 05/03/2026 to Fri 05/15/2026
0700 Continuous 1800 UPDATED by ISONE 02/18/2026 11:51
Work scheduled by: ISONE

SCH - NPX_CSC **0 MW** **0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

FWD (Import) REV (Export)

MILLWOOD-EASTVIEW_345_W82

Mon 05/04/2026 to Mon 05/04/2026
0001 Continuous 2200 CANCELLED by TO 04/24/2026 15:05
Work scheduled by: ConEd

UPNY CONED **8015 MW**
Impacts Total Transfer Capability 195 MW
TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|---|------------|----------------|---|-----------------------------------|---------------------------|
| SPRNBK_345KV_RNS4 | | | | FWD (Import) | REV (Export) |
| Mon 05/04/2026 | to | Mon 05/04/2026 | <u>CANCELLED by TO 04/24/2026 15:05</u> | SPR/DUN-SOUTH | 3200 MW |
| 0001 | Continuous | 0030 | | Impacts Total Transfer Capability | 1400 MW |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 4600 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| BECK_-NIAGARA_230_PA27 | | | | FWD (Import) | REV (Export) |
| Mon 05/04/2026 | to | Fri 05/08/2026 | | SCH - OH - NY | 1900 MW |
| 0900 | Continuous | 1700 | | Impacts Total Transfer Capability | 100 MW |
| Work scheduled by: IESO | | | | TTC with All Lines In Service | 2000 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| SPRNBK_345KV_RNS4 | | | | FWD (Import) | REV (Export) |
| Mon 05/04/2026 | to | Mon 05/04/2026 | <u>CANCELLED by TO 04/24/2026 15:05</u> | SPR/DUN-SOUTH | 3200 MW |
| 2130 | Continuous | 2200 | | Impacts Total Transfer Capability | 1400 MW |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 4600 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| HOPATCON-RAMAPO_500_5018 | | | | FWD (Import) | REV (Export) |
| Thu 05/07/2026 | to | Sat 05/09/2026 | | SCH - PJ - NY | 1000 MW 1050 MW |
| 0001 | Continuous | 1800 | | Impacts Total Transfer Capability | 1200 MW 150 MW |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 2200 MW 1200 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| HOPATCON-RAMAPO_500_5018 | | | | FWD (Import) | REV (Export) |
| Thu 05/07/2026 | to | Sat 05/09/2026 | | UPNY CONED | 8015 MW |
| 0001 | Continuous | 1800 | | Impacts Total Transfer Capability | 195 MW |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 8210 MW |
| <hr style="border-top: 1px dashed black;"/> | | | | | |
| HOPATCON-RAMAPO_500_5018 | | | | FWD (Import) | REV (Export) |
| Thu 05/07/2026 | to | Sat 05/09/2026 | | TOTAL EAST | 6800 MW |
| 0001 | Continuous | 1800 | | Impacts Total Transfer Capability | 750 MW |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 7550 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__345_345_PAR3500

Thu 05/07/2026 to Sat 05/09/2026
 0001 Continuous 1800
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|----------------|
| SCH - PJ - NY | FWD (Import) | REV (Export) |
| | 1350 MW | 1050 MW |
| Impacts Total Transfer Capability | 850 MW | 150 MW |
| TTC with All Lines In Service | 2200 MW | 1200 MW |

RAMAPO__345_345_PAR4500

Thu 05/07/2026 to Sat 05/09/2026
 0001 Continuous 1800
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|----------------|
| SCH - PJ - NY | FWD (Import) | REV (Export) |
| | 1350 MW | 1050 MW |
| Impacts Total Transfer Capability | 850 MW | 150 MW |
| TTC with All Lines In Service | 2200 MW | 1200 MW |

RAMAPO__500_345_BK 1500

Thu 05/07/2026 to Sat 05/09/2026
 0001 Continuous 1800
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|----------------|
| SCH - PJ - NY | FWD (Import) | REV (Export) |
| | 1000 MW | 1050 MW |
| Impacts Total Transfer Capability | 1200 MW | 150 MW |
| TTC with All Lines In Service | 2200 MW | 1200 MW |

RAMAPO__500_345_BK 1500

Thu 05/07/2026 to Sat 05/09/2026
 0001 Continuous 1800
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 8015 MW | |
| Impacts Total Transfer Capability | 195 MW | |
| TTC with All Lines In Service | 8210 MW | |

MARCY__FRASANX_345_UCC2-41

Thu 05/07/2026 to Sat 05/30/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

| | | |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | FWD (Import) | REV (Export) |
| | 3225 MW | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3725 MW | |

DUNWODIE_345KV_3

Sat 05/09/2026 to Sat 05/09/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

EXTENDED by ConEd 04/25/2026 14:38

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

Sat 05/09/2026 to Sat 05/09/2026
0130 Continuous 0200
Work scheduled by: ConEd

EXTENDED by ConEd 04/25/2026 14:38

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

RAMAPO_-BUCHAN_N_345_Y94

Sat 05/09/2026 to Sun 05/10/2026
1801 Continuous 1300
Work scheduled by: ConEd

UPDATED by ConEd 04/27/2026 08:01

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7795 MW
415 MW
8210 MW

BECK_-PACKARD_230_BP76

Sun 05/10/2026 to Fri 05/15/2026
0530 Continuous 1600
Work scheduled by: IESO

UPDATED by NGrid 04/20/2026 11:53

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1600 MW 1050 MW
400 MW 550 MW
2000 MW 1600 MW

FIVEMILE-LIMELAKE_345_49

Mon 05/11/2026 to Thu 06/25/2026
0500 Continuous 1800
Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2000 MW 1050 MW
200 MW 150 MW
2200 MW 1200 MW

LIMELAKE-ESTOLERD_345_29

Mon 05/11/2026 to Thu 06/25/2026
0500 Continuous 1800
Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2000 MW 1050 MW
200 MW 150 MW
2200 MW 1200 MW

NIAGARA_345_230_AT4

Mon 05/11/2026 to Sat 05/30/2026
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1900 MW 1200 MW
100 MW 400 MW
2000 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Tue 05/12/2026 to Sun 05/31/2026
 0500 Continuous 2100
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

MILLWOOD-EASTVIEW_345_W85

Thu 05/14/2026 to Thu 05/14/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 8015 MW | |
| Impacts Total Transfer Capability | 195 MW | |
| TTC with All Lines In Service | 8210 MW | |

SPRNBRK_345KV_RNS3

Thu 05/14/2026 to Thu 05/14/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

RAMAPO_-BUCHAN_N_345_Y94

Thu 05/14/2026 to Thu 05/14/2026
 0330 Continuous 0400
 Work scheduled by: ConEd

UPDATED by ConEd 04/27/2026 08:01

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 7795 MW | |
| Impacts Total Transfer Capability | 415 MW | |
| TTC with All Lines In Service | 8210 MW | |

SPRNBRK_345KV_RNS3

Thu 05/14/2026 to Thu 05/14/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

MILLWOOD-EASTVIEW_345_W99

Fri 05/15/2026 to Sat 05/16/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 8015 MW | |
| Impacts Total Transfer Capability | 195 MW | |
| TTC with All Lines In Service | 8210 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|---------------|--------------|
| FWD (Import) | REV (Export) |
| 300 MW | |
| 360 MW | |
| 660 MW | |

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|---------------|--------------|
| FWD (Import) | REV (Export) |
| 300 MW | |
| 360 MW | |
| 660 MW | |

SPRNBK_345KV_RNS5

Fri 05/15/2026 to Fri 05/15/2026
 0201 Continuous 0230
 Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 3200 MW | |
| 1400 MW | |
| 4600 MW | |

SPRNBK_W49TH_ST_345_M51

Fri 05/15/2026 to Mon 06/01/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 3200 MW | |
| 1400 MW | |
| 4600 MW | |

W49TH_ST_345KV_5

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|---------------|--------------|
| FWD (Import) | REV (Export) |
| 300 MW | |
| 360 MW | |
| 660 MW | |

W49TH_ST_345KV_7

Fri 05/15/2026 to Fri 05/15/2026
 1430 Continuous 1500
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|---------------|--------------|
| FWD (Import) | REV (Export) |
| 300 MW | |
| 360 MW | |
| 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

W49TH_ST_345KV_7

Sat 05/16/2026 to Sat 05/16/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

DUNWODIE_345KV_4

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_6

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

SPR/DUN-SOUTH

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
800 MW
 700 MW
 1500 MW

SHORE_RD_345_138_BK 1

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA

Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
 150 MW
 1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2

Sat 05/16/2026 to Thu 05/28/2026
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/01/2026 10:07

CONED - LIPA
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
 150 MW
 1500 MW

W49TH_ST_345KV_5

Mon 05/18/2026 to Mon 05/18/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

W49TH_ST_345KV_7

Mon 05/18/2026 to Mon 05/18/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

CANCELLED by TO 04/28/2026 15:14

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

BEAR SWP-EASTOVER_230_E205W

Mon 05/18/2026 to Sat 05/23/2026
 0630 Continuous 1800
 Work scheduled by: NGrid

UPDATED by NGrid 04/24/2026 15:05

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
 900 MW
 3200 MW

ROCHESTR-PANNELL_345_RP2

Mon 05/18/2026 to Fri 05/22/2026
 0700 Continuous 1500
 Work scheduled by: RGE

DYSINGER EAST
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
 900 MW
 3200 MW

GOETHALS_345KV_5

Sun 05/24/2026 to Sat 05/30/2026
 0001 Continuous 0300
 Work scheduled by: ConEd

STATEN ISLAND
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS5

Mon 06/01/2026 to Mon 06/01/2026
 0130 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3200 MW | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

HUDSONTP-W49TH_ST_345_Y56

Mon 06/01/2026 to Fri 06/05/2026
 0600 Continuous 1600
 Work scheduled by: ConEd

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_7

Mon 06/01/2026 to Mon 06/01/2026
 0600 Continuous 0630
 Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_8

Mon 06/01/2026 to Mon 06/01/2026
 0600 Continuous 0630
 Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

MARCY_345KV_CSC

Mon 06/01/2026 to Sun 06/14/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | FWD (Import) | REV (Export) |
| | 3650 MW | |
| Impacts Total Transfer Capability | 75 MW | |
| TTC with All Lines In Service | 3725 MW | |

LEEDS_-HURLYAVE_345_301

Mon 06/01/2026 to Fri 07/03/2026
 0800 Continuous 1600
 Work scheduled by: CHGE

UPDATED by CHGE 01/16/2026 09:18

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 8120 MW | |
| Impacts Total Transfer Capability | 90 MW | |
| TTC with All Lines In Service | 8210 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY__345_Q11

Thu 06/04/2026 to Sun 06/07/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

EXTENDED by ConEd 04/20/2026 11:31

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Fri 06/05/2026 to Fri 06/05/2026
 1530 Continuous 1600
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_8

Fri 06/05/2026 to Fri 06/05/2026
 1530 Continuous 1600
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

MAINESBG-WATRCURE_345_30

Wed 06/10/2026 to Fri 06/12/2026
 0700 Continuous 1500
 Work scheduled by: NYSEG

SCH - PJ - NY **1600 MW 1050 MW**
 Impacts Total Transfer Capability 600 MW 150 MW
 TTC with All Lines In Service 2200 MW 1200 MW

FWD (Import) REV (Export)

INGHAM_C_115_115_PAR 2

Mon 06/22/2026 to Sat 08/29/2026
 0500 Continuous 1900
 Work scheduled by: NGrid

CENTRAL EAST - VC **3605 MW**
 Impacts Total Transfer Capability 120 MW
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
 0900 Continuous 1630
 Work scheduled by: NYPA

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Mon 06/22/2026 to Fri 06/26/2026
0900 Continuous 1630
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
0900 Continuous 1630
Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Mon 07/06/2026 to Fri 07/10/2026
0900 Continuous 1630
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

FIVEMILE-LIMELAKE_345_49

Thu 07/09/2026 to Fri 10/02/2026
0700 Continuous 1700
Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability 200 MW 150 MW
TTC with All Lines In Service 2200 MW 1200 MW

FWD (Import) REV (Export)

LIMELAKE-ESTOLERD_345_29

Thu 07/09/2026 to Fri 10/02/2026
0700 Continuous 1700
Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability 200 MW 150 MW
TTC with All Lines In Service 2200 MW 1200 MW

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Tue 07/21/2026 to Tue 07/21/2026
1200 Continuous 1600
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Tue 07/21/2026 to Tue 07/21/2026
1200 Continuous 1600
Work scheduled by: ISONE

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3625 MW
100 MW
3725 MW

SAND_BAR-PLATSBRG_115_PV20

Wed 07/22/2026 to Fri 07/24/2026
0700 Continuous 1500
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SAND_BAR-PLATSBRG_115_PV20

Wed 07/22/2026 to Fri 07/24/2026
0700 Continuous 1500
Work scheduled by: ISONE

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3625 MW
100 MW
3725 MW

GOETHALS_345KV_5

Sat 08/15/2026 to Sat 08/15/2026
0301 Continuous 0330
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

GOETHALS_345KV_5

Mon 08/17/2026 to Mon 08/17/2026
0630 Continuous 0700
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Sat 09/05/2026 to Sat 09/05/2026
0201 Continuous 2359
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45

Wed 09/09/2026 to Fri 09/11/2026
 0001 Continuous 1830
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

MARCY__765_345_AT1

Wed 09/09/2026 to Thu 09/10/2026
 0700 Continuous 1530
 Work scheduled by: NYPA ARR: 19

MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1650 MW
 TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

W49TH_ST-E13THSTA_345_M54

Fri 09/11/2026 to Fri 09/11/2026
 0001 Continuous 1830
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

MARCY__765_345_AT2

Fri 09/11/2026 to Sat 09/12/2026
 0700 Continuous 1530
 Work scheduled by: NYPA ARR: 19

MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

HUDSONTP-W49TH_ST_345_Y56

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Sat 09/12/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 09/12/2026 to Sat 09/26/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

SCH - PJM_HTP
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
 360 MW
 660 MW

DUNWODIE_345KV_7

Mon 09/14/2026 to Tue 09/15/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30
 SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_8

Mon 09/14/2026 to Tue 09/15/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30
 SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE-MOTTHAVN_345_72

Mon 09/14/2026 to Thu 10/29/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30
 SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

STLAWRNC-MOSES__230_L34P

Mon 09/14/2026 to Fri 09/18/2026
 0600 Continuous 1630
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

BECK__-NIAGARA_230_PA27

Tue 09/15/2026 to Tue 11/17/2026
 0500 Continuous 2330
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
1900 MW
 100 MW
 2000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| MARCY__FRASANNX_345_UCC2-41 | | | | | | | |
|------------------------------------|------------|----------------|--|-----------------------------------|----------------|--------------|--------------|
| Tue 09/15/2026 | to | Tue 09/29/2026 | | | | | |
| 0700 | Continuous | 1530 | | | | | |
| Work scheduled by: NYPA | | | | ARR: 19 | | | |
| | | | | CENTRAL EAST - VC | | FWD (Import) | REV (Export) |
| | | | | Impacts Total Transfer Capability | 3225 MW | | |
| | | | | TTC with All Lines In Service | 500 MW | | |
| | | | | | 3725 MW | | |
| W49TH_ST_345KV_5 | | | | | | | |
| Sat 09/26/2026 | to | Thu 12/24/2026 | | | | | |
| 0201 | Continuous | 2359 | | | | | |
| Work scheduled by: ConEd | | | | | | | |
| | | | | SCH - PJM_HTP | | FWD (Import) | REV (Export) |
| | | | | Impacts Total Transfer Capability | 300 MW | | |
| | | | | TTC with All Lines In Service | 360 MW | | |
| | | | | | 660 MW | | |
| GOETHALS_345KV_5 | | | | | | | |
| Mon 09/28/2026 | to | Sat 10/03/2026 | | | | | |
| 0001 | Continuous | 0300 | | | | | |
| Work scheduled by: ConEd | | | | | | | |
| | | | | STATEN ISLAND | | FWD (Import) | REV (Export) |
| | | | | Impacts Total Transfer Capability | | | |
| | | | | TTC with All Lines In Service | | | |
| PANNELL_-CLAY___345_1 | | | | | | | |
| Mon 09/28/2026 | to | Fri 10/02/2026 | | | | | |
| 0700 | Continuous | 1530 | | | | | |
| Work scheduled by: NYPA | | | | | | | |
| | | | | WEST CENTRAL | | FWD (Import) | REV (Export) |
| | | | | Impacts Total Transfer Capability | 1300 MW | | |
| | | | | TTC with All Lines In Service | 950 MW | | |
| | | | | | 2250 MW | | |
| PANNELL_-CLAY___345_2 | | | | | | | |
| Mon 10/05/2026 | to | Fri 10/09/2026 | | | | | |
| 0700 | Continuous | 1530 | | | | | |
| Work scheduled by: NYPA | | | | | | | |
| | | | | WEST CENTRAL | | FWD (Import) | REV (Export) |
| | | | | Impacts Total Transfer Capability | 1300 MW | | |
| | | | | TTC with All Lines In Service | 950 MW | | |
| | | | | | 2250 MW | | |
| DYSINGER-STA_255_345_DH1 | | | | | | | |
| Sun 10/11/2026 | to | Wed 11/04/2026 | | | | | |
| 0500 | Continuous | 2100 | | | | | |
| Work scheduled by: NYPA | | | | | | | |
| | | | | DYSINGER EAST | | FWD (Import) | REV (Export) |
| | | | | Impacts Total Transfer Capability | 2850 MW | | |
| | | | | TTC with All Lines In Service | 350 MW | | |
| | | | | | 3200 MW | | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_1

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_2

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE-DUFFYAVE_345_501

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ - NY | FWD (Import) | REV (Export) |
| | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1750 MW | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| MARCY__765_345_AT1 | | | | | | | |
|---------------------------------|------------|----------------|---------|-----------------------------------|--|----------------|----------------|
| Wed 10/14/2026 | to | Wed 10/28/2026 | | MOSES SOUTH | | FWD (Import) | REV (Export) |
| 0001 | Continuous | 2359 | ARR: 19 | Impacts Total Transfer Capability | | 1750 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | | 1650 MW | |
| | | | | | | 3400 MW | |
| MARCY__765_345_AT2 | | | | | | | |
| Wed 10/14/2026 | to | Wed 10/28/2026 | | MOSES SOUTH | | FWD (Import) | REV (Export) |
| 0001 | Continuous | 2359 | ARR: 19 | Impacts Total Transfer Capability | | 1700 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | | 1700 MW | |
| | | | | | | 3400 MW | |
| MASSENA_-MARCY__765_MSU1 | | | | | | | |
| Wed 10/14/2026 | to | Wed 10/28/2026 | | SCH - HQ - NY | | FWD (Import) | REV (Export) |
| 0001 | Continuous | 2359 | | Impacts Total Transfer Capability | | 475 MW | 1000 MW |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | | 1025 MW | 0 MW |
| | | | | | | 1500 MW | 1000 MW |
| MASSENA_-MARCY__765_MSU1 | | | | | | | |
| Wed 10/14/2026 | to | Wed 10/28/2026 | | CENTRAL EAST - VC | | FWD (Import) | REV (Export) |
| 0001 | Continuous | 2359 | | Impacts Total Transfer Capability | | 2595 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | | 1130 MW | |
| | | | | | | 3725 MW | |
| MASSENA_-MARCY__765_MSU1 | | | | | | | |
| Wed 10/14/2026 | to | Wed 10/28/2026 | | SCH - HQ_CEDARS | | FWD (Import) | REV (Export) |
| 0001 | Continuous | 2359 | | Impacts Total Transfer Capability | | 190 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | | 80 MW | |
| | | | | | | 270 MW | |
| MASSENA_-MARCY__765_MSU1 | | | | | | | |
| Wed 10/14/2026 | to | Wed 10/28/2026 | | MOSES SOUTH | | FWD (Import) | REV (Export) |
| 0001 | Continuous | 2359 | | Impacts Total Transfer Capability | | 500 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | | 2900 MW | |
| | | | | | | 3400 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Wed 10/14/2026 to Wed 10/28/2026
 0001 to 2359
 Work scheduled by:

| | | |
|-----------------------------------|---------------|--------------|
| MOSES SOUTH | FWD (Import) | REV (Export) |
| | 500 MW | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

ROSETON_EFISHKIL_345_RFK305

Mon 10/26/2026 to Fri 11/06/2026
 0700 Continuous to 1530
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 7470 MW | |
| Impacts Total Transfer Capability | 740 MW | |
| TTC with All Lines In Service | 8210 MW | |

DUNWODIE_345KV_7

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous to 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

DUNWODIE_345KV_8

Wed 10/28/2026 to Thu 10/29/2026
 0001 Continuous to 0200
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

STLAWRNC-MOSES__230_L34P

Thu 10/29/2026 to Fri 11/13/2026
 0900 Continuous to 1600
 Work scheduled by: IESO

| | | |
|-----------------------------------|--------------|--------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

DUNWODIE_345KV_3

Mon 11/02/2026 to Mon 11/02/2026
 0001 Continuous to 2200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5

Mon 11/02/2026 to Mon 11/02/2026
 0001 Continuous 2200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 3800 MW | |
| 800 MW | |
| 4600 MW | |

DUNWODIE-MOTTHAVN_345_71

Mon 11/02/2026 to Mon 12/14/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 3800 MW | |
| 800 MW | |
| 4600 MW | |

LINDN_CG-LNDVFT_345_V-3022

Mon 11/02/2026 to Sat 11/07/2026
 0800 Continuous 1900
 Work scheduled by: PJM

SCH - PJM_VFT
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|--------------|--------------|
| FWD (Import) | REV (Export) |
| 0 MW | 0 MW |
| 315 MW | 315 MW |
| 315 MW | 315 MW |

ROSETON_EFISHKIL_345_RFK305

Fri 11/06/2026 to Fri 11/13/2026
 1600 Continuous 1600
 Work scheduled by: CHGE

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 7470 MW | |
| 740 MW | |
| 8210 MW | |

MILLWOOD-EASTVIEW_345_W99

Mon 11/09/2026 to Mon 11/09/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 8015 MW | |
| 195 MW | |
| 8210 MW | |

SPRNBRK_345KV_RNS5

Mon 11/09/2026 to Mon 11/09/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

| | |
|----------------|--------------|
| FWD (Import) | REV (Export) |
| 3200 MW | |
| 1400 MW | |
| 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W97

Mon 11/16/2026 to Sat 11/28/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED **8175 MW**
 Impacts Total Transfer Capability 35 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

BUCHAN_S-MILLWOOD_345_W98

Mon 11/16/2026 to Sat 11/28/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED **8175 MW**
 Impacts Total Transfer Capability 35 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

LOVETT_-BUCHAN_S_345_Y88

Mon 11/16/2026 to Sat 11/28/2026
 0001 Continuous 2330
 Work scheduled by: ConEd

UPNY CONED **7960 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

STLAWRNC-MOSES__230_L33P

Mon 11/16/2026 to Fri 11/20/2026
 0600 Continuous 1630
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)

BECK_-NIAGARA_230_PA27

Mon 11/23/2026 to Fri 11/27/2026
 0630 Continuous 1600
 Work scheduled by: IESO

SCH - OH - NY **2050 MW**
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 2500 MW

FWD (Import) REV (Export)

EDIC_-FRASER_345_EF24-40

Mon 11/30/2026 to Sun 12/06/2026
 0700 Continuous 1530
 Work scheduled by: NYPA

CENTRAL EAST - VC **3225 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Fri 12/04/2026 to Fri 12/04/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

W49TH_ST-E13THSTA_345_M54

Fri 12/04/2026 to Fri 12/04/2026
 0101 Continuous 0130
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

W49TH_ST-E13THSTA_345_M54

Thu 12/10/2026 to Thu 12/10/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_3

Sat 12/12/2026 to Mon 12/14/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

DUNWODIE_345KV_5

Sat 12/12/2026 to Mon 12/14/2026
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
 800 MW
 4600 MW

MILLWOOD-EASTVIEW_345_W99

Wed 12/23/2026 to Wed 12/23/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

UPNY CONED
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FWD (Import) REV (Export)
8015 MW
 195 MW
 8210 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_345KV_RNS5

Wed 12/23/2026 to Wed 12/23/2026
 2130 Continuous 2200
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | SPR/DUN-SOUTH | 3200 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 1400 MW | | |
| | TTC with All Lines In Service | 4600 MW | | |

HUDSONTP-W49TH_ST_345_Y56

Fri 12/25/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|-------------|--------------|--------------|
| | SCH - PJM_HTP | 0 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 660 MW | | |
| | TTC with All Lines In Service | 660 MW | | |

W49TH_ST_345KV_8

Fri 12/25/2026 to Tue 01/12/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|---------------|--------------|--------------|
| | SCH - PJM_HTP | 300 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 360 MW | | |
| | TTC with All Lines In Service | 660 MW | | |

STLAWRNC-MOSES__230_L34P

Fri 12/25/2026 to Fri 12/25/2026
 0800 Continuous 1600
 Work scheduled by: IESO

| | | | | |
|--|-----------------------------------|--|--------------|--------------|
| | SCH - OH - NY | | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | | | |
| | TTC with All Lines In Service | | | |

W49TH_ST-E13THSTA_345_M54

Sun 12/27/2026 to Sun 12/27/2026
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | SPR/DUN-SOUTH | 3800 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 800 MW | | |
| | TTC with All Lines In Service | 4600 MW | | |

W49TH_ST-E13THSTA_345_M54

Wed 12/30/2026 to Wed 12/30/2026
 0030 Continuous 0100
 Work scheduled by: ConEd

| | | | | |
|--|-----------------------------------|----------------|--------------|--------------|
| | SPR/DUN-SOUTH | 3800 MW | FWD (Import) | REV (Export) |
| | Impacts Total Transfer Capability | 800 MW | | |
| | TTC with All Lines In Service | 4600 MW | | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Mon 02/08/2027 to Tue 02/09/2027
 0001 0200
 Work scheduled by:

| | | |
|-----------------------------------|----------------|------------------------------|
| SPR/DUN-SOUTH | 3800 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

SPRNBK_345KV_RNS5

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|------------------------------|
| SPR/DUN-SOUTH | 3200 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

SPRNBK_-W49TH_ST_345_M51

Tue 02/09/2027 to Fri 02/19/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|------------------------------|
| SPR/DUN-SOUTH | 3200 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

BUCHAN_S-MILLWOOD_345_W97

Mon 03/01/2027 to Wed 03/03/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|------------------------------|
| UPNY CONED | 8175 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Thu 03/11/2027 to Sun 03/14/2027
 0001 0100
 Work scheduled by:

| | | |
|-----------------------------------|----------------|------------------------------|
| SPR/DUN-SOUTH | 3800 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

SPRNBK_345KV_RNS5

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|------------------------------|
| SPR/DUN-SOUTH | 3200 MW | FWD (Import) REV (Export) |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_W49TH_ST_345_M51

Sun 03/14/2027 to Wed 03/17/2027
 0101 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3200 MW | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Sun 04/04/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 8175 MW | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Wed 04/07/2027
 0201 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 8175 MW | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_1

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_2

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 05/10/2027 to Fri 05/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|--------------|--------------|
| SCH - HQ - NY | FWD (Import) | REV (Export) |
| | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1750 MW | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

MARCY__765_345_AT1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

| | | |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1750 MW | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

MARCY__765_345_AT2

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

ARR: 19

| | | |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | FWD (Import) | REV (Export) |
| | 1700 MW | |
| Impacts Total Transfer Capability | 1700 MW | |
| TTC with All Lines In Service | 3400 MW | |

MASSENA -MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|---------------|----------------|
| SCH - HQ - NY | FWD (Import) | REV (Export) |
| | 475 MW | 1000 MW |
| Impacts Total Transfer Capability | 1025 MW | 0 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| CENTRAL EAST - VC | 2595 MW | |
| Impacts Total Transfer Capability | 1130 MW | |
| TTC with All Lines In Service | 3725 MW | |

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ_CEDARS | 190 MW | |
| Impacts Total Transfer Capability | 80 MW | |
| TTC with All Lines In Service | 270 MW | |

MASSENA_MARCY__765_MSU1

Tue 05/25/2027 to Sat 05/29/2027
 0001 Continuous 0130
 Work scheduled by: NYPA

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| MOSES SOUTH | 500 MW | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Tue 05/25/2027 to Sat 05/29/2027
 0001 0130
 Work scheduled by:

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| MOSES SOUTH | 500 MW | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

BUCHAN_S-MILLWOOD_345_W97

Mon 09/20/2027 to Mon 09/20/2027
 0001 Continuous 0030
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| UPNY CONED | 8175 MW | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

BUCHAN_S-MILLWOOD_345_W97

Tue 09/21/2027 to Tue 09/21/2027
 0130 Continuous 0200
 Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| UPNY CONED | 8175 MW | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_PLSNTVLE_345_Y87

Mon 10/04/2027 to Sat 10/16/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED **7795 MW**
 Impacts Total Transfer Capability 415 MW
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

SPRNBK_UNIONHBS_345_Y49

Mon 10/04/2027 to Fri 05/26/2028
 0800 Continuous 1530
 Work scheduled by: NYPA

CONED - LIPA **775 MW**
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

UNIONDHB_345_138_AT1

Mon 10/04/2027 to Fri 05/26/2028
 0800 Continuous 1530
 Work scheduled by: NYPA

CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

UNIONDHB_345_138_AT2

Mon 10/04/2027 to Fri 05/26/2028
 0800 Continuous 1530
 Work scheduled by: NYPA

CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NEWBRDGE_345_138_BK_1

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 28, 2026 to Wednesday, October 27, 2027

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 7550 MW |
| UPNY CONED | 8210 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3400 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE-DUFFYAVE_345_501

Mon 10/11/2027 to Thu 10/14/2027
 0600 Continuous 1600
 Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

BUCHAN_S-MILLWOOD_345_W97

Sun 10/24/2027 to Wed 10/27/2027
 0001 Continuous 0200
 Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| UPNY CONED | 8175 MW | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |