

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-PJM_LIMIT_1000

| | | | | | | | |
|--------------------------|------------|----------------|-----------------|-----------------|-------------------|-----------------------------------|-------------------------|
| Sun 06/29/2014 | to | Fri 10/31/2014 | <u>EXTENDED</u> | <u>by NYISO</u> | <u>08/07/2014</u> | | REV |
| 2000 | Continuous | 2359 | | | | SCH - PJ - NY | (Export) 1300 MW |
| Work scheduled by: NYISO | | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | | TTC with All Lines In Service | 2700 MW |

CHAT_DC_GC2

| | | | | | | | |
|-----------------------|------------|----------------|-----------------|--------------|-------------------|-----------------------------------|-------------------------|
| Wed 09/03/2014 | to | Thu 11/27/2014 | <u>EXTENDED</u> | <u>by HQ</u> | <u>10/24/2014</u> | | FWD |
| 0700 | Continuous | 1700 | | | | MOSES SOUTH | (Import) 2150 MW |
| Work scheduled by: HQ | | | | | | Impacts Total Transfer Capability | 450 MW |
| | | | | | | TTC with All Lines In Service | 2600 MW |

CHAT_DC_GC2

| | | | | | | | |
|-----------------------|------------|----------------|-----------------|--------------|-------------------|-----------------------------------|------------------------|
| Wed 09/03/2014 | to | Thu 11/27/2014 | <u>EXTENDED</u> | <u>by HQ</u> | <u>10/24/2014</u> | | REV |
| 0700 | Continuous | 1700 | | | | SCH - HQ - NY | (Export) 500 MW |
| Work scheduled by: HQ | | | | | | Impacts Total Transfer Capability | 500 MW |
| | | | | | | TTC with All Lines In Service | 1000 MW |

SCH-HQ-NYISO_LIMIT_1350

| | | | | | | | |
|-----------------------|------------|----------------|-----------------|--------------|-------------------|-----------------------------------|-------------------------|
| Wed 10/01/2014 | to | Sun 10/26/2014 | <u>EXTENDED</u> | <u>by HQ</u> | <u>10/24/2014</u> | | FWD |
| 0001 | Continuous | 2200 | | | | SCH - HQ - NY | (Import) 1350 MW |
| Work scheduled by: HQ | | | | | | Impacts Total Transfer Capability | 150 MW |
| | | | | | | TTC with All Lines In Service | 1500 MW |

MARCY____765_345_BK 1

| | | | | | | | |
|-------------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|-------------------------|
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | | FWD |
| 0500 | Continuous | 2200 | | | | MOSES SOUTH | (Import) 1750 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 850 MW |
| | | | | | | TTC with All Lines In Service | 2600 MW |

CHATGUAY-MASSENA__765_7040

| | | | | | | | | |
|-------------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|----------------------|----------------------|
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | | FWD | REV |
| 1200 | Continuous | 2200 | | | | SCH - HQ - NY | (Import) 0 MW | (Export) 0 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| | | | | | | TTC with All Lines In Service | 1500 MW | 1000 MW |

MARCY____765_345_BK 2

| | | | | | | | |
|-------------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|-------------------------|
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | | FWD |
| 1200 | Continuous | 2200 | | | | MOSES SOUTH | (Import) 1700 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 900 MW |
| | | | | | | TTC with All Lines In Service | 2600 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | | | | | |
|----------------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|----------|---------|--|--|--|
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | | |
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | (Import) | | | | | |
| 1200 | Continuous | 2200 | | | | CENTRAL EAST - VC | 2315 MW | | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 660 MW | | | | |
| | | | | | | TTC with All Lines In Service | 2975 MW | | | | |
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | | | | | |
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | (Import) | | | | | |
| 1200 | Continuous | 2200 | | | | MOSES SOUTH | 675 MW | | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1925 MW | | | | |
| | | | | | | TTC with All Lines In Service | 2600 MW | | | | |
| MASSENA_-MARCY____765_MSU1 | | | | | | FWD | REV | | | | |
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | (Import) | (Export) | | | | |
| 1200 | Continuous | 2200 | | | | SCH - HQ - NY | 475 MW | 1000 MW | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1025 MW | 0 MW | | | |
| | | | | | | TTC with All Lines In Service | 1500 MW | 1000 MW | | | |
| CHAT_DC_GC1 | | | | | | FWD | | | | | |
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | (Import) | | | | | |
| 1219 | Continuous | 2200 | | | | MOSES SOUTH | 2150 MW | | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 450 MW | | | | |
| | | | | | | TTC with All Lines In Service | 2600 MW | | | | |
| CHAT_DC_GC1 | | | | | | | REV | | | | |
| Sat 10/04/2014 | to | Sun 10/26/2014 | <u>UPDATED</u> | <u>by HQ</u> | <u>10/25/2014</u> | | (Export) | | | | |
| 1219 | Continuous | 2200 | | | | SCH - HQ - NY | 500 MW | | | | |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 500 MW | | | | |
| | | | | | | TTC with All Lines In Service | 1000 MW | | | | |
| CHAT_DC_GC1 & CHAT_DC_GC2 | | | | | | FWD | | | | | |
| Sat 10/04/2014 | to | Sun 10/26/2014 | | | | (Import) | | | | | |
| 1219 | | 2200 | | | | MOSES SOUTH | 2000 MW | | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 600 MW | | | | |
| | | | | | | TTC with All Lines In Service | 2600 MW | | | | |
| CHAT_DC_GC1 & CHAT_DC_GC2 | | | | | | FWD | REV | | | | |
| Sat 10/04/2014 | to | Sun 10/26/2014 | | | | (Import) | (Export) | | | | |
| 1219 | | 2200 | | | | SCH - HQ - NY | 1370 MW | 0 MW | | | |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 130 MW | 1000 MW | | | |
| | | | | | | TTC with All Lines In Service | 1500 MW | 1000 MW | | | |

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 10/06/2014 to Mon 10/20/2014
0700 Continuous 0559

EXTENDED by HQ 10/08/2014

Work scheduled by: HQ

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

0 MW

40 MW

40 MW

BEAR SWP-ROTTDAM_230_E205W

Mon 10/06/2014 to Fri 10/24/2014
0730 Continuous 1500

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

BECK____-NIAGARA_345_PA301

Fri 10/10/2014 to Fri 10/24/2014
0700 Continuous 1800

UPDATED by NYISO 10/09/2014

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV

(Import) (Export)

1200 MW 1100 MW

700 MW 800 MW

1900 MW 1900 MW

SCH-IMO-NYISO_LIMIT_700

Sat 10/11/2014 to Fri 10/24/2014
0800 Continuous 1800

UPDATED by NYISO 10/09/2014

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

1000 MW

900 MW

1900 MW

COOPERS_-ROCKTVRN_345_CRT-42

Fri 10/17/2014 to Mon 10/20/2014
2200 Continuous 0700

UPDATED by NYISO 10/18/2014

Work scheduled by: NYISO

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

2720 MW

255 MW

2975 MW

WOOD_ST_-PLSNTVLE_345_Y87

Mon 10/20/2014 to Mon 10/20/2014
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

4000 MW

1100 MW

5100 MW

PLSNTVLY_345KV_RNS4

Mon 10/20/2014 to Thu 10/23/2014
0001 Continuous 2300

EXTENDED by CONED 10/23/2014

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

3800 MW

1300 MW

5100 MW

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90

Mon 10/20/2014 to Sat 10/25/2014

0001 Continuous 2030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

EGRDNCTY_345_138_BK 1

Mon 10/20/2014 to Sun 11/09/2014

0100 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_BK 2

Mon 10/20/2014 to Sun 11/09/2014

0100 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SPRNBRK_-EGRDNCTR_345_Y49

Mon 10/20/2014 to Sun 11/09/2014

0100 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **775 MW**
Impacts Total Transfer Capability 725 MW
TTC with All Lines In Service 1500 MW

FROST_BR-LONG_MTN_345_352

Mon 10/20/2014 to Fri 10/24/2014

0600 Continuous 1637

Work scheduled by: ISONE

UPDATED by ISONE 10/24/2014

FWD REV
(Import) (Export)
SCH - NE - NY **1150 MW 1600 MW**
Impacts Total Transfer Capability 250 MW 0 MW
TTC with All Lines In Service 1400 MW 1600 MW

SCH-NYISO-NE_LIMIT_1200

Mon 10/20/2014 to Fri 10/24/2014

0600 Continuous 1642

Work scheduled by: ISONE

UPDATED by ISONE 10/24/2014

REV
(Export)
SCH - NE - NY **1400 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 1600 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 10/20/2014 to Fri 10/24/2014

0600 Continuous 2033

Work scheduled by: IESO

UPDATED by IESO 10/25/2014

REV
(Export)
SCH - HQ_CEDARS **0 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | |
|-------------------------------|------------|----------------|----------------|-----------------|-----------------------------------|-------------------|----------------|
| GILBOA -LEEDS 345_GL3 | | | | | FWD | | |
| Mon 10/20/2014 | to | Fri 10/24/2014 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/09/2014</u> | (Import) | |
| 0700 | Continuous | 1530 | | | | CENTRAL EAST - VC | 2200 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | | |
| | | | | | TTC with All Lines In Service | | |
| | | | | | 2975 MW | | |
| LEEDS 345_LEEDS SVC | | | | | FWD | | |
| Fri 10/24/2014 | to | Wed 10/29/2014 | <u>FORCED</u> | <u>by NGRID</u> | <u>10/24/2014</u> | (Import) | |
| 0453 | Continuous | 1600 | | | | CENTRAL EAST - VC | 2950 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | | |
| | | | | | TTC with All Lines In Service | | |
| | | | | | 2975 MW | | |
| COOPERS -ROCKTVRN 345_CRT-42 | | | | | FWD | | |
| Fri 10/24/2014 | to | Mon 10/27/2014 | <u>UPDATED</u> | <u>by NYISO</u> | <u>10/24/2014</u> | (Import) | |
| 2200 | Continuous | 0700 | | | | CENTRAL EAST - VC | 2720 MW |
| Work scheduled by: NYISO | | | | | Impacts Total Transfer Capability | | |
| | | | | | TTC with All Lines In Service | | |
| | | | | | 2975 MW | | |
| SHOR_NPX-SHOREHAM 138_NPX_CSC | | | | | FWD | REV | |
| Sat 10/25/2014 | to | Mon 10/27/2014 | <u>FORCED</u> | <u>by LI</u> | <u>10/25/2014</u> | (Import) | (Export) |
| 1709 | Continuous | 2359 | | | | SCH - NPX_CSC | 0 MW 0 MW |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | | |
| | | | | | TTC with All Lines In Service | | |
| | | | | | 330 MW 330 MW | | |
| WOOD_ST -PLSNTVLE 345_Y87 | | | | | FWD | | |
| Sat 10/25/2014 | to | Sat 10/25/2014 | | | | (Import) | |
| 2000 | Continuous | 2030 | | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | | |
| | | | | | TTC with All Lines In Service | | |
| | | | | | 5100 MW | | |
| LONG_MTN-PLSNTVLY 345_398 | | | | | FWD | REV | |
| Mon 10/27/2014 | to | Sat 11/15/2014 | | | | (Import) | (Export) |
| 0001 | Continuous | 2000 | | | | SCH - NE - NY | 500 MW 1300 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | | |
| | | | | | TTC with All Lines In Service | | |
| | | | | | 900 MW 300 MW | | |
| LONG_MTN-PLSNTVLY 345_398 | | | | | FWD | REV | |
| Mon 10/27/2014 | to | Sat 11/15/2014 | | | | (Import) | (Export) |
| 0001 | Continuous | 2000 | | | | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | | |
| | | | | | TTC with All Lines In Service | | |
| | | | | | 100 MW 100 MW | | |
| | | | | | 200 MW 200 MW | | |

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 2850MW
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_COMPLEX_AVR_O/S

Mon 10/27/2014 to Mon 10/27/2014
0900 Continuous 1600

Work scheduled by: Gen

FWD
(Import)
CENTRAL EAST - VC **2870 MW**
Impacts Total Transfer Capability 105 MW
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_3-BT

Tue 10/28/2014 to Thu 10/30/2014
0700 Continuous 1700

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

COLTON__-FLATROCK_115_2-CF

Tue 10/28/2014 to Tue 10/28/2014
0900 Daily(No Weekends) 1600

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **100 MW 40 MW**
Impacts Total Transfer Capability 90 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

MARCY__-EDIC____345_UE1-7

Wed 10/29/2014 to Wed 10/29/2014
0700 Continuous 1700

Work scheduled by: NYPA

ARR: 16

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

DENNISON-ROSEMNTA_115_1-RD

Thu 10/30/2014 to Tue 11/04/2014
0700 Continuous 1200

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **95 MW 40 MW**
Impacts Total Transfer Capability 95 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

DENNISON-ROSEMNTB_115_2-RD

Thu 10/30/2014 to Tue 11/04/2014
1200 Continuous 1700

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **95 MW 40 MW**
Impacts Total Transfer Capability 95 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

BECK____-NIAGARA_230_PA27

Fri 10/31/2014 to Sat 11/01/2014
0900 Continuous 1630

Work scheduled by: IESO

CANCELLED by NYPA 10/23/2014

FWD REV
(Import) (Export)
SCH - OH - NY **1900 MW 1900 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 1900 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 2850MW
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Sat 11/01/2014 to Sat 11/01/2014
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4000 MW
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

BECK_-NIAGARA_345_PA302

Sun 11/02/2014 to Fri 12/05/2014
0700 Continuous 1700

Work scheduled by: NYPA

UPDATED by PA 09/19/2014

FWD REV
(Import) (Export)
SCH - OH - NY 1200 MW 1100 MW
Impacts Total Transfer Capability 700 MW 800 MW
TTC with All Lines In Service 1900 MW 1900 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Mon 11/03/2014 to Tue 11/04/2014
0630 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

OSWEGO_-ELBRIDGE_345_17-EO

Mon 11/03/2014 to Tue 11/04/2014
0630 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FRASER_-GILBOA_345_GF5-35

Mon 11/03/2014 to Fri 11/07/2014
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2650 MW
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA1

Mon 11/03/2014 to Fri 11/07/2014
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

HOMER C_-WATRCURE_345_30

Mon 11/03/2014 to Fri 11/07/2014
0700 Continuous 1630

Work scheduled by: NYSEG

FWD REV
(Import) (Export)
SCH - PJ - NY 2450 MW 2500 MW
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2450 MW 2700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Tue 11/04/2014 to Tue 11/04/2014
2330 Continuous 2359
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

COOPERS_-MIDDLETP_345_CMT-34

Wed 11/05/2014 to Wed 11/05/2014
0800 Continuous 1600
Work scheduled by: CHGE

UPDATED by CHGE 10/21/2014

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

ADIRNDCK-PORTER___230_12-AP

Sat 11/08/2014 to Sat 11/08/2014
0800 Daily 1200
Work scheduled by: NGrid

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 2600 MW

LIND_CG_-LNDVFT___345_V-3022

Sun 11/09/2014 to Fri 11/14/2014
1400 Continuous 2000
Work scheduled by: PJM

UPDATED by NYISO 05/21/2014

| FWD | REV |
|--|-------------|
| (Import) | (Export) |
| SCH - PJM_VFT 0 MW | 0 MW |
| Impacts Total Transfer Capability 315 MW | 315 MW |
| TTC with All Lines In Service 315 MW | 315 MW |

MOSES_-ADIRNDCK_230_MAI

Mon 11/10/2014 to Fri 11/14/2014
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

HOMER C_-WATRCURE_345_30

Mon 11/10/2014 to Fri 11/14/2014
0700 Continuous 1630
Work scheduled by: NYSEG

| FWD | REV |
|--|----------------|
| (Import) | (Export) |
| SCH - PJ - NY 2450 MW | 2500 MW |
| Impacts Total Transfer Capability 0 MW | 200 MW |
| TTC with All Lines In Service 2450 MW | 2700 MW |

LEEDS_-HURLYAVE_345_301

Mon 11/10/2014 to Fri 12/12/2014
0700 Continuous 1600
Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

FWD

Mon 11/10/2014 to Mon 11/10/2014

UPDATEDby NGRID 09/05/2014

(Import)

0730 Daily(No Weekends) 1500

Work scheduled by: NGrid

CENTRAL EAST - VC

2090 MW

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

SCH-HQ-NYISO_LIMIT_1150

FWD

Mon 11/10/2014 to Mon 11/10/2014

UPDATEDby NGRID 09/05/2014

(Import)

0730 Daily(No Weekends) 1500

Work scheduled by: NGrid

SCH - HQ - NY

1150 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 1500 MW

HURLYAVE-ROSETON__345_303

FWD

Mon 11/10/2014 to Fri 11/14/2014

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

W49TH_ST_345KV_6

FWD

Mon 11/10/2014 to Mon 11/10/2014

(Import)

2200 Continuous 2359

Work scheduled by: ConEd

SCH - PJM_HTP

260 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Mon 11/10/2014 to Mon 11/10/2014

(Import)

2200 Continuous 2359

Work scheduled by: ConEd

SCH - PJM_HTP

260 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_6

FWD

Tue 11/11/2014 to Tue 11/11/2014

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

260 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Tue 11/11/2014 to Tue 11/11/2014

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

260 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-DUNWODIE_345_W75

FWD

Wed 11/12/2014 to Wed 11/12/2014 UPDATED by CE 10/22/2014

(Import)

0001 Continuous 2000

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

FWD

Wed 11/12/2014 to Thu 11/13/2014 CANCELLED by ConEd 10/22/2014

(Import)

1700 Continuous 1900

SCH - PJM_HTP **260 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_8

FWD

Wed 11/12/2014 to Thu 11/13/2014 CANCELLED by ConEd 10/22/2014

(Import)

1700 Continuous 1900

SCH - PJM_HTP **260 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

HUDSONP_-FARRAGUT_345_B3402

FWD

REV

Thu 11/13/2014 to Tue 11/18/2014 UPDATED by CONED 10/21/2014

(Import) (Export)

0001 Continuous 2359

SCH - PJ - NY **2450 MW 2600 MW**
Impacts Total Transfer Capability 0 MW 100 MW
TTC with All Lines In Service 2450 MW 2700 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

FWD

Thu 11/13/2014 to Thu 11/13/2014

(Import)

2100 Continuous 2300

SCH - PJM_HTP **260 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_8

FWD

Thu 11/13/2014 to Thu 11/13/2014

(Import)

2100 Continuous 2300

SCH - PJM_HTP **260 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK_345_W78

FWD

Mon 11/17/2014 to Thu 11/20/2014

(Import)

0001 Continuous 2359

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Mon 11/17/2014 to Thu 11/20/2014

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

SPRNBRK_345KV_RNS3

Mon 11/17/2014 to Thu 11/20/2014

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

MOSES_-ADIRNDCK_230_MAL

Mon 11/17/2014 to Fri 11/21/2014

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

HOMER C_-WATRCURE_345_30

Mon 11/17/2014 to Fri 11/21/2014

0700 Continuous 1630

Work scheduled by: NYSEG

FWD

REV

(Import) (Export)

SCH - PJ - NY

2450 MW 2500 MW

Impacts Total Transfer Capability 0 MW 200 MW

TTC with All Lines In Service 2450 MW 2700 MW

BERKSHIR-ALPS_345_393

Mon 11/17/2014 to Mon 11/17/2014

0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

UPDATED**by NGRID 09/09/2014**

FWD

REV

(Import) (Export)

SCH - NE - NY

1200 MW 1000 MW

Impacts Total Transfer Capability 200 MW 600 MW

TTC with All Lines In Service 1400 MW 1600 MW

BERKSHIR-ALPS_345_393

Mon 11/17/2014 to Mon 11/17/2014

0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

UPDATED**by NGRID 09/09/2014**

FWD

REV

(Import) (Export)

SCH - NPX_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

N.SCTLND-ALPS_345_2-AN

Fri 11/21/2014 to Sun 11/23/2014

0600 Continuous 1800

Work scheduled by: NGrid

UPDATED**by NGRID 09/30/2014**

FWD

REV

(Import) (Export)

SCH - NE - NY

750 MW 1550 MW

Impacts Total Transfer Capability 650 MW 50 MW

TTC with All Lines In Service 1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| N.SCTLND-ALPS_____345_2-AN | | | | | FWD | REV |
|------------------------------|------------|----------------|----------------|-----------------------------------|-----------------------------------|----------------|
| | | | | | (Import) | (Export) |
| Fri 11/21/2014 | to | Sun 11/23/2014 | <u>UPDATED</u> | <u>by NGRID</u> <u>09/30/2014</u> | SCH - NPX_1385 | 100 MW |
| 0600 | Continuous | 1800 | | | Impacts Total Transfer Capability | 100 MW |
| Work scheduled by: NGrid | | | | | TTC with All Lines In Service | 200 MW |
| LINDEN__-GOETHALS_230_A2253 | | | | | FWD | REV |
| | | | | | (Import) | (Export) |
| Sat 11/22/2014 | to | Sat 11/22/2014 | <u>UPDATED</u> | <u>by CONED</u> <u>10/24/2014</u> | SCH - PJ - NY | 2450 MW |
| 0100 | Continuous | 2300 | | | Impacts Total Transfer Capability | 0 MW |
| Work scheduled by: ConEd | | | | | TTC with All Lines In Service | 2700 MW |
| EDIC____-N.SCTLND_345_14-EN | | | | | FWD | |
| | | | | | (Import) | |
| Sat 11/22/2014 | to | Sat 11/22/2014 | | | CENTRAL EAST - VC | 2240 MW |
| 0700 | Daily | 1200 | | | Impacts Total Transfer Capability | 735 MW |
| Work scheduled by: NGrid | | | | | TTC with All Lines In Service | 2975 MW |
| HUDSONP_-FARRAGUT_345_C3403 | | | | | FWD | REV |
| | | | | | (Import) | (Export) |
| Sun 11/23/2014 | to | Wed 11/26/2014 | | | SCH - PJ - NY | 2450 MW |
| 0001 | Continuous | 2359 | | | Impacts Total Transfer Capability | 0 MW |
| Work scheduled by: ConEd | | | | | TTC with All Lines In Service | 2700 MW |
| GILBOA__-N.SCTLND_345_GNS1 | | | | | FWD | |
| | | | | | (Import) | |
| Mon 11/24/2014 | to | Wed 11/26/2014 | | | CENTRAL EAST - VC | 2520 MW |
| 0500 | Continuous | 1800 | | | Impacts Total Transfer Capability | 455 MW |
| Work scheduled by: NGrid | | | | | TTC with All Lines In Service | 2975 MW |
| MARCY____-N.SCTLND_345_18 | | | | | FWD | |
| | | | | | (Import) | |
| Mon 11/24/2014 | to | Wed 11/26/2014 | | | CENTRAL EAST - VC | 2090 MW |
| 0500 | Continuous | 1800 | | | Impacts Total Transfer Capability | 885 MW |
| Work scheduled by: NGrid | | | | | TTC with All Lines In Service | 2975 MW |
| N.SCTLND-LEEDS_____345_94-LN | | | | | FWD | |
| | | | | | (Import) | |
| Mon 11/24/2014 | to | Wed 11/26/2014 | | | CENTRAL EAST - VC | 2650 MW |
| 0500 | Continuous | 1800 | | | Impacts Total Transfer Capability | 325 MW |
| Work scheduled by: NGrid | | | | | TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150

Mon 11/24/2014 to Wed 11/26/2014
0500 Continuous 1800
Work scheduled by: NGrid

FWD
(Import)
SCH - HQ - NY **1150 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 1500 MW

HOMER C_-WATRCURE_345_30

Mon 11/24/2014 to Wed 11/26/2014
0700 Continuous 1630
Work scheduled by: NYSEG

FWD REV
(Import) (Export)
SCH - PJ - NY **2450 MW 2500 MW**
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2450 MW 2700 MW

MOSES_-ADIRNDCK_230_MA2

Mon 12/01/2014 to Fri 12/05/2014
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

HOMER C_-WATRCURE_345_30

Mon 12/01/2014 to Fri 12/05/2014
0700 Continuous 1630
Work scheduled by: NYSEG

FWD REV
(Import) (Export)
SCH - PJ - NY **2450 MW 2500 MW**
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2450 MW 2700 MW

MOSES_-ADIRNDCK_230_MA2

Mon 12/08/2014 to Fri 12/12/2014
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

MARCY_345_STATCOM SVC

Tue 12/09/2014 to Wed 12/10/2014
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

WETHSRFD-MEYER_230_85/87

Tue 12/09/2014 to Tue 12/09/2014
0800 Continuous 1400
Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **2650 MW**
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 2850 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ATHENS__-PLSNTVLY_345_91

Sun 12/14/2014 to Sat 12/27/2014

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS4

Sun 12/14/2014 to Sat 12/27/2014

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/15/2014 to Fri 12/19/2014

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 12/16/2014 to Wed 12/17/2014

0600 Continuous 1600

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

OSWEGO__-ELBRIDGE_345_17-EO

Tue 12/16/2014 to Wed 12/17/2014

0600 Continuous 1600

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

E13THSTA-FARRAGUT_345_46

Sun 12/21/2014 to Sun 12/21/2014

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Sun 12/21/2014 to Sun 12/21/2014

0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sun 12/21/2014 to Sun 12/21/2014
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **260 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_46

Sun 12/28/2014 to Sun 12/28/2014
2230 Continuous 2300
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M55

Sun 12/28/2014 to Sun 12/28/2014
2230 Continuous 2300
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Sun 12/28/2014 to Sun 12/28/2014
2230 Continuous 2300
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **260 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 660 MW

E13THSTA-FARRAGUT_345_45

Mon 01/05/2015 to Tue 01/06/2015 **UPDATED by CONED 08/27/2014**
0001 Continuous 2359
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Mon 01/05/2015 to Fri 01/09/2015 **UPDATED by CONED 08/27/2014**
0001 Continuous 1900
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

E13THSTA-FARRAGUT_345_45

Fri 01/09/2015 to Fri 01/09/2015 **UPDATED by CONED 08/27/2014**
1830 Continuous 1900
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1

FWD

Mon 01/12/2015 to Sat 01/17/2015

(Import)

0000 Continuous 2359

CONED - LIPA

1350 MW

Impacts Total Transfer Capability 150 MW

Work scheduled by: LI

TTC with All Lines In Service 1500 MW

NIAGARA_-ROCHESTR_345_NR2

FWD

Mon 01/12/2015 to Wed 01/14/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

1700 MW

Impacts Total Transfer Capability 1150 MW

Work scheduled by: NYPA

TTC with All Lines In Service 2850 MW

ATHENS_-PLSNTVLY_345_91

FWD

Tue 01/13/2015 to Fri 01/16/2015

(Import)

0001 Continuous 2359

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

Work scheduled by: ConEd

TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS4

FWD

Tue 01/13/2015 to Fri 01/16/2015

(Import)

0001 Continuous 2359

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

Work scheduled by: ConEd

TTC with All Lines In Service 5100 MW

NIAGARA_-KINTIGH_345_NS1-38

FWD

Thu 01/15/2015 to Fri 01/16/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

1700 MW

Impacts Total Transfer Capability 1150 MW

Work scheduled by: NYPA

TTC with All Lines In Service 2850 MW

PLSNTVLY_345KV_RNS4

FWD

Sun 01/18/2015 to Sun 01/18/2015

(Import)

0900 Continuous 2259

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

Work scheduled by: ConEd

TTC with All Lines In Service 5100 MW

MOSES_-ADIRNDCK_230_MAL

FWD

Mon 01/19/2015 to Fri 01/23/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

Work scheduled by: NYPA

TTC with All Lines In Service 2600 MW

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

FWD

Mon 01/19/2015 to Mon 01/19/2015
0900 Continuous 2359

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

MOSES__-ADIRNDCK_230_MAL

FWD

Mon 01/26/2015 to Fri 01/30/2015
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

MOSES__-ADIRNDCK_230_MAL

FWD

Mon 02/02/2015 to Fri 02/06/2015
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

FROST_BR-LONG_MTN_345_352

FWD

REV

Wed 02/04/2015 to Wed 02/04/2015
0700 Continuous 1600

(Import) (Export)

Work scheduled by: ISONE

SCH - NE - NY **1150 MW 1600 MW**
Impacts Total Transfer Capability 250 MW 0 MW
TTC with All Lines In Service 1400 MW 1600 MW

MOSES__-ADIRNDCK_230_MA2

FWD

Mon 02/09/2015 to Fri 02/13/2015
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

ADIRNDCK-CHASLAKE_230_13

FWD

Tue 02/17/2015 to Wed 02/18/2015
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 2600 MW

MOSES__-ADIRNDCK_230_MAL

FWD

Tue 02/17/2015 to Wed 02/18/2015
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 2850MW
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES____-ADIRNDCK_230_MA2

Thu 02/19/2015 to Fri 02/20/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

HUDSONP_-FARRAGUT_345_C3403

Mon 02/23/2015 to Wed 03/04/2015
0200 Continuous 2359

Work scheduled by: PJM

UPDATED by CONED 08/26/2014

FWD REV
(Import) (Export)
SCH - PJ - NY 2450 MW 2600 MW
Impacts Total Transfer Capability 0 MW 100 MW
TTC with All Lines In Service 2450 MW 2700 MW

KINTIGH_-ROCHESTR_345_SRI-39

Mon 02/23/2015 to Tue 02/24/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST 1700 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 2850 MW

STLAWRNC-MOSES____230_L34P

Mon 02/23/2015 to Tue 02/24/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY 1800 MW 1850 MW
Impacts Total Transfer Capability 100 MW 50 MW
TTC with All Lines In Service 1900 MW 1900 MW

MOSES____-ADIRNDCK_230_MA2

Mon 02/23/2015 to Fri 02/27/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

MARCY____345_STATCOM SVC

Tue 02/24/2015 to Fri 02/27/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2925 MW
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

STLAWRNC-MOSES____230_L33P

Wed 02/25/2015 to Thu 02/26/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY 1800 MW 1850 MW
Impacts Total Transfer Capability 100 MW 50 MW
TTC with All Lines In Service 1900 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

FWD

Mon 03/02/2015 to Fri 03/06/2015

(Import)

0700 Continuous 1530

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

MOSES_-ADIRNDCK_230_MA1

FWD

Mon 03/09/2015 to Fri 03/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

MARCY_345_STATCOM SVC

FWD

Mon 03/16/2015 to Mon 03/16/2015

(Import)

0700 Continuous 1530

CENTRAL EAST - VC **2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MOSES_-ADIRNDCK_230_MA1

FWD

Mon 03/16/2015 to Fri 03/20/2015

(Import)

0700 Continuous 1530

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

ROCHESTR-PANNELL_345_RP1

FWD

Mon 03/16/2015 to Fri 03/20/2015

(Import)

0700 Continuous 1530

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

MOSES_-ADIRNDCK_230_MA2

FWD

Mon 03/23/2015 to Fri 03/27/2015

(Import)

0700 Continuous 1530

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

ROCHESTR-PANNELL_345_RP1

FWD

Mon 03/23/2015 to Fri 03/27/2015

(Import)

0700 Continuous 1530

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 03/30/2015 to Fri 04/03/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

ROCHESTR-PANNELL___345_RP1

FWD

Mon 03/30/2015 to Fri 04/03/2015

(Import)

0700 Continuous 1700

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

HUDSONP_-FARRAGUT_345_B3402

FWD

REV

Wed 04/01/2015 to Fri 04/10/2015

(Import) (Export)

0001 Continuous 2359

UPDATEDby CONED 10/14/2014

SCH - PJ - NY

2450 MW 2600 MW

Impacts Total Transfer Capability 0 MW 100 MW

TTC with All Lines In Service 2450 MW 2700 MW

Work scheduled by: PJM

CLAY___-EDIC___345_1-16

FWD

Mon 04/06/2015 to Tue 04/07/2015

(Import)

0700 Continuous 1530

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

MARCY___-COOPERS___345_UC2-41

FWD

Mon 04/06/2015 to Fri 04/10/2015

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 04/06/2015 to Fri 04/10/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

ROSETON_-ROCKTVRN_345_311

FWD

Mon 04/06/2015 to Fri 04/24/2015

(Import)

0800 Continuous 1600

UPNY CONED

4400 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_2-15

Wed 04/08/2015 to Thu 04/09/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

PANNELL -CLAY 345_PC1

Mon 04/13/2015 to Tue 04/14/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NRTH1385-NOR HBR_138_601

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602

Mon 04/20/2015 to Thu 04/30/2015
0500 1500

Work scheduled by:

FWD REV
(Import) (Export)
SCH - NPX_1385 **0 MW 0 MW**
Impacts Total Transfer Capability 200 MW 200 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603

Mon 04/20/2015 to Thu 04/30/2015
0500 1500

Work scheduled by:

FWD REV
(Import) (Export)
SCH - NPX_1385 **0 MW 0 MW**
Impacts Total Transfer Capability 200 MW 200 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_602

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603

Mon 04/20/2015 to Thu 04/30/2015
0500 1500

Work scheduled by:

FWD REV
(Import) (Export)
SCH - NPX_1385 **0 MW 0 MW**
Impacts Total Transfer Capability 200 MW 200 MW
TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | |
|-------------------------------|------------|----------------|-----------------------------------|---------------|
| NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | Continuous | 1500 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NRTHPORT_138_1385 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | Continuous | 1500 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| ROCHESTR-PANNELL__345_RP2 | | | FWD | |
| Mon 04/20/2015 | to | Fri 04/24/2015 | (Import) | |
| 0700 | Continuous | 1530 | DYSINGER EAST | 2300 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 550 MW |
| | | | TTC with All Lines In Service | 2850 MW |
| LEEDS__345_LEEDS SVC | | | FWD | |
| Mon 04/27/2015 | to | Fri 05/01/2015 | (Import) | |
| 0700 | Continuous | 1500 | CENTRAL EAST - VC | 2950 MW |
| Work scheduled by: NGrid | | | Impacts Total Transfer Capability | 25 MW |
| | | | TTC with All Lines In Service | 2975 MW |
| ROCHESTR-PANNELL__345_RP2 | | | FWD | |
| Mon 04/27/2015 | to | Fri 05/01/2015 | (Import) | |
| 0700 | Continuous | 1530 | DYSINGER EAST | 2300 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 550 MW |
| | | | TTC with All Lines In Service | 2850 MW |
| NEPTUNE_-DUFFYAVE_345_NEPTUNE | | | FWD | |
| Mon 05/04/2015 | to | Tue 05/12/2015 | (Import) | |
| 0600 | Continuous | 2100 | SCH - PJM_NEPTUNE | 0 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 660 MW |
| | | | TTC with All Lines In Service | 660 MW |
| NEWBRDGE-DUFFYAVE_345_501 | | | FWD | |
| Mon 05/04/2015 | to | Tue 05/12/2015 | (Import) | |
| 0600 | Continuous | 2100 | SCH - PJM_NEPTUNE | 0 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 660 MW |
| | | | TTC with All Lines In Service | 660 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

SCH-NE-NYISO_LIMIT_900

Mon 05/04/2015 to Thu 05/21/2015
0600 Continuous 1700
Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 1400 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 05/04/2015 to Tue 05/05/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 2850 MW

MOSES_-ADIRNDCK_230_MAI

Mon 05/04/2015 to Fri 05/08/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

FRASER_-GILBOA_345_GF5-35

Mon 05/04/2015 to Fri 05/08/2015
0700 Continuous 1600
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MAI

Mon 05/11/2015 to Fri 05/15/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC____-FRASER____345_EF24-40

Mon 05/11/2015 to Fri 05/15/2015
0900 Continuous 1530

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES____-ADIRNDCK_230_MA2

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

STLAWRNC-MOSES____230_L33P

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1750 MW 1750 MW**
Impacts Total Transfer Capability 150 MW 150 MW
TTC with All Lines In Service 1900 MW 1900 MW

MOSES____-ADIRNDCK_230_MA2

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

STLAWRNC-MOSES____230_L34P

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1750 MW 1750 MW**
Impacts Total Transfer Capability 150 MW 150 MW
TTC with All Lines In Service 1900 MW 1900 MW

MOSES____-ADIRNDCK_230_MA1

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

PANNELL_-CLAY____345_PC2

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 2850MW
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Wed 06/03/2015 to Thu 06/04/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

MOSES___-ADIRNDCK_230_MA1

FWD

Thu 08/13/2015 to Thu 08/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

MOSES___-ADIRNDCK_230_MA2

FWD

Tue 08/18/2015 to Tue 08/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

ADIRNDCK-PORTER___230_12-AP

FWD

Wed 08/19/2015 to Wed 08/19/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

ADIRNDCK-CHASLAKE_230_13

FWD

Thu 08/20/2015 to Thu 08/20/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 08/31/2015 to Fri 09/04/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

MARCY___765_345_BK 2

FWD

Mon 09/07/2015 to Fri 09/11/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 2850MW
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303

Mon 09/07/2015 to Fri 09/25/2015
0800 Continuous 1600
Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

NIAGARA__345_230_BK 4

Mon 09/07/2015 to Fri 10/09/2015
0800 Continuous 1530
Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1900 MW 1900 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 1900 MW 1900 MW

MOSES__-ADIRNDCK_230_MA2

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

COOPERS_-MIDDLETP_345_CMT-34

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1600
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA1

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 2600 MW

COOPERS_-ROCKTVRN_345_CRT-42

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1600
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700
Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - NE - NY **500 MW 1300 MW**
Impacts Total Transfer Capability 900 MW 300 MW
TTC with All Lines In Service 1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 2850MW
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

MOSES-ADIRNDCK_230_MA2

Mon 09/28/2015 to Fri 10/02/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

CHATGUAY-MASSENA_765_7040

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014
0100 Continuous 1730

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - HQ - NY | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

MARCY_765_345_BK 1

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 19

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 1750 MW |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 2600 MW |

MARCY_765_345_BK 2

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 19

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 1700 MW |
| Impacts Total Transfer Capability | 900 MW |
| TTC with All Lines In Service | 2600 MW |

MASSENA-MARCY_765_MSU1

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 20

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2315 MW |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 2975 MW |

MASSENA-MARCY_765_MSU1

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 20

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 675 MW |
| Impacts Total Transfer Capability | 1925 MW |
| TTC with All Lines In Service | 2600 MW |

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 2850MW
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | |
|--------------------------------------|------------|----------------|----------------|-----------------|-----------------------------------|----------------|----------------|
| MASSENA_-MARCY_765_MSU1 | | | | | | FWD | REV |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | (Export) |
| 0100 | Continuous | 1730 | | | | 475 MW | 1000 MW |
| Work scheduled by: NYPA | | | | | SCH - HQ - NY | | |
| | | | | | Impacts Total Transfer Capability | 1025 MW | 0 MW |
| | | | | | TTC with All Lines In Service | 1500 MW | 1000 MW |
| SHOR_NPX-SHOREHAM_138_NPX_CSC | | | | | | FWD | REV |
| Mon 10/05/2015 | to | Sun 10/11/2015 | <u>UPDATED</u> | <u>by ISONE</u> | <u>07/25/2014</u> | (Import) | (Export) |
| 0530 | Continuous | 1800 | | | | 0 MW | 0 MW |
| Work scheduled by: LI | | | | | SCH - NPX_CSC | | |
| | | | | | Impacts Total Transfer Capability | 330 MW | 330 MW |
| | | | | | TTC with All Lines In Service | 330 MW | 330 MW |
| GILBOA_-LEEDS_345_GL3 | | | | | | FWD | |
| Mon 10/05/2015 | to | Fri 10/09/2015 | | | | (Import) | |
| 0700 | Continuous | 1600 | | | CENTRAL EAST - VC | 2200 MW | |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 775 MW | |
| | | | | | TTC with All Lines In Service | 2975 MW | |
| MALONE_-WILLIS_115_1-MW | | | | | | | REV |
| Tue 10/06/2015 | to | Tue 10/06/2015 | | | | | (Export) |
| 0800 | Continuous | 1530 | | | SCH - HQ_CEDARS | | 40 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | | 0 MW |
| | | | | | TTC with All Lines In Service | | 40 MW |
| LEEDS_-HURLYAVE_345_301 | | | | | | FWD | |
| Mon 10/12/2015 | to | Fri 10/30/2015 | | | | (Import) | |
| 0800 | Continuous | 1600 | | | UPNY CONED | 4100 MW | |
| Work scheduled by: CHGE | | | | | Impacts Total Transfer Capability | 1000 MW | |
| | | | | | TTC with All Lines In Service | 5100 MW | |
| GILBOA_-N.SCTLND_345_GNS1 | | | | | | FWD | |
| Mon 10/19/2015 | to | Fri 10/23/2015 | <u>UPDATED</u> | <u>by NYISO</u> | <u>09/12/2014</u> | (Import) | |
| 0700 | Continuous | 1600 | | | CENTRAL EAST - VC | 2520 MW | |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 455 MW | |
| | | | | | TTC with All Lines In Service | 2975 MW | |
| MARCY_-COOPERS_345_UC2-41 | | | | | | FWD | |
| Mon 11/02/2015 | to | Fri 11/06/2015 | | | | (Import) | |
| 0700 | Continuous | 1530 | | | CENTRAL EAST - VC | 2500 MW | |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 475 MW | |
| | | | | | TTC with All Lines In Service | 2975 MW | |

NYISO TRANSFER LIMITATIONS

Saturday ,October 25, 2014 to Monday ,April 25, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | |
|-----------------------------------|------------|----------------|-----------------------------------|----------------|
| BERKSHIR-ALPS_____345_393 | | | FWD | REV |
| Mon 11/30/2015 | to | Fri 12/04/2015 | (Import) | (Export) |
| 0600 | Continuous | 1500 | SCH - NE - NY | 1200 MW |
| Work scheduled by: NGrid | | | Impacts Total Transfer Capability | 600 MW |
| | | | TTC with All Lines In Service | 1400 MW |
| BERKSHIR-ALPS_____345_393 | | | FWD | REV |
| Mon 11/30/2015 | to | Fri 12/04/2015 | (Import) | (Export) |
| 0600 | Continuous | 1500 | SCH - NPX_1385 | 100 MW |
| Work scheduled by: NGrid | | | Impacts Total Transfer Capability | 100 MW |
| | | | TTC with All Lines In Service | 200 MW |
| MOSES____-ADIRNDCK_230_MAL | | | FWD | |
| Mon 11/30/2015 | to | Fri 12/04/2015 | (Import) | |
| 0700 | Continuous | 1530 | MOSES SOUTH | 2000 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 600 MW |
| | | | TTC with All Lines In Service | 2600 MW |
| MOSES____-ADIRNDCK_230_MAL | | | FWD | |
| Mon 12/07/2015 | to | Fri 12/11/2015 | (Import) | |
| 0700 | Continuous | 1530 | MOSES SOUTH | 2000 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 600 MW |
| | | | TTC with All Lines In Service | 2600 MW |
| MOSES____-ADIRNDCK_230_MAL | | | FWD | |
| Mon 12/14/2015 | to | Fri 12/18/2015 | (Import) | |
| 0700 | Continuous | 1530 | MOSES SOUTH | 2000 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 600 MW |
| | | | TTC with All Lines In Service | 2600 MW |