

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-PJM\_LIMIT\_1000**

REV

Sun 06/29/2014 to Fri 10/31/2014 EXTENDED by NYISO 08/07/2014

(Export)

2000 Continuous 2359

SCH - PJ - NY

**1300 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

2700 MW

Work scheduled by: NYISO

**CHAT\_DC\_GC2**

FWD

Wed 09/03/2014 to Thu 11/20/2014 UPDATED by HQ 10/01/2014

(Import)

0700 Continuous 1700

MOSES SOUTH

**2150 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: HQ

**CHAT\_DC\_GC2**

REV

Wed 09/03/2014 to Thu 11/20/2014 UPDATED by HQ 10/01/2014

(Export)

0700 Continuous 1700

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

**SHOR\_NPX-SHOREHAM\_138\_NPX\_CSC**

FWD

REV

Fri 09/26/2014 to Fri 10/17/2014 EXT FORCE by ISONE 09/29/2014

(Import) (Export)

0455 Continuous 2359

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: ISONE

**SCH-HQ-NYISO\_LIMIT\_1350**

FWD

Wed 10/01/2014 to Sun 10/26/2014 UPDATED by HQ 10/01/2014

(Import)

0001 Continuous 2200

SCH - HQ - NY

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**MARCY\_765\_345\_BK 1**

FWD

Sat 10/04/2014 to Sun 10/26/2014 UPDATED by NYPA 10/08/2014

(Import)

0500 Continuous 2200

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ARR: 19****CHATGUAY-MASSENA\_765\_7040**

FWD

REV

Sat 10/04/2014 to Sun 10/26/2014 UPDATED by NYPA 10/08/2014

(Import) (Export)

1200 Continuous 2200

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>2850MW</b>
<b>WEST CENTRAL</b>	<b>2250MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY____765_345_BK 2</b>						FWD	
Sat 10/04/2014	to	Sun 10/26/2014	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2014</u>	(Import)	
1200	Continuous	2200				MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA				<b>ARR: 19</b>		Impacts Total Transfer Capability	900 MW
						TTC with All Lines In Service	2600 MW
<b>MASSENA_-MARCY____765_MSU1</b>						FWD	
Sat 10/04/2014	to	Sun 10/26/2014	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2014</u>	(Import)	
1200	Continuous	2200				CENTRAL EAST - VC	<b>2315 MW</b>
Work scheduled by: NYPA				<b>ARR: 20</b>		Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY____765_MSU1</b>						FWD	
Sat 10/04/2014	to	Sun 10/26/2014	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2014</u>	(Import)	
1200	Continuous	2200				MOSES SOUTH	<b>675 MW</b>
Work scheduled by: NYPA				<b>ARR: 20</b>		Impacts Total Transfer Capability	1925 MW
						TTC with All Lines In Service	2600 MW
<b>MASSENA_-MARCY____765_MSU1</b>						FWD	REV
Sat 10/04/2014	to	Sun 10/26/2014	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2014</u>	(Import) (Export)	
1200	Continuous	2200				SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA				<b>ARR: 20</b>		Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC1</b>						FWD	
Sat 10/04/2014	to	Mon 10/27/2014	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2014</u>	(Import)	
1219	Continuous	1700				MOSES SOUTH	<b>2150 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	2600 MW
<b>CHAT_DC_GC1</b>							REV
Sat 10/04/2014	to	Mon 10/27/2014	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2014</u>	(Export)	
1219	Continuous	1700				SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	
Sat 10/04/2014	to	Mon 10/27/2014				(Import)	
1219		1700				MOSES SOUTH	<b>2000 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	2600 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Sat 10/04/2014 to Mon 10/27/2014  
 1219 1700

Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **1370 MW 0 MW**  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**LEEDS -HURLYAVE\_345\_301**

Mon 10/06/2014 to Fri 10/17/2014  
 0700 Continuous 1800

Work scheduled by: CHGE

**UPDATED by CHGE 10/15/2014**

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

Mon 10/06/2014 to Mon 10/20/2014  
 0700 Continuous 0559

Work scheduled by: HQ

**EXTENDED by HQ 10/08/2014**

REV  
 (Export)  
 SCH - HQ\_CEDARS **0 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 40 MW

**BEAR SWP-ROTTDAM\_230\_E205W**

Mon 10/06/2014 to Fri 10/24/2014  
 0730 Continuous 1500

Work scheduled by: NGrid

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**BECK -NIAGARA\_345\_PA301**

Fri 10/10/2014 to Fri 10/24/2014  
 0700 Continuous 1800

Work scheduled by: NYPA

**UPDATED by NYISO 10/09/2014**

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1200 MW 1100 MW**  
 Impacts Total Transfer Capability 700 MW 800 MW  
 TTC with All Lines In Service 1900 MW 1900 MW

**SCH-IMO-NYISO\_LIMIT\_700**

Sat 10/11/2014 to Fri 10/24/2014  
 0800 Continuous 1800

Work scheduled by: NYPA

**UPDATED by NYISO 10/09/2014**

FWD  
 (Import)  
 SCH - OH - NY **1000 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 1900 MW

**NEPTUNE -DUFFYAVE\_345\_NEPTUNE**

Tue 10/14/2014 to Sat 10/18/2014  
 1308 Continuous 2011

Work scheduled by: PJM

**FORCED by PJM 10/19/2014**

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NEWBRIDGE-DUFFYAVE\_345\_501

Tue 10/14/2014 to Sat 10/18/2014 **FORCED** **by PJM** **10/19/2014**  
 1308 Continuous 2011  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

## EASTVIEW-SPRNBK\_345\_W65

Fri 10/17/2014 to Fri 10/17/2014 **EXTENDED** **by CONED** **10/18/2014**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

## SPRNBK\_345KV\_RNS4

Fri 10/17/2014 to Fri 10/17/2014 **EXTENDED** **by CONED** **10/18/2014**  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

## MILLWOOD-EASTVIEW\_345\_W82

Fri 10/17/2014 to Sat 10/18/2014 **EXTENDED** **by CONED** **10/18/2014**  
 0001 Continuous 1759  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Fri 10/17/2014 to Mon 10/20/2014 **UPDATED** **by NYISO** **10/18/2014**  
 2200 Continuous 0700  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Sat 10/18/2014 to Sat 10/18/2014 **CANCELLED** **by ConEd** **10/18/2014**  
 0001 Continuous 1530  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1100 MW  
 TTC with All Lines In Service 5100 MW

## LEEDS\_-PLSNTVLY\_345\_92

Sat 10/18/2014 to Sun 10/19/2014 **UPDATED** **by CONED** **10/15/2014**  
 0800 Continuous 2359  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS5**

FWD

Sat 10/18/2014 to Sun 10/19/2014 **UPDATED by CONED 10/15/2014**

(Import)

0800 Continuous 2359

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: NGrid

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Mon 10/20/2014 to Mon 10/20/2014

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Mon 10/20/2014 to Wed 10/22/2014

(Import)

0001 Continuous 2300

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Mon 10/20/2014 to Sat 10/25/2014

(Import)

0001 Continuous 2030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**EGRDNCTY\_345\_138\_BK 1**

FWD

Mon 10/20/2014 to Sun 11/09/2014

(Import)

0100 Continuous 2359

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**EGRDNCTY\_345\_138\_BK 2**

FWD

Mon 10/20/2014 to Sun 11/09/2014

(Import)

0100 Continuous 2359

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**SPRNBK\_-EGRDNCTR\_345\_Y49**

FWD

Mon 10/20/2014 to Sun 11/09/2014

(Import)

0100 Continuous 2359

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FROST_BR-LONG_MTN_345_352</b>				FWD	REV
Mon 10/20/2014	to	Sat 10/25/2014		(Import)	(Export)
0600	Continuous	1800		<b>SCH - NE - NY 1150 MW</b>	<b>1600 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>					REV
Mon 10/20/2014	to	Sat 10/25/2014			(Export)
0600	Continuous	1800		<b>SCH - NE - NY 1400 MW</b>	
Work scheduled by: ISONE				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1600 MW
<b>SCH-NYISO-HQ_CEDARS_LIMIT_0</b>					REV
Mon 10/20/2014	to	Sun 10/26/2014			(Export)
0600	Continuous	1700		<b>SCH - HQ_CEDARS 0 MW</b>	
Work scheduled by: IESO				Impacts Total Transfer Capability	40 MW
				TTC with All Lines In Service	40 MW
<b>GILBOA_-LEEDS_345_GL3</b>				FWD	
Mon 10/20/2014	to	Fri 10/24/2014	<b><u>UPDATED</u></b>	(Import)	
0700	Continuous	1530	<b><u>by NYPA</u></b>	<b>CENTRAL EAST - VC 2200 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	775 MW
				TTC with All Lines In Service	2975 MW
<b>COOPERS_-ROCKTVRN_345_CRT-42</b>				FWD	
Fri 10/24/2014	to	Mon 10/27/2014		(Import)	
2200	Continuous	0700		<b>CENTRAL EAST - VC 2720 MW</b>	
Work scheduled by: NYISO				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>				FWD	
Sat 10/25/2014	to	Sat 10/25/2014		(Import)	
2000	Continuous	2030		<b>UPNY CONED 4000 MW</b>	
Work scheduled by: ConEd				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
<b>SCH-HQ-NYISO_LIMIT_1200</b>				FWD	
Sun 10/26/2014	to	Mon 10/27/2014	<b><u>UPDATED</u></b>	(Import)	
2200	Continuous	1700	<b><u>by NYPA</u></b>	<b>SCH - HQ - NY 1200 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	1500 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-HQ-NYISO\_LIMIT\_1400**

Sun 10/26/2014 to Thu 11/20/2014 **UPDATED by HQ 10/01/2014**  
2200 Continuous 1700

Work scheduled by: HQ

FWD  
(Import)  
**1400 MW**  
SCH - HQ - NY  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1500 MW

**LONG\_MTN-PLSNTVLY\_345\_398**

Mon 10/27/2014 to Sat 11/15/2014  
0001 Continuous 2000

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
**500 MW 1300 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 900 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

**LONG\_MTN-PLSNTVLY\_345\_398**

Mon 10/27/2014 to Sat 11/15/2014  
0001 Continuous 2000

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
**100 MW 100 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

**ELBRIDGE-LAFAYTTE\_345\_17-LE**

Mon 10/27/2014 to Tue 10/28/2014  
0630 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
**5250 MW**  
OSWEGO EXPORT  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**OSWEGO\_-ELBRIDGE\_345\_17-EO**

Mon 10/27/2014 to Tue 10/28/2014  
0630 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
**5250 MW**  
OSWEGO EXPORT  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**BROWNFLS-TAYLORVL\_115\_3-BT**

Tue 10/28/2014 to Thu 10/30/2014  
0700 Continuous 1700

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
**70 MW 40 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**COLTON\_-FLATROCK\_115\_2-CF**

Tue 10/28/2014 to Tue 10/28/2014  
0900 Daily(No Weekends) 1600

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
**100 MW 40 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 90 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday, April 22, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY -EDIC 345 UE1-7**

Wed 10/29/2014 to Wed 10/29/2014  
0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

---

**DENNISON-ROSEMNTA 115 1-RD**

Thu 10/30/2014 to Tue 11/04/2014  
0700 Continuous 1200

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 95 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**DENNISON-ROSEMNTB 115 2-RD**

Thu 10/30/2014 to Tue 11/04/2014  
1200 Continuous 1700

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **95 MW 40 MW**  
Impacts Total Transfer Capability 95 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**BECK -NIAGARA 230 PA27**

Fri 10/31/2014 to Sat 11/01/2014  
0900 Continuous 1630

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY **1950 MW 2000 MW**  
Impacts Total Transfer Capability -50 MW -100 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**PLSNTVLE-DUNWODIE 345 W89**

Sat 11/01/2014 to Sat 11/01/2014  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

---

**BECK -NIAGARA 345 PA302**

Sun 11/02/2014 to Fri 12/05/2014  
0700 Continuous 1700

Work scheduled by: NYPA

**UPDATED by PA 09/19/2014**

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1100 MW**  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**FRASER -GILBOA 345 GF5-35**

Mon 11/03/2014 to Fri 11/07/2014  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW



**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

FWD

Mon 11/03/2014 to Fri 11/07/2014

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**HOMER C\_-WATRCURE\_345\_30**

FWD

REV

Mon 11/03/2014 to Fri 11/07/2014

(Import) (Export)

0700 Continuous 1630

SCH - PJ - NY

**2450 MW 2500 MW**

Impacts Total Transfer Capability 0 MW 200 MW

TTC with All Lines In Service 2450 MW 2700 MW

Work scheduled by: NYSEG

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Tue 11/04/2014 to Tue 11/04/2014

(Import)

2330 Continuous 2359

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Wed 11/05/2014 to Wed 11/05/2014

(Import)

0800 Continuous 1600

**UPDATED by CHGE 10/21/2014**

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

**ADIRNDCK-PORTER\_\_\_230\_12-AP**

FWD

Sat 11/08/2014 to Sat 11/08/2014

(Import)

0800 Daily 1200

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NGrid

**LIND\_CG\_-LNDVFT\_\_\_345\_V-3022**

FWD

REV

Sun 11/09/2014 to Fri 11/14/2014

(Import) (Export)

1400 Continuous 2000

**UPDATED by NYISO 05/21/2014**

SCH - PJM\_VFT

**0 MW 0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

FWD

Mon 11/10/2014 to Fri 11/14/2014

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HOMER C\_-WATRCURE\_345\_30**

Mon 11/10/2014 to Fri 11/14/2014  
0700 Continuous 1630

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2450 MW</b>	<b>2500 MW</b>
Impacts Total Transfer Capability	0 MW	200 MW
TTC with All Lines In Service	2450 MW	2700 MW

**LEEDS\_-HURLYAVE\_345\_301**

Mon 11/10/2014 to Fri 12/12/2014  
0700 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

**MARCY\_-N.SCTLND\_345\_18**

Mon 11/10/2014 to Mon 11/10/2014  
0730 Daily(No Weekends) 1500

Work scheduled by: NGrid

**UPDATED by NGRID 09/05/2014**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2090 MW</b>
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

**SCH-HQ-NYISO\_LIMIT\_1150**

Mon 11/10/2014 to Mon 11/10/2014  
0730 Daily(No Weekends) 1500

Work scheduled by: NGrid

**UPDATED by NGRID 09/05/2014**

	FWD
	(Import)
SCH - HQ - NY	<b>1150 MW</b>
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	1500 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 11/10/2014 to Fri 11/14/2014  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

**W49TH\_ST\_345KV\_6**

Mon 11/10/2014 to Mon 11/10/2014  
2200 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>260 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	660 MW

**W49TH\_ST\_345KV\_8**

Mon 11/10/2014 to Mon 11/10/2014  
2200 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	<b>260 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	660 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST_345KV_6</b>					FWD		
Tue 11/11/2014	to	Tue 11/11/2014	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>10/22/2014</u></b>	(Import)	
0001	Continuous	0200				SCH - PJM_HTP	<b>260 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>					FWD		
Tue 11/11/2014	to	Tue 11/11/2014	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>10/22/2014</u></b>	(Import)	
0001	Continuous	0200				SCH - PJM_HTP	<b>260 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	660 MW
<b>SPRNBK_-DUNWODIE_345_W75</b>					FWD		
Wed 11/12/2014	to	Wed 11/12/2014	<b><u>UPDATED</u></b>	<b><u>by CE</u></b>	<b><u>10/22/2014</u></b>	(Import)	
0001	Continuous	2000				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>W49TH_ST_345KV_6</b>					FWD		
Wed 11/12/2014	to	Thu 11/13/2014	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>10/22/2014</u></b>	(Import)	
1700	Continuous	1900				SCH - PJM_HTP	<b>260 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>					FWD		
Wed 11/12/2014	to	Thu 11/13/2014	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>10/22/2014</u></b>	(Import)	
1700	Continuous	1900				SCH - PJM_HTP	<b>260 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	660 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD		
Thu 11/13/2014	to	Tue 11/18/2014	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>10/21/2014</u></b>	(Import)	REV (Export)
0001	Continuous	2359				SCH - PJ - NY	<b>2450 MW 2600 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	0 MW 100 MW
						TTC with All Lines In Service	2450 MW 2700 MW
<b>W49TH_ST_345KV_6</b>					FWD		
Thu 11/13/2014	to	Thu 11/13/2014				(Import)	
2100	Continuous	2300				SCH - PJM_HTP	<b>260 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_8**

Thu 11/13/2014 to Thu 11/13/2014  
2100 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **260 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 660 MW

**EASTVIEW-SPRNBK\_\_345\_W78**

Mon 11/17/2014 to Thu 11/20/2014  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**MILLWOOD-EASTVIEW\_345\_W85**

Mon 11/17/2014 to Thu 11/20/2014  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBK\_\_345KV\_RNS3**

Mon 11/17/2014 to Thu 11/20/2014  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 11/17/2014 to Fri 11/21/2014  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

**HOMER C\_-WATRCURE\_345\_30**

Mon 11/17/2014 to Fri 11/21/2014  
0700 Continuous 1630

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2450 MW 2500 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2450 MW 2700 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

Mon 11/17/2014 to Mon 11/17/2014  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

UPDATED by NGRID 09/09/2014

FWD REV  
(Import) (Export)  
SCH - NE - NY **1200 MW 1000 MW**  
Impacts Total Transfer Capability 200 MW 600 MW  
TTC with All Lines In Service 1400 MW 1600 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>					FWD	REV
Mon 11/17/2014	to	Mon 11/17/2014	<u>UPDATED</u>	<u>by NGRID</u> <u>09/09/2014</u>	(Import)	(Export)
0800	Daily(No Weekends)	1500			SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>N.SCTLND-ALPS_____345_2-AN</b>					FWD	REV
Fri 11/21/2014	to	Sun 11/23/2014	<u>UPDATED</u>	<u>by NGRID</u> <u>09/30/2014</u>	(Import)	(Export)
0600	Continuous	1800			SCH - NE - NY	<b>750 MW</b> <b>1550 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	650 MW 50 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>N.SCTLND-ALPS_____345_2-AN</b>					FWD	REV
Fri 11/21/2014	to	Sun 11/23/2014	<u>UPDATED</u>	<u>by NGRID</u> <u>09/30/2014</u>	(Import)	(Export)
0600	Continuous	1800			SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>LINDEN__-GOETHALS_230_A2253</b>					FWD	REV
Sat 11/22/2014	to	Sat 11/22/2014	<u>UPDATED</u>	<u>by CE</u> <u>10/21/2014</u>	(Import)	(Export)
0100	Continuous	2300			SCH - PJ - NY	<b>2450 MW</b> <b>2600 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	0 MW 100 MW
					TTC with All Lines In Service	2450 MW 2700 MW
<b>EDIC____-N.SCTLND_345_14-EN</b>					FWD	
Sat 11/22/2014	to	Sat 11/22/2014			(Import)	
0700	Daily	1200			CENTRAL EAST - VC	<b>2240 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	735 MW
					TTC with All Lines In Service	2975 MW
<b>HUDSONP_-FARRAGUT_345_C3403</b>					FWD	REV
Sun 11/23/2014	to	Wed 11/26/2014			(Import)	(Export)
0001	Continuous	2359			SCH - PJ - NY	<b>2450 MW</b> <b>2600 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	0 MW 100 MW
					TTC with All Lines In Service	2450 MW 2700 MW
<b>GILBOA__-N.SCTLND_345_GNS1</b>					FWD	
Mon 11/24/2014	to	Wed 11/26/2014			(Import)	
0500	Continuous	1800			CENTRAL EAST - VC	<b>2520 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_-N.SCTLND\_345\_18**

FWD

Mon 11/24/2014 to Wed 11/26/2014

(Import)

0500 Continuous 1800

CENTRAL EAST - VC

**2090 MW**

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**N.SCTLND-LEEDS\_\_\_345\_94-LN**

FWD

Mon 11/24/2014 to Wed 11/26/2014

(Import)

0500 Continuous 1800

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**HOMER C\_-WATRCURE\_345\_30**

FWD

REV

Mon 11/24/2014 to Wed 11/26/2014

(Import) (Export)

0700 Continuous 1630

SCH - PJ - NY

**2450 MW 2500 MW**

Impacts Total Transfer Capability 0 MW 200 MW

TTC with All Lines In Service 2450 MW 2700 MW

Work scheduled by: NYSEG

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/01/2014 to Fri 12/05/2014

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**HOMER C\_-WATRCURE\_345\_30**

FWD

REV

Mon 12/01/2014 to Fri 12/05/2014

(Import) (Export)

0700 Continuous 1630

SCH - PJ - NY

**2450 MW 2500 MW**

Impacts Total Transfer Capability 0 MW 200 MW

TTC with All Lines In Service 2450 MW 2700 MW

Work scheduled by: NYSEG

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/08/2014 to Fri 12/12/2014

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**MARCY\_\_\_345\_STATCOM SVC**

FWD

Tue 12/09/2014 to Wed 12/10/2014

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ATHENS\_\_-PLSNTVLY\_345\_91**

FWD

Sun 12/14/2014 to Sat 12/27/2014

(Import)

0001 Continuous 2359

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Sun 12/14/2014 to Sat 12/27/2014

(Import)

0001 Continuous 2359

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/15/2014 to Fri 12/19/2014

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ELBRIDGE-LAFAYTTE\_345\_17-LE**

FWD

Tue 12/16/2014 to Wed 12/17/2014

(Import)

0600 Continuous 1600

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**OSWEGO\_\_-ELBRIDGE\_345\_17-EO**

FWD

Tue 12/16/2014 to Wed 12/17/2014

(Import)

0600 Continuous 1600

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**E13THSTA-FARRAGUT\_345\_46**

FWD

Sun 12/21/2014 to Sun 12/21/2014

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Sun 12/21/2014 to Sun 12/21/2014

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

FWD

Sun 12/21/2014 to Sun 12/21/2014

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**260 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_46**

FWD

Sun 12/28/2014 to Sun 12/28/2014

(Import)

2230 Continuous 2300

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Sun 12/28/2014 to Sun 12/28/2014

(Import)

2230 Continuous 2300

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_6**

FWD

Sun 12/28/2014 to Sun 12/28/2014

(Import)

2230 Continuous 2300

SCH - PJM\_HTP

**260 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 660 MW

**E13THSTA-FARRAGUT\_345\_45**

FWD

Mon 01/05/2015 to Tue 01/06/2015

**UPDATED****by CONED 08/27/2014**

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

FWD

Mon 01/05/2015 to Fri 01/09/2015

**UPDATED****by CONED 08/27/2014**

(Import)

0001 Continuous 1900

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**E13THSTA-FARRAGUT\_345\_45**

FWD

Fri 01/09/2015 to Fri 01/09/2015

**UPDATED****by CONED 08/27/2014**

(Import)

1830 Continuous 1900

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW



**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SHORE\_RD\_345\_138\_BK 1**

FWD

Mon 01/12/2015 to Sat 01/17/2015

(Import)

0000 Continuous 2359

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Mon 01/12/2015 to Wed 01/14/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

**ATHENS\_-PLSNTVLY\_345\_91**

FWD

Tue 01/13/2015 to Fri 01/16/2015

(Import)

0001 Continuous 2359

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Tue 01/13/2015 to Fri 01/16/2015

(Import)

0001 Continuous 2359

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Thu 01/15/2015 to Fri 01/16/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

**PLSNTVLY\_345KV\_RNS4**

FWD

Sun 01/18/2015 to Sun 01/18/2015

(Import)

0900 Continuous 2259

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MAL**

FWD

Mon 01/19/2015 to Fri 01/23/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS4**

FWD

Mon 01/19/2015 to Mon 01/19/2015

(Import)

0900 Continuous 2359

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 01/26/2015 to Fri 01/30/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/02/2015 to Fri 02/06/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/09/2015 to Fri 02/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ADIRNDCK-CHASLAKE\_230\_13**

FWD

Tue 02/17/2015 to Wed 02/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**MOSES\_\_-ADIRNDCK\_230\_MA1**

FWD

Tue 02/17/2015 to Wed 02/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Thu 02/19/2015 to Fri 02/20/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_C3403

Mon 02/23/2015 to Wed 03/04/2015  
0200 Continuous 2359

Work scheduled by: PJM

UPDATED by CONED 08/26/2014

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2450 MW</b>	<b>2600 MW</b>
Impacts Total Transfer Capability	0 MW	100 MW
TTC with All Lines In Service	2450 MW	2700 MW

## KINTIGH\_-ROCHESTR\_345\_SR1-39

Mon 02/23/2015 to Tue 02/24/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	2850 MW

## STLAWRNC-MOSES\_\_\_\_230\_L34P

Mon 02/23/2015 to Tue 02/24/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1800 MW</b>	<b>1850 MW</b>
Impacts Total Transfer Capability	100 MW	50 MW
TTC with All Lines In Service	1900 MW	1900 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 02/23/2015 to Fri 02/27/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

## MARCY\_\_\_\_345\_STATCOM SVC

Tue 02/24/2015 to Fri 02/27/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2925 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P

Wed 02/25/2015 to Thu 02/26/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1800 MW</b>	<b>1850 MW</b>
Impacts Total Transfer Capability	100 MW	50 MW
TTC with All Lines In Service	1900 MW	1900 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 03/02/2015 to Fri 03/06/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	2850 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 03/09/2015 to Fri 03/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**MARCY\_\_\_345\_STATCOM SVC**

FWD

Mon 03/16/2015 to Mon 03/16/2015

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 03/16/2015 to Fri 03/20/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_\_\_345\_RP1**

FWD

Mon 03/16/2015 to Fri 03/20/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/23/2015 to Fri 03/27/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_\_\_345\_RP1**

FWD

Mon 03/23/2015 to Fri 03/27/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/30/2015 to Fri 04/03/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ROCHESTR-PANNELL\_\_345\_RP1**

Mon 03/30/2015 to Fri 04/03/2015  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 550 MW  
TTC with All Lines In Service 2850 MW

---

**HUDSONP\_-FARRAGUT\_345\_B3402**

Wed 04/01/2015 to Fri 04/10/2015  
0001 Continuous 2359

Work scheduled by: PJM

UPDATED by CONED 10/14/2014

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2450 MW 2600 MW**  
Impacts Total Transfer Capability 0 MW 100 MW  
TTC with All Lines In Service 2450 MW 2700 MW

---

**CLAY\_-EDIC\_\_345\_1-16**

Mon 04/06/2015 to Tue 04/07/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

---

**MARCY\_-COOPERS\_\_345\_UC2-41**

Mon 04/06/2015 to Fri 04/10/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

---

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 04/06/2015 to Fri 04/10/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 04/06/2015 to Fri 04/24/2015  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

---

**CLAY\_-EDIC\_\_345\_2-15**

Wed 04/08/2015 to Thu 04/09/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_____345_PC1</b>				FWD		
Mon 04/13/2015	to	Tue 04/14/2015		(Import)		
0700	Continuous	1530		<b>WEST CENTRAL</b>	<b>1300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW	
				TTC with All Lines In Service	2250 MW	
<b>NRTH1385-NOR HBR__138_601</b>				FWD	REV	
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)	
0500	Continuous	1500		<b>SCH - NPX_1385</b>	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>				FWD	REV	
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)	
0500		1500		<b>SCH - NPX_1385</b>	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW	200 MW
				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>				FWD	REV	
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)	
0500		1500		<b>SCH - NPX_1385</b>	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW	200 MW
				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR__138_602</b>				FWD	REV	
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)	
0500	Continuous	1500		<b>SCH - NPX_1385</b>	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>				FWD	REV	
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)	
0500		1500		<b>SCH - NPX_1385</b>	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	200 MW	200 MW
				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR__138_603</b>				FWD	REV	
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)	
0500	Continuous	1500		<b>SCH - NPX_1385</b>	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>2850MW</b>
<b>WEST CENTRAL</b>	<b>2250MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NRTH1385-NRTHPORT\_138\_1385**

Mon 04/20/2015 to Thu 04/30/2015  
0500 Continuous 1500

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**ROCHESTR-PANNELL\_345\_RP2**

Mon 04/20/2015 to Fri 04/24/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2300 MW</b>
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

**LEEDS\_345\_LEEDS SVC**

Mon 04/27/2015 to Fri 05/01/2015  
0700 Continuous 1500

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	<b>2950 MW</b>
Impacts Total Transfer Capability	25 MW
TTC with All Lines In Service	2975 MW

**ROCHESTR-PANNELL\_345\_RP2**

Mon 04/27/2015 to Fri 05/01/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2300 MW</b>
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>2850MW</b>
<b>WEST CENTRAL</b>	<b>2250MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE\_345\_138\_BK\_2**

FWD

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**SCH-NE-NYISO\_LIMIT\_900**

FWD

Mon 05/04/2015 to Thu 05/21/2015  
0600 Continuous 1700

(Import)

SCH - NE - NY

**1100 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Mon 05/04/2015 to Tue 05/05/2015  
0700 Continuous 1530

(Import)

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Mon 05/04/2015 to Fri 05/08/2015  
0700 Continuous 1530

(Import)

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**FRASER\_-GILBOA\_345\_GF5-35**

FWD

Mon 05/04/2015 to Fri 05/08/2015  
0700 Continuous 1600

(Import)

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Mon 05/11/2015 to Fri 05/15/2015  
0700 Continuous 1530

(Import)

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**EDIC\_-FRASER\_345\_EF24-40**

FWD

Mon 05/11/2015 to Fri 05/15/2015  
0900 Continuous 1530

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG



# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday ,April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 05/18/2015 to Fri 05/22/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 05/18/2015 to Fri 05/22/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

## STLAWRNC-MOSES\_\_\_\_230\_L34P

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA1

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

## PANNELL\_-CLAY\_\_\_\_345\_PC2

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Wed 06/03/2015 to Thu 06/04/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Thu 08/13/2015 to Thu 08/13/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 2600 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 08/18/2015 to Tue 08/18/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 2600 MW

**ADIRNDCK-PORTER\_\_\_230\_12-AP**

FWD

Wed 08/19/2015 to Wed 08/19/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 2600 MW

**ADIRNDCK-CHASLAKE\_230\_13**

FWD

Thu 08/20/2015 to Thu 08/20/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 2600 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 08/31/2015 to Fri 09/04/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 2600 MW

**MARCY\_\_\_765\_345\_BK 2**

FWD

Mon 09/07/2015 to Fri 09/11/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 2600 MW

**HURLYAVE-ROSETON\_\_\_345\_303**

FWD

Mon 09/07/2015 to Fri 09/25/2015  
 0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_BK 4				FWD	REV
Mon 09/07/2015 to Fri 10/09/2015				(Import)	(Export)
0800	Continuous	1530	SCH - OH - NY	1900 MW	1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	1900 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
Mon 09/14/2015 to Fri 09/18/2015				(Import)	
0700	Continuous	1530	MOSES SOUTH	2000 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	2600 MW
COOPERS_-MIDDLETP_345_CMT-34				FWD	
Mon 09/14/2015 to Fri 09/18/2015				(Import)	
0700	Continuous	1600	CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
MOSES__-ADIRNDCK_230_MA1				FWD	
Mon 09/21/2015 to Fri 09/25/2015				(Import)	
0700	Continuous	1530	MOSES SOUTH	2000 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	2600 MW
COOPERS_-ROCKTVRN_345_CRT-42				FWD	
Mon 09/21/2015 to Fri 09/25/2015				(Import)	
0700	Continuous	1600	CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
LONG_MTN-PLSNTVLY_345_398				FWD	REV
Wed 09/23/2015 to Fri 10/02/2015				(Import)	(Export)
0500	Continuous	1700	SCH - NE - NY	500 MW	1300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	900 MW
				TTC with All Lines In Service	1400 MW
LONG_MTN-PLSNTVLY_345_398				FWD	REV
Wed 09/23/2015 to Fri 10/02/2015				(Import)	(Export)
0500	Continuous	1700	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 09/28/2015 to Fri 10/02/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA\_\_\_765\_7040**

FWD

REV

Sat 10/03/2015 to Sun 10/25/2015

**UPDATED****by NYPA****10/07/2014**

(Import) (Export)

0100 Continuous 1730

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**MARCY\_\_\_765\_345\_BK 1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

**UPDATED****by NYPA****10/07/2014**

(Import)

0100 Continuous 1730

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_765\_345\_BK 2**

FWD

Sat 10/03/2015 to Sun 10/25/2015

**UPDATED****by NYPA****10/07/2014**

(Import)

0100 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ARR: 19****MASSENA\_-MARCY\_\_\_765\_MSU1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

**UPDATED****by NYPA****10/07/2014**

(Import)

0100 Continuous 1730

CENTRAL EAST - VC

**2315 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 20****MASSENA\_-MARCY\_\_\_765\_MSU1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

**UPDATED****by NYPA****10/07/2014**

(Import)

0100 Continuous 1730

MOSES SOUTH

**675 MW**

Impacts Total Transfer Capability 1925 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ARR: 20****MASSENA\_-MARCY\_\_\_765\_MSU1**

FWD

REV

Sat 10/03/2015 to Sun 10/25/2015

**UPDATED****by NYPA****10/07/2014**

(Import) (Export)

0100 Continuous 1730

SCH - HQ - NY

**475 MW****1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**ARR: 20**

**NYISO TRANSFER LIMITATIONS**

Wednesday, October 22, 2014 to Friday , April 22, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 2850MW**  
**WEST CENTRAL 2250MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SHOR\_NPX-SHOREHAM\_138\_NPX\_CSC**Mon 10/05/2015 to Sun 10/11/2015 **UPDATED by ISONE 07/25/2014**

0530 Continuous 1800

Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

**GILBOA\_-LEEDS\_345\_GL3**

Mon 10/05/2015 to Fri 10/09/2015

0700 Continuous 1600

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	<b>2200 MW</b>
Impacts Total Transfer Capability	775 MW
TTC with All Lines In Service	2975 MW

**MALONE\_-WILLIS\_115\_1-MW**

Tue 10/06/2015 to Tue 10/06/2015

0800 Continuous 1530

Work scheduled by: NYPA

**ARR: 20&38**

	REV (Export)
SCH - HQ_CEDARS	<b>40 MW</b>
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	40 MW

**LEEDS\_-HURLYAVE\_345\_301**

Mon 10/12/2015 to Fri 10/30/2015

0800 Continuous 1600

Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

**GILBOA\_-N.SCTLND\_345\_GNS1**Mon 10/19/2015 to Fri 10/23/2015 **UPDATED by NYISO 09/12/2014**

0700 Continuous 1600

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	<b>2520 MW</b>
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

**MARCY\_-COOPERS\_345\_UC2-41**

Mon 11/02/2015 to Fri 11/06/2015

0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**BERKSHIR-ALPS\_345\_393**

Mon 11/30/2015 to Fri 12/04/2015

0600 Continuous 1500

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1200 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 22, 2014 to Friday , April 22, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393			FWD	REV
Mon 11/30/2015	to	Fri 12/04/2015	(Import)	(Export)
0600	Continuous	1500	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
MOSES____-ADIRNDCK_230_MAL			FWD	
Mon 11/30/2015	to	Fri 12/04/2015	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	2600 MW
MOSES____-ADIRNDCK_230_MAL			FWD	
Mon 12/07/2015	to	Fri 12/11/2015	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	2600 MW
MOSES____-ADIRNDCK_230_MAL			FWD	
Mon 12/14/2015	to	Fri 12/18/2015	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	2600 MW