NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_NPX_CSC

Sat 10/25/2014 1709 to Sat 01/31/2015 1600 Continuous

EXT FORCE **by NE** **01/06/2015**

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_CSC	**0 MW**	**0 MW**
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

SHORE_RD_345_138_BK 1

Mon 01/12/2015 0000 to Mon 01/26/2015 1512 Continuous

RETURNED **by LI** **01/26/2015**

Work scheduled by: LI

	FWD (Import)
CONED - LIPA	**1350 MW**
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	1500 MW

MOSES___-ADIRNDCK_230_MA1

Mon 01/19/2015 0700 to Fri 01/23/2015 1530 Continuous

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

RAMAPO___345_345_PAR4500

Thu 01/22/2015 0139 to Fri 01/23/2015 2359 Continuous

UPDATED **by CONED** **01/23/2015**

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2400 MW**	**1300 MW**
Impacts Total Transfer Capability	50 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

HOPATCON-RAMAPO___500_5018

Fri 01/23/2015 0116 to Fri 01/23/2015 0446 Continuous

UPDATED **by CONED** **01/23/2015**

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2100 MW**	**1000 MW**
Impacts Total Transfer Capability	350 MW	300 MW
TTC with All Lines In Service	2450 MW	1300 MW

HOPATCON-RAMAPO___500_5018

Fri 01/23/2015 0116 to Fri 01/23/2015 0446 Continuous

UPDATED **by CONED** **01/23/2015**

Work scheduled by: ConEd

	FWD (Import)
TOTAL EAST	**6400 MW**
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	6500 MW

HOPATCON-RAMAPO___500_5018

Fri 01/23/2015 0116 to Fri 01/23/2015 0446 Continuous

UPDATED **by CONED** **01/23/2015**

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500

Fri 01/23/2015 to Fri 01/23/2015 **UPDATED** **by CONED** **01/23/2015**
0116 Continuous 0446
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2400 MW**	**1300 MW**
Impacts Total Transfer Capability	50 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

RAMAPO___500_345_BK 1500

Fri 01/23/2015 to Fri 01/23/2015 **UPDATED** **by CONED** **01/23/2015**
0116 Continuous 0446
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2100 MW**	**1000 MW**
Impacts Total Transfer Capability	350 MW	300 MW
TTC with All Lines In Service	2450 MW	1300 MW

ATHENS__-PLSNTVLY_345_91

Sat 01/24/2015 to Sun 01/25/2015 **UPDATED** **by CE** **01/26/2015**
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY_345KV_RNS4

Sat 01/24/2015 to Sun 03/01/2015 **UPDATED** **by CE** **01/26/2015**
0001 Continuous 0859
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

MOSES___-ADIRNDCK_230_MA1

Mon 01/26/2015 to Fri 01/30/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

PLSNTVLY-WOOD_ST__345_F31

Wed 01/28/2015 to Thu 01/29/2015 **UPDATED** **by CE** **01/26/2015**
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

CHAT_DC_GC2

Sun 02/01/2015 to Sun 02/01/2015 **UPDATED** **by HQ** **01/23/2015**
0700 Continuous 1100
Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	**2150 MW**
Impacts Total Transfer Capability	450 MW
TTC with All Lines In Service	2600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Sun 02/01/2015 0700 to Sun 02/01/2015 1100 Continuous

Work scheduled by: HQ

UPDATED **by HQ** **01/23/2015**

	REV (Export)
SCH - HQ - NY	**500 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

SCH-HQ-NYISO_LIMIT_1400

Sun 02/01/2015 0700 to Sun 02/01/2015 1100 Continuous

Work scheduled by: HQ

UPDATED **by HQ** **01/23/2015**

	FWD (Import)
SCH - HQ - NY	**1400 MW**
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	1500 MW

W49TH_ST_345KV_6

Mon 02/02/2015 0001 to Mon 02/02/2015 0100 Continuous

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_8

Mon 02/02/2015 0001 to Mon 02/02/2015 0100 Continuous

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 02/02/2015 0500 to Wed 02/04/2015 1600 Continuous

Work scheduled by: NYPA

UPDATED **by NYPA** **01/22/2015**

	FWD (Import)
DYSINGER EAST	**1700 MW**
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	2850 MW

ADIRNDCK-PORTER___230_12-AP

Mon 02/02/2015 0700 to Mon 02/02/2015 2200 Continuous

Work scheduled by: NYPA

UPDATED **by NYPA** **01/20/2015**

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA2

Mon 02/02/2015 0700 to Mon 02/02/2015 2200 Continuous

Work scheduled by: NYPA

UPDATED **by NYPA** **01/20/2015**

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Tue 02/03/2015 to Fri 02/06/2015 **UPDATED** **by NYPA** **01/15/2015**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

HUDSONTP-W49TH_ST_345_Y56

Tue 02/03/2015 to Tue 02/03/2015
1800 Continuous 1900
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_6

Tue 02/03/2015 to Tue 02/03/2015
1800 Continuous 1900
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_8

Tue 02/03/2015 to Tue 02/03/2015
1800 Continuous 1900
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_6

Wed 02/04/2015 to Wed 02/04/2015
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_8

Wed 02/04/2015 to Wed 02/04/2015
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

FROST_BR-LONG_MTN_345_352

Wed 02/04/2015 to Wed 02/04/2015
0700 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	**1300 MW**	**1600 MW**
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	1400 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38

Thu 02/05/2015 to Fri 02/06/2015 **UPDATED** **by NYPA** **01/26/2015**

0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**1700 MW**
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	2850 MW

W49TH_ST_345KV_6

Fri 02/06/2015 to Fri 02/06/2015

1800 Continuous 1900

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_8

Fri 02/06/2015 to Fri 02/06/2015

1800 Continuous 1900

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_6

Fri 02/06/2015 to Fri 02/06/2015

2200 Continuous 2230

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_8

Fri 02/06/2015 to Fri 02/06/2015

2200 Continuous 2230

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_6

Sun 02/08/2015 to Sun 02/08/2015

2230 Continuous 2300

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

W49TH_ST_345KV_8

Sun 02/08/2015 to Sun 02/08/2015

2230 Continuous 2300

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____345_STATCOM SVC

Mon 02/09/2015 to Fri 02/27/2015 **UPDATED** **by PA** **11/20/2014**
0500 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2925 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 02/09/2015 to Fri 02/13/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA2

Mon 02/09/2015 to Fri 02/13/2015 **CANCELLED** **by NYPA** **01/26/2015**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA1

Tue 02/17/2015 to Tue 02/17/2015 **UPDATED** **by NYPA** **01/13/2015**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

ADIRNDCK-CHASLAKE_230_13

Wed 02/18/2015 to Wed 02/18/2015 **UPDATED** **by NYPA** **01/15/2015**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA2

Thu 02/19/2015 to Fri 02/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

W49TH_ST_345KV_7

Mon 02/23/2015 to Fri 02/27/2015
0001 Continuous 1900
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**340 MW**
Impacts Total Transfer Capability	320 MW
TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_C3403

Mon 02/23/2015 to Wed 03/04/2015 **UPDATED** **by CONED** **12/05/2014**
0200 Continuous 1700
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2450 MW**	**1300 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

KINTIGH_-ROCHESTR_345_SR1-39

Mon 02/23/2015 to Tue 02/24/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**1300 MW**
Impacts Total Transfer Capability	1550 MW
TTC with All Lines In Service	2850 MW

STLAWRNC-MOSES____230_L34P

Mon 02/23/2015 to Tue 02/24/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1750 MW**	**1750 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES___-ADIRNDCK_230_MA2

Mon 02/23/2015 to Fri 02/27/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

W49TH_ST_345KV_5

Tue 02/24/2015 to Tue 02/24/2015
0001 Continuous 1900
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**340 MW**
Impacts Total Transfer Capability	320 MW
TTC with All Lines In Service	660 MW

PLSNTVLY-WOOD_ST__345_F31

Wed 02/25/2015 to Thu 02/26/2015 **UPDATED** **by CE** **01/26/2015**
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4000 MW**
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

ROCHESTR-PANNELL__345_RP1

Wed 02/25/2015 to Wed 02/25/2015 **UPDATED** **by RGE** **01/27/2015**
0700 Continuous 1500
Work scheduled by: RGE

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES____230_L33P

Wed 02/25/2015 to Thu 02/26/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1750 MW**	**1750 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	1900 MW	1900 MW

ROCHESTR-PANNELL__345_RP2

Thu 02/26/2015 to Thu 02/26/2015
0700 Continuous 1500
Work scheduled by: RGE

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

W49TH_ST_345KV_5

Thu 02/26/2015 to Thu 02/26/2015 **UPDATED** **by NYISO** **01/26/2015**
1830 Continuous 1900
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**340 MW**
Impacts Total Transfer Capability	320 MW
TTC with All Lines In Service	660 MW

ATHENS__-PLSNTVLY_345_91

Fri 02/27/2015 to Sat 02/28/2015 **UPDATED** **by CE** **01/26/2015**
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

PLSNTVLY_345KV_RNS4

Sun 03/01/2015 to Mon 03/02/2015 **UPDATED** **by CE** **01/26/2015**
2300 Continuous 0859
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**3800 MW**
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

LADENTWN-BUCHAN_S_345_Y88

Mon 03/02/2015 to Wed 03/18/2015
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4150 MW**
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	5100 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 03/02/2015 to Fri 03/06/2015 **UPDATED** **by RGE** **01/06/2015**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**1700 MW**
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	2850 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-EDIC_____345_UE1-7

Mon 03/02/2015 to Fri 03/06/2015
0800 Continuous 1530
Work scheduled by: NYPA

ARR: 16

	FWD (Import)
OSWEGO EXPORT	**5250 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

WATRCURE-OAKDALE__345_31

Mon 03/02/2015 to Fri 03/06/2015 **EXTENDED** **by NYSEG** **01/06/2015**
0900 Daily 1500
Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2450 MW**	**1300 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

MILLWOOD_345KV_18

Tue 03/03/2015 to Tue 03/03/2015
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

E13THSTA-FARRAGUT_345_46

Sat 03/07/2015 to Sun 03/08/2015
0001 Continuous 2330
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

W49TH_ST-E13THSTA_345_M55

Sat 03/07/2015 to Sun 03/08/2015
0001 Continuous 2330
Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	**3800 MW**
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

W49TH_ST_345KV_6

Sat 03/07/2015 to Sun 03/08/2015
0001 Continuous 2330
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**300 MW**
Impacts Total Transfer Capability	360 MW
TTC with All Lines In Service	660 MW

MOSES___-ADIRNDCK_230_MA1

Mon 03/09/2015 to Fri 03/13/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY____345_19

Mon 03/09/2015 to Fri 03/13/2015
0800 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2825 MW**
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	2975 MW

VOLNEY__-MARCY____345_19

Mon 03/09/2015 to Fri 03/13/2015
0800 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
OSWEGO EXPORT	**4900 MW**
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	5250 MW

BECK____-NIAGARA__230_PA27

Tue 03/10/2015 to Tue 03/10/2015
0800 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1900 MW**	**1900 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1900 MW

MILLWOOD_345KV_18

Wed 03/11/2015 to Wed 03/11/2015
0001 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

MARCY____345_STATCOM SVC

Mon 03/16/2015 to Mon 03/16/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2925 MW**
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 03/16/2015 to Fri 03/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

ROCHESTR-PANNELL__345_RP1

Mon 03/16/2015 to Fri 03/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18

Wed 03/18/2015 to Wed 03/18/2015
2330 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	**4350 MW**
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

MOSES___-ADIRNDCK_230_MA2

Mon 03/23/2015 to Fri 03/27/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

ROCHESTR-PANNELL__345_RP1

Mon 03/23/2015 to Fri 03/27/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

BECK____-PACKARD__230_BP76

Thu 03/26/2015 to Thu 03/26/2015
0800 Daily(No Weekends) 1530
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - OH - NY	**1900 MW**	**1800 MW**
Impacts Total Transfer Capability	0 MW	100 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES___-ADIRNDCK_230_MA2

Mon 03/30/2015 to Fri 04/03/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

ROCHESTR-PANNELL__345_RP1

Mon 03/30/2015 to Fri 04/03/2015
0700 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

HUDSONP_-FARRAGUT_345_B3402

Wed 04/01/2015 to Fri 04/10/2015 **UPDATED by CONED 12/05/2014**
0001 Continuous 1530
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2450 MW**	**1300 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY____-EDIC_____345_1-16

Mon 04/06/2015 to Tue 04/07/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
OSWEGO EXPORT	**4850 MW**
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

MOSES___-ADIRNDCK_230_MA2

Mon 04/06/2015 to Fri 04/10/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

ROSETON_-ROCKTVRN_345_311

Mon 04/06/2015 to Fri 04/24/2015
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4400 MW**
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5100 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 04/06/2015 to Sat 04/11/2015
2200 Continuous 2100
Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

PANNELL_-CLAY_____345_PC1

Mon 04/13/2015 to Tue 04/14/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
WEST CENTRAL	**1300 MW**
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

MARCY___-COOPERS__345_UC2-41

Mon 04/13/2015 to Fri 04/17/2015 **UPDATED** **by NYPA** **01/20/2015**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

BERKSHIR-ALPS_____345_393

Wed 04/15/2015 to Thu 04/16/2015
0800 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NE - NY	**1300 MW**	**1300 MW**
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393

Wed 04/15/2015 to Thu 04/16/2015
0800 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_601

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602

Mon 04/20/2015 to Thu 04/30/2015
0500 1500
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603

Mon 04/20/2015 to Thu 04/30/2015
0500 1500
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_602

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 04/20/2015 to Thu 04/30/2015
0500 1500
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_603

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NRTHPORT_138_1385

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

ROCHESTR-PANNELL__345_RP2

Mon 04/20/2015 to Fri 04/24/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

LIND_CG_-LNDVFT___345_V-3022

Tue 04/21/2015 to Wed 04/22/2015
0900 Continuous 1400
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	**0 MW**	**0 MW**
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

LEEDS____345_LEEDS SVC

Mon 04/27/2015 to Fri 05/01/2015
0700 Continuous 1500
Work scheduled by: NGrid

	FWD (Import)
CENTRAL EAST - VC	**2950 MW**
Impacts Total Transfer Capability	25 MW
TTC with All Lines In Service	2975 MW

ROCHESTR-PANNELL__345_RP2

Mon 04/27/2015 to Fri 05/01/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**2300 MW**
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	2850 MW

FRASER__-GILBOA___345_GF5-35

Mon 04/27/2015 to Fri 05/08/2015 **UPDATED** **by NYPA** **01/09/2015**
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2650 MW**
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**0 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_2

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

	FWD (Import)
SCH - PJM_NEPTUNE	**375 MW**
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

SCH-NE-NYISO_LIMIT_900

Mon 05/04/2015 to Thu 05/21/2015
0600 Continuous 1700
Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	**1100 MW**
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	1400 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 05/04/2015 to Tue 05/05/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
DYSINGER EAST	**1700 MW**
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	2850 MW

MOSES___-ADIRNDCK_230_MA1

Mon 05/04/2015 to Fri 05/08/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

CHATGUAY-MASSENA__765_7040

Mon 05/04/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 05/11/2015 to Fri 05/15/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

EDIC____-FRASER___345_EF24-40

Mon 05/11/2015 to Fri 05/15/2015
0900 Continuous 1530
Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

BECK____-PACKARD__230_BP76

Tue 05/12/2015 to Tue 05/12/2015
0730 Daily(No Weekends) 1600
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - OH - NY	**1750 MW**	**1200 MW**
Impacts Total Transfer Capability	150 MW	700 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES___-ADIRNDCK_230_MA2

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

STLAWRNC-MOSES____230_L33P

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1750 MW**	**1750 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES___-ADIRNDCK_230_MA2

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

STLAWRNC-MOSES____230_L34P

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1750 MW**	**1750 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	1900 MW	1900 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

PANNELL_-CLAY_____345_PC2

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
WEST CENTRAL	**1300 MW**
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

MOSES___-ADIRNDCK_230_MA2

Wed 06/03/2015 to Thu 06/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

BECK____-NIAGARA__345_PA302

Thu 06/25/2015 to Fri 06/26/2015
0500 Continuous 1600
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1200 MW**	**1100 MW**
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES___-ADIRNDCK_230_MA1

Thu 08/13/2015 to Thu 08/13/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA2

Tue 08/18/2015 to Tue 08/18/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

ADIRNDCK-PORTER___230_12-AP

Wed 08/19/2015 to Wed 08/19/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	2600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Thu 08/20/2015 to Thu 08/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2100 MW**
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA2

Mon 08/31/2015 to Fri 09/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

CLAY____-EDIC_____345_2-15

Thu 09/03/2015 to Fri 09/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
OSWEGO EXPORT	**4850 MW**
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

MARCY____765_345_BK 2

Mon 09/07/2015 to Fri 09/11/2015
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	900 MW
TTC with All Lines In Service	2600 MW

HURLYAVE-ROSETON__345_303

Mon 09/07/2015 to Fri 09/25/2015
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

NIAGARA__345_230_BK 4

Mon 09/07/2015 to Fri 10/09/2015
0800 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1900 MW**	**1900 MW**
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-MIDDLETP_345_CMT-34

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1600
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2720 MW**
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

COOPERS_-ROCKTVRN_345_CRT-42

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1600
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2720 MW**
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	**500 MW**	**1300 MW**
Impacts Total Transfer Capability	900 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BECK____-NIAGARA__345_PA302

Thu 09/24/2015 to Fri 09/25/2015
0500 Continuous 1600
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1200 MW**	**1100 MW**
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/28/2015 to Fri 10/02/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MARCY____765_345_BK 1

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1750 MW**
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	2600 MW

MARCY____765_345_BK 2

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

	FWD (Import)
MOSES SOUTH	**1700 MW**
Impacts Total Transfer Capability	900 MW
TTC with All Lines In Service	2600 MW

MASSENA_-MARCY____765_MSU1

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 20**

	FWD (Import)
CENTRAL EAST - VC	**2315 MW**
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	2975 MW

MASSENA_-MARCY____765_MSU1

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 20**

	FWD (Import)
MOSES SOUTH	**675 MW**
Impacts Total Transfer Capability	1925 MW
TTC with All Lines In Service	2600 MW

MASSENA_-MARCY____765_MSU1

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 20**

	FWD (Import)	REV (Export)
SCH - HQ - NY	**475 MW**	**1000 MW**
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

SHOR_NPX-SHOREHAM_138_NPX_CSC

Mon 10/05/2015 to Sun 10/11/2015 **UPDATED** **by ISONE** **07/25/2014**
0530 Continuous 1800
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	**0 MW**	**0 MW**
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-LEEDS____345_GL3

Mon 10/05/2015 to Fri 10/09/2015
0700 Continuous 1600
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2200 MW**
Impacts Total Transfer Capability	775 MW
TTC with All Lines In Service	2975 MW

MALONE__-WILLIS___115_1-MW

Tue 10/06/2015 to Tue 10/06/2015
0800 Continuous 1530
Work scheduled by: NYPA

ARR: 20&38

	REV (Export)
SCH - HQ_CEDARS	**40 MW**
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	40 MW

LEEDS___-HURLYAVE_345_301

Mon 10/12/2015 to Fri 10/30/2015
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4100 MW**
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

GILBOA__-N.SCTLND_345_GNS1

Mon 10/19/2015 to Fri 10/23/2015 **UPDATED** **by NYISO** **09/12/2014**
0700 Continuous 1600
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2520 MW**
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

MARCY___-COOPERS__345_UC2-41

Mon 11/02/2015 to Fri 11/06/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	**2500 MW**
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

ROCKTVRN-RAMAPO___345_77

Sat 11/07/2015 to Fri 11/20/2015 **UPDATED** **by CH** **12/16/2014**
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
CENTRAL EAST - VC	**2570 MW**
Impacts Total Transfer Capability	405 MW
TTC with All Lines In Service	2975 MW

ROSETON_-ROCKTVRN_345_311

Sat 11/07/2015 to Fri 11/20/2015 **UPDATED** **by CH** **12/16/2014**
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
UPNY CONED	**4400 MW**
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday,January 28, 2015 to Friday ,July 29, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NE - NY	**1300 MW**	**1300 MW**
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/30/2015 to Fri 12/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA1

Mon 12/07/2015 to Fri 12/11/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

MOSES___-ADIRNDCK_230_MA1

Mon 12/14/2015 to Fri 12/18/2015
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	**2000 MW**
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

BECK____-NIAGARA__345_PA302

Thu 12/17/2015 to Fri 12/18/2015
0500 Continuous 1600
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1400 MW**	**1250 MW**
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

ROCKTVRN-RAMAPO___345_77

Mon 04/04/2016 to Fri 04/29/2016
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)
CENTRAL EAST - VC	**2570 MW**
Impacts Total Transfer Capability	405 MW
TTC with All Lines In Service	2975 MW