# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SHOR_NPX-SHOREHAM_138_NPX_CSC**

Sat 10/25/2014 1709 to Sat 01/31/2015 1600 Continuous

**EXT FORCE** **by NE** **01/06/2015**

Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_CSC | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

**SHORE_RD_345_138_BK 1**

Mon 01/12/2015 0000 to Thu 01/22/2015 2359 Continuous

**EXTENDED** **by LI** **12/15/2014**

Work scheduled by: LI

| | FWD (Import) |
|---|---|
| CONED - LIPA | **1350 MW** |
| Impacts Total Transfer Capability | 150 MW |
| TTC with All Lines In Service | 1500 MW |

**ATHENS__-PLSNTVLY_345_91**

Wed 01/14/2015 1600 to Sun 01/18/2015 2359 Continuous

**UPDATED** **by CE** **01/16/2015**

Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

**PLSNTVLY_345KV_RNS4**

Wed 01/14/2015 1600 to Sun 01/18/2015 2359 Continuous

**UPDATED** **by CE** **01/16/2015**

Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

**FRASER___345_FRASER SVC**

Thu 01/15/2015 0930 to Thu 01/15/2015 1200 Continuous

**UPDATED** **by NY** **01/09/2015**

Work scheduled by: NYSEG

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2935 MW** |
| Impacts Total Transfer Capability | 40 MW |
| TTC with All Lines In Service | 2975 MW |

**BROWNFLS-TAYLORVL_115_4-BT**

Thu 01/15/2015 1200 to Thu 01/15/2015 1530 Daily(No Weekends)

**CANCELLED** **by NGrid** **01/15/2015**

**ARR: 38**

Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 99 MW | 0 MW |
| TTC with All Lines In Service | 199 MW | 100 MW |

**CHAT_DC_GC2**

Sun 01/18/2015 0600 to Sun 01/18/2015 1600 Continuous

**UPDATED** **by HQ** **01/15/2015**

Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2150 MW** |
| Impacts Total Transfer Capability | 450 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**CHAT_DC_GC2**

Sun 01/18/2015 0600 to Sun 01/18/2015 1600 Continuous — **UPDATED** **by HQ** **01/15/2015**

Work scheduled by: HQ

| | REV (Export) |
|---|---|
| SCH - HQ - NY | **500 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 1000 MW |

---

**SCH-HQ-NYISO_LIMIT_1100**

Sun 01/18/2015 0600 to Sun 01/18/2015 1600 Continuous — **UPDATED** **by HQ** **01/15/2015**

Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| SCH - HQ - NY | **1100 MW** |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 1500 MW |

---

**LOWVILLE-BOONVLLE_115_5-LB**

Sun 01/18/2015 1200 to Sun 01/18/2015 1600 Daily

Work scheduled by: NGrid

**ARR: 38**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **199 MW** | **100 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 199 MW | 100 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 01/19/2015 0700 to Fri 01/23/2015 1530 Continuous

Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**PLSNTVLY_345KV_RNS4**

Tue 01/20/2015 0900 to Tue 01/20/2015 2259 Continuous — **UPDATED** **by CE** **01/16/2015**

Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**PLSNTVLY_345KV_RNS4**

Wed 01/21/2015 0900 to Wed 01/21/2015 2359 Continuous — **UPDATED** **by CE** **01/16/2015**

Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**ATHENS__-PLSNTVLY_345_91**

Sat 01/24/2015 0001 to Sun 01/25/2015 2359 Continuous

Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**PLSNTVLY_345KV_RNS4**

Sat 01/24/2015 to Sun 03/01/2015
0001 Continuous 0859
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**PLSNTVLY-WOOD_ST__345_F31**

Mon 01/26/2015 to Tue 01/27/2015
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4000 MW** |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

---

**NIAGARA_-ROCHESTR_345_NR2**

Mon 01/26/2015 to Wed 01/28/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **1700 MW** |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 2850 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 01/26/2015 to Fri 01/30/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**NIAGARA_-KINTIGH__345_NS1-38**

Thu 01/29/2015 to Fri 01/30/2015 **UPDATED** **by NYISO** **01/09/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **1700 MW** |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 2850 MW |

---

**CHAT_DC_GC2**

Sun 02/01/2015 to Sun 02/01/2015 **UPDATED** **by HQ** **01/20/2015**
0700 Continuous 1100
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2150 MW** |
| Impacts Total Transfer Capability | 450 MW |
| TTC with All Lines In Service | 2600 MW |

---

**CHAT_DC_GC2**

Sun 02/01/2015 to Sun 02/01/2015 **UPDATED** **by HQ** **01/20/2015**
0700 Continuous 1100
Work scheduled by: HQ

| | REV (Export) |
|---|---|
| SCH - HQ - NY | **500 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 1000 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SCH-HQ-NYISO_LIMIT_1500**

Sun 02/01/2015 to Sun 02/01/2015 **UPDATED** **by HQ** **01/20/2015**
0700 Continuous 1100
Work scheduled by: HQ

| | FWD (Import) |
|---|---|
| SCH - HQ - NY | **1500 MW** |
| Impacts Total Transfer Capability | 0 MW |
| TTC with All Lines In Service | 1500 MW |

---

**W49TH_ST_345KV_6**

Mon 02/02/2015 to Mon 02/02/2015
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

---

**W49TH_ST_345KV_8**

Mon 02/02/2015 to Mon 02/02/2015
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

---

**ROCHESTR-PANNELL__345_RP1**

Mon 02/02/2015 to Mon 02/02/2015
0700 Continuous 1500
Work scheduled by: RGE

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2300 MW** |
| Impacts Total Transfer Capability | 550 MW |
| TTC with All Lines In Service | 2850 MW |

---

**ADIRNDCK-PORTER___230_12-AP**

Mon 02/02/2015 to Mon 02/02/2015 **UPDATED** **by NYPA** **01/20/2015**
0700 Continuous 2200
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 2600 MW |

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 02/02/2015 to Mon 02/02/2015 **UPDATED** **by NYPA** **01/20/2015**
0700 Continuous 2200
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Tue 02/03/2015 to Fri 02/06/2015 **UPDATED** **by NYPA** **01/15/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HUDSONTP-W49TH_ST_345_Y56**

Tue 02/03/2015 to Tue 02/03/2015
1800 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

**W49TH_ST_345KV_6**

Tue 02/03/2015 to Tue 02/03/2015
1800 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

**W49TH_ST_345KV_8**

Tue 02/03/2015 to Tue 02/03/2015
1800 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

**W49TH_ST_345KV_6**

Wed 02/04/2015 to Wed 02/04/2015
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

**W49TH_ST_345KV_8**

Wed 02/04/2015 to Wed 02/04/2015
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

**FROST_BR-LONG_MTN_345_352**

Wed 02/04/2015 to Wed 02/04/2015
0700 Continuous 1600
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1300 MW** | **1600 MW** |
| Impacts Total Transfer Capability | 100 MW | 0 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**W49TH_ST_345KV_6**

Fri 02/06/2015 to Fri 02/06/2015
1800 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**W49TH_ST_345KV_8**

Fri 02/06/2015 to Fri 02/06/2015
1800 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

---

**BEAR SWP-ROTTRDAM_230_E205W**

Sat 02/07/2015 to Sun 02/15/2015 **CANCELLED** **by NGRID** **01/20/2015**
0630 Continuous 1600
Work scheduled by: NGrid

| | |
|---|---|
| SCH - NE - NY | |
| Impacts Total Transfer Capability | |
| TTC with All Lines In Service | |

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 02/09/2015 to Fri 02/13/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**MARCY____345_STATCOM SVC**

Mon 02/09/2015 to Fri 02/27/2015 **UPDATED** **by PA** **11/20/2014**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2925 MW** |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Tue 02/17/2015 to Tue 02/17/2015 **UPDATED** **by NYPA** **01/13/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**ADIRNDCK-CHASLAKE_230_13**

Wed 02/18/2015 to Wed 02/18/2015 **UPDATED** **by NYPA** **01/15/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 2600 MW |

---

**MOSES___-ADIRNDCK_230_MA2**

Thu 02/19/2015 to Fri 02/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH_ST_345KV_7**

Mon 02/23/2015 to Fri 02/27/2015
0001 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **340 MW** |
| Impacts Total Transfer Capability | 320 MW |
| TTC with All Lines In Service | 660 MW |

**HUDSONP_-FARRAGUT_345_C3403**

Mon 02/23/2015 to Wed 03/04/2015 **UPDATED** **by CONED** **12/05/2014**
0200 Continuous 1700
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2450 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2450 MW | 1300 MW |

**KINTIGH_-ROCHESTR_345_SR1-39**

Mon 02/23/2015 to Tue 02/24/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **1300 MW** |
| Impacts Total Transfer Capability | 1550 MW |
| TTC with All Lines In Service | 2850 MW |

**STLAWRNC-MOSES____230_L34P**

Mon 02/23/2015 to Tue 02/24/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1750 MW** | **1750 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

**MOSES___-ADIRNDCK_230_MA2**

Mon 02/23/2015 to Fri 02/27/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**W49TH_ST_345KV_5**

Tue 02/24/2015 to Tue 02/24/2015
0001 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **340 MW** |
| Impacts Total Transfer Capability | 320 MW |
| TTC with All Lines In Service | 660 MW |

**PLSNTVLY-WOOD_ST__345_F31**

Wed 02/25/2015 to Thu 02/26/2015
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4000 MW** |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**STLAWRNC-MOSES____230_L33P**

Wed 02/25/2015 to Thu 02/26/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1750 MW** | **1750 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

---

**W49TH_ST_345KV_5**

Thu 02/26/2015 to Thu 02/26/2015
1830 Continuous 1900
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **340 MW** |
| Impacts Total Transfer Capability | 320 MW |
| TTC with All Lines In Service | 660 MW |

---

**ATHENS__-PLSNTVLY_345_91**

Fri 02/27/2015 to Sat 02/28/2015
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**PLSNTVLY_345KV_RNS4**

Sun 03/01/2015 to Mon 03/02/2015
2300 Continuous 0859
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **3800 MW** |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

---

**LADENTWN-BUCHAN_S_345_Y88**

Mon 03/02/2015 to Sun 03/15/2015 **CANCELLED by NYISO 01/20/2015**
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4150 MW** |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 5100 MW |

---

**LADENTWN-BUCHAN_S_345_Y88**

Mon 03/02/2015 to Wed 03/18/2015
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4150 MW** |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 5100 MW |

---

**NIAGARA_-ROCHESTR_345_NR2**

Mon 03/02/2015 to Fri 03/06/2015 **UPDATED by RGE 01/06/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **1700 MW** |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 2850 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**MARCY___-EDIC_____345_UE1-7**

Mon 03/02/2015 to Fri 03/06/2015
0800 Continuous 1530
Work scheduled by: NYPA

**ARR: 16**

| | FWD (Import) |
|---|---|
| OSWEGO EXPORT | **5250 MW** |
| Impacts Total Transfer Capability | 0 MW |
| TTC with All Lines In Service | 5250 MW |

---

**WATRCURE-OAKDALE__345_31**

Mon 03/02/2015 to Fri 03/06/2015 **EXTENDED** **by NYSEG** **01/06/2015**
0900 Daily 1500
Work scheduled by: NYSEG

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2450 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2450 MW | 1300 MW |

---

**MILLWOOD_345KV_18**

Tue 03/03/2015 to Tue 03/03/2015
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4350 MW** |
| Impacts Total Transfer Capability | 750 MW |
| TTC with All Lines In Service | 5100 MW |

---

**E13THSTA-FARRAGUT_345_46**

Sat 03/07/2015 to Sun 03/08/2015
0001 Continuous 2330
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

---

**W49TH_ST-E13THSTA_345_M55**

Sat 03/07/2015 to Sun 03/08/2015
0001 Continuous 2330
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SPR/DUN-SOUTH | **3800 MW** |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

---

**W49TH_ST_345KV_6**

Sat 03/07/2015 to Sun 03/08/2015
0001 Continuous 2330
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **300 MW** |
| Impacts Total Transfer Capability | 360 MW |
| TTC with All Lines In Service | 660 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 03/09/2015 to Fri 03/13/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**VOLNEY__-MARCY____345_19**

Mon 03/09/2015 to Fri 03/13/2015
0800 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2825 MW** |
| Impacts Total Transfer Capability | 150 MW |
| TTC with All Lines In Service | 2975 MW |

---

**VOLNEY__-MARCY____345_19**

Mon 03/09/2015 to Fri 03/13/2015
0800 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| OSWEGO EXPORT | **4900 MW** |
| Impacts Total Transfer Capability | 350 MW |
| TTC with All Lines In Service | 5250 MW |

---

**BECK____-NIAGARA__230_PA27**

Tue 03/10/2015 to Tue 03/10/2015
0800 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1900 MW** | **1900 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

---

**MILLWOOD_345KV_18**

Wed 03/11/2015 to Wed 03/11/2015
0001 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4350 MW** |
| Impacts Total Transfer Capability | 750 MW |
| TTC with All Lines In Service | 5100 MW |

---

**LADENTWN-BUCHAN_S_345_Y88**

Mon 03/16/2015 to Mon 03/16/2015 **CANCELLED by NYISO 01/20/2015**
0001 Continuous 2359
Work scheduled by: ORU

| | FWD (Import) |
|---|---|
| UPNY CONED | **4150 MW** |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 5100 MW |

---

**MARCY____345_STATCOM SVC**

Mon 03/16/2015 to Mon 03/16/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2925 MW** |
| Impacts Total Transfer Capability | 50 MW |
| TTC with All Lines In Service | 2975 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 03/16/2015 to Fri 03/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**ROCHESTR-PANNELL__345_RP1**

Mon 03/16/2015 to Fri 03/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2300 MW** |
| Impacts Total Transfer Capability | 550 MW |
| TTC with All Lines In Service | 2850 MW |

**MILLWOOD_345KV_18**

Wed 03/18/2015 to Wed 03/18/2015
2330 Continuous 2359
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| UPNY CONED | **4350 MW** |
| Impacts Total Transfer Capability | 750 MW |
| TTC with All Lines In Service | 5100 MW |

**MOSES___-ADIRNDCK_230_MA2**

Mon 03/23/2015 to Fri 03/27/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**ROCHESTR-PANNELL__345_RP1**

Mon 03/23/2015 to Fri 03/27/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2300 MW** |
| Impacts Total Transfer Capability | 550 MW |
| TTC with All Lines In Service | 2850 MW |

**BECK____-PACKARD__230_BP76**

Thu 03/26/2015 to Thu 03/26/2015
0800 Daily(No Weekends) 1530
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1900 MW** | **1800 MW** |
| Impacts Total Transfer Capability | 0 MW | 100 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

**MOSES___-ADIRNDCK_230_MA2**

Mon 03/30/2015 to Fri 04/03/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**ROCHESTR-PANNELL__345_RP1**

Mon 03/30/2015 to Fri 04/03/2015
0700 Continuous 1700
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2300 MW** |
| Impacts Total Transfer Capability | 550 MW |
| TTC with All Lines In Service | 2850 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**HUDSONP_-FARRAGUT_345_B3402**

Wed 04/01/2015 to Fri 04/10/2015 **UPDATED** **by CONED** **12/05/2014**
0001 Continuous 1530
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2450 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 2450 MW | 1300 MW |

---

**CLAY____-EDIC_____345_1-16**

Mon 04/06/2015 to Tue 04/07/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| OSWEGO EXPORT | **4850 MW** |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 5250 MW |

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 04/06/2015 to Fri 04/10/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**ROSETON_-ROCKTVRN_345_311**

Mon 04/06/2015 to Fri 04/24/2015
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4400 MW** |
| Impacts Total Transfer Capability | 700 MW |
| TTC with All Lines In Service | 5100 MW |

---

**HUDSONTP-W49TH_ST_345_Y56**

Mon 04/06/2015 to Sat 04/11/2015
2200 Continuous 2100
Work scheduled by: ConEd

| | FWD (Import) |
|---|---|
| SCH - PJM_HTP | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

---

**PANNELL_-CLAY_____345_PC1**

Mon 04/13/2015 to Tue 04/14/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| WEST CENTRAL | **1300 MW** |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 2250 MW |

---

**MARCY___-COOPERS__345_UC2-41**

Mon 04/13/2015 to Fri 04/17/2015 **UPDATED** **by NYPA** **01/20/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2500 MW** |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BERKSHIR-ALPS_____345_393**

Wed 04/15/2015 to Thu 04/16/2015
0800 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1300 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 100 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**BERKSHIR-ALPS_____345_393**

Wed 04/15/2015 to Thu 04/16/2015
0800 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NOR HBR__138_601**

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602**

Mon 04/20/2015 to Thu 04/30/2015
0500 1500
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603**

Mon 04/20/2015 to Thu 04/30/2015
0500 1500
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NOR HBR__138_602**

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603**

Mon 04/20/2015 to Thu 04/30/2015
0500 1500
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NRTH1385-NOR HBR__138_603**

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NRTHPORT_138_1385**

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**ROCHESTR-PANNELL__345_RP2**

Mon 04/20/2015 to Fri 04/24/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2300 MW** |
| Impacts Total Transfer Capability | 550 MW |
| TTC with All Lines In Service | 2850 MW |

**LIND_CG_-LNDVFT___345_V-3022**

Tue 04/21/2015 to Wed 04/22/2015
0900 Continuous 1400
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_VFT | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

**LEEDS____345_LEEDS SVC**

Mon 04/27/2015 to Fri 05/01/2015
0700 Continuous 1500
Work scheduled by: NGrid

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2950 MW** |
| Impacts Total Transfer Capability | 25 MW |
| TTC with All Lines In Service | 2975 MW |

**ROCHESTR-PANNELL__345_RP2**

Mon 04/27/2015 to Fri 05/01/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **2300 MW** |
| Impacts Total Transfer Capability | 550 MW |
| TTC with All Lines In Service | 2850 MW |

**FRASER__-GILBOA___345_GF5-35**

Mon 04/27/2015 to Fri 05/08/2015 **UPDATED** **by NYPA** **01/09/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2650 MW** |
| Impacts Total Transfer Capability | 325 MW |
| TTC with All Lines In Service | 2975 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NEPTUNE_-DUFFYAVE_345_NEPTUNE**

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

**NEWBRDGE-DUFFYAVE_345_501**

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **0 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 660 MW |

**NEWBRDGE_345_138_BK_1**

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **375 MW** |
| Impacts Total Transfer Capability | 285 MW |
| TTC with All Lines In Service | 660 MW |

**NEWBRDGE_345_138_BK_2**

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100
Work scheduled by: LI

| | FWD (Import) |
|---|---|
| SCH - PJM_NEPTUNE | **375 MW** |
| Impacts Total Transfer Capability | 285 MW |
| TTC with All Lines In Service | 660 MW |

**SCH-NE-NYISO_LIMIT_900**

Mon 05/04/2015 to Thu 05/21/2015
0600 Continuous 1700
Work scheduled by: ISONE

| | FWD (Import) |
|---|---|
| SCH - NE - NY | **1100 MW** |
| Impacts Total Transfer Capability | 300 MW |
| TTC with All Lines In Service | 1400 MW |

**NIAGARA_-ROCHESTR_345_NR2**

Mon 05/04/2015 to Tue 05/05/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| DYSINGER EAST | **1700 MW** |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 2850 MW |

**MOSES___-ADIRNDCK_230_MA1**

Mon 05/04/2015 to Fri 05/08/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHATGUAY-MASSENA__765_7040**

Mon 05/04/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

**MOSES___-ADIRNDCK_230_MA1**

Mon 05/11/2015 to Fri 05/15/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**EDIC____-FRASER___345_EF24-40**

Mon 05/11/2015 to Fri 05/15/2015
0900 Continuous 1530
Work scheduled by: NYSEG

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2500 MW** |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

**BECK____-PACKARD__230_BP76**

Tue 05/12/2015 to Tue 05/12/2015
0730 Daily(No Weekends) 1600
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1750 MW** | **1200 MW** |
| Impacts Total Transfer Capability | 150 MW | 700 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

**MOSES___-ADIRNDCK_230_MA2**

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**STLAWRNC-MOSES____230_L33P**

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1750 MW** | **1750 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

**MOSES___-ADIRNDCK_230_MA2**

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**STLAWRNC-MOSES____230_L34P**

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1750 MW** | **1750 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

**MOSES___-ADIRNDCK_230_MA1**

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**PANNELL_-CLAY_____345_PC2**

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| WEST CENTRAL | **1300 MW** |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 2250 MW |

**MOSES___-ADIRNDCK_230_MA2**

Wed 06/03/2015 to Thu 06/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**MOSES___-ADIRNDCK_230_MA1**

Thu 08/13/2015 to Thu 08/13/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**MOSES___-ADIRNDCK_230_MA2**

Tue 08/18/2015 to Tue 08/18/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**ADIRNDCK-PORTER___230_12-AP**

Wed 08/19/2015 to Wed 08/19/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**ADIRNDCK-CHASLAKE_230_13**

Thu 08/20/2015 to Thu 08/20/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2100 MW** |
| Impacts Total Transfer Capability | 500 MW |
| TTC with All Lines In Service | 2600 MW |

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 08/31/2015 to Fri 09/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**CLAY____-EDIC_____345_2-15**

Thu 09/03/2015 to Fri 09/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| OSWEGO EXPORT | **4850 MW** |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 5250 MW |

---

**MARCY____765_345_BK 2**

Mon 09/07/2015 to Fri 09/11/2015
0700 Continuous 1530
Work scheduled by: NYPA

**ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 900 MW |
| TTC with All Lines In Service | 2600 MW |

---

**HURLYAVE-ROSETON__345_303**

Mon 09/07/2015 to Fri 09/25/2015
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4100 MW** |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

---

**NIAGARA__345_230_BK 4**

Mon 09/07/2015 to Fri 10/09/2015
0800 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1900 MW** | **1900 MW** |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

---

**MOSES___-ADIRNDCK_230_MA2**

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**COOPERS_-MIDDLETP_345_CMT-34**

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1600
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2720 MW** |
| Impacts Total Transfer Capability | 255 MW |
| TTC with All Lines In Service | 2975 MW |

**MOSES___-ADIRNDCK_230_MA1**

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**COOPERS_-ROCKTVRN_345_CRT-42**

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1600
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2720 MW** |
| Impacts Total Transfer Capability | 255 MW |
| TTC with All Lines In Service | 2975 MW |

**LONG_MTN-PLSNTVLY_345_398**

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **500 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 900 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

**LONG_MTN-PLSNTVLY_345_398**

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**MOSES___-ADIRNDCK_230_MA2**

Mon 09/28/2015 to Fri 10/02/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

**CHATGUAY-MASSENA__765_7040**

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED by NYPA 10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY____765_345_BK 1**

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1750 MW** |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 2600 MW |

**MARCY____765_345_BK 2**

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 19**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **1700 MW** |
| Impacts Total Transfer Capability | 900 MW |
| TTC with All Lines In Service | 2600 MW |

**MASSENA_-MARCY____765_MSU1**

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 20**

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2315 MW** |
| Impacts Total Transfer Capability | 660 MW |
| TTC with All Lines In Service | 2975 MW |

**MASSENA_-MARCY____765_MSU1**

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 20**

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **675 MW** |
| Impacts Total Transfer Capability | 1925 MW |
| TTC with All Lines In Service | 2600 MW |

**MASSENA_-MARCY____765_MSU1**

Sat 10/03/2015 to Sun 10/25/2015 **UPDATED** **by NYPA** **10/07/2014**
0100 Continuous 1730
Work scheduled by: NYPA **ARR: 20**

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **475 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 1025 MW | 0 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

**SHOR_NPX-SHOREHAM_138_NPX_CSC**

Mon 10/05/2015 to Sun 10/11/2015 **UPDATED** **by ISONE** **07/25/2014**
0530 Continuous 1800
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_CSC | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

**GILBOA__-LEEDS____345_GL3**

Mon 10/05/2015 to Fri 10/09/2015
0700 Continuous 1600
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2200 MW** |
| Impacts Total Transfer Capability | 775 MW |
| TTC with All Lines In Service | 2975 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

**Seasonal Limits**

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MALONE__-WILLIS___115_1-MW**

Tue 10/06/2015 to Tue 10/06/2015
0800 Continuous 1530
Work scheduled by: NYPA

**ARR: 20&38**

| | REV (Export) |
|---|---|
| SCH - HQ_CEDARS | **40 MW** |
| Impacts Total Transfer Capability | 0 MW |
| TTC with All Lines In Service | 40 MW |

**LEEDS___-HURLYAVE_345_301**

Mon 10/12/2015 to Fri 10/30/2015
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4100 MW** |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

**GILBOA__-N.SCTLND_345_GNS1**

Mon 10/19/2015 to Fri 10/23/2015 **UPDATED** **by NYISO** **09/12/2014**
0700 Continuous 1600
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2520 MW** |
| Impacts Total Transfer Capability | 455 MW |
| TTC with All Lines In Service | 2975 MW |

**MARCY___-COOPERS__345_UC2-41**

Mon 11/02/2015 to Fri 11/06/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2500 MW** |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

**ROCKTVRN-RAMAPO___345_77**

Sat 11/07/2015 to Fri 11/20/2015 **UPDATED** **by CH** **12/16/2014**
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2570 MW** |
| Impacts Total Transfer Capability | 405 MW |
| TTC with All Lines In Service | 2975 MW |

**ROSETON_-ROCKTVRN_345_311**

Sat 11/07/2015 to Fri 11/20/2015 **UPDATED** **by CH** **12/16/2014**
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| UPNY CONED | **4400 MW** |
| Impacts Total Transfer Capability | 700 MW |
| TTC with All Lines In Service | 5100 MW |

**BERKSHIR-ALPS_____345_393**

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1300 MW** | **1300 MW** |
| Impacts Total Transfer Capability | 100 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

# NYISO TRANSFER LIMITATIONS

Tuesday ,January 20, 2015 to Thursday ,July 21, 2016

| | |
|---|---|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 2850MW |
| WEST CENTRAL | 2250MW |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**BERKSHIR-ALPS_____345_393**

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 11/30/2015 to Fri 12/04/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 12/07/2015 to Fri 12/11/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**MOSES___-ADIRNDCK_230_MA1**

Mon 12/14/2015 to Fri 12/18/2015
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) |
|---|---|
| MOSES SOUTH | **2000 MW** |
| Impacts Total Transfer Capability | 600 MW |
| TTC with All Lines In Service | 2600 MW |

---

**ROCKTVRN-RAMAPO___345_77**

Mon 04/04/2016 to Fri 04/29/2016
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) |
|---|---|
| CENTRAL EAST - VC | **2570 MW** |
| Impacts Total Transfer Capability | 405 MW |
| TTC with All Lines In Service | 2975 MW |