

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday, August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RNS4

FWD

Sat 01/24/2015 to Sun 03/01/2015 UPDATED by CE 01/26/2015

(Import)

0001 Continuous 0859

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## MOSES-ADIRNDCK\_230\_MAI

FWD

Tue 02/03/2015 to Fri 02/06/2015 UPDATED by NYPA 02/03/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

REV

Fri 02/06/2015 to Fri 02/13/2015 EXTENDED by HQ 02/10/2015

(Export)

0757 Continuous 2359

SCH - HQ\_CEDARS

0 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 100 MW

Work scheduled by: HQ

## W49TH\_ST\_345KV\_6

FWD

Fri 02/06/2015 to Fri 02/06/2015 CANCELLED by ConEd 02/06/2015

(Import)

2200 Continuous 2230

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_8

FWD

Fri 02/06/2015 to Fri 02/06/2015 CANCELLED by ConEd 02/06/2015

(Import)

2200 Continuous 2230

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_6

FWD

Sat 02/07/2015 to Sat 02/07/2015 UPDATED by CONED 02/07/2015

(Import)

1500 Continuous 1900

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_8

FWD

Sat 02/07/2015 to Sat 02/07/2015 UPDATED by CONED 02/07/2015

(Import)

1500 Continuous 1900

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**Sun 02/08/2015 to Sun 02/08/2015 **CANCELLED** **by ConEd** **02/06/2015**

2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**Sun 02/08/2015 to Sun 02/08/2015 **CANCELLED** **by ConEd** **02/06/2015**

2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**MARCY\_\_\_345\_STATCOM SVC**Mon 02/09/2015 to Fri 02/27/2015 **UPDATED** **by PA** **11/20/2014**

0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**Mon 02/09/2015 to Fri 02/13/2015 **by PA**

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

**W49TH\_ST\_345KV\_6**

Fri 02/13/2015 to Fri 02/13/2015

2300 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Fri 02/13/2015 to Fri 02/13/2015

2300 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Sat 02/14/2015 to Sat 02/14/2015

0700 Continuous 1300

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE-DUFFYAVE\_345\_501**

Sat 02/14/2015 to Sat 02/14/2015  
0700 Continuous 1300

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE 0 MW  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_5**

Mon 02/16/2015 to Fri 02/20/2015  
0001 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP 340 MW  
Impacts Total Transfer Capability 320 MW  
TTC with All Lines In Service 660 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Tue 02/17/2015 to Tue 02/17/2015 UPDATED by NYPA 01/13/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2000 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

**BROWNFLS-TAYLORVL\_115\_3-BT**

Tue 02/17/2015 to Fri 02/27/2015  
0900 Continuous 1700

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 100 MW 100 MW  
Impacts Total Transfer Capability 99 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

**ADIRNDCK-CHASLAKE\_230\_13**

Wed 02/18/2015 to Wed 02/18/2015 UPDATED by NYPA 01/15/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2600 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Thu 02/19/2015 to Fri 02/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2000 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

**SPRNBK-W49TH\_ST\_345\_M51**

Sat 02/21/2015 to Sat 02/21/2015 UPDATED by CE 02/11/2015  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH 3200 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>					FWD		
Sat 02/21/2015	to	Sat 02/21/2015	<u>UPDATED</u>	<u>by CE</u>	<u>02/11/2015</u>	(Import)	
0001	Continuous	2359				SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	4600 MW
<b>W49TH_ST_345KV_7</b>					FWD		
Mon 02/23/2015	to	Fri 02/27/2015	<u>CANCELLED</u>	<u>by ConEd</u>	<u>02/06/2015</u>	(Import)	
0001	Continuous	1900				SCH - PJM_HTP	<b>340 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	320 MW
						TTC with All Lines In Service	660 MW
<b>HUDSONP_-FARRAGUT_345_C3403</b>					FWD REV		
Mon 02/23/2015	to	Wed 03/04/2015	<u>UPDATED</u>	<u>by CONED</u>	<u>12/05/2014</u>	(Import) (Export)	
0200	Continuous	1700				SCH - PJ - NY	<b>2450 MW 1300 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	0 MW 0 MW
						TTC with All Lines In Service	2450 MW 1300 MW
<b>KINTIGH_-ROCHESTR_345_SR1-39</b>					FWD		
Mon 02/23/2015	to	Tue 02/24/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/07/2015</u>	(Import)	
0500	Continuous	1600				DYSINGER EAST	<b>1300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1550 MW
						TTC with All Lines In Service	2850 MW
<b>STLAWRNC-MOSES____230_L34P</b>					FWD REV		
Mon 02/23/2015	to	Tue 02/24/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/06/2015</u>	(Import) (Export)	
0700	Continuous	1530				SCH - OH - NY	<b>1750 MW 1750 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	150 MW 150 MW
						TTC with All Lines In Service	1900 MW 1900 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD		
Mon 02/23/2015	to	Fri 02/27/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/05/2015</u>	(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	2600 MW
<b>W49TH_ST_345KV_5</b>					FWD		
Tue 02/24/2015	to	Tue 02/24/2015	<u>CANCELLED</u>	<u>by ConEd</u>	<u>02/06/2015</u>	(Import)	
0001	Continuous	1900				SCH - PJM_HTP	<b>340 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	320 MW
						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-WOOD\_ST\_\_345\_F31

FWD

Wed 02/25/2015 to Thu 02/26/2015

UPDATEDby CE01/26/2015

(Import)

0001 Continuous 2359

UPNY CONED

**4000 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

## BEAR SWP-ROTTDAM\_230\_E205W

Wed 02/25/2015 to Thu 03/05/2015

0630 Continuous 2000

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## ROCHESTR-PANNELL\_\_345\_RP1

FWD

Wed 02/25/2015 to Wed 02/25/2015

UPDATEDby RGE01/27/2015

(Import)

0700 Continuous 1500

Work scheduled by: RGE

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P

FWD

REV

Wed 02/25/2015 to Thu 02/26/2015

UPDATEDby NYPA02/06/2015

(Import) (Export)

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

**1750 MW 1750 MW**

Impacts Total Transfer Capability 150 MW 150 MW

TTC with All Lines In Service 1900 MW 1900 MW

## ROCHESTR-PANNELL\_\_345\_RP2

FWD

Thu 02/26/2015 to Thu 02/26/2015

0700 Continuous 1500

Work scheduled by: RGE

(Import)

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

## W49TH\_ST\_345KV\_5

FWD

Thu 02/26/2015 to Thu 02/26/2015

UPDATEDby NYISO01/26/2015

(Import)

1830 Continuous 1900

Work scheduled by: ConEd

SCH - PJM\_HTP

**340 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

## ATHENS\_\_-PLSNTVLY\_345\_91

FWD

Fri 02/27/2015 to Sat 02/28/2015

UPDATEDby CE01/26/2015

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RNS4

FWD

Sun 03/01/2015 to Mon 03/02/2015 UPDATED by CE 01/26/2015

(Import)

2300 Continuous 0859

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## LADENTWN-BUCHAN\_S\_345\_Y88

FWD

Mon 03/02/2015 to Wed 03/18/2015

(Import)

0001 Continuous 2359

UPNY CONED

**4150 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## NIAGARA\_-ROCHESTR\_345\_NR2

FWD

Mon 03/02/2015 to Fri 03/06/2015 UPDATED by RGE 01/06/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

## MARCY\_-EDIC\_345\_UE1-7

FWD

Mon 03/02/2015 to Fri 03/06/2015 UPDATED by NYPA 02/10/2015

(Import)

0800 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 16

## WATRCURE-OAKDALE\_345\_31

FWD

REV

Mon 03/02/2015 to Fri 03/06/2015 EXTENDED by NYSEG 01/06/2015

(Import) (Export)

0900 Daily 1500

SCH - PJ - NY

**2450 MW 1300 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2450 MW 1300 MW

Work scheduled by: NYSEG

## MILLWOOD\_345KV\_18

FWD

Tue 03/03/2015 to Tue 03/03/2015

(Import)

0001 Continuous 0030

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## E13THSTA-FARRAGUT\_345\_46

FWD

Sat 03/07/2015 to Sun 03/08/2015

(Import)

0001 Continuous 2330

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M55

Sat 03/07/2015 to Sun 03/08/2015

0001 Continuous 2330

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_6

Sat 03/07/2015 to Sun 03/08/2015

0001 Continuous 2330

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 03/09/2015 to Tue 03/10/2015

0500 Continuous 1600

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 2850 MW

### BECK\_-NIAGARA\_230\_PA27

Mon 03/09/2015 to Fri 03/13/2015

0700 Continuous 1430

Work scheduled by: IESO

UPDATED by IESO 01/30/2015

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1900 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1900 MW 1900 MW

### MOSES\_-ADIRNDCK\_230\_MA1

Mon 03/09/2015 to Fri 03/13/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

### BULYMO\_-BOONVILLE\_115\_6

Mon 03/09/2015 to Wed 04/08/2015

0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NGRID 02/10/2015

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **199 MW 100 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

### TAYLORVL-BULYMO\_115\_6

Mon 03/09/2015 to Wed 04/08/2015

0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NGRID 02/10/2015

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **199 MW 100 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__ -MARCY__ 345_19					FWD	
Mon 03/09/2015	to	Fri 03/13/2015	<u>UPDATED</u>	<u>by PA</u>	<u>02/10/2015</u>	(Import)
0800	Continuous	1530				
Work scheduled by: NYPA					CENTRAL EAST - VC	2825 MW
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2975 MW
VOLNEY__ -MARCY__ 345_19					FWD	
Mon 03/09/2015	to	Fri 03/13/2015	<u>UPDATED</u>	<u>by PA</u>	<u>02/10/2015</u>	(Import)
0800	Continuous	1530				
Work scheduled by: NYPA					OSWEGO EXPORT	4900 MW
					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	5250 MW
MILLWOOD_345KV_18					FWD	
Wed 03/11/2015	to	Wed 03/11/2015				(Import)
0001	Continuous	2359				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	750 MW
					TTC with All Lines In Service	5100 MW
MARCY__ 345_STATCOM SVC					FWD	
Mon 03/16/2015	to	Mon 03/16/2015				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					CENTRAL EAST - VC	2925 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
MOSES__ -ADIRNDCK_230_MAI					FWD	
Mon 03/16/2015	to	Fri 03/20/2015				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	2000 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	2600 MW
ROCHESTR-PANNELL__ 345_RP1					FWD	
Mon 03/16/2015	to	Fri 03/20/2015				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					DYSINGER EAST	2300 MW
					Impacts Total Transfer Capability	550 MW
					TTC with All Lines In Service	2850 MW
BECK__ -NIAGARA__ 345_PA302					FWD	REV
Tue 03/17/2015	to	Wed 03/18/2015				(Import) (Export)
0500	Continuous	1600				
Work scheduled by: NYPA					SCH - OH - NY	1400 MW 1250 MW
					Impacts Total Transfer Capability	500 MW 650 MW
					TTC with All Lines In Service	1900 MW 1900 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD\_345KV\_18**

FWD

Wed 03/18/2015 to Wed 03/18/2015

(Import)

2330 Continuous 2359

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/23/2015 to Fri 03/27/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_345\_RP1**

FWD

Mon 03/23/2015 to Fri 03/27/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

**BECK\_-NIAGARA\_345\_PA301**

FWD

REV

Tue 03/24/2015 to Tue 03/24/2015

(Import) (Export)

0800 Continuous 1530

SCH - OH - NY

**1400 MW 1250 MW**

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**BECK\_-PACKARD\_230\_BP76**

FWD

REV

Thu 03/26/2015 to Thu 03/26/2015

(Import) (Export)

0800 Daily(No Weekends) 1530

SCH - OH - NY

**1900 MW 1800 MW**

Impacts Total Transfer Capability 0 MW 100 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NGrid

**MOSES\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/30/2015 to Fri 04/03/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_345\_RP1**

FWD

Mon 03/30/2015 to Fri 04/03/2015

(Import)

0700 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402				FWD	REV
				(Import)	(Export)
Wed 04/01/2015	to	Fri 04/10/2015	<u>UPDATED</u> <u>by CONED</u> <u>12/05/2014</u>	SCH - PJ - NY	<b>2450 MW</b> <b>1300 MW</b>
0001	Continuous	1530		Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by: PJM				TTC with All Lines In Service	2450 MW 1300 MW
EGRDNCTY_345_138_BK 1				FWD	
				(Import)	
Mon 04/06/2015	to	Mon 04/06/2015		CONED - LIPA	<b>1250 MW</b>
0001	Continuous	2359		Impacts Total Transfer Capability	250 MW
Work scheduled by: LI				TTC with All Lines In Service	1500 MW
CLAY_-EDIC_345_1-16				FWD	
				(Import)	
Mon 04/06/2015	to	Tue 04/07/2015		OSWEGO EXPORT	<b>4850 MW</b>
0700	Continuous	1530		Impacts Total Transfer Capability	400 MW
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW
MOSES_-ADIRNDCK_230_MA2				FWD	
				(Import)	
Mon 04/06/2015	to	Fri 04/10/2015		MOSES SOUTH	<b>2000 MW</b>
0700	Continuous	1530		Impacts Total Transfer Capability	600 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2600 MW
OAKDALE_-FRASER_345_32				FWD	
				(Import)	
Mon 04/06/2015	to	Wed 04/08/2015		CENTRAL EAST - VC	<b>2650 MW</b>
0800	Continuous	1630		Impacts Total Transfer Capability	325 MW
Work scheduled by: NYSEG				TTC with All Lines In Service	2975 MW
ROSETON_-ROCKTVRN_345_311				FWD	
				(Import)	
Mon 04/06/2015	to	Fri 04/24/2015		UPNY CONED	<b>4400 MW</b>
0800	Continuous	1600		Impacts Total Transfer Capability	700 MW
Work scheduled by: CHGE				TTC with All Lines In Service	5100 MW
HUDSONTP-W49TH_ST_345_Y56				FWD	
				(Import)	
Mon 04/06/2015	to	Sat 04/11/2015		SCH - PJM_HTP	<b>0 MW</b>
2200	Continuous	2100		Impacts Total Transfer Capability	660 MW
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EGRDNCTY_345_138_BK 2</b>					FWD		
Tue 04/07/2015	to	Tue 04/07/2015			(Import)		
0001	Continuous	2359			CONED - LIPA	<b>1250 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>PANNELL -CLAY_345_PC1</b>					FWD		
Mon 04/13/2015	to	Tue 04/14/2015			(Import)		
0700	Continuous	1530			WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW	
					TTC with All Lines In Service	2250 MW	
<b>MARCY -COOPERS_345_UC2-41</b>					FWD		
Mon 04/13/2015	to	Fri 04/17/2015	<b>UPDATED</b>	<b>by NYPA</b>	(Import)		
0700	Continuous	1530		<b>01/20/2015</b>	CENTRAL EAST - VC	<b>2500 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW	
					TTC with All Lines In Service	2975 MW	
<b>BERKSHIR-ALPS_345_393</b>					FWD	REV	
Wed 04/15/2015	to	Thu 04/16/2015	<b>UPDATED</b>	<b>by NE</b>	(Import)	(Export)	
0700	Continuous	1700		<b>01/30/2015</b>	SCH - NE - NY	<b>1300 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW	300 MW
					TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-ALPS_345_393</b>					FWD	REV	
Wed 04/15/2015	to	Thu 04/16/2015	<b>UPDATED</b>	<b>by NE</b>	(Import)	(Export)	
0700	Continuous	1700		<b>01/30/2015</b>	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW
<b>BERKSHIR-ALPS_345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV	
Wed 04/15/2015	to	Thu 04/16/2015			(Import)	(Export)	
0700		1700			SCH - NE - NY	<b>1300 MW</b>	<b>1300 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	100 MW	300 MW
					TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV	
Wed 04/15/2015	to	Thu 04/16/2015	<b>UPDATED</b>	<b>by NE</b>	(Import)	(Export)	
0700	Continuous	1700		<b>01/30/2015</b>	SCH - NE - NY	<b>1400 MW</b>	<b>1450 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW	150 MW
					TTC with All Lines In Service	1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>BERKSHIR-NORTHFLD_345_312</b>						
Wed 04/15/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by NE</u>	<u>01/30/2015</u>	
0700	Continuous	1700			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>GOETHALS-LINDN.CG_345_G23L &amp; GOETHALS-LINDN.CG_345_G23M</b>						
Sun 04/19/2015	to	Tue 04/21/2015			SCH - PJM_VFT	<b>0 MW</b>
0001		2359			Impacts Total Transfer Capability	315 MW
Work scheduled by:					TTC with All Lines In Service	315 MW
<b>NRTH1385-NOR HBR_138_601</b>						
Mon 04/20/2015	to	Thu 04/30/2015			SCH - NPX_1385	<b>100 MW</b>
0500	Continuous	1500			Impacts Total Transfer Capability	100 MW
Work scheduled by: LI					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>						
Mon 04/20/2015	to	Thu 04/30/2015			SCH - NPX_1385	<b>0 MW</b>
0500		1500			Impacts Total Transfer Capability	200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_603</b>						
Mon 04/20/2015	to	Thu 04/30/2015			SCH - NPX_1385	<b>0 MW</b>
0500		1500			Impacts Total Transfer Capability	200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_602</b>						
Mon 04/20/2015	to	Thu 04/30/2015			SCH - NPX_1385	<b>100 MW</b>
0500	Continuous	1500			Impacts Total Transfer Capability	100 MW
Work scheduled by: LI					TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_602 &amp; NRTH1385-NOR HBR_138_603</b>						
Mon 04/20/2015	to	Thu 04/30/2015			SCH - NPX_1385	<b>0 MW</b>
0500		1500			Impacts Total Transfer Capability	200 MW
Work scheduled by:					TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)
0500	Continuous	1500		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_1385				FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015		(Import)	(Export)
0500	Continuous	1500		SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
ROCHESTR-PANNELL__345_RP2				FWD	
Mon 04/20/2015	to	Fri 04/24/2015		(Import)	
0700	Continuous	1530		DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	550 MW
				TTC with All Lines In Service	2850 MW
LIND_CG_-LNDVFT__345_V-3022				FWD	REV
Tue 04/21/2015	to	Wed 04/22/2015		(Import)	(Export)
0900	Continuous	1400		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
LEEDS__345_LEEDS SVC				FWD	
Mon 04/27/2015	to	Fri 05/01/2015		(Import)	
0700	Continuous	1500		CENTRAL EAST - VC	2950 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	25 MW
				TTC with All Lines In Service	2975 MW
ROCHESTR-PANNELL__345_RP2				FWD	
Mon 04/27/2015	to	Fri 05/01/2015		(Import)	
0700	Continuous	1530		DYSINGER EAST	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	550 MW
				TTC with All Lines In Service	2850 MW
FRASER_-GILBOA__345_GF5-35				FWD	
Mon 04/27/2015	to	Fri 05/08/2015		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2650 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW

UPDATED by NYPA 01/09/2015

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday, August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

---

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

---

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**375 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

---

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**375 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

---

**SCH-NE-NYISO\_LIMIT\_900**

Mon 05/04/2015 to Thu 05/21/2015  
0600 Continuous 1700

Work scheduled by: ISONE

FWD  
(Import)  
**1100 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

---

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 05/04/2015 to Tue 05/05/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**1700 MW**  
DYSINGER EAST  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 2850 MW

---

**MOSES\_-ADIRNDCK\_230\_MAL**

Mon 05/04/2015 to Fri 05/08/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**2000 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>			FWD	REV
Mon 05/04/2015	to	Fri 05/22/2015	(Import)	(Export)
0700	Continuous	1530	SCH - HQ - NY	<b>0 MW</b> <b>0 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
<b>SHORE_RD_345_138_BK_2</b>			FWD	
Wed 05/06/2015	to	Wed 05/13/2015	(Import)	
0001	Continuous	2359	CONED - LIPA	<b>1350 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	150 MW
			TTC with All Lines In Service	1500 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>			FWD	
Mon 05/11/2015	to	Fri 05/15/2015	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	2600 MW
<b>EDIC__-FRASER__345_EF24-40</b>			FWD	
Mon 05/11/2015	to	Fri 05/15/2015	(Import)	
0900	Continuous	1530	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
<b>BECK__-PACKARD__230_BP76</b>			FWD	REV
Tue 05/12/2015	to	Tue 05/12/2015	(Import)	(Export)
0730	Daily(No Weekends)	1600	SCH - OH - NY	<b>1750 MW</b> <b>1200 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	150 MW 700 MW
			TTC with All Lines In Service	1900 MW 1900 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>			FWD	
Mon 05/18/2015	to	Fri 05/22/2015	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	2600 MW
<b>STLAWRNC-MOSES__230_L33P</b>			FWD	REV
Mon 05/18/2015	to	Fri 05/22/2015	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	<b>1750 MW</b> <b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW 150 MW
			TTC with All Lines In Service	1900 MW 1900 MW

**CANCELLED by NGRID 02/11/2015**

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY\_\_\_-COOPERS\_\_\_345\_UC2-41**

Tue 05/19/2015 to Fri 05/22/2015  
0900 Daily 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

**STLAWRNC-MOSES\_\_\_230\_L34P**

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

**PANNELL\_-CLAY\_\_\_345\_PC2**

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Wed 06/03/2015 to Thu 06/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

**BECK\_\_\_-NIAGARA\_\_\_345\_PA302**

Thu 06/25/2015 to Fri 06/26/2015  
0500 Continuous 1600

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1100 MW**  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---



# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Thu 08/13/2015 to Thu 08/13/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 08/18/2015 to Tue 08/18/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

**ADIRNDCK-PORTER\_\_\_230\_12-AP**

Wed 08/19/2015 to Wed 08/19/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2600 MW

---

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 08/20/2015 to Thu 08/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2600 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 08/31/2015 to Fri 09/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

---

**CLAY\_\_\_-EDIC\_\_\_345\_2-15**

Thu 09/03/2015 to Fri 09/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

---

**MARCY\_\_\_765\_345\_BK 2**

Mon 09/07/2015 to Fri 09/11/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 2600 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

Mon 09/07/2015 to Fri 09/25/2015  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## NIAGARA\_\_345\_230\_BK 4

Mon 09/07/2015 to Fri 10/09/2015  
0800 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1900 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 09/14/2015 to Fri 09/18/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

## COOPERS\_-MIDDLETP\_345\_CMT-34

Mon 09/14/2015 to Fri 09/18/2015  
0700 Continuous 1600

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 09/21/2015 to Fri 09/25/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 2600 MW

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 09/21/2015 to Fri 09/25/2015  
0700 Continuous 1600

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## LONG\_MTN-PLSNTVLY\_345\_398

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NE - NY **500 MW 1300 MW**  
Impacts Total Transfer Capability 900 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday, August 12, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LONG\_MTN-PLSNTVLY\_345\_398

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## BECK\_-NIAGARA\_345\_PA302

Thu 09/24/2015 to Fri 09/25/2015  
0500 Continuous 1600

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1200 MW	1100 MW
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 09/28/2015 to Fri 10/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	2600 MW

## BECK\_-NIAGARA\_345\_PA301

Mon 09/28/2015 to Fri 10/02/2015  
0800 Continuous 1600

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1200 MW	1100 MW
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 09/28/2015 to Fri 10/02/2015  
0900 Daily 1600

Work scheduled by: NYSEG

	FWD (Import)
CENTRAL EAST - VC	2720 MW
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014  
0100 Continuous 1730

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## MARCY\_765\_345\_BK 1

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014  
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD (Import)
MOSES SOUTH	1750 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	2600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_BK 2						FWD		
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)		
0100	Continuous	1730				MOSES SOUTH	1700 MW	
Work scheduled by: NYPA				ARR: 19		Impacts Total Transfer Capability	900 MW	
						TTC with All Lines In Service	2600 MW	
MASSENA_-MARCY____765_MSU1							FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)		
0100	Continuous	1730				CENTRAL EAST - VC	2315 MW	
Work scheduled by: NYPA				ARR: 20		Impacts Total Transfer Capability	660 MW	
						TTC with All Lines In Service	2975 MW	
MASSENA_-MARCY____765_MSU1							FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)		
0100	Continuous	1730				MOSES SOUTH	675 MW	
Work scheduled by: NYPA				ARR: 20		Impacts Total Transfer Capability	1925 MW	
						TTC with All Lines In Service	2600 MW	
MASSENA_-MARCY____765_MSU1							FWD	REV
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	(Export)	
0100	Continuous	1730				SCH - HQ - NY	475 MW 1000 MW	
Work scheduled by: NYPA				ARR: 20		Impacts Total Transfer Capability	1025 MW 0 MW	
						TTC with All Lines In Service	1500 MW 1000 MW	
SHOR_NPX-SHOREHAM_138_NPX_CSC							FWD	REV
Mon 10/05/2015	to	Sun 10/11/2015	<u>UPDATED</u>	<u>by ISONE</u>	<u>07/25/2014</u>	(Import)	(Export)	
0530	Continuous	1800				SCH - NPX_CSC	0 MW 0 MW	
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW 330 MW	
						TTC with All Lines In Service	330 MW 330 MW	
GILBOA_-LEEDS____345_GL3							FWD	
Mon 10/05/2015	to	Fri 10/09/2015				(Import)		
0700	Continuous	1600				CENTRAL EAST - VC	2200 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	775 MW	
						TTC with All Lines In Service	2975 MW	
MALONE_-WILLIS____115_1-MW								REV
Tue 10/06/2015	to	Tue 10/06/2015					(Export)	
0800	Continuous	1530				SCH - HQ_CEDARS	40 MW	
Work scheduled by: NYPA				ARR: 20&38		Impacts Total Transfer Capability	0 MW	
						TTC with All Lines In Service	40 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_-HURLYAVE\_345\_301

FWD

Mon 10/12/2015 to Fri 10/30/2015

(Import)

0800 Continuous 1600

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

## GILBOA\_\_\_-N.SCTLND\_345\_GNS1

FWD

Mon 10/19/2015 to Fri 10/23/2015

(Import)

UPDATEDby NYISO 09/12/2014

0700 Continuous 1600

CENTRAL EAST - VC

2520 MW

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## GOETHALS-LINDN.CG\_345\_G23L &amp; GOETHALS-LINDN.CG\_345\_G23M

FWD

REV

Tue 10/20/2015 to Fri 10/23/2015

(Import) (Export)

0001 2359

SCH - PJM\_VFT

0 MW 315 MW

Impacts Total Transfer Capability 315 MW 0 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by:

## MARCY\_\_\_-COOPERS\_\_\_345\_UC2-41

FWD

Mon 11/02/2015 to Fri 11/06/2015

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94

FWD

Sat 11/07/2015 to Mon 11/09/2015

(Import)

0001 Continuous 2359

UPNY CONED

4150 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

## ROCKTVRN-RAMAPO\_\_\_345\_77

FWD

Sat 11/07/2015 to Fri 11/20/2015

(Import)

UPDATEDby CH12/16/2014

0800 Continuous 1600

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Sat 11/07/2015 to Fri 11/20/2015

(Import)

UPDATEDby CH12/16/2014

0800 Continuous 1600

UPNY CONED

4400 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

# NYISO TRANSFER LIMITATIONS

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 2850MW  
WEST CENTRAL 2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCKTVRN-RAMAPO\_\_\_345\_77

Fri 11/20/2015 to Sat 12/12/2015

1601 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

## GOETHALS-LINDN.CG\_345\_G23L &amp; GOETHALS-LINDN.CG\_345\_G23M

Mon 11/23/2015 to Thu 11/26/2015

0001 2359

Work scheduled by:

FWD

(Import) (Export)

SCH - PJM\_VFT

0 MW 315 MW

Impacts Total Transfer Capability 315 MW 0 MW

TTC with All Lines In Service 315 MW 315 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Sun 11/29/2015 to Sat 12/05/2015

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4150 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 11/30/2015 to Fri 12/04/2015

0600 Continuous 1500

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NE - NY

1300 MW 1300 MW

Impacts Total Transfer Capability 100 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 11/30/2015 to Fri 12/04/2015

0600 Continuous 1500

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 11/30/2015 to Fri 12/04/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 12/07/2015 to Fri 12/11/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, February 11, 2015 to Friday , August 12, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	2850MW
WEST CENTRAL	2250MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 12/14/2015 to Fri 12/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 2600 MW

Work scheduled by: NYPA

**BECK\_\_\_-NIAGARA\_345\_PA302**

FWD

REV

Thu 12/17/2015 to Fri 12/18/2015

(Import) (Export)

0500 Continuous 1600

SCH - OH - NY

**1400 MW 1250 MW**

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**ROCKTVRN-RAMAPO\_\_\_345\_77**

FWD

Mon 04/04/2016 to Fri 04/29/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE