

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Fri 02/06/2015 to Thu 04/09/2015 EXT FORCE by HQ 03/10/2015

0757 Continuous 2359

Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

0 MW

100 MW

100 MW

## BEAR SWP-EASTOVER\_230\_E205

Wed 02/25/2015 to Fri 03/06/2015 EXTENDED by NGRID 02/19/2015

0630 Continuous 1600

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 03/02/2015 to Fri 03/06/2015 UPDATED by NYPA 03/02/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

FWD

(Import)

1700 MW

1450 MW

3150 MW

## WATRCURE-OAKDALE\_345\_31

Mon 03/02/2015 to Mon 03/09/2015 EXTENDED by NYSEG 03/05/2015

0900 Daily 1630

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2450 MW 1300 MW

FWD

(Import)

2450 MW 1300 MW

0 MW 0 MW

2450 MW 1300 MW

## LADENTWN-BUCHAN\_S\_345\_Y88

Tue 03/03/2015 to Wed 03/18/2015 UPDATED by CONED 02/27/2015

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)

UPNY CONED

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

FWD

(Import)

4150 MW

950 MW

5100 MW

## MARCY\_-EDIC\_345\_UE1-7

Wed 03/04/2015 to Fri 03/06/2015 UPDATED by NYPA 03/04/2015

2100 Continuous 1530

Work scheduled by: NYPA

ARR: 16

FWD  
(Import)

OSWEGO EXPORT

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

FWD

(Import)

5250 MW

0 MW

5250 MW

## WATRCURE-OAKDALE\_345\_31

Thu 03/05/2015 to Fri 03/06/2015 EXTENDED by NYSEG 03/05/2015

0800 Daily 1500

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)

SCH - PJ - NY

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2450 MW 1300 MW

FWD

(Import)

2450 MW 1300 MW

0 MW 0 MW

2450 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_\_345\_FRASER SVC

FWD

Fri 03/06/2015 to Fri 03/06/2015 UPDATED by NYSEG 03/04/2015

(Import)

0900 Continuous 1600

CENTRAL EAST - VC **2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

## E13THSTA-FARRAGUT\_345\_46

FWD

Sat 03/07/2015 to Sun 03/08/2015 CANCELLED by ConEd 03/06/2015

(Import)

0001 Continuous 2330

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## W49TH\_ST-E13THSTA\_345\_M55

FWD

Sat 03/07/2015 to Sun 03/08/2015 CANCELLED by ConEd 03/06/2015

(Import)

0001 Continuous 2330

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_6

FWD

Sat 03/07/2015 to Sun 03/08/2015 CANCELLED by ConEd 03/06/2015

(Import)

0001 Continuous 2330

SCH - PJM\_HTP **320 MW**

Impacts Total Transfer Capability 340 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## ROCHESTR-PANNELL\_\_\_345\_RP1

FWD

Sat 03/07/2015 to Sun 03/08/2015 UPDATED by RGE 03/08/2015

(Import)

0700 Continuous 1647

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: RGE

## SPRNBRK\_-W49TH\_ST\_345\_M51

FWD

Mon 03/09/2015 to Mon 03/09/2015

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SPRNBRK\_\_\_345KV\_RNS5

FWD

Mon 03/09/2015 to Mon 03/09/2015

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Wednesday, March 11, 2015 to Friday, September 09, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Mon 03/09/2015 to Tue 03/10/2015

(Import)

0500 Continuous 1600

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BECK\_-NIAGARA\_230\_PA27**

FWD

REV

Mon 03/09/2015 to Sat 03/14/2015

(Import) (Export)

0600 Continuous 1530

by IESO 03/05/2015

SCH - OH - NY

**1900 MW 1900 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: IESO

**STLAWRNC-MOSES\_230\_L34P**

FWD

REV

Mon 03/09/2015 to Mon 03/09/2015

(Import) (Export)

0700 Continuous 1636

RETURNED by NYPA 03/09/2015

SCH - OH - NY

**1750 MW 1750 MW**

Impacts Total Transfer Capability 150 MW 150 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Mon 03/09/2015 to Fri 03/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**VOLNEY\_-MARC\_345\_19**

FWD

Mon 03/09/2015 to Fri 03/13/2015

(Import)

0800 Continuous 1530

UPDATED by PA 02/10/2015

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**VOLNEY\_-MARC\_345\_19**

FWD

Mon 03/09/2015 to Fri 03/13/2015

(Import)

0800 Continuous 1530

UPDATED by PA 02/10/2015

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**SCH-NE-NYISO\_LIMIT\_800**

FWD

Tue 03/10/2015 to Tue 03/10/2015

(Import)

0630 Continuous 2100

UPDATED by NE 03/05/2015

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**NYISO TRANSFER LIMITATIONS**

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N.SCTLND-ALPS_____345_2-AN</b>					FWD	REV
Tue 03/10/2015 to Tue 03/10/2015					(Import)	(Export)
0800	Daily(No Weekends)	1459			SCH - NE - NY	<b>900 MW 1600 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	500 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>N.SCTLND-ALPS_____345_2-AN</b>					FWD	REV
Tue 03/10/2015 to Tue 03/10/2015					(Import)	(Export)
0800	Daily(No Weekends)	1459			SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>WATRCURE-OAKDALE__345_31</b>					FWD	REV
Tue 03/10/2015 to Tue 03/10/2015					(Import)	(Export)
0900	Daily	1500	<u>EXTENDED</u>	<u>by NYSEG 03/05/2015</u>	SCH - PJ - NY	<b>2450 MW 1300 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2450 MW 1300 MW
<b>MILLWOOD_345KV_18</b>					FWD	
Wed 03/11/2015 to Wed 03/11/2015					(Import)	
0001	Continuous	2359	<u>UPDATED</u>	<u>by CONED 02/27/2015</u>	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	750 MW
					TTC with All Lines In Service	5100 MW
<b>KINTIGH_-ROCHESTR_345_SRI-39</b>					FWD	
Wed 03/11/2015 to Wed 03/11/2015					(Import)	
0500	Continuous	1500			DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>STLAWRNC-MOSES_____230_L33P</b>					FWD	REV
Thu 03/12/2015 to Fri 03/13/2015					(Import)	(Export)
0700	Continuous	1530	<u>UPDATED</u>	<u>by NYPA 02/26/2015</u>	SCH - OH - NY	<b>1750 MW 1750 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	150 MW 150 MW
					TTC with All Lines In Service	1900 MW 1900 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Fri 03/13/2015 to Sun 03/15/2015					(Import)	(Export)
2000	Continuous	2000	<u>UPDATED</u>	<u>by PJM 03/08/2015</u>	SCH - PJ - NY	<b>2450 MW 1300 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2450 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCHESTR-PANNELL\_\_345\_RP2

Sat 03/14/2015 to Sat 03/14/2015  
0700 Continuous 1500

Work scheduled by: RGE

FWD  
(Import)  
DYSINGER EAST 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_\_345\_STATCOM SVC

Mon 03/16/2015 to Mon 03/16/2015  
0500 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 02/27/2015

FWD  
(Import)  
CENTRAL EAST - VC 2925 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## ROCHESTR-PANNELL\_\_345\_RP1

Mon 03/16/2015 to Fri 03/27/2015  
0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by PA 03/04/2015

FWD  
(Import)  
DYSINGER EAST 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 03/16/2015 to Fri 03/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2000 MW  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

## DENNISON-ROSEMNTB\_115\_2-RD

Tue 03/17/2015 to Tue 03/17/2015  
0800 Daily(No Weekends) 1530

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 95 MW 100 MW  
Impacts Total Transfer Capability 104 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

## MILLWOOD\_345KV\_18

Wed 03/18/2015 to Wed 03/18/2015  
2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/27/2015

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## BROWNFLS-HIGLEY\_\_115\_1-BH

Thu 03/19/2015 to Thu 03/19/2015  
1000 Daily(No Weekends) 1530

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 130 MW 100 MW  
Impacts Total Transfer Capability 69 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday , September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 03/23/2015 to Fri 03/27/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

## BECK\_\_\_-NIAGARA\_345\_PA301

Tue 03/24/2015 to Tue 03/24/2015  
0800 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1400 MW 1250 MW**  
Impacts Total Transfer Capability 500 MW 650 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## BECK\_\_\_-PACKARD\_230\_BP76

Thu 03/26/2015 to Thu 03/26/2015  
0800 Daily(No Weekends) 1530

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1800 MW**  
Impacts Total Transfer Capability 0 MW 100 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## HOPATCON-RAMAPO\_\_\_500\_5018

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2100 MW 1000 MW**  
Impacts Total Transfer Capability 350 MW 300 MW  
TTC with All Lines In Service 2450 MW 1300 MW

## HOPATCON-RAMAPO\_\_\_500\_5018

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
TOTAL EAST **6400 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 6500 MW

## HOPATCON-RAMAPO\_\_\_500\_5018

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## RAMAPO\_\_\_345\_345\_PAR3500

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2400 MW 1300 MW**  
Impacts Total Transfer Capability 50 MW 0 MW  
TTC with All Lines In Service 2450 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday , September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___345_345_PAR4500</b>					FWD	REV
Sat 03/28/2015	to	Sat 03/28/2015			(Import)	(Export)
0200	Continuous	1900			SCH - PJ - NY	<b>2400 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2450 MW
<b>RAMAPO___500_345_BK 1500</b>					FWD	REV
Sat 03/28/2015	to	Sat 03/28/2015			(Import)	(Export)
0200	Continuous	1900			SCH - PJ - NY	<b>2100 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	2450 MW
<b>ROCHESTR-PANNELL___345_RP1</b>					FWD	
Sun 03/29/2015	to	Fri 04/03/2015	<u>UPDATED</u>	<u>by PA</u>	(Import)	
0500	Continuous	1700		<u>03/04/2015</u>	DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES___-ADIRNDCK_230_MA2</b>					FWD	
Mon 03/30/2015	to	Fri 04/03/2015			(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1150 MW
					TTC with All Lines In Service	3150 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Wed 04/01/2015	to	Sun 04/05/2015			(Import)	
0001	Continuous	1900			SCH - PJM_HTP	<b>370 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	290 MW
					TTC with All Lines In Service	660 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Wed 04/01/2015	to	Fri 04/10/2015	<u>UPDATED</u>	<u>by CONED</u>	(Import)	(Export)
0001	Continuous	1530		<u>12/05/2014</u>	SCH - PJ - NY	<b>2450 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2450 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Thu 04/02/2015	to	Thu 04/02/2015			(Import)	
0001	Continuous	1900			SCH - PJM_HTP	<b>370 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	290 MW
					TTC with All Lines In Service	660 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLE-DUNWODIE\_345\_W89

Sat 04/04/2015 to Sat 04/04/2015

0001 Continuous 1930

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

## EGRDNCTY\_345\_138\_BK 1

Mon 04/06/2015 to Mon 04/06/2015

0001 Continuous 2359

Work scheduled by: LI

FWD

(Import)

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

## PLSNTVLE-DUNWODIE\_345\_W90

Mon 04/06/2015 to Sun 04/12/2015

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

## CLAY-EDIC\_345\_1-16

Mon 04/06/2015 to Tue 04/07/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## MOSES-ADIRNDCK\_230\_MA2

Mon 04/06/2015 to Fri 04/10/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

## OAKDALE-FRASER\_345\_32

Mon 04/06/2015 to Wed 04/08/2015 UPDATED by NYSEG 02/19/2015

0800 Continuous 1630

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

## ROSETON-ROCKTVRN\_345\_311

Mon 04/06/2015 to Fri 04/24/2015

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

4400 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56					FWD	
Mon 04/06/2015	to	Sat 04/11/2015	<u>UPDATED</u>	<u>by CONED</u>	<u>02/25/2015</u>	(Import)
2200	Continuous	2100				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability
						660 MW
					TTC with All Lines In Service	660 MW
EGRDNCTY_345_138_BK 2					FWD	
Tue 04/07/2015	to	Tue 04/07/2015				(Import)
0001	Continuous	2359				1250 MW
Work scheduled by: LI					CONED - LIPA	Impacts Total Transfer Capability
						250 MW
					TTC with All Lines In Service	1500 MW
W49TH_ST_345KV_7					FWD	
Tue 04/07/2015	to	Thu 04/09/2015	<u>UPDATED</u>	<u>by CONED</u>	<u>02/25/2015</u>	(Import)
0001	Continuous	1900				370 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability
						290 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8					FWD	
Tue 04/07/2015	to	Thu 04/09/2015	<u>UPDATED</u>	<u>by CONED</u>	<u>02/25/2015</u>	(Import)
0001	Continuous	1900				300 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability
						360 MW
					TTC with All Lines In Service	660 MW
BECK____-NIAGARA_345_PA302					FWD	REV
Thu 04/09/2015	to	Fri 04/10/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/09/2015</u>	(Import) (Export)
0500	Continuous	1600				1400 MW 1250 MW
Work scheduled by: NYPA					SCH - OH - NY	Impacts Total Transfer Capability
						500 MW 650 MW
					TTC with All Lines In Service	1900 MW 1900 MW
OAKDALE_-FRASER_345_32					FWD	
Thu 04/09/2015	to	Thu 04/09/2015	<u>UPDATED</u>	<u>by NYSEG</u>	<u>02/19/2015</u>	(Import)
0800	Continuous	1600				2650 MW
Work scheduled by: NYSEG					CENTRAL EAST - VC	Impacts Total Transfer Capability
						325 MW
					TTC with All Lines In Service	2975 MW
SPRNBK_-TREMONT_345_X28					FWD	
Fri 04/10/2015	to	Fri 04/10/2015				(Import)
0001	Continuous	2359				4200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability
						400 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

Mon 04/13/2015 to Mon 04/13/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## EFISHKIL-WOOD\_ST\_345\_F39

Mon 04/13/2015 to Wed 04/15/2015  
0001 Continuous 1930

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## PANNELL\_-CLAY\_345\_PC1

Mon 04/13/2015 to Tue 04/14/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## MARCY\_-COOPERS\_345\_UC2-41

Mon 04/13/2015 to Fri 04/17/2015 **UPDATED by NYPA 01/20/2015**  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## BERKSHIR-ALPS\_345\_393

Wed 04/15/2015 to Thu 04/16/2015 **UPDATED by NE 01/30/2015**  
0700 Continuous 1700

Work scheduled by: NGrid

FWD	REV
(Import)	(Export)
SCH - NE - NY <b>1300 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability 100 MW	300 MW
TTC with All Lines In Service 1400 MW	1600 MW

## BERKSHIR-ALPS\_345\_393

Wed 04/15/2015 to Thu 04/16/2015 **UPDATED by NE 01/30/2015**  
0700 Continuous 1700

Work scheduled by: NGrid

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

## BERKSHIR-ALPS\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Wed 04/15/2015 to Thu 04/16/2015  
0700 1700

Work scheduled by:

FWD	REV
(Import)	(Export)
SCH - NE - NY <b>1300 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability 100 MW	300 MW
TTC with All Lines In Service 1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-NORTHFLD_345_312</b>							
Wed 04/15/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by NE</u>	<u>01/30/2015</u>	SCH - NE - NY	<b>1400 MW</b>
0700	Continuous	1700				Impacts Total Transfer Capability	150 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>							
Wed 04/15/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by NE</u>	<u>01/30/2015</u>	SCH - NPX_1385	<b>100 MW</b>
0700	Continuous	1700				Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>							
Wed 04/15/2015	to	Wed 04/15/2015				UPNY CONED	<b>4000 MW</b>
1900	Continuous	1930				Impacts Total Transfer Capability	1100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>							
Thu 04/16/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by CE</u>	<u>02/26/2015</u>	UPNY CONED	<b>4000 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	1100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW
<b>EFISHKIL-WOOD_ST__345_F38</b>							
Thu 04/16/2015	to	Sun 04/19/2015	<u>UPDATED</u>	<u>by CE</u>	<u>02/26/2015</u>	UPNY CONED	<b>4000 MW</b>
0001	Continuous	1930				Impacts Total Transfer Capability	1100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>							
Fri 04/17/2015	to	Sun 04/19/2015	<u>UPDATED</u>	<u>by CE</u>	<u>02/26/2015</u>	UPNY CONED	<b>4000 MW</b>
0001	Continuous	1930				Impacts Total Transfer Capability	1100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW
<b>NRTH1385-NOR HBR__138_601</b>							
Mon 04/20/2015	to	Thu 04/30/2015				SCH - NPX_1385	<b>100 MW</b>
0500	Continuous	1500				Impacts Total Transfer Capability	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602**

Mon 04/20/2015 to Thu 04/30/2015  
0500 1500

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 04/20/2015 to Thu 04/30/2015  
0500 1500

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602**

Mon 04/20/2015 to Thu 04/30/2015  
0500 Continuous 1500

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 04/20/2015 to Thu 04/30/2015  
0500 1500

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_603**

Mon 04/20/2015 to Thu 04/30/2015  
0500 Continuous 1500

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NRTHPORT\_138\_1385**

Mon 04/20/2015 to Thu 04/30/2015  
0500 Continuous 1500

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**ROCHESTR-PANNELL\_\_345\_RP2**

Mon 04/20/2015 to Fri 04/24/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LIND\_CG\_-LNDVFT\_\_\_345\_V-3022

Tue 04/21/2015 to Wed 04/22/2015  
0900 Continuous 1400

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

## EASTVIEW-SPRNBK\_\_\_345\_W64

Wed 04/22/2015 to Wed 04/22/2015  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

## MILLWOOD-EASTVIEW\_345\_W99

Wed 04/22/2015 to Sat 04/25/2015  
0001 Continuous 1930

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

## GOETHALS-LINDN\_CG\_345\_G23L & GOETHALS-LINDN\_CG\_345\_G23M

Fri 04/24/2015 to Sun 04/26/2015  
0001 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	315 MW
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

## EASTVIEW-SPRNBK\_\_\_345\_W64

Sat 04/25/2015 to Sat 04/25/2015  
1900 Continuous 1930

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

## W49TH\_ST\_345KV\_5

Mon 04/27/2015 to Mon 04/27/2015 UPDATED by CE 02/26/2015  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD (Import)
SCH - PJM_HTP	370 MW
Impacts Total Transfer Capability	290 MW
TTC with All Lines In Service	660 MW

## SPRNBK\_-W49TH\_ST\_345\_M52

Mon 04/27/2015 to Sat 05/02/2015 UPDATED by CE 02/26/2015  
0001 Continuous 2300

Work scheduled by: ConEd

	FWD (Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_\_345KV\_RNS4

FWD

Mon 04/27/2015 to Sat 05/02/2015 UPDATED by CE 02/26/2015

(Import)

0001 Continuous 2300

SPR/DUN-SOUTH

**3200 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

## LEEDS\_\_345\_LEEDS SVC

FWD

Mon 04/27/2015 to Fri 05/01/2015

(Import)

0700 Continuous 1500

CENTRAL EAST - VC

**2950 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

## ROCHESTR-PANNELL\_\_345\_RP2

FWD

Mon 04/27/2015 to Fri 05/01/2015

(Import)

0700 Continuous 1530

DYSINGER EAST

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## FRASER\_\_-GILBOA\_\_345\_GF5-35

FWD

Mon 04/27/2015 to Fri 05/08/2015 UPDATED by NYPA 01/09/2015

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

## W49TH\_ST\_345KV\_5

FWD

Sat 05/02/2015 to Sat 05/02/2015 UPDATED by CE 02/26/2015

(Import)

2230 Continuous 2300

SCH - PJM\_HTP

**225 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 435 MW

TTC with All Lines In Service 660 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 05/04/2015 to Tue 05/12/2015

(Import)

0600 Continuous 2100

SCH - PJM\_NEPTUNE

**0 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 05/04/2015 to Tue 05/12/2015

(Import)

0600 Continuous 2100

SCH - PJM\_NEPTUNE

**0 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE\_345\_138\_BK\_1**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**NEWBRIDGE\_345\_138\_BK\_2**

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**SCH-NE-NYISO\_LIMIT\_900**

Mon 05/04/2015 to Thu 05/21/2015  
0600 Continuous 1700

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 05/04/2015 to Tue 05/05/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_230\_MAI**

Mon 05/04/2015 to Fri 05/08/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Mon 05/04/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Mon 05/04/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SHORE\_RD\_345\_138\_BK 2

Wed 05/06/2015 to Wed 05/13/2015  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

## MOSES -ADIRNDCK\_230\_MA1

Mon 05/11/2015 to Fri 05/15/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

## HOMER C -WATRCURE\_345\_30

Mon 05/11/2015 to Fri 05/15/2015  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2200 MW 1300 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 2450 MW 1300 MW

## EDIC -FRASER\_345\_EF24-40

Mon 05/11/2015 to Fri 05/15/2015  
0900 Continuous 1530

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MOSES -ADIRNDCK\_230\_MA2

Mon 05/18/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

## STLAWRNC-MOSES\_230\_L33P

Mon 05/18/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## HOMER C -WATRCURE\_345\_30

Mon 05/18/2015 to Fri 05/22/2015  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2200 MW 1300 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 2450 MW 1300 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_-COOPERS\_\_\_345\_UC2-41

Tue 05/19/2015 to Fri 05/22/2015  
0900 Daily 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### FROST\_BR-LONG\_MTN\_345\_352

Fri 05/22/2015 to Sun 05/31/2015  
0600 Continuous 1500

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY **1150 MW 1600 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

### HOMER C\_-WATRCURE\_345\_30

Mon 05/25/2015 to Fri 05/29/2015  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2200 MW 1300 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 2450 MW 1300 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### STLAWRNC-MOSES\_\_\_230\_L34P

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### PANNELL\_-CLAY\_\_\_345\_PC2

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Wed 06/03/2015 to Thu 06/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**BECK\_\_\_-NIAGARA\_345\_PA302**

Thu 06/25/2015 to Fri 06/26/2015  
0500 Continuous 1600

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1100 MW**  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Thu 08/13/2015 to Thu 08/13/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 08/18/2015 to Tue 08/18/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**ADIRNDCK-PORTER\_\_\_230\_12-AP**

Wed 08/19/2015 to Wed 08/19/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 08/20/2015 to Thu 08/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**EDIC\_\_\_-FRASER\_\_\_345\_EF24-40**

Mon 08/24/2015 to Fri 08/28/2015  
0700 Continuous 1630

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 08/31/2015 to Fri 09/04/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**CLAY\_\_\_-EDIC\_\_\_345\_2-15**

FWD

Thu 09/03/2015 to Fri 09/04/2015

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

---

**MARCY\_\_\_765\_345\_BK 2**

FWD

Mon 09/07/2015 to Fri 09/11/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19**


---

**HURLYAVE-ROSETON\_\_\_345\_303**

FWD

Mon 09/07/2015 to Fri 09/25/2015

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

---

**NIAGARA\_\_\_345\_230\_BK 4**

FWD

REV

Mon 09/07/2015 to Fri 10/09/2015

(Import) (Export)

0800 Continuous 1530

SCH - OH - NY

**1900 MW 1900 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 09/14/2015 to Fri 09/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Mon 09/14/2015 to Fri 09/18/2015

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 09/21/2015 to Fri 09/25/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

Mon 09/21/2015 to Fri 09/25/2015  
0700 Continuous 1600

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

---

**LONG\_MTN-PLSNTVLY\_345\_398**

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NE - NY **500 MW 1300 MW**  
Impacts Total Transfer Capability 900 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

---

**LONG\_MTN-PLSNTVLY\_345\_398**

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

---

**BECK\_\_\_-NIAGARA\_345\_PA302**

Thu 09/24/2015 to Fri 09/25/2015  
0500 Continuous 1600

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1100 MW**  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 09/28/2015 to Fri 10/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**BECK\_\_\_-NIAGARA\_345\_PA301**

Mon 09/28/2015 to Fri 10/02/2015  
0800 Continuous 1600

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1100 MW**  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 09/28/2015 to Fri 10/02/2015  
0900 Daily 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 10/03/2015 to Sun 10/25/2015  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/07/2014

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 10/03/2015 to Sun 10/25/2015  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/07/2014

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MARCY\_765\_345\_BK 1

Sat 10/03/2015 to Sun 10/25/2015  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/07/2014

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_765\_345\_BK 2

Sat 10/03/2015 to Sun 10/25/2015  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/07/2014

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/03/2015 to Sun 10/25/2015  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/07/2014

ARR: 20

FWD  
(Import)  
CENTRAL EAST - VC **2315 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 2975 MW

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/03/2015 to Sun 10/25/2015  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/07/2014

ARR: 20

FWD  
(Import)  
MOSES SOUTH **675 MW**  
Impacts Total Transfer Capability 2475 MW  
TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, March 11, 2015 to Friday, September 09, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>						FWD	REV
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	(Export)
0100	Continuous	1730				<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA					ARR: 20	Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>							
Sat 10/03/2015	to	Sun 10/25/2015					
0100		1730					
Work scheduled by:					ARR: 20	MOSES SOUTH	
						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						FWD	REV
Sat 10/03/2015	to	Sun 10/25/2015				(Import)	(Export)
0100		1730				<b>850 MW</b>	<b>0 MW</b>
Work scheduled by:					ARR: 20	Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>SHOR_NPX-SHOREHAM_138_NPX_CSC</b>						FWD	REV
Mon 10/05/2015	to	Sun 10/11/2015	<u>UPDATED</u>	<u>by ISONE</u>	<u>07/25/2014</u>	(Import)	(Export)
0530	Continuous	1800				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW 330 MW
						TTC with All Lines In Service	330 MW 330 MW
<b>GILBOA_-LEEDS_345_GL3</b>						FWD	
Mon 10/05/2015	to	Fri 10/09/2015				(Import)	
0700	Continuous	1600				<b>2200 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	775 MW
						TTC with All Lines In Service	2975 MW
<b>BECK_-PACKARD_230_BP76</b>						FWD	REV
Mon 10/05/2015	to	Fri 10/09/2015				(Import)	(Export)
0800	Continuous	1600				<b>1750 MW</b>	<b>1200 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	150 MW 700 MW
						TTC with All Lines In Service	1900 MW 1900 MW
<b>MALONE_-WILLIS_115_1-MW</b>							REV
Tue 10/06/2015	to	Tue 10/06/2015					(Export)
0800	Continuous	1530					<b>40 MW</b>
Work scheduled by: NYPA					ARR: 20&38	Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	40 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 10/12/2015 to Fri 10/30/2015

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

## GILBOA\_\_\_-N.SCTLND\_345\_GNS1

Mon 10/19/2015 to Fri 10/23/2015

0700 Continuous 1600

Work scheduled by: NYPA

UPDATEDby NYISO 09/12/2014

FWD

(Import)

CENTRAL EAST - VC

2520 MW

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

## GOETHALS-LINDN.CG\_345\_G23L &amp; GOETHALS-LINDN.CG\_345\_G23M

Tue 10/20/2015 to Fri 10/23/2015

0001 2359

Work scheduled by:

FWD

(Import) (Export)

SCH - PJM\_VFT

0 MW

315 MW 0 MW

Impacts Total Transfer Capability 315 MW

TTC with All Lines In Service 315 MW 315 MW

## RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94

Sat 11/07/2015 to Mon 11/09/2015

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4150 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

## ROCKTVRN-RAMAPO\_\_\_345\_77

Sat 11/07/2015 to Fri 11/20/2015

0800 Continuous 1600

Work scheduled by: CHGE

UPDATEDby CH12/16/2014

FWD

(Import)

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

## ROSETON\_-ROCKTVRN\_345\_311

Sat 11/07/2015 to Fri 11/20/2015

0800 Continuous 1600

Work scheduled by: CHGE

UPDATEDby CH12/16/2014

FWD

(Import)

UPNY CONED

4400 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

## ROCKTVRN-RAMAPO\_\_\_345\_77

Fri 11/20/2015 to Sat 12/12/2015

1601 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, March 11, 2015 to Friday, September 09, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GOETHALS-LINDN CG\_345\_G23L & GOETHALS-LINDN CG\_345\_G23M

Mon 11/23/2015 to Thu 11/26/2015  
0001 2359

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	315 MW
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

## RAMAPO -BUCHAN N\_345\_Y94

Sun 11/29/2015 to Sat 12/05/2015  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4150 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	5100 MW

## BERKSHIR-ALPS 345\_393

Mon 11/30/2015 to Fri 12/04/2015  
0600 Continuous 1500

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NE - NY	1300 MW	1300 MW
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

## BERKSHIR-ALPS 345\_393

Mon 11/30/2015 to Fri 12/04/2015  
0600 Continuous 1500

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## MOSES -ADIRNDCK\_230\_MAI

Mon 11/30/2015 to Fri 12/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

## MOSES -ADIRNDCK\_230\_MAI

Mon 12/07/2015 to Fri 12/11/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

## MOSES -ADIRNDCK\_230\_MAI

Mon 12/14/2015 to Fri 12/18/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW



**NYISO TRANSFER LIMITATIONS**

Wednesday, March 11, 2015 to Friday , September 09, 2016

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Thu 12/17/2015 to Fri 12/18/2015

0500 Continuous 1600

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

FWD REV  
(Import) (Export)**1400 MW 1250 MW**

ROCKTVRN-RAMAPO\_\_345\_77

Mon 04/04/2016 to Fri 04/29/2016

0800 Continuous 1600

Work scheduled by: CHGE

CENTRAL EAST - VC

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

FWD  
(Import)**2570 MW**