

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Fri 02/06/2015 to Thu 03/26/2015 EXT FORCE by HQ 02/12/2015  
0757 Continuous 2359

Work scheduled by: HQ

REV  
(Export)  
0 MW  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 100 MW

## BEAR SWP-ROTTDAM\_230\_E205W

Wed 02/25/2015 to Fri 03/06/2015 EXTENDED by NGRID 02/19/2015  
0630 Continuous 1600

Work scheduled by: NGrid

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 03/02/2015 to Fri 03/06/2015 UPDATED by NYPA 03/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_-EDIC\_345\_UE1-7

Mon 03/02/2015 to Wed 03/04/2015 UPDATED by NYPA 03/04/2015  
0800 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## WATRCURE-OAKDALE\_345\_31

Mon 03/02/2015 to Wed 03/04/2015 EXTENDED by NYSEG 03/05/2015  
0900 Daily 1500

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY 2450 MW 1300 MW  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2450 MW 1300 MW

## MILLWOOD\_345KV\_18

Tue 03/03/2015 to Tue 03/03/2015 UPDATED by CONED 02/27/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## LADENTWN-BUCHAN\_S\_345\_Y88

Tue 03/03/2015 to Wed 03/18/2015 UPDATED by CONED 02/27/2015  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4150 MW  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY -EDIC 345 UE1-7</b>						FWD	
Wed 03/04/2015	to	Fri 03/06/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/04/2015</u>	(Import)	
2100	Continuous	1530				OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	0 MW
ARR: 16						TTC with All Lines In Service	5250 MW
<b>WATRCURE-OAKDALE 345 31</b>						FWD	REV
Thu 03/05/2015	to	Fri 03/06/2015	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>03/05/2015</u>	(Import)	(Export)
0800	Daily	1500				SCH - PJ - NY	<b>2450 MW 1300 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	0 MW 0 MW
						TTC with All Lines In Service	2450 MW 1300 MW
<b>FRASER 345 FRASER SVC</b>						FWD	
Fri 03/06/2015	to	Fri 03/06/2015	<u>UPDATED</u>	<u>by NYSEG</u>	<u>03/04/2015</u>	(Import)	
0900	Continuous	1600				CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	40 MW
						TTC with All Lines In Service	2975 MW
<b>E13THSTA-FARRAGUT 345 46</b>						FWD	
Sat 03/07/2015	to	Sun 03/08/2015	<u>CANCELLED</u>	<u>by ConEd</u>	<u>03/06/2015</u>	(Import)	
0001	Continuous	2330				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>W49TH_ST-E13THSTA 345 M55</b>						FWD	
Sat 03/07/2015	to	Sun 03/08/2015	<u>CANCELLED</u>	<u>by ConEd</u>	<u>03/06/2015</u>	(Import)	
0001	Continuous	2330				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>W49TH_ST 345KV 6</b>						FWD	
Sat 03/07/2015	to	Sun 03/08/2015	<u>CANCELLED</u>	<u>by ConEd</u>	<u>03/06/2015</u>	(Import)	
0001	Continuous	2330				SCH - PJM_HTP	<b>320 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	340 MW
						TTC with All Lines In Service	660 MW
<b>ROCHESTR-PANNELL 345 RP1</b>						FWD	
Sat 03/07/2015	to	Sun 03/08/2015	<u>UPDATED</u>	<u>by RGE</u>	<u>03/08/2015</u>	(Import)	
0700	Continuous	1647				DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: RGE						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBRK\_-W49TH\_ST\_345\_M51**

FWD

Mon 03/09/2015 to Mon 03/09/2015

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_345KV\_RNS5**

FWD

Mon 03/09/2015 to Mon 03/09/2015

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Mon 03/09/2015 to Tue 03/10/2015

(Import)

0500 Continuous 1600

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BECK\_-NIAGARA\_230\_PA27**

FWD

REV

Mon 03/09/2015 to Sat 03/14/2015

(Import) (Export)

0600 Continuous 1530

**by IESO 03/05/2015**

SCH - OH - NY

**1900 MW 1900 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: IESO

**STLAWRNC-MOSES\_230\_L34P**

FWD

REV

Mon 03/09/2015 to Tue 03/10/2015

(Import) (Export)

0700 Continuous 1530

**UPDATED by NYPA 02/26/2015**

SCH - OH - NY

**1750 MW 1750 MW**

Impacts Total Transfer Capability 150 MW 150 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Mon 03/09/2015 to Fri 03/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**VOLNEY\_-MARC\_345\_19**

FWD

Mon 03/09/2015 to Fri 03/13/2015

(Import)

0800 Continuous 1530

**UPDATED by PA 02/10/2015**

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY__-MARCY____345_19					FWD	
Mon 03/09/2015	to	Fri 03/13/2015	<u>UPDATED</u>	<u>by PA</u>	<u>02/10/2015</u>	(Import)
0800	Continuous	1530				
Work scheduled by: NYPA					OSWEGO EXPORT	4900 MW
					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	5250 MW
SCH-NE-NYISO_LIMIT_800					FWD	
Tue 03/10/2015	to	Tue 03/10/2015	<u>UPDATED</u>	<u>by NE</u>	<u>03/05/2015</u>	(Import)
0630	Continuous	2100				
Work scheduled by: ISONE					SCH - NE - NY	1000 MW
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS____345_2-AN					FWD	REV
Tue 03/10/2015	to	Tue 03/10/2015			(Import)	(Export)
0800	Daily(No Weekends)	1459			SCH - NE - NY	900 MW 1600 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	500 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
N.SCTLND-ALPS____345_2-AN					FWD	REV
Tue 03/10/2015	to	Tue 03/10/2015			(Import)	(Export)
0800	Daily(No Weekends)	1459			SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
WATRCURE-OAKDALE__345_31					FWD	REV
Tue 03/10/2015	to	Tue 03/10/2015	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>03/05/2015</u>	(Import) (Export)
0900	Daily	1500			SCH - PJ - NY	2450 MW 1300 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2450 MW 1300 MW
MILLWOOD_345KV_18					FWD	
Wed 03/11/2015	to	Wed 03/11/2015	<u>UPDATED</u>	<u>by CONED</u>	<u>02/27/2015</u>	(Import)
0001	Continuous	2359				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	750 MW
					TTC with All Lines In Service	5100 MW
KINTIGH_-ROCHESTR_345_SRL-39					FWD	
Wed 03/11/2015	to	Thu 03/12/2015				(Import)
0500	Continuous	1600			DYSINGER EAST	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1850 MW
					TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>STLAWRNC-MOSES____230_L33P</b>							
Thu 03/12/2015	to	Fri 03/13/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/26/2015</u>	SCH - OH - NY	<b>1750 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	150 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1900 MW
<b>ROCHESTR-PANNELL____345_RP2</b>						FWD	
Sat 03/14/2015	to	Sat 03/14/2015				(Import)	
0700	Continuous	1500				DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: RGE						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY____345_STATCOM SVC</b>						FWD	
Mon 03/16/2015	to	Mon 03/16/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/27/2015</u>	(Import)	
0500	Continuous	1530				CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW
						TTC with All Lines In Service	2975 MW
<b>ROCHESTR-PANNELL____345_RP1</b>						FWD	
Mon 03/16/2015	to	Fri 03/27/2015	<u>UPDATED</u>	<u>by PA</u>	<u>03/04/2015</u>	(Import)	
0500	Continuous	1700				DYSINGER EAST	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES____-ADIRNDCK_230_MA1</b>						FWD	
Mon 03/16/2015	to	Fri 03/20/2015				(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1150 MW
						TTC with All Lines In Service	3150 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>						FWD	REV
Tue 03/17/2015	to	Thu 03/19/2015				(Import)	(Export)
0200	Continuous	2300				SCH - PJ - NY	<b>2450 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2450 MW
<b>MARCY____345_STATCOM SVC</b>						FWD	
Tue 03/17/2015	to	Wed 03/18/2015				(Import)	
0500	Continuous	1530				CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	50 MW
						TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DENNISON-ROSEMNTB\_115\_2-RD

Tue 03/17/2015 to Tue 03/17/2015

0800 Daily(No Weekends) 1530

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	100 MW
Impacts Total Transfer Capability	104 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

### MILLWOOD\_345KV\_18

Wed 03/18/2015 to Wed 03/18/2015

2330 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 02/27/2015

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 03/23/2015 to Fri 03/27/2015

0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

### ROCHESTR-PANNELL\_345\_RP1

Mon 03/23/2015 to Fri 03/27/2015

0700 Continuous 1530

Work scheduled by: NYPA

CANCELLED by NYISO 03/04/2015

	FWD
	(Import)
DYSINGER EAST	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### BECK\_\_-NIAGARA\_345\_PA301

Tue 03/24/2015 to Tue 03/24/2015

0800 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1400 MW	1250 MW
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

### BECK\_\_-PACKARD\_230\_BP76

Thu 03/26/2015 to Thu 03/26/2015

0800 Daily(No Weekends) 1530

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1800 MW
Impacts Total Transfer Capability	0 MW	100 MW
TTC with All Lines In Service	1900 MW	1900 MW

### HOPATCON-RAMAPO\_500\_5018

Sat 03/28/2015 to Sat 03/28/2015

0200 Continuous 1900

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2100 MW	1000 MW
Impacts Total Transfer Capability	350 MW	300 MW
TTC with All Lines In Service	2450 MW	1300 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOPATCON-RAMAPO\_\_500\_5018

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900  
Work scheduled by: ConEd

FWD  
(Import)  
TOTAL EAST 6400 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 6500 MW

### HOPATCON-RAMAPO\_\_500\_5018

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4000 MW  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### RAMAPO\_\_345\_345\_PAR3500

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	2400 MW	1300 MW
Impacts Total Transfer Capability	50 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

### RAMAPO\_\_345\_345\_PAR4500

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	2400 MW	1300 MW
Impacts Total Transfer Capability	50 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

### RAMAPO\_\_500\_345\_BK 1500

Sat 03/28/2015 to Sat 03/28/2015  
0200 Continuous 1900  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	2100 MW	1000 MW
Impacts Total Transfer Capability	350 MW	300 MW
TTC with All Lines In Service	2450 MW	1300 MW

### ROCHESTR-PANNELL\_\_345\_RP1

Sun 03/29/2015 to Fri 04/03/2015 UPDATED by PA 03/04/2015  
0500 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 03/30/2015 to Fri 04/03/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2000 MW  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Wed 04/01/2015 to Sun 04/05/2015

0001 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **370 MW**  
Impacts Total Transfer Capability 290 MW  
TTC with All Lines In Service 660 MW

### HUDSONP\_-FARRAGUT\_345\_B3402

Wed 04/01/2015 to Fri 04/10/2015

0001 Continuous 1530

Work scheduled by: PJM

UPDATED by CONED 12/05/2014

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2450 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2450 MW 1300 MW

### W49TH\_ST\_345KV\_5

Thu 04/02/2015 to Thu 04/02/2015

0001 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **370 MW**  
Impacts Total Transfer Capability 290 MW  
TTC with All Lines In Service 660 MW

### PLSNTVLE-DUNWODIE\_345\_W89

Sat 04/04/2015 to Sat 04/04/2015

0001 Continuous 1930

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### EGRDNCTY\_345\_138\_BK 1

Mon 04/06/2015 to Mon 04/06/2015

0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### PLSNTVLE-DUNWODIE\_345\_W90

Mon 04/06/2015 to Sun 04/12/2015

0001 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### CLAY\_-EDIC\_345\_1-16

Mon 04/06/2015 to Tue 04/07/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 04/06/2015 to Fri 04/10/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### OAKDALE\_-FRASER\_\_\_345\_32

Mon 04/06/2015 to Wed 04/08/2015  
0800 Continuous 1630

Work scheduled by: NYSEG

UPDATED by NYSEG 02/19/2015

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### ROSETON\_-ROCKTVRN\_345\_311

Mon 04/06/2015 to Fri 04/24/2015  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

### HUDSONTP-W49TH\_ST\_345\_Y56

Mon 04/06/2015 to Sat 04/11/2015  
2200 Continuous 2100

Work scheduled by: ConEd

UPDATED by CONED 02/25/2015

FWD  
(Import)  
SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### EGRDNCTY\_345\_138\_BK 2

Tue 04/07/2015 to Tue 04/07/2015  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### W49TH\_ST\_345KV\_7

Tue 04/07/2015 to Thu 04/09/2015  
0001 Continuous 1900

Work scheduled by: ConEd

UPDATED by CONED 02/25/2015

FWD  
(Import)  
SCH - PJM\_HTP **370 MW**  
Impacts Total Transfer Capability 290 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_8

Tue 04/07/2015 to Thu 04/09/2015  
0001 Continuous 1900

Work scheduled by: ConEd

UPDATED by CONED 02/25/2015

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Thu 04/09/2015 to Fri 04/10/2015 UPDATED by NYPA 02/13/2015  
0500 Continuous 1600

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1400 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

### OAKDALE\_-FRASER\_\_345\_32

Thu 04/09/2015 to Thu 04/09/2015 UPDATED by NYSEG 02/19/2015  
0800 Continuous 1600

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

### SPRNBK\_-TREMONT\_\_345\_X28

Fri 04/10/2015 to Fri 04/10/2015  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>4200 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	4600 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

Mon 04/13/2015 to Mon 04/13/2015  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

### EFISHKIL-WOOD\_ST\_\_345\_F39

Mon 04/13/2015 to Wed 04/15/2015  
0001 Continuous 1930

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

### PANNELL\_-CLAY\_\_\_\_345\_PC1

Mon 04/13/2015 to Tue 04/14/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	<b>1300 MW</b>
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

### MARCY\_\_\_\_-COOPERS\_\_345\_UC2-41

Mon 04/13/2015 to Fri 04/17/2015 UPDATED by NYPA 01/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-ALPS_____345_393</b>							
Wed 04/15/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by NE</u>	<u>01/30/2015</u>		
0700	Continuous	1700				SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-ALPS_____345_393</b>							
Wed 04/15/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by NE</u>	<u>01/30/2015</u>		
0700	Continuous	1700				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>							
Wed 04/15/2015	to	Thu 04/16/2015					
0700		1700				SCH - NE - NY	<b>1300 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>							
Wed 04/15/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by NE</u>	<u>01/30/2015</u>		
0700	Continuous	1700				SCH - NE - NY	<b>1400 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>							
Wed 04/15/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by NE</u>	<u>01/30/2015</u>		
0700	Continuous	1700				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>							
Wed 04/15/2015	to	Wed 04/15/2015					
1900	Continuous	1930				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>							
Thu 04/16/2015	to	Thu 04/16/2015	<u>UPDATED</u>	<u>by CE</u>	<u>02/26/2015</u>		
0001	Continuous	0030				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EFISHKIL-WOOD_ST__345_F38</b>					FWD	
Thu 04/16/2015	to	Sun 04/19/2015	<u>UPDATED</u>	<u>by CE</u>	<u>02/26/2015</u>	(Import)
0001	Continuous	1930				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD	
Fri 04/17/2015	to	Sun 04/19/2015	<u>UPDATED</u>	<u>by CE</u>	<u>02/26/2015</u>	(Import)
0001	Continuous	1930				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<b>NRTH1385-NOR HBR__138_601</b>					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015				(Import) (Export)
0500	Continuous	1500			SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015				(Import) (Export)
0500		1500			SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015				(Import) (Export)
0500		1500			SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_602</b>					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015				(Import) (Export)
0500	Continuous	1500			SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015				(Import) (Export)
0500		1500			SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NRTH1385-NOR HBR\_\_138\_603**

Mon 04/20/2015 to Thu 04/30/2015  
 0500 Continuous 1500

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**NRTH1385-NRTHPORT\_138\_1385**

Mon 04/20/2015 to Thu 04/30/2015  
 0500 Continuous 1500

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**ROCHESTR-PANNELL\_\_345\_RP2**

Mon 04/20/2015 to Fri 04/24/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

**LIND\_CG\_-LNDVFT\_\_345\_V-3022**

Tue 04/21/2015 to Wed 04/22/2015  
 0900 Continuous 1400

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

**EASTVIEW-SPRNBK\_\_345\_W64**

Wed 04/22/2015 to Wed 04/22/2015  
 0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Wed 04/22/2015 to Sat 04/25/2015  
 0001 Continuous 1930

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

**GOETHALS-LINDN\_CG\_345\_G23L & GOETHALS-LINDN\_CG\_345\_G23M**

Fri 04/24/2015 to Sun 04/26/2015  
 0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>315 MW</b>
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W64

Sat 04/25/2015 to Sat 04/25/2015  
1900 Continuous 1930  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## W49TH\_ST\_345KV\_5

Mon 04/27/2015 to Mon 04/27/2015  
0001 Continuous 0030  
Work scheduled by: ConEd

UPDATED by CE 02/26/2015

FWD  
(Import)  
SCH - PJM\_HTP **370 MW**  
Impacts Total Transfer Capability 290 MW  
TTC with All Lines In Service 660 MW

## SPRNBK\_-W49TH\_ST\_345\_M52

Mon 04/27/2015 to Sat 05/02/2015  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by CE 02/26/2015

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## SPRNBK\_\_345KV\_RNS4

Mon 04/27/2015 to Sat 05/02/2015  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by CE 02/26/2015

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## LEEDS\_\_345\_LEEDS SVC

Mon 04/27/2015 to Fri 05/01/2015  
0700 Continuous 1500  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2950 MW**  
Impacts Total Transfer Capability 25 MW  
TTC with All Lines In Service 2975 MW

## ROCHESTR-PANNELL\_\_345\_RP2

Mon 04/27/2015 to Fri 05/01/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## FRASER\_-GILBOA\_\_345\_GF5-35

Mon 04/27/2015 to Fri 05/08/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

UPDATED by NYPA 01/09/2015

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Sat 05/02/2015 to Sat 05/02/2015 UPDATED by CE 02/26/2015  
2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
**225 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 435 MW  
TTC with All Lines In Service 660 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**0 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**375 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

Work scheduled by: LI

FWD  
(Import)  
**375 MW**  
SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### SCH-NE-NYISO\_LIMIT\_900

Mon 05/04/2015 to Thu 05/21/2015  
0600 Continuous 1700

Work scheduled by: ISONE

FWD  
(Import)  
**1100 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

### NIAGARA\_-ROCHESTR\_345\_NR2

Mon 05/04/2015 to Tue 05/05/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**1700 MW**  
DYSINGER EAST  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_Ma1

Mon 05/04/2015 to Fri 05/08/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### CHATGUAY-MASSENA\_\_\_765\_7040

Mon 05/04/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### SHORE\_RD\_345\_138\_BK 2

Wed 05/06/2015 to Wed 05/13/2015  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### MOSES\_\_\_-ADIRNDCK\_230\_Ma1

Mon 05/11/2015 to Fri 05/15/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### HOMER C\_-WATRCURE\_345\_30

Mon 05/11/2015 to Fri 05/15/2015  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2200 MW 1300 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 2450 MW 1300 MW

### EDIC\_\_\_-FRASER\_\_\_345\_EF24-40

Mon 05/11/2015 to Fri 05/15/2015  
0900 Continuous 1530

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MOSES\_\_\_-ADIRNDCK\_230\_Ma2

Mon 05/18/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW



**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>STLAWRNC-MOSES____230_L33P</b>			FWD	REV
Mon 05/18/2015	to	Fri 05/22/2015	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	<b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW
			TTC with All Lines In Service	1900 MW
<b>HOMER C_-WATRCURE_345_30</b>			FWD	REV
Mon 05/18/2015	to	Fri 05/22/2015	(Import)	(Export)
0800	Continuous	1600	SCH - PJ - NY	<b>2200 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	250 MW
			TTC with All Lines In Service	2450 MW
<b>MARCY____-COOPERS__345_UC2-41</b>			FWD	
Tue 05/19/2015	to	Fri 05/22/2015	(Import)	
0900	Daily	1600	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	475 MW
			TTC with All Lines In Service	2975 MW
<b>FROST_BR-LONG_MTN_345_352</b>			FWD	REV
Fri 05/22/2015	to	Sun 05/31/2015	(Import)	(Export)
0600	Continuous	1500	SCH - NE - NY	<b>1150 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	250 MW
			TTC with All Lines In Service	1400 MW
<b>HOMER C_-WATRCURE_345_30</b>			FWD	REV
Mon 05/25/2015	to	Fri 05/29/2015	(Import)	(Export)
0800	Continuous	1600	SCH - PJ - NY	<b>2200 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability	250 MW
			TTC with All Lines In Service	2450 MW
<b>MOSES____-ADIRNDCK_230_MA2</b>			FWD	
Tue 05/26/2015	to	Fri 05/29/2015	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1150 MW
			TTC with All Lines In Service	3150 MW
<b>STLAWRNC-MOSES____230_L34P</b>			FWD	REV
Tue 05/26/2015	to	Fri 05/29/2015	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	<b>1750 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW
			TTC with All Lines In Service	1900 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 06/01/2015 to Tue 06/02/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**PANNELL\_-CLAY\_\_\_345\_PC2**

FWD

Mon 06/01/2015 to Tue 06/02/2015

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Wed 06/03/2015 to Thu 06/04/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BECK\_\_\_-NIAGARA\_\_\_345\_PA302**

FWD

REV

Thu 06/25/2015 to Fri 06/26/2015

(Import) (Export)

0500 Continuous 1600

SCH - OH - NY

**1200 MW 1100 MW**

Impacts Total Transfer Capability 700 MW 800 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Thu 08/13/2015 to Thu 08/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 08/18/2015 to Tue 08/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ADIRNDCK-PORTER\_\_\_230\_12-AP**

FWD

Wed 08/19/2015 to Wed 08/19/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-CHASLAKE\_230\_13

Thu 08/20/2015 to Thu 08/20/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### EDIC-\_-FRASER\_345\_EF24-40

Mon 08/24/2015 to Fri 08/28/2015  
0700 Continuous 1630  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MOSES-\_-ADIRNDCK\_230\_MA2

Mon 08/31/2015 to Fri 09/04/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### CLAY-\_-EDIC\_345\_2-15

Thu 09/03/2015 to Fri 09/04/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### MARCY\_765\_345\_BK 2

Mon 09/07/2015 to Fri 09/11/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

ARR: 19

### HURLYAVE-ROSETON\_345\_303

Mon 09/07/2015 to Fri 09/25/2015  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

### NIAGARA\_345\_230\_BK 4

Mon 09/07/2015 to Fri 10/09/2015  
0800 Continuous 1530  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1900 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 09/14/2015 to Fri 09/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Mon 09/14/2015 to Fri 09/18/2015

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 09/21/2015 to Fri 09/25/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

FWD

Mon 09/21/2015 to Fri 09/25/2015

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**LONG\_MTN-PLSNTVLY\_345\_398**

FWD

REV

Wed 09/23/2015 to Fri 10/02/2015

(Import) (Export)

0500 Continuous 1700

SCH - NE - NY

**500 MW****1300 MW**

Impacts Total Transfer Capability 900 MW

300 MW

TTC with All Lines In Service 1400 MW

1600 MW

Work scheduled by: ConEd

**LONG\_MTN-PLSNTVLY\_345\_398**

FWD

REV

Wed 09/23/2015 to Fri 10/02/2015

(Import) (Export)

0500 Continuous 1700

SCH - NPX\_1385

**100 MW****100 MW**

Impacts Total Transfer Capability 100 MW

100 MW

TTC with All Lines In Service 200 MW

200 MW

Work scheduled by: ConEd

**BECK\_\_\_-NIAGARA\_345\_PA302**

FWD

REV

Thu 09/24/2015 to Fri 09/25/2015

(Import) (Export)

0500 Continuous 1600

SCH - OH - NY

**1200 MW****1100 MW**

Impacts Total Transfer Capability 700 MW

800 MW

TTC with All Lines In Service 1900 MW

1900 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 09/28/2015 to Fri 10/02/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BECK\_\_\_-NIAGARA\_345\_PA301**

FWD

REV

Mon 09/28/2015 to Fri 10/02/2015

(Import) (Export)

0800 Continuous 1600

SCH - OH - NY

**1200 MW 1100 MW**

Impacts Total Transfer Capability 700 MW 800 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

FWD

Mon 09/28/2015 to Fri 10/02/2015

(Import)

0900 Daily 1600

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**CHATGUAY-MASSENA\_765\_7040**

FWD

REV

Sat 10/03/2015 to Sun 10/25/2015

(Import) (Export)

0100 Continuous 1730

**UPDATED****by NYPA****10/07/2014**

SCH - HQ - NY

**0 MW 0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**MARCY\_\_\_765\_345\_BK 1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

0100 Continuous 1730

**UPDATED****by NYPA****10/07/2014**

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_\_765\_345\_BK 2**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

0100 Continuous 1730

**UPDATED****by NYPA****10/07/2014**

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MASSENA\_-MARCY\_\_\_765\_MSU1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

0100 Continuous 1730

**UPDATED****by NYPA****10/07/2014**

CENTRAL EAST - VC

**2315 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 20**

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>					FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)
0100	Continuous	1730				MOSES SOUTH <b>675 MW</b>
Work scheduled by: NYPA					ARR: 20	Impacts Total Transfer Capability 2475 MW
						TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>					FWD REV	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import) (Export)
0100	Continuous	1730				SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA					ARR: 20	Impacts Total Transfer Capability 1025 MW 0 MW
						TTC with All Lines In Service 1500 MW 1000 MW
<b>SHOR_NPX-SHOREHAM_138_NPX_CSC</b>					FWD REV	
Mon 10/05/2015	to	Sun 10/11/2015	<u>UPDATED</u>	<u>by ISONE</u>	<u>07/25/2014</u>	(Import) (Export)
0530	Continuous	1800				SCH - NPX_CSC <b>0 MW 0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 330 MW 330 MW
						TTC with All Lines In Service 330 MW 330 MW
<b>GILBOA_-LEEDS_345_GL3</b>					FWD	
Mon 10/05/2015	to	Fri 10/09/2015				(Import)
0700	Continuous	1600				CENTRAL EAST - VC <b>2200 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 775 MW
						TTC with All Lines In Service 2975 MW
<b>BECK_-PACKARD_230_BP76</b>					FWD REV	
Mon 10/05/2015	to	Fri 10/09/2015				(Import) (Export)
0800	Continuous	1600				SCH - OH - NY <b>1750 MW 1200 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 150 MW 700 MW
						TTC with All Lines In Service 1900 MW 1900 MW
<b>MALONE_-WILLIS_115_1-MW</b>					REV	
Tue 10/06/2015	to	Tue 10/06/2015				(Export)
0800	Continuous	1530				SCH - HQ_CEDARS <b>40 MW</b>
Work scheduled by: NYPA					ARR: 20&38	Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 40 MW
<b>LEEDS_-HURLYAVE_345_301</b>					FWD	
Mon 10/12/2015	to	Fri 10/30/2015				(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1000 MW
						TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**GILBOA\_\_-N.SCTLND\_345\_GNS1**

FWD

Mon 10/19/2015 to Fri 10/23/2015 **UPDATED by NYISO 09/12/2014**

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2520 MW**

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**GOETHALS-LINDN.CG\_345\_G23L & GOETHALS-LINDN.CG\_345\_G23M**

FWD

REV

Tue 10/20/2015 to Fri 10/23/2015

(Import) (Export)

0001 2359

SCH - PJM\_VFT

**0 MW****315 MW**

Impacts Total Transfer Capability 315 MW 0 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by:

**MARCY\_\_-COOPERS\_345\_UC2-41**

FWD

Mon 11/02/2015 to Fri 11/06/2015 **CANCELLED by NYPA 03/03/2015**

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Sat 11/07/2015 to Mon 11/09/2015

(Import)

0001 Continuous 2359

UPNY CONED

**4150 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**ROCKTVRN-RAMAPO\_\_345\_77**

FWD

Sat 11/07/2015 to Fri 11/20/2015 **UPDATED by CH 12/16/2014**

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

**ROSETON\_-ROCKTVRN\_345\_311**

FWD

Sat 11/07/2015 to Fri 11/20/2015 **UPDATED by CH 12/16/2014**

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**ROCKTVRN-RAMAPO\_\_345\_77**

FWD

Fri 11/20/2015 to Sat 12/12/2015

(Import)

1601 Continuous 2359

CENTRAL EAST - VC

**2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS-LINDN CG\_345\_G23L & GOETHALS-LINDN CG\_345\_G23M

Mon 11/23/2015 to Thu 11/26/2015  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	315 MW
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

### RAMAPO -BUCHAN N\_345\_Y94

Sun 11/29/2015 to Sat 12/05/2015  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4150 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	5100 MW

### BERKSHIR-ALPS 345\_393

Mon 11/30/2015 to Fri 12/04/2015  
0600 Continuous 1500

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1300 MW	1300 MW
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

### BERKSHIR-ALPS 345\_393

Mon 11/30/2015 to Fri 12/04/2015  
0600 Continuous 1500

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### MOSES -ADIRNDCK\_230\_MAI

Mon 11/30/2015 to Fri 12/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

### MOSES -ADIRNDCK\_230\_MAI

Mon 12/07/2015 to Fri 12/11/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

### MOSES -ADIRNDCK\_230\_MAI

Mon 12/14/2015 to Fri 12/18/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW



**NYISO TRANSFER LIMITATIONS**

Sunday ,March 08, 2015 to Tuesday ,September06, 2016

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Thu 12/17/2015 to Fri 12/18/2015  
 0500 Continuous 1600

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1400 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

ROCKTVRN-RAMAPO\_\_345\_77

Mon 04/04/2016 to Fri 04/29/2016  
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
CENTRAL EAST - VC	<b>2570 MW</b>
Impacts Total Transfer Capability	405 MW
TTC with All Lines In Service	2975 MW