

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**Fri 02/06/2015 to Wed 04/15/2015 **EXT FORCE by HQ 04/15/2015**

0757 Continuous 1725

Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**0 MW**

100 MW

100 MW

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 04/06/2015 to Fri 04/24/2015

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**4400 MW**

700 MW

5100 MW

**EFISHKIL-WOOD\_ST\_345\_F39**

Mon 04/13/2015 to Wed 04/15/2015

0001 Continuous 1930

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**4000 MW**

1100 MW

5100 MW

**MARCY\_-COOPERS\_345\_UC2-41**

Mon 04/13/2015 to Fri 04/17/2015

0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/20/2015**

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**2500 MW**

475 MW

2975 MW

**LOWVILLE-BOONVILLE\_115\_5-LB**

Mon 04/13/2015 to Fri 05/08/2015

0800 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import) (Export)

**199 MW**

0 MW

199 MW

**100 MW**

0 MW

100 MW

**BERKSHIR-ALPS\_345\_393**

Wed 04/15/2015 to Thu 04/16/2015

0700 Continuous 1700

Work scheduled by: NGrid

**UPDATED by ISONE 04/10/2015**

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import) (Export)

**1300 MW**

100 MW

1400 MW

**1300 MW**

300 MW

1600 MW

**BERKSHIR-ALPS\_345\_393**

Wed 04/15/2015 to Thu 04/16/2015

0700 Continuous 1700

Work scheduled by: NGrid

**UPDATED by ISONE 04/10/2015**

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import) (Export)

**100 MW**

100 MW

200 MW

**100 MW**

100 MW

200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BERKSHIR-ALPS\_\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312**

Wed 04/15/2015 to Thu 04/16/2015  
0700 1700

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>1300 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

Wed 04/15/2015 to Thu 04/16/2015  
0700 Continuous 1700

Work scheduled by: NGrid

UPDATED by ISONE 04/10/2015

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>1400 MW</b>	<b>1450 MW</b>
Impacts Total Transfer Capability	0 MW	150 MW
TTC with All Lines In Service	1400 MW	1600 MW

**BERKSHIR-NORTHFLD\_345\_312**

Wed 04/15/2015 to Thu 04/16/2015  
0700 Continuous 1700

Work scheduled by: NGrid

UPDATED by ISONE 04/10/2015

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**SCH-NE-NYISO\_LIMIT\_500**

Wed 04/15/2015 to Thu 04/16/2015  
0700 Continuous 1700

Work scheduled by: NGrid

UPDATED by ISONE 04/10/2015

	FWD
	(Import)
SCH - NE - NY	<b>700 MW</b>
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1400 MW

**SCH-NYISO-NE\_LIMIT\_700**

Wed 04/15/2015 to Thu 04/16/2015  
0700 Continuous 1700

Work scheduled by: NGrid

UPDATED by ISONE 04/10/2015

		REV
		(Export)
SCH - NE - NY		<b>900 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1600 MW

**STOLLERD-HISHELDN\_230\_67**

Wed 04/15/2015 to Wed 04/15/2015  
1000 Continuous 1015

Work scheduled by: NYSEG

CANCELLED by NYSEG 04/15/2015

	FWD
	(Import)
DYSINGER EAST	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Wed 04/15/2015 to Wed 04/15/2015  
1900 Continuous 1930

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_-TREMONT\_\_345\_X28**

FWD

Thu 04/16/2015 to Thu 04/16/2015 **UPDATED** **by CONED** **04/16/2015**

(Import)

0001 Continuous 1100

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**EFISHKIL-WOOD\_ST\_\_345\_F38**

FWD

Thu 04/16/2015 to Sun 04/19/2015 **UPDATED** **by CE** **02/26/2015**

(Import)

0001 Continuous 1930

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

FWD

Thu 04/16/2015 to Sun 04/19/2015 **UPDATED** **by CE** **02/26/2015**

(Import)

0001 Continuous 1930

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**MARCY\_-COOPERS\_\_345\_UC2-41**

FWD

Fri 04/17/2015 to Mon 04/20/2015 **UPDATED** **by NYISO** **04/19/2015**

(Import)

1531 Continuous 0659

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

**CHATGUAY-MASSENA\_\_765\_7040**

FWD

Sat 04/18/2015 to Sat 04/18/2015

(Import)

0100 Continuous 1700

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA\_\_765\_7040**

FWD

REV

Sat 04/18/2015 to Sat 04/18/2015

(Import) (Export)

0100 Continuous 1700

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**CHAT\_DC\_GC2**

FWD

Sat 04/18/2015 to Sat 04/18/2015

(Import)

0600 Continuous 1800

MOSES SOUTH

**2150 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC2**

REV

Sat 04/18/2015 to Sat 04/18/2015  
 0600 Continuous 1800

Work scheduled by: HQ

SCH - HQ - NY

(Export)

Impacts Total Transfer Capability

**500 MW**

TTC with All Lines In Service

500 MW

1000 MW

**SCH-HQ-NYISO\_LIMIT\_1400**

FWD

Sat 04/18/2015 to Sun 04/19/2015  
 0600 Continuous 0659

Work scheduled by: NYISO

**UPDATED****by NYISO 04/19/2015**

(Import)

SCH - HQ - NY

**1400 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1500 MW

**HUDSONP\_-FARRAGUT\_345\_C3403**

FWD

REV

Sun 04/19/2015 to Fri 04/24/2015  
 2011 Continuous 2359

Work scheduled by: PJM

**FORCED****by PJM 04/20/2015**

(Import) (Export)

SCH - PJ - NY

**2450 MW 1300 MW**

Impacts Total Transfer Capability

0 MW

0 MW

TTC with All Lines In Service

2450 MW

1300 MW

**NRTH1385-NOR HBR\_138\_601**

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015  
 0500 Continuous 1700

Work scheduled by: LI

**UPDATED****by NYISO 04/16/2015**

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

**NRTH1385-NOR HBR\_138\_601 & NRTH1385-NOR HBR\_138\_602**

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015  
 0500 1700

Work scheduled by:

SCH - NPX\_1385

**0 MW****0 MW**

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

**NRTH1385-NOR HBR\_138\_601 & NRTH1385-NOR HBR\_138\_603**

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015  
 0500 1700

Work scheduled by:

SCH - NPX\_1385

**0 MW****0 MW**

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

**NRTH1385-NOR HBR\_138\_602**

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015  
 0500 Continuous 1700

Work scheduled by: LI

**UPDATED****by NYISO 04/16/2015**

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 04/20/2015 to Thu 04/30/2015  
0500 1700

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_603

Mon 04/20/2015 to Thu 04/30/2015  
0500 Continuous 1700

Work scheduled by: LI

UPDATED by NYISO 04/16/2015

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NRTHPORT\_138\_1385

Mon 04/20/2015 to Thu 04/30/2015  
0500 Continuous 1700

Work scheduled by: LI

UPDATED by NYISO 04/16/2015

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

ROCHESTR-PANNELL\_\_345\_RP2

Mon 04/20/2015 to Fri 05/01/2015  
0700 Continuous 1600

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

ROSETON\_-EFISHKIL\_345\_305

Mon 04/20/2015 to Mon 04/20/2015  
0800 Daily(No Weekends) 1600

Work scheduled by: CHGE

CANCELLED by CHGE 04/17/2015

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

LIND\_CG\_-LNDVFT\_\_345\_V-3022

Tue 04/21/2015 to Wed 04/22/2015  
0900 Continuous 1400

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT 0 MW 0 MW  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

EASTVIEW-SPRNBK\_\_345\_W64

Wed 04/22/2015 to Wed 04/22/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W99**

FWD

Wed 04/22/2015 to Sat 04/25/2015

(Import)

0001 Continuous 1930

UPNY CONED

**4350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

**NEWBRIDGE\_345\_138\_BK\_2**

FWD

Wed 04/22/2015 to Wed 04/22/2015

(Import)

0530 Continuous 2000

SCH - PJM\_NEPTUNE

**375 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**BECK\_\_\_\_-NIAGARA\_345\_PA302**

FWD

REV

Thu 04/23/2015 to Fri 04/24/2015

(Import) (Export)

0400 Continuous 1700

UPDATEDby NYPA04/16/2015

SCH - OH - NY

**1400 MW 1250 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Sat 04/25/2015 to Sat 04/25/2015

(Import)

0700 Daily 1600

UPDATEDby NTISO04/20/2015

CENTRAL EAST - VC

**2720 MW**

Work scheduled by: CHGE

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

**EASTVIEW-SPRNBK\_345\_W64**

FWD

Sat 04/25/2015 to Sat 04/25/2015

(Import)

1900 Continuous 1930

UPNY CONED

**4350 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

**LEEDS\_\_\_\_345\_LEEDS SVC**

FWD

Mon 04/27/2015 to Fri 05/01/2015

(Import)

0700 Continuous 1500

CENTRAL EAST - VC

**2950 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

**FRASER\_-GILBOA\_345\_GF5-35**

FWD

Mon 04/27/2015 to Fri 05/08/2015

(Import)

0700 Continuous 1530

UPDATEDby NYPA01/09/2015

CENTRAL EAST - VC

**2650 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

FWD

Tue 04/28/2015 to Tue 04/28/2015 UPDATED by CONED 03/17/2015

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**329 MW**

Impacts Total Transfer Capability 331 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SPRNBRK\_-W49TH\_ST\_345\_M52**

FWD

Tue 04/28/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015

(Import)

0001 Continuous 2300

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**SPRNBRK\_\_345KV\_RNS4**

FWD

Tue 04/28/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015

(Import)

0001 Continuous 2300

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_5**

FWD

Sun 05/03/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015

(Import)

2230 Continuous 2300

SCH - PJM\_HTP

**315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SPRNBRK\_\_345KV\_RNS5**

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_5**

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EASTVIEW-SPRNBK\_\_345\_W64**

Mon 05/04/2015 to Tue 05/05/2015

0001 Continuous 2000

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Mon 05/04/2015 to Tue 05/05/2015

0001 Continuous 2000

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/04/2015 to Tue 05/12/2015

0600 Continuous 2100

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/04/2015 to Tue 05/12/2015

0600 Continuous 2100

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/04/2015 to Tue 05/12/2015

0600 Continuous 2100

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/04/2015 to Tue 05/12/2015

0600 Continuous 2100

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**SCH-NE-NYISO\_LIMIT\_900**

Mon 05/04/2015 to Thu 05/21/2015

0600 Continuous 1700

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY

**1100 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW



# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MAl

FWD

Mon 05/04/2015 to Fri 05/08/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## CHATGUAY-MASSENA\_\_\_765\_7040

FWD

Mon 05/04/2015 to Fri 05/22/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## CHATGUAY-MASSENA\_\_\_765\_7040

FWD

REV

Mon 05/04/2015 to Fri 05/22/2015

(Import) (Export)

0700 Continuous 1530

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

## HOMER C\_-WATRCURE\_345\_30

FWD

REV

Mon 05/04/2015 to Thu 05/28/2015

(Import) (Export)

0800 Continuous 1600

UPDATEDby PJM03/24/2015

SCH - PJ - NY

**2200 MW****1300 MW**

Impacts Total Transfer Capability 250 MW 0 MW

TTC with All Lines In Service 2450 MW 1300 MW

Work scheduled by: NYSEG

## HUDSONP\_-FARRAGUT\_345\_B3402

FWD

REV

Tue 05/05/2015 to Thu 05/14/2015

(Import) (Export)

0001 Continuous 2300

SCH - PJ - NY

**2300 MW****1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2450 MW 1300 MW

Work scheduled by: ConEd

## SPRNBRK\_\_\_345KV\_RNS5

FWD

Tue 05/05/2015 to Tue 05/05/2015

(Import)

1930 Continuous 2000

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## DUNWODIE-SHORE\_RD\_345\_Y50

FWD

Wed 05/06/2015 to Thu 05/07/2015

(Import)

0001 Continuous 2359

CONED - LIPA

**800 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHORE\_RD\_345\_138\_BK 1

Wed 05/06/2015 to Thu 05/07/2015  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK 2

Wed 05/06/2015 to Wed 05/13/2015  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### W49TH\_ST\_345KV\_5

Wed 05/06/2015 to Wed 05/06/2015  
1830 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_7

Wed 05/06/2015 to Wed 05/06/2015  
1830 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

### MILLWOOD-EASTVIEW\_345\_W82

Fri 05/08/2015 to Fri 05/08/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

### SPRNBRK\_\_345KV\_RNS4

Fri 05/08/2015 to Fri 05/08/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### EASTVIEW-SPRNBRK\_\_345\_W65

Fri 05/08/2015 to Sun 05/10/2015  
0001 Continuous 2000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_BK 1				FWD	
Sat 05/09/2015	to	Sun 05/10/2015		(Import)	
0700	Continuous	2030		MOSES SOUTH	1750 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
MARCY____765_345_BK 2				FWD	
Sat 05/09/2015	to	Sun 05/10/2015		(Import)	
0700	Continuous	2030		MOSES SOUTH	1700 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY____765_MSU1				FWD	
Sat 05/09/2015	to	Sun 05/10/2015		(Import)	
0700	Continuous	2030		CENTRAL EAST - VC	2315 MW
Work scheduled by: NYPA			ARR: 20	Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	2975 MW
MASSENA_-MARCY____765_MSU1				FWD	
Sat 05/09/2015	to	Sun 05/10/2015		(Import)	
0700	Continuous	2030		MOSES SOUTH	675 MW
Work scheduled by: NYPA			ARR: 20	Impacts Total Transfer Capability	2475 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY____765_MSU1				FWD	REV
Sat 05/09/2015	to	Sun 05/10/2015		(Import)	(Export)
0700	Continuous	2030		SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			ARR: 20	Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA_765_7040					
Sat 05/09/2015	to	Sun 05/10/2015		MOSES SOUTH	
0700		2030		Impacts Total Transfer Capability	
Work scheduled by:			ARR: 20	TTC with All Lines In Service	
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	REV
Sat 05/09/2015	to	Sun 05/10/2015		(Import)	(Export)
0700		2030		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:			ARR: 20	Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MILLWOOD-EASTVIEW\_345\_W82

Sun 05/10/2015 to Sun 05/10/2015  
1930 Continuous 2000  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## SPRNBRK\_345KV\_RNS4

Sun 05/10/2015 to Sun 05/10/2015  
1930 Continuous 2000  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLY\_345KV\_RNS4

Mon 05/11/2015 to Mon 05/11/2015  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLY-WOOD\_ST\_345\_F31

Mon 05/11/2015 to Tue 05/12/2015  
0001 Continuous 1800  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## MOSES\_-ADIRNDCK\_230\_MAI

Mon 05/11/2015 to Fri 05/15/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

## LOWVILLE-BOONVILLE\_115\_5-LB

Mon 05/11/2015 to Fri 06/12/2015  
0800 Continuous 1800  
Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **130 MW 40 MW**  
Impacts Total Transfer Capability 60 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

ARR: 38

## EDIC\_-FRASER\_345\_EF24-40

Mon 05/11/2015 to Fri 05/15/2015  
0900 Continuous 1530  
Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RNS4

Tue 05/12/2015 to Tue 05/12/2015  
1730 Continuous 1800  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLY\_345KV\_RNS4

Wed 05/13/2015 to Wed 05/13/2015  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLY-WOOD\_ST\_345\_F31

Wed 05/13/2015 to Wed 05/13/2015  
0001 Continuous 2000  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## SHOR\_NPX-SHOREHAM\_138\_NPX\_CSC

Wed 05/13/2015 to Sun 05/17/2015  
0500 Continuous 1500  
Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

## PLSNTVLY\_345KV\_RNS4

Wed 05/13/2015 to Wed 05/13/2015  
1930 Continuous 2000  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## PORTER\_-ROTTRDAM\_230\_31-PR

Fri 05/15/2015 to Sun 05/17/2015  
0600 Continuous 1800  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## HUDSONP\_-FARRAGUT\_345\_C3403

Sat 05/16/2015 to Mon 05/25/2015  
0200 Continuous 2300  
Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2300 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2450 MW	1300 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 05/18/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2000 MW  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

## STLAWRNC-MOSES\_\_\_230\_L33P

Mon 05/18/2015 to Fri 05/22/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY 1750 MW 1750 MW  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## MARCY\_\_\_-COOPERS\_\_\_345\_UC2-41

Tue 05/19/2015 to Fri 05/22/2015 UPDATED by NYISO 04/10/2015  
0900 Daily 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## SCH-HQ-NYISO\_LIMIT\_1400

Tue 05/19/2015 to Fri 05/22/2015 UPDATED by NYISO 04/10/2015  
0900 Daily 1600

Work scheduled by: NYSEG

FWD  
(Import)  
SCH - HQ - NY 1400 MW  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1500 MW

## CLAY\_\_\_-EDIC\_\_\_345\_1-16

Thu 05/21/2015 to Fri 05/22/2015 UPDATED by NYISO 03/13/2015  
0700 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT 4850 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## FROST\_BR-LONG\_MTN\_345\_352

Fri 05/22/2015 to Sun 05/31/2015  
0600 Continuous 1500

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY 1150 MW 1600 MW  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## CLAY\_\_\_-EDIC\_\_\_345\_2-15

Tue 05/26/2015 to Wed 05/27/2015 UPDATED by NGRID 03/13/2015  
0700 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT 4850 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**STLAWRNC-MOSES\_\_\_230\_L34P**

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**ROCKTVRN-RAMAPO\_\_\_345\_77**

Sat 05/30/2015 to Sat 06/06/2015  
0600 Continuous 2300

Work scheduled by: ORU

FWD  
(Import)  
CENTRAL EAST - VC **2570 MW**  
Impacts Total Transfer Capability 405 MW  
TTC with All Lines In Service 2975 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**PANNELL\_-CLAY\_\_\_345\_PC2**

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Wed 06/03/2015 to Thu 06/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

---

**FRASER\_\_\_345\_FRASER SVC**

Mon 06/15/2015 to Fri 06/19/2015  
0800 Continuous 1430

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_\_-NIAGARA\_\_345\_PA302**

Thu 06/25/2015 to Fri 06/26/2015  
0500 Continuous 1600

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1200 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

Thu 08/13/2015 to Thu 08/13/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

Tue 08/18/2015 to Tue 08/18/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

**ADIRNDCK-PORTER\_\_\_\_230\_12-AP**

Wed 08/19/2015 to Wed 08/19/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**ADIRNDCK-CHASLAKE\_230\_13**

Thu 08/20/2015 to Thu 08/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40**

Mon 08/24/2015 to Fri 08/28/2015  
0700 Continuous 1630

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

Mon 08/31/2015 to Fri 09/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_BK 2</b>				FWD	
Mon 09/07/2015	to	Fri 09/11/2015		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>HURLYAVE-ROSETON___345_303</b>				FWD	
Mon 09/07/2015	to	Fri 09/25/2015		(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
<b>NIAGARA___345_230_BK 4</b>				FWD	REV
Mon 09/07/2015	to	Fri 10/09/2015		(Import)	(Export)
0800	Continuous	1530		SCH - OH - NY	<b>1900 MW 1900 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	1900 MW 1900 MW
<b>MOSES___-ADIRNDCK_230_MA2</b>				FWD	
Mon 09/14/2015	to	Fri 09/18/2015		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW
				TTC with All Lines In Service	3150 MW
<b>COOPERS_-MIDDLETP_345_CMT-34</b>				FWD	
Mon 09/14/2015	to	Fri 09/18/2015		(Import)	
0700	Continuous	1600		CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
<b>MOSES___-ADIRNDCK_230_MA1</b>				FWD	
Mon 09/21/2015	to	Fri 09/25/2015		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW
				TTC with All Lines In Service	3150 MW
<b>COOPERS_-ROCKTVRN_345_CRT-42</b>				FWD	
Mon 09/21/2015	to	Fri 09/25/2015		(Import)	
0700	Continuous	1600		CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-PLSNTVLY\_345\_398

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700  
Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	500 MW	1300 MW
Impacts Total Transfer Capability	900 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

### LONG\_MTN-PLSNTVLY\_345\_398

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700  
Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### BECK\_\_\_\_-NIAGARA\_345\_PA302

Thu 09/24/2015 to Fri 09/25/2015  
0500 Continuous 1600  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1200 MW	1100 MW
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

### PLSNTVLE-DUNWODIE\_345\_W89

Mon 09/28/2015 to Mon 09/28/2015  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 09/28/2015 to Fri 10/02/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2000 MW
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

### BECK\_\_\_\_-NIAGARA\_345\_PA301

Mon 09/28/2015 to Fri 10/02/2015  
0800 Continuous 1600  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1200 MW	1100 MW
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

### COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 09/28/2015 to Fri 10/02/2015  
0900 Daily 1600  
Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2720 MW
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Fri 10/02/2015 to Fri 10/02/2015

(Import)

1830 Continuous 1900

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**CHATGUAY-MASSENA\_765\_7040**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

**UPDATED****by NYPA****10/07/2014**

0100 Continuous 1730

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA\_765\_7040**

FWD

REV

Sat 10/03/2015 to Sun 10/25/2015

(Import) (Export)

**UPDATED****by NYPA****10/07/2014**

0100 Continuous 1730

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**MARCY\_765\_345\_BK 1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

**UPDATED****by NYPA****10/07/2014**

0100 Continuous 1730

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_765\_345\_BK 2**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

**UPDATED****by NYPA****10/07/2014**

0100 Continuous 1730

MOSES SOUTH

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****MASSENA\_-MARCY\_765\_MSU1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

**UPDATED****by NYPA****10/07/2014**

0100 Continuous 1730

CENTRAL EAST - VC

**2315 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 20****MASSENA\_-MARCY\_765\_MSU1**

FWD

Sat 10/03/2015 to Sun 10/25/2015

(Import)

**UPDATED****by NYPA****10/07/2014**

0100 Continuous 1730

MOSES SOUTH

**675 MW**

Impacts Total Transfer Capability 2475 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 20**

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>MASSENA_-MARCY_765_MSU1</b>						
Sat 10/03/2015	to	Sun 10/25/2015	<b>UPDATED</b>	<b>by NYPA 10/07/2014</b>	SCH - HQ - NY	<b>475 MW 1000 MW</b>
0100	Continuous	1730			Impacts Total Transfer Capability	1025 MW 0 MW
Work scheduled by: NYPA					TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						
Sat 10/03/2015	to	Sun 10/25/2015			MOSES SOUTH	
0100		1730			Impacts Total Transfer Capability	
Work scheduled by:					TTC with All Lines In Service	
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						
Sat 10/03/2015	to	Sun 10/25/2015			SCH - HQ - NY	<b>850 MW 0 MW</b>
0100		1730			Impacts Total Transfer Capability	650 MW 1000 MW
Work scheduled by:					TTC with All Lines In Service	1500 MW 1000 MW
<b>SHOR_NPX-SHOREHAM_138_NPX_CSC</b>						
Mon 10/05/2015	to	Sun 10/11/2015	<b>UPDATED</b>	<b>by ISONE 07/25/2014</b>	SCH - NPX_CSC	<b>0 MW 0 MW</b>
0530	Continuous	1800			Impacts Total Transfer Capability	330 MW 330 MW
Work scheduled by: LI					TTC with All Lines In Service	330 MW 330 MW
<b>GILBOA_-LEEDS_345_GL3</b>						
Mon 10/05/2015	to	Fri 10/09/2015			CENTRAL EAST - VC	<b>2200 MW</b>
0700	Continuous	1600			Impacts Total Transfer Capability	775 MW
Work scheduled by: NYPA					TTC with All Lines In Service	2975 MW
<b>BECK_-PACKARD_230_BP76</b>						
Mon 10/05/2015	to	Fri 10/09/2015			SCH - OH - NY	<b>1750 MW 1200 MW</b>
0800	Continuous	1600			Impacts Total Transfer Capability	150 MW 700 MW
Work scheduled by: NGrid					TTC with All Lines In Service	1900 MW 1900 MW
<b>MALONE_-WILLIS_115_1-MW</b>						
Tue 10/06/2015	to	Tue 10/06/2015			SCH - HQ_CEDARS	<b>40 MW</b>
0800	Continuous	1530			Impacts Total Transfer Capability	0 MW
Work scheduled by: NYPA					TTC with All Lines In Service	40 MW

ARR: 20&amp;38

# NYISO TRANSFER LIMITATIONS

Monday ,April 20, 2015 to Wednesday,October 19, 2016

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GILBOA\_\_-N.SCTLND\_345\_GNS1

FWD

Mon 10/12/2015 to Fri 10/30/2015

(Import)

0730 Continuous 1500

Work scheduled by: NGrid

CENTRAL EAST - VC

2520 MW

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

## LEEDS\_\_-HURLYAVE\_345\_301

FWD

Mon 10/12/2015 to Fri 10/30/2015

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

## GOETHALS-LINDN\_CG\_345\_G23L &amp; GOETHALS-LINDN\_CG\_345\_G23M

FWD

REV

Tue 10/20/2015 to Fri 10/23/2015

(Import) (Export)

0001 2359

Work scheduled by:

SCH - PJM\_VFT

0 MW

315 MW

Impacts Total Transfer Capability 315 MW 0 MW

TTC with All Lines In Service 315 MW 315 MW

## CLAY\_\_-EDIC\_\_345\_2-15

FWD

Mon 10/26/2015 to Tue 10/27/2015

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

UPDATEDby PA03/27/2015

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

FWD

Sat 11/07/2015 to Mon 11/09/2015

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED

4150 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

## ROCKTVRN-RAMAPO\_\_345\_77

FWD

Sat 11/07/2015 to Fri 11/20/2015

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPDATEDby CH12/16/2014

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Sat 11/07/2015 to Fri 11/20/2015

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPDATEDby CH12/16/2014

UPNY CONED

4400 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LIND\_CG\_-LNDVFT\_\_\_345\_V-3022**

Sun 11/08/2015 to Fri 11/13/2015

1400 Continuous 1800

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

**ROCKTVRN-RAMAPO\_\_\_345\_77**

Fri 11/20/2015 to Sat 12/12/2015

1601 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
CENTRAL EAST - VC	<b>2570 MW</b>
Impacts Total Transfer Capability	405 MW
TTC with All Lines In Service	2975 MW

**GOETHALS-LINDN\_CG\_345\_G23L & GOETHALS-LINDN\_CG\_345\_G23M**

Mon 11/23/2015 to Thu 11/26/2015

0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>315 MW</b>
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

Sun 11/29/2015 to Sat 12/05/2015

0001 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4150 MW</b>
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	5100 MW

**BERKSHIR-ALPS\_\_\_345\_393**

Mon 11/30/2015 to Fri 12/04/2015

0600 Continuous 1500

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>1300 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

**BERKSHIR-ALPS\_\_\_345\_393**

Mon 11/30/2015 to Fri 12/04/2015

0600 Continuous 1500

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**MOSES\_-ADIRNDCK\_230\_MAL**

Mon 11/30/2015 to Fri 12/04/2015

0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,April 20, 2015 to Wednesday,October 19, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_-N.SCTLND\_345\_18**

FWD

Wed 12/02/2015 to Wed 12/23/2015 **UPDATED by NGRID 04/17/2015**

(Import)

0700 Continuous 1500

CENTRAL EAST - VC **2090 MW**

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGRID

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 12/07/2015 to Fri 12/11/2015

(Import)

0700 Continuous 1530

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 12/14/2015 to Fri 12/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BECK\_\_\_-NIAGARA\_345\_PA302**

FWD

REV

Thu 12/17/2015 to Fri 12/18/2015

(Import) (Export)

0500 Continuous 1600

SCH - OH - NY **1400 MW 1250 MW**

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**ROCKTVRN-RAMAPO\_\_\_345\_77**

FWD

Mon 04/04/2016 to Fri 04/29/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC **2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE