

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Fri 02/06/2015 to Thu 04/09/2015 **EXT FORCE** **by HQ** **03/12/2015**

0757 Continuous 2259

Work scheduled by: HQ

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

0 MW

100 MW

100 MW

ROCHESTR-PANNELL_345_RP1

Mon 03/30/2015 to Fri 04/03/2015 **UPDATED** **by PA** **03/26/2015**

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

2300 MW

850 MW

3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 03/30/2015 to Thu 04/02/2015 **UPDATED** **by NYPA** **03/23/2015**

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

2000 MW

1150 MW

3150 MW

W49TH_ST_345KV_7

Wed 04/01/2015 to Sun 04/05/2015

0001 Continuous 1900

Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

329 MW

331 MW

660 MW

NINEMILE-CLAY_345_8-NC

Wed 04/01/2015 to Thu 04/02/2015 **CANCELLED** **by NGRID** **03/31/2015**

0400 Continuous 0600

Work scheduled by: NGrid

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

5150 MW

100 MW

5250 MW

W49TH_ST_345KV_5

Thu 04/02/2015 to Thu 04/02/2015

0001 Continuous 1900

Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

329 MW

331 MW

660 MW

CHASLAKE-PORTER_230_11

Fri 04/03/2015 to Fri 04/03/2015 **UPDATED** **by NYISO** **03/13/2015**

0730 Daily(No Weekends) 1000

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

2100 MW

1050 MW

3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-MIDDLETP_345_CMT-34

FWD

Fri 04/03/2015 to Fri 04/03/2015 **CANCELLED by CHGE 04/01/2015**
0800 Daily 1600

Work scheduled by: CHGE

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

NINEMILE-CLAY_345_8-NC

FWD

Fri 04/03/2015 to Sun 04/05/2015
1200 Continuous 1200

Work scheduled by: NGrid

(Import)
OSWEGO EXPORT **5150 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

PLSNTVLE-DUNWODIE_345_W89

FWD

Sat 04/04/2015 to Sat 04/04/2015
0001 Continuous 1930

Work scheduled by: ConEd

(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

OSWEGO_COMPLEX_AVR_O/S

FWD

Sun 04/05/2015 to Sun 04/05/2015
0900 Continuous 1100

Work scheduled by: NYPA

(Import)
CENTRAL EAST - VC **2870 MW**
Impacts Total Transfer Capability 105 MW
TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_6

FWD

Mon 04/06/2015 to Mon 04/06/2015 **UPDATED by CE 04/03/2015**
0001 Continuous 0030

Work scheduled by: ConEd

(Import)
SCH - PJM_HTP **320 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Mon 04/06/2015 to Mon 04/06/2015 **UPDATED by CE 04/03/2015**
0001 Continuous 0030

Work scheduled by: ConEd

(Import)
SCH - PJM_HTP **320 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

PLSNTVLE-DUNWODIE_345_W90

FWD

Mon 04/06/2015 to Sun 04/12/2015
0001 Continuous 1900

Work scheduled by: ConEd

(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

FWD

Mon 04/06/2015 to Mon 04/06/2015 UPDATED by CE 04/03/2015
0430 Continuous 0500

Work scheduled by: ConEd

SCH - PJM_HTP 320 MW
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Mon 04/06/2015 to Mon 04/06/2015 UPDATED by CE 04/03/2015
0430 Continuous 0500

Work scheduled by: ConEd

SCH - PJM_HTP 320 MW
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

MARCY___345_STATCOM SVC

FWD

Mon 04/06/2015 to Thu 04/09/2015 UPDATED by NYPA 03/25/2015
0500 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC 2925 MW
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

CLAY___-EDIC___345_1-16

FWD

Mon 04/06/2015 to Tue 04/07/2015
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT 4850 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 04/06/2015 to Fri 04/10/2015
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

OAKDALE_-FRASER___345_32

FWD

Mon 04/06/2015 to Wed 04/08/2015 UPDATED by NYSEG 02/19/2015
0800 Continuous 1630

Work scheduled by: NYSEG

CENTRAL EAST - VC 2650 MW
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

ROSETON_-ROCKTVRN_345_311

FWD

Mon 04/06/2015 to Fri 04/24/2015
0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED 4400 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Mon 04/06/2015 to Mon 04/06/2015
1930 Continuous 2000

UPDATED

by CE

04/03/2015

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **320 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 04/06/2015 to Mon 04/06/2015
1930 Continuous 2000

UPDATED

by CE

04/03/2015

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **320 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 04/06/2015 to Sat 04/11/2015
2200 Continuous 2100

UPDATED

by CONED

03/31/2015

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

BECK_-NIAGARA_345_PA302

Thu 04/09/2015 to Fri 04/10/2015
0500 Continuous 1600

UPDATED

by NYPA

03/09/2015

Work scheduled by: NYPA

| | |
|-----------------------------------|------------------------|
| FWD | REV |
| (Import) | (Export) |
| SCH - OH - NY | 1400 MW 1250 MW |
| Impacts Total Transfer Capability | 500 MW 650 MW |
| TTC with All Lines In Service | 1900 MW 1900 MW |

OAKDALE_-FRASER_345_32

Thu 04/09/2015 to Thu 04/09/2015
0800 Continuous 1600

UPDATED

by NYSEG

02/19/2015

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

DENNISON-NORFOLK_115_4-DA

Thu 04/09/2015 to Thu 04/09/2015
0830 Daily(No Weekends) 1000

Work scheduled by: NGrid

ARR: 38

| | |
|-----------------------------------|----------------------|
| FWD | REV |
| (Import) | (Export) |
| SCH - HQ_CEDARS | 150 MW 100 MW |
| Impacts Total Transfer Capability | 49 MW 0 MW |
| TTC with All Lines In Service | 199 MW 100 MW |

NORFOLK_-SANDSTON_115_4-NS

Thu 04/09/2015 to Thu 04/09/2015
0830 Daily(No Weekends) 1000

Work scheduled by: NGrid

ARR: 38

| | |
|-----------------------------------|----------------------|
| FWD | REV |
| (Import) | (Export) |
| SCH - HQ_CEDARS | 150 MW 100 MW |
| Impacts Total Transfer Capability | 49 MW 0 MW |
| TTC with All Lines In Service | 199 MW 100 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|----------------------------------|--|--|--|--|-----------------------------------|---------------|
| SANDSTON-COLTON__115_4-SC | | | | | FWD | REV |
| Thu 04/09/2015 to Thu 04/09/2015 | | | | | (Import) | (Export) |
| 0830 Daily(No Weekends) 1000 | | | | | SCH - HQ_CEDARS | 150 MW 100 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 49 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 199 MW 100 MW |
| WOOD_ST_-PLSNTVLE_345_Y87 | | | | | FWD | |
| Mon 04/13/2015 to Mon 04/13/2015 | | | | | (Import) | |
| 0001 Continuous 0030 | | | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 1100 MW |
| | | | | | TTC with All Lines In Service | 5100 MW |
| SPRNBK__345KV_RNS4 | | | | | FWD | |
| Mon 04/13/2015 to Mon 04/13/2015 | | | | | (Import) | |
| 0001 Continuous 1530 | | | | | SPR/DUN-SOUTH | 3200 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| EGRDNCTY_345_138_BK 1 | | | | | FWD | |
| Mon 04/13/2015 to Mon 04/13/2015 | | | | | (Import) | |
| 0001 Continuous 2359 | | | | | CONED - LIPA | 1250 MW |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 250 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| EFISHKIL-WOOD_ST__345_F39 | | | | | FWD | |
| Mon 04/13/2015 to Wed 04/15/2015 | | | | | (Import) | |
| 0001 Continuous 1930 | | | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 1100 MW |
| | | | | | TTC with All Lines In Service | 5100 MW |
| PANNELL_-CLAY____345_PC1 | | | | | FWD | |
| Mon 04/13/2015 to Tue 04/14/2015 | | | | | (Import) | |
| 0700 Continuous 1530 | | | | | WEST CENTRAL | 1300 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 950 MW |
| | | | | | TTC with All Lines In Service | 2250 MW |
| MARCY____-COOPERS__345_UC2-41 | | | | | FWD | |
| Mon 04/13/2015 to Fri 04/17/2015 | | | | | (Import) | |
| 0700 Continuous 1530 | | | | | CENTRAL EAST - VC | 2500 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 475 MW |
| | | | | | TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|--|------------|----------------|----------------|-----------------------------------|-----------------------------------|------------------------|
| LOWVILLE-BOONVILLE_115_5-LB | | | | | FWD | REV |
| Mon 04/13/2015 | to | Fri 05/08/2015 | | | (Import) | (Export) |
| 0800 | Continuous | 1800 | | | SCH - HQ_CEDARS | 199 MW 100 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 0 MW 0 MW |
| ARR: 38 | | | | | TTC with All Lines In Service | 199 MW 100 MW |
| EGRDNCTY_345_138_BK 2 | | | | | FWD | |
| Tue 04/14/2015 | to | Tue 04/14/2015 | <u>UPDATED</u> | <u>by LI</u> <u>03/27/2015</u> | (Import) | |
| 0001 | Continuous | 2359 | | | CONED - LIPA | 1250 MW |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 250 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| SPRNBK_-TREMONT_345_X28 | | | | | FWD | |
| Tue 04/14/2015 | to | Tue 04/14/2015 | <u>UPDATED</u> | <u>by CONED</u> <u>03/13/2015</u> | (Import) | |
| 0001 | Continuous | 2359 | | | SPR/DUN-SOUTH | 4200 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| BERKSHIR-ALPS_____345_393 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by NE</u> <u>01/30/2015</u> | (Import) | (Export) |
| 0700 | Continuous | 1700 | | | SCH - NE - NY | 1300 MW 1300 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 100 MW 300 MW |
| | | | | | TTC with All Lines In Service | 1400 MW 1600 MW |
| BERKSHIR-ALPS_____345_393 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by NE</u> <u>01/30/2015</u> | (Import) | (Export) |
| 0700 | Continuous | 1700 | | | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | | TTC with All Lines In Service | 200 MW 200 MW |
| BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | | | (Import) | (Export) |
| 0700 | | 1700 | | | SCH - NE - NY | 1300 MW 1300 MW |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 100 MW 300 MW |
| | | | | | TTC with All Lines In Service | 1400 MW 1600 MW |
| BERKSHIR-NORTHFLD_345_312 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by NE</u> <u>01/30/2015</u> | (Import) | (Export) |
| 0700 | Continuous | 1700 | | | SCH - NE - NY | 1400 MW 1450 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 0 MW 150 MW |
| | | | | | TTC with All Lines In Service | 1400 MW 1600 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | FWD | REV |
|-----------------------------------|------------|----------------|----------------|--------------|-------------------|-----------------------------------|----------------|
| | | | | | | (Import) | (Export) |
| BERKSHIR-NORTHFLD_345_312 | | | | | | | |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by NE</u> | <u>01/30/2015</u> | SCH - NPX_1385 | 100 MW |
| 0700 | Continuous | 1700 | | | | Impacts Total Transfer Capability | 100 MW |
| Work scheduled by: NGrid | | | | | | TTC with All Lines In Service | 200 MW |
| STOLLERD-HISHELDN_230_67 | | | | | | FWD | |
| Wed 04/15/2015 | to | Wed 04/15/2015 | | | | (Import) | |
| 1000 | Continuous | 1015 | | | | DYSINGER EAST | 2850 MW |
| Work scheduled by: NYSEG | | | | | | Impacts Total Transfer Capability | 300 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |
| WOOD_ST_-PLSNTVLE_345_Y87 | | | | | | FWD | |
| Wed 04/15/2015 | to | Wed 04/15/2015 | | | | (Import) | |
| 1900 | Continuous | 1930 | | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 1100 MW |
| | | | | | | TTC with All Lines In Service | 5100 MW |
| WOOD_ST_-PLSNTVLE_345_Y86 | | | | | | FWD | |
| Thu 04/16/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by CE</u> | <u>02/26/2015</u> | (Import) | |
| 0001 | Continuous | 0030 | | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 1100 MW |
| | | | | | | TTC with All Lines In Service | 5100 MW |
| EFISHKIL-WOOD_ST__345_F38 | | | | | | FWD | |
| Thu 04/16/2015 | to | Sun 04/19/2015 | <u>UPDATED</u> | <u>by CE</u> | <u>02/26/2015</u> | (Import) | |
| 0001 | Continuous | 1930 | | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 1100 MW |
| | | | | | | TTC with All Lines In Service | 5100 MW |
| WOOD_ST_-PLSNTVLE_345_Y86 | | | | | | FWD | |
| Fri 04/17/2015 | to | Sun 04/19/2015 | <u>UPDATED</u> | <u>by CE</u> | <u>02/26/2015</u> | (Import) | |
| 0001 | Continuous | 1930 | | | | UPNY CONED | 4000 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 1100 MW |
| | | | | | | TTC with All Lines In Service | 5100 MW |
| CHATGUAY-MASSENA__765_7040 | | | | | | FWD | |
| Sat 04/18/2015 | to | Sat 04/18/2015 | | | | (Import) | |
| 0100 | Continuous | 1700 | | | | MOSES SOUTH | 1550 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1600 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | |
|---|------------|----------------|-----------------------------------|-----------------|
| CHATGUAY-MASSENA__765_7040 | | | FWD | REV |
| Sat 04/18/2015 | to | Sat 04/18/2015 | (Import) | (Export) |
| 0100 | Continuous | 1700 | SCH - HQ - NY | 0 MW 0 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 1500 MW 1000 MW |
| | | | TTC with All Lines In Service | 1500 MW 1000 MW |
| NRTH1385-NOR HBR__138_601 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | Continuous | 1500 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | | 1500 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | | 1500 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_602 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | Continuous | 1500 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | | 1500 | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR__138_603 | | | FWD | REV |
| Mon 04/20/2015 | to | Thu 04/30/2015 | (Import) | (Export) |
| 0500 | Continuous | 1500 | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: LI | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | TTC with All Lines In Service | 200 MW 200 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NRTHPORT_138_1385

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1500
Work scheduled by: LI

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - NPX_1385 | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

SCH-NYISO-IMO_NIAGARA_CB_3002

Mon 04/20/2015 to Tue 04/21/2015 **UPDATED by NYISO 04/02/2015**
0700 Continuous 1530
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - OH - NY | 1800 MW | 1700 MW |
| Impacts Total Transfer Capability | 100 MW | 200 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

ROCHESTR-PANNELL_345_RP2

Mon 04/20/2015 to Fri 05/01/2015
0700 Continuous 1600
Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| DYSINGER EAST | 2300 MW |
| Impacts Total Transfer Capability | 850 MW |
| TTC with All Lines In Service | 3150 MW |

ROSETON_-EFISHKIL_345_305

Mon 04/20/2015 to Mon 04/20/2015
0800 Daily(No Weekends) 1600
Work scheduled by: CHGE

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| UPNY CONED | 4100 MW |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

LIND_CG_-LNDVFT_345_V-3022

Tue 04/21/2015 to Wed 04/22/2015
0900 Continuous 1400
Work scheduled by: PJM

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

EASTVIEW-SPRNBRK_345_W64

Wed 04/22/2015 to Wed 04/22/2015
0001 Continuous 0030
Work scheduled by: ConEd

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| UPNY CONED | 4350 MW |
| Impacts Total Transfer Capability | 750 MW |
| TTC with All Lines In Service | 5100 MW |

MILLWOOD-EASTVIEW_345_W99

Wed 04/22/2015 to Sat 04/25/2015
0001 Continuous 1930
Work scheduled by: ConEd

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| UPNY CONED | 4350 MW |
| Impacts Total Transfer Capability | 750 MW |
| TTC with All Lines In Service | 5100 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK 345_W64

Sat 04/25/2015 to Sat 04/25/2015
1900 Continuous 1930
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

LEEDS 345_LEEDS SVC

Mon 04/27/2015 to Fri 05/01/2015
0700 Continuous 1500
Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2950 MW**
Impacts Total Transfer Capability 25 MW
TTC with All Lines In Service 2975 MW

ROCHESTR-PANNELL 345_RP2

Mon 04/27/2015 to Fri 05/01/2015 CANCELLED by NYPA 03/31/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FRASER -GILBOA 345_GF5-35

Mon 04/27/2015 to Fri 05/08/2015 UPDATED by NYPA 01/09/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_5

Tue 04/28/2015 to Tue 04/28/2015 UPDATED by CONED 03/17/2015
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **329 MW**
Impacts Total Transfer Capability 331 MW
TTC with All Lines In Service 660 MW

SPRNBK -W49TH_ST_345_M52

Tue 04/28/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015
0001 Continuous 2300
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBK 345KV_RNS4

Tue 04/28/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015
0001 Continuous 2300
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

FWD

Sun 05/03/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015

(Import)

2230 Continuous 2300

SCH - PJM_HTP **315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

SPRNBK__345KV_RNS5

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH **3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_5

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM_HTP **315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_7

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM_HTP **315 MW**

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK__345_W64

FWD

Mon 05/04/2015 to Tue 05/05/2015

(Import)

0001 Continuous 2000

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW_345_W99

FWD

Mon 05/04/2015 to Tue 05/05/2015

(Import)

0001 Continuous 2000

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

NEPTUNE_-DUFFYAVE_345_NEPTUNE

FWD

Mon 05/04/2015 to Tue 05/12/2015

(Import)

0600 Continuous 2100

SCH - PJM_NEPTUNE **0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE 0 MW
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE 375 MW
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE 375 MW
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

SCH-NE-NYISO_LIMIT_900

Mon 05/04/2015 to Thu 05/21/2015
0600 Continuous 1700

Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY 1100 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 1400 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 05/04/2015 to Tue 05/05/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA1

Mon 05/04/2015 to Fri 05/08/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Mon 05/04/2015 to Fri 05/22/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 1550 MW
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Mon 05/04/2015 to Fri 05/22/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - HQ - NY | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

HOMER C_-WATRCURE_345_30

Mon 05/04/2015 to Thu 05/28/2015
0800 Continuous 1600

Work scheduled by: NYSEG

UPDATED by PJM 03/24/2015

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - PJ - NY | 2200 MW | 1300 MW |
| Impacts Total Transfer Capability | 250 MW | 0 MW |
| TTC with All Lines In Service | 2450 MW | 1300 MW |

HUDSONP_-FARRAGUT_345_B3402

Tue 05/05/2015 to Thu 05/14/2015
0001 Continuous 2300

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - PJ - NY | 2300 MW | 1300 MW |
| Impacts Total Transfer Capability | 150 MW | 0 MW |
| TTC with All Lines In Service | 2450 MW | 1300 MW |

SPRNBRK__345KV_RNS5

Tue 05/05/2015 to Tue 05/05/2015
1930 Continuous 2000

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| SPR/DUN-SOUTH | 3200 MW |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 4600 MW |

DUNWODIE-SHORE_RD_345_Y50

Wed 05/06/2015 to Thu 05/07/2015
0001 Continuous 2359

Work scheduled by: LI

| | FWD |
|-----------------------------------|---------------|
| | (Import) |
| CONED - LIPA | 800 MW |
| Impacts Total Transfer Capability | 700 MW |
| TTC with All Lines In Service | 1500 MW |

SHORE_RD_345_138_BK 1

Wed 05/06/2015 to Thu 05/07/2015
0001 Continuous 2359

Work scheduled by: LI

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| CONED - LIPA | 1350 MW |
| Impacts Total Transfer Capability | 150 MW |
| TTC with All Lines In Service | 1500 MW |

SHORE_RD_345_138_BK 2

Wed 05/06/2015 to Wed 05/13/2015
0001 Continuous 2359

Work scheduled by: LI

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| CONED - LIPA | 1350 MW |
| Impacts Total Transfer Capability | 150 MW |
| TTC with All Lines In Service | 1500 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

FWD

Wed 05/06/2015 to Wed 05/06/2015

(Import)

1830 Continuous 1900

SCH - PJM_HTP

315 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

FWD

Wed 05/06/2015 to Wed 05/06/2015

(Import)

1830 Continuous 1900

SCH - PJM_HTP

315 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

MILLWOOD-EASTVIEW_345_W82

FWD

Fri 05/08/2015 to Fri 05/08/2015

(Import)

0001 Continuous 0030

UPNY CONED

4350 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS4

FWD

Fri 05/08/2015 to Fri 05/08/2015

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

3200 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W65

FWD

Fri 05/08/2015 to Sun 05/10/2015

(Import)

0001 Continuous 2000

UPNY CONED

4350 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

MARCY____765_345_BK 1

FWD

Sat 05/09/2015 to Sun 05/10/2015

(Import)

0700 Continuous 2030

MOSES SOUTH

1750 MW

Work scheduled by: NYPA

ARR: 19

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

MARCY____765_345_BK 2

FWD

Sat 05/09/2015 to Sun 05/10/2015

(Import)

0700 Continuous 2030

MOSES SOUTH

1700 MW

Work scheduled by: NYPA

ARR: 19

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030

Work scheduled by: NYPA

ARR: 20

FWD
(Import)
CENTRAL EAST - VC **2315 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030

Work scheduled by: NYPA

ARR: 20

FWD
(Import)
MOSES SOUTH **675 MW**
Impacts Total Transfer Capability 2475 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030

Work scheduled by: NYPA

ARR: 20

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA___765_7040

Sat 05/09/2015 to Sun 05/10/2015
0700 2030

Work scheduled by:

ARR: 20

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

MILLWOOD-EASTVIEW_345_W82

Sun 05/10/2015 to Sun 05/10/2015
1930 Continuous 2000

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK___345KV_RNS4

Sun 05/10/2015 to Sun 05/10/2015
1930 Continuous 2000

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

PLSNTVLY_345KV_RNS4

Mon 05/11/2015 to Mon 05/11/2015
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F31

FWD

Mon 05/11/2015 to Tue 05/12/2015

(Import)

0001 Continuous 1800

UPNY CONED

4000 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

MOSES__-ADIRNDCK_230_MAI

FWD

Mon 05/11/2015 to Fri 05/15/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

LOWVILLE-BOONVILLE_115_5-LB

FWD

REV

Mon 05/11/2015 to Fri 06/12/2015

(Import) (Export)

0800 Continuous 1800

SCH - HQ_CEDARS

130 MW 40 MW

Work scheduled by: NGrid

ARR: 38

Impacts Total Transfer Capability 60 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

EDIC__-FRASER__345_EF24-40

FWD

Mon 05/11/2015 to Fri 05/15/2015

(Import)

0900 Continuous 1530

CENTRAL EAST - VC

2500 MW

Work scheduled by: NYSEG

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

PLSNTVLY_345KV_RNS4

FWD

Tue 05/12/2015 to Tue 05/12/2015

(Import)

1730 Continuous 1800

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS4

FWD

Wed 05/13/2015 to Wed 05/13/2015

(Import)

0001 Continuous 0030

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

PLSNTVLY-WOOD_ST__345_F31

FWD

Wed 05/13/2015 to Wed 05/13/2015

(Import)

0001 Continuous 2000

UPNY CONED

4000 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_NPX_CSC

Wed 05/13/2015 to Sun 05/17/2015
0500 Continuous 1500

Work scheduled by: LI

| | FWD | REV |
|-----------------------------------|-------------|-------------|
| | (Import) | (Export) |
| SCH - NPX_CSC | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

PLSNTVLY_345KV_RNS4

Wed 05/13/2015 to Wed 05/13/2015
1930 Continuous 2000

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| UPNY CONED | 3800 MW |
| Impacts Total Transfer Capability | 1300 MW |
| TTC with All Lines In Service | 5100 MW |

HUDSONP_-FARRAGUT_345_C3403

Sat 05/16/2015 to Mon 05/25/2015
0200 Continuous 2300

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - PJ - NY | 2300 MW | 1300 MW |
| Impacts Total Transfer Capability | 150 MW | 0 MW |
| TTC with All Lines In Service | 2450 MW | 1300 MW |

MOSES_-ADIRNDCK_230_MA2

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

STLAWRNC-MOSES_230_L33P

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - OH - NY | 1750 MW | 1750 MW |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

MARCY_-COOPERS_345_UC2-41

Tue 05/19/2015 to Fri 05/22/2015
0900 Daily 1600

Work scheduled by: NYSEG

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| CENTRAL EAST - VC | 2500 MW |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

CLAY_-EDIC_345_1-16

Thu 05/21/2015 to Fri 05/22/2015
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NYISO 03/13/2015

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| OSWEGO EXPORT | 4850 MW |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 5250 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|----------------------------------|------------|------|------------------------------------|-----------------------------------|----------------|
| FROST_BR-LONG_MTN_345_352 | | | | FWD | REV |
| Fri 05/22/2015 to Sun 05/31/2015 | | | | (Import) | (Export) |
| 0600 | Continuous | 1500 | | SCH - NE - NY | 1150 MW |
| Work scheduled by: ISONE | | | | Impacts Total Transfer Capability | 250 MW |
| | | | | TTC with All Lines In Service | 1400 MW |
| CLAY -EDIC 345_2-15 | | | | FWD | |
| Tue 05/26/2015 to Wed 05/27/2015 | | | | (Import) | |
| 0700 | Continuous | 1600 | UPDATED by NGRID 03/13/2015 | OSWEGO EXPORT | 4850 MW |
| Work scheduled by: NGrid | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | TTC with All Lines In Service | 5250 MW |
| MOSES -ADIRNDCK_230_MA2 | | | | FWD | |
| Tue 05/26/2015 to Fri 05/29/2015 | | | | (Import) | |
| 0700 | Continuous | 1530 | | MOSES SOUTH | 2000 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 1150 MW |
| | | | | TTC with All Lines In Service | 3150 MW |
| STLAWRNC-MOSES 230_L34P | | | | FWD | REV |
| Tue 05/26/2015 to Fri 05/29/2015 | | | | (Import) | (Export) |
| 0700 | Continuous | 1530 | | SCH - OH - NY | 1750 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 150 MW |
| | | | | TTC with All Lines In Service | 1900 MW |
| MOSES -ADIRNDCK_230_MA1 | | | | FWD | |
| Mon 06/01/2015 to Tue 06/02/2015 | | | | (Import) | |
| 0700 | Continuous | 1530 | | MOSES SOUTH | 2000 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 1150 MW |
| | | | | TTC with All Lines In Service | 3150 MW |
| PANNELL -CLAY 345_PC2 | | | | FWD | |
| Mon 06/01/2015 to Tue 06/02/2015 | | | | (Import) | |
| 0700 | Continuous | 1530 | | WEST CENTRAL | 1300 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 950 MW |
| | | | | TTC with All Lines In Service | 2250 MW |
| MOSES -ADIRNDCK_230_MA2 | | | | FWD | |
| Wed 06/03/2015 to Thu 06/04/2015 | | | | (Import) | |
| 0700 | Continuous | 1530 | | MOSES SOUTH | 2000 MW |
| Work scheduled by: NYPA | | | | Impacts Total Transfer Capability | 1150 MW |
| | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK____-NIAGARA__345_PA302

Thu 06/25/2015 to Fri 06/26/2015
0500 Continuous 1600

Work scheduled by: NYPA

| | | |
|-----------------------------------|----------|----------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - OH - NY | 1200 MW | 1100 MW |
| Impacts Total Transfer Capability | 700 MW | 800 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

MOSES____-ADIRNDCK_230_MA1

Thu 08/13/2015 to Thu 08/13/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

MOSES____-ADIRNDCK_230_MA2

Tue 08/18/2015 to Tue 08/18/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

ADIRNDCK-PORTER____230_12-AP

Wed 08/19/2015 to Wed 08/19/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| MOSES SOUTH | 2100 MW |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

ADIRNDCK-CHASLAKE_230_13

Thu 08/20/2015 to Thu 08/20/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| MOSES SOUTH | 2100 MW |
| Impacts Total Transfer Capability | 1050 MW |
| TTC with All Lines In Service | 3150 MW |

EDIC____-FRASER____345_EF24-40

Mon 08/24/2015 to Fri 08/28/2015
0700 Continuous 1630

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| CENTRAL EAST - VC | 2500 MW |
| Impacts Total Transfer Capability | 475 MW |
| TTC with All Lines In Service | 2975 MW |

MOSES____-ADIRNDCK_230_MA2

Mon 08/31/2015 to Fri 09/04/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | |
|-----------------------------------|----------|
| | FWD |
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_BK 2

Mon 09/07/2015 to Fri 09/11/2015
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON___345_303

Mon 09/07/2015 to Fri 09/25/2015
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED 4100 MW
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

NIAGARA___345_230_BK 4

Mon 09/07/2015 to Fri 10/09/2015
0800 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY 1900 MW 1900 MW
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 1900 MW 1900 MW

MOSES___-ADIRNDCK_230_MA2

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

COOPERS_-MIDDLETP_345_CMT-34

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1600

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2720 MW
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

COOPERS_-ROCKTVRN_345_CRT-42

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1600

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2720 MW
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NE - NY | 500 MW | 1300 MW |
| Impacts Total Transfer Capability | 900 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

BECK____-NIAGARA_345_PA302

Thu 09/24/2015 to Fri 09/25/2015
0500 Continuous 1600

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - OH - NY | 1200 MW | 1100 MW |
| Impacts Total Transfer Capability | 700 MW | 800 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

MOSES____-ADIRNDCK_230_MA2

Mon 09/28/2015 to Fri 10/02/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

BECK____-NIAGARA_345_PA301

Mon 09/28/2015 to Fri 10/02/2015
0800 Continuous 1600

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - OH - NY | 1200 MW | 1100 MW |
| Impacts Total Transfer Capability | 700 MW | 800 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

COOPERS_-ROCKTVRN_345_CRT-42

Mon 09/28/2015 to Fri 10/02/2015
0900 Daily 1600

Work scheduled by: NYSEG

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2720 MW |
| Impacts Total Transfer Capability | 255 MW |
| TTC with All Lines In Service | 2975 MW |

CHATGUAY-MASSENA_765_7040

Sat 10/03/2015 to Sun 10/25/2015
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/07/2014

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 1550 MW |
| Impacts Total Transfer Capability | 1600 MW |
| TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | |
|--|------------|----------------|----------------|----------------|-------------------|-----------------------------------|----------------|
| CHATGUAY-MASSENA__765_7040 | | | | | | FWD | REV |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | (Export) |
| 0100 | Continuous | 1730 | | | | 0 MW | 0 MW |
| Work scheduled by: NYPA | | | | | | SCH - HQ - NY | |
| | | | | | | Impacts Total Transfer Capability | 1500 MW |
| | | | | | | TTC with All Lines In Service | 1500 MW |
| MARCY__765_345_BK 1 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | 1750 MW | |
| Work scheduled by: NYPA | | | | ARR: 19 | | MOSES SOUTH | |
| | | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |
| MARCY__765_345_BK 2 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | 1700 MW | |
| Work scheduled by: NYPA | | | | ARR: 19 | | MOSES SOUTH | |
| | | | | | | Impacts Total Transfer Capability | 1450 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |
| MASSENA_-MARCY__765_MSU1 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | 2315 MW | |
| Work scheduled by: NYPA | | | | ARR: 20 | | CENTRAL EAST - VC | |
| | | | | | | Impacts Total Transfer Capability | 660 MW |
| | | | | | | TTC with All Lines In Service | 2975 MW |
| MASSENA_-MARCY__765_MSU1 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | 675 MW | |
| Work scheduled by: NYPA | | | | ARR: 20 | | MOSES SOUTH | |
| | | | | | | Impacts Total Transfer Capability | 2475 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |
| MASSENA_-MARCY__765_MSU1 | | | | | | FWD | REV |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | (Export) |
| 0100 | Continuous | 1730 | | | | 475 MW | 1000 MW |
| Work scheduled by: NYPA | | | | ARR: 20 | | SCH - HQ - NY | |
| | | | | | | Impacts Total Transfer Capability | 1025 MW |
| | | | | | | TTC with All Lines In Service | 1500 MW |
| MASSENA_-MARCY__765_MSU1 & CHATGUAY-MASSENA__765_7040 | | | | | | | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | | | | | |
| 0100 | | 1730 | | | | | |
| Work scheduled by: | | | | ARR: 20 | | MOSES SOUTH | |
| | | | | | | Impacts Total Transfer Capability | |
| | | | | | | TTC with All Lines In Service | |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/03/2015 to Sun 10/25/2015
0100 1730

Work scheduled by:

ARR: 20

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - HQ - NY | 850 MW | 0 MW |
| Impacts Total Transfer Capability | 650 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

SHOR_NPX-SHOREHAM 138_NPX_CSC

Mon 10/05/2015 to Sun 10/11/2015
0530 Continuous 1800

Work scheduled by: LI

UPDATED by ISONE 07/25/2014

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NPX_CSC | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

GILBOA -LEEDS 345_GL3

Mon 10/05/2015 to Fri 10/09/2015
0700 Continuous 1600

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2200 MW |
| Impacts Total Transfer Capability | 775 MW |
| TTC with All Lines In Service | 2975 MW |

BECK -PACKARD 230_BP76

Mon 10/05/2015 to Fri 10/09/2015
0800 Continuous 1600

Work scheduled by: NGrid

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - OH - NY | 1750 MW | 1200 MW |
| Impacts Total Transfer Capability | 150 MW | 700 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

MALONE -WILLIS 115_1-MW

Tue 10/06/2015 to Tue 10/06/2015
0800 Continuous 1530

Work scheduled by: NYPA

ARR: 20&38

| | | REV |
|-----------------------------------|--|----------|
| | | (Export) |
| SCH - HQ_CEDARS | | 40 MW |
| Impacts Total Transfer Capability | | 0 MW |
| TTC with All Lines In Service | | 40 MW |

GILBOA -N.SCTLND 345_GNS1

Mon 10/12/2015 to Fri 10/30/2015
0730 Continuous 1500

Work scheduled by: NGrid

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2520 MW |
| Impacts Total Transfer Capability | 455 MW |
| TTC with All Lines In Service | 2975 MW |

LEEDS -HURLYAVE 345_301

Mon 10/12/2015 to Fri 10/30/2015
0800 Continuous 1600

Work scheduled by: CHGE

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| UPNY CONED | 4100 MW |
| Impacts Total Transfer Capability | 1000 MW |
| TTC with All Lines In Service | 5100 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS-LINDN_CG_345_G23L & GOETHALS-LINDN_CG_345_G23M

Tue 10/20/2015 to Fri 10/23/2015
 0001 2359

Work scheduled by:

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 315 MW |
| Impacts Total Transfer Capability | 315 MW | 0 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

CLAY -EDIC 345_2-15

Mon 10/26/2015 to Tue 10/27/2015
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by PA 03/27/2015

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| OSWEGO EXPORT | 4850 MW |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 5250 MW |

RAMAPO -BUCHAN_N_345_Y94

Sat 11/07/2015 to Mon 11/09/2015
 0001 Continuous 2359

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| UPNY CONED | 4150 MW |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 5100 MW |

ROCKTVRN-RAMAPO 345_77

Sat 11/07/2015 to Fri 11/20/2015
 0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 12/16/2014

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2570 MW |
| Impacts Total Transfer Capability | 405 MW |
| TTC with All Lines In Service | 2975 MW |

ROSETON -ROCKTVRN_345_311

Sat 11/07/2015 to Fri 11/20/2015
 0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 12/16/2014

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| UPNY CONED | 4400 MW |
| Impacts Total Transfer Capability | 700 MW |
| TTC with All Lines In Service | 5100 MW |

LIND_CG -LNDVFT 345_V-3022

Sun 11/08/2015 to Fri 11/13/2015
 1400 Continuous 1800

Work scheduled by: PJM

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

ROCKTVRN-RAMAPO 345_77

Fri 11/20/2015 to Sat 12/12/2015
 1601 Continuous 2359

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2570 MW |
| Impacts Total Transfer Capability | 405 MW |
| TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS-LINDN CG_345_G23L & GOETHALS-LINDN CG_345_G23M

Mon 11/23/2015 to Thu 11/26/2015
0001 2359

Work scheduled by:

| | FWD | REV |
|-----------------------------------|-------------|---------------|
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 315 MW |
| Impacts Total Transfer Capability | 315 MW | 0 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

RAMAPO -BUCHAN N_345_Y94

Sun 11/29/2015 to Sat 12/05/2015
0001 Continuous 2359

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| UPNY CONED | 4150 MW |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 5100 MW |

BERKSHIR-ALPS 345_393

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500

Work scheduled by: NGrid

| | FWD | REV |
|-----------------------------------|----------------|----------------|
| | (Import) | (Export) |
| SCH - NE - NY | 1300 MW | 1300 MW |
| Impacts Total Transfer Capability | 100 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

BERKSHIR-ALPS 345_393

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500

Work scheduled by: NGrid

| | FWD | REV |
|-----------------------------------|---------------|---------------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

MOSES -ADIRNDCK_230_MAI

Mon 11/30/2015 to Fri 12/04/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

MARCY -N.SCTLND_345_18

Mon 11/30/2015 to Sun 12/20/2015
0800 Continuous 1500

Work scheduled by: NGrid

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| CENTRAL EAST - VC | 2090 MW |
| Impacts Total Transfer Capability | 885 MW |
| TTC with All Lines In Service | 2975 MW |

MOSES -ADIRNDCK_230_MAI

Mon 12/07/2015 to Fri 12/11/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Friday ,April 03, 2015 to Sunday ,October 02, 2016

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 12/14/2015 to Fri 12/18/2015
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2000 MW**
 Impacts Total Transfer Capability 1150 MW
 TTC with All Lines In Service 3150 MW

BECK___-NIAGARA_345_PA302

Thu 12/17/2015 to Fri 12/18/2015
 0500 Continuous 1600
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1400 MW 1250 MW**
 Impacts Total Transfer Capability 500 MW 650 MW
 TTC with All Lines In Service 1900 MW 1900 MW

ROCKTVRN-RAMAPO___345_77

Mon 04/04/2016 to Fri 04/29/2016
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 CENTRAL EAST - VC **2570 MW**
 Impacts Total Transfer Capability 405 MW
 TTC with All Lines In Service 2975 MW