

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Fri 02/06/2015 to Wed 04/15/2015 EXT FORCE by HQ 04/15/2015

0757 Continuous 1725

Work scheduled by: HQ

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

0 MW

100 MW

100 MW

ROSETON_-ROCKTVRN_345_311

Mon 04/06/2015 to Fri 04/24/2015

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

4400 MW

700 MW

5100 MW

EFISHKIL-WOOD_ST_345_F39

Mon 04/13/2015 to Wed 04/15/2015

0001 Continuous 1930

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

4000 MW

1100 MW

5100 MW

MARCY_-COOPERS_345_UC2-41

Mon 04/13/2015 to Fri 04/17/2015

0700 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA01/20/2015

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

2500 MW

475 MW

2975 MW

LOWVILLE-BOONVILLE_115_5-LB

Mon 04/13/2015 to Fri 05/08/2015

0800 Continuous 1800

Work scheduled by: NGrid

ARR: 38

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import) (Export)

199 MW

100 MW

0 MW

0 MW

199 MW

100 MW

EGRDNCTY_345_138_BK 2

Tue 04/14/2015 to Tue 04/14/2015

0001 Continuous 2359

Work scheduled by: LI

UPDATEDby LI03/27/2015

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

1250 MW

250 MW

1500 MW

BERKSHIR-ALPS_345_393

Wed 04/15/2015 to Thu 04/16/2015

0700 Continuous 1700

Work scheduled by: NGrid

UPDATEDby ISONE04/10/2015

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import) (Export)

1300 MW

1300 MW

100 MW

300 MW

1400 MW

1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|--|------------|----------------|------------------|----------------------------|-----------------------------------|----------------|
| BERKSHIR-ALPS_____345_393 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by ISONE 04/10/2015</u> | (Import) | (Export) |
| 0700 | Continuous | 1700 | | | SCH - NPX_1385 | 100 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 100 MW |
| | | | | | TTC with All Lines In Service | 200 MW |
| BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | | | (Import) | (Export) |
| 0700 | | 1700 | | | SCH - NE - NY | 1300 MW |
| Work scheduled by: | | | | | Impacts Total Transfer Capability | 100 MW |
| | | | | | TTC with All Lines In Service | 1400 MW |
| BERKSHIR-NORTHFLD_345_312 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by ISONE 04/10/2015</u> | (Import) | (Export) |
| 0700 | Continuous | 1700 | | | SCH - NE - NY | 1400 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 0 MW |
| | | | | | TTC with All Lines In Service | 1400 MW |
| BERKSHIR-NORTHFLD_345_312 | | | | | FWD | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by ISONE 04/10/2015</u> | (Import) | (Export) |
| 0700 | Continuous | 1700 | | | SCH - NPX_1385 | 100 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 100 MW |
| | | | | | TTC with All Lines In Service | 200 MW |
| SCH-NE-NYISO_LIMIT_500 | | | | | FWD | |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by ISONE 04/10/2015</u> | (Import) | |
| 0700 | Continuous | 1700 | | | SCH - NE - NY | 700 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 700 MW |
| | | | | | TTC with All Lines In Service | 1400 MW |
| SCH-NYISO-NE_LIMIT_700 | | | | | | REV |
| Wed 04/15/2015 | to | Thu 04/16/2015 | <u>UPDATED</u> | <u>by ISONE 04/10/2015</u> | | (Export) |
| 0700 | Continuous | 1700 | | | SCH - NE - NY | 900 MW |
| Work scheduled by: NGrid | | | | | Impacts Total Transfer Capability | 700 MW |
| | | | | | TTC with All Lines In Service | 1600 MW |
| STOLLERD-HISHELDN_230_67 | | | | | FWD | |
| Wed 04/15/2015 | to | Wed 04/15/2015 | <u>CANCELLED</u> | <u>by NYSEG 04/15/2015</u> | (Import) | |
| 1000 | Continuous | 1015 | | | DYSINGER EAST | 2850 MW |
| Work scheduled by: NYSEG | | | | | Impacts Total Transfer Capability | 300 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

FWD

Wed 04/15/2015 to Wed 04/15/2015
1900 Continuous 1930

Work scheduled by: ConEd

(Import)
UPNY CONED 4000 MW
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

SPRNBRK_-TREMONT_345_X28

FWD

Thu 04/16/2015 to Thu 04/16/2015
0001 Continuous 1100

Work scheduled by: ConEd

UPDATED by CONED 04/16/2015

(Import)
SPR/DUN-SOUTH 4200 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

EFISHKIL-WOOD_ST_345_F38

FWD

Thu 04/16/2015 to Sun 04/19/2015
0001 Continuous 1930

Work scheduled by: ConEd

UPDATED by CE 02/26/2015

(Import)
UPNY CONED 4000 MW
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y86

FWD

Thu 04/16/2015 to Sun 04/19/2015
0001 Continuous 1930

Work scheduled by: ConEd

UPDATED by CE 02/26/2015

(Import)
UPNY CONED 4000 MW
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

MARCY_-COOPERS_345_UC2-41

FWD

Fri 04/17/2015 to Mon 04/20/2015
1531 Continuous 0659

Work scheduled by: NYISO

UPDATED by NYISO 04/19/2015

(Import)
CENTRAL EAST - VC 2500 MW
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

CHATGUAY-MASSENA_765_7040

FWD

Sat 04/18/2015 to Sat 04/18/2015
0100 Continuous 1700

Work scheduled by: NYPA

(Import)
MOSES SOUTH 1550 MW
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

FWD

REV

Sat 04/18/2015 to Sat 04/18/2015
0100 Continuous 1700

Work scheduled by: NYPA

(Import) (Export)
SCH - HQ - NY 0 MW 0 MW
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

FWD

Sat 04/18/2015 to Sat 04/18/2015
0600 Continuous 1800

(Import)

MOSES SOUTH

2150 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

CHAT_DC_GC2

REV

Sat 04/18/2015 to Sat 04/18/2015
0600 Continuous 1800

(Export)

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

SCH-HQ-NYISO_LIMIT_1400

FWD

Sat 04/18/2015 to Sun 04/19/2015 **UPDATED** **by NYISO** **04/19/2015**
0600 Continuous 0659

(Import)

SCH - HQ - NY

1400 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: NYISO

NRTH1385-NOR HBR__138_601

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015 **UPDATED** **by NYISO** **04/16/2015**
0500 Continuous 1700

(Import) (Export)

SCH - NPX_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015
0500 1700

(Import) (Export)

SCH - NPX_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015
0500 1700

(Import) (Export)

SCH - NPX_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

NRTH1385-NOR HBR__138_602

FWD

REV

Mon 04/20/2015 to Thu 04/30/2015 **UPDATED** **by NYISO** **04/16/2015**
0500 Continuous 1700

(Import) (Export)

SCH - NPX_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 04/20/2015 to Thu 04/30/2015
0500 1700

Work scheduled by:

FWD REV
(Import) (Export)
SCH - NPX_1385 0 MW 0 MW
Impacts Total Transfer Capability 200 MW 200 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR__138_603

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1700

Work scheduled by: LI

UPDATED by NYISO 04/16/2015

FWD REV
(Import) (Export)
SCH - NPX_1385 100 MW 100 MW
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NRTHPORT_138_1385

Mon 04/20/2015 to Thu 04/30/2015
0500 Continuous 1700

Work scheduled by: LI

UPDATED by NYISO 04/16/2015

FWD REV
(Import) (Export)
SCH - NPX_1385 0 MW 0 MW
Impacts Total Transfer Capability 200 MW 200 MW
TTC with All Lines In Service 200 MW 200 MW

ROCHESTR-PANNELL__345_RP2

Mon 04/20/2015 to Fri 05/01/2015
0700 Continuous 1600

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

ROSETON_-EFISHKIL_345_305

Mon 04/20/2015 to Mon 04/20/2015
0800 Daily(No Weekends) 1600

Work scheduled by: CHGE

CANCELLED by CHGE 04/17/2015

FWD
(Import)
UPNY CONED 4100 MW
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

LIND_CG_-LNDVFT__345_V-3022

Tue 04/21/2015 to Wed 04/22/2015
0900 Continuous 1400

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJM_VFT 0 MW 0 MW
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

EASTVIEW-SPRNBK__345_W64

Wed 04/22/2015 to Wed 04/22/2015
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Wed 04/22/2015 to Sat 04/25/2015
0001 Continuous 1930

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

BECK_-NIAGARA_345_PA302

Thu 04/23/2015 to Fri 04/24/2015
0400 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 04/16/2015

FWD REV
(Import) (Export)
SCH - OH - NY **1400 MW 1250 MW**
Impacts Total Transfer Capability 500 MW 650 MW
TTC with All Lines In Service 1900 MW 1900 MW

EASTVIEW-SPRNBK_345_W64

Sat 04/25/2015 to Sat 04/25/2015
1900 Continuous 1930

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

LEEDS_345_LEEDS SVC

Mon 04/27/2015 to Fri 05/01/2015
0700 Continuous 1500

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2950 MW**
Impacts Total Transfer Capability 25 MW
TTC with All Lines In Service 2975 MW

FRASER_-GILBOA_345_GF5-35

Mon 04/27/2015 to Fri 05/08/2015
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 01/09/2015

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

W49TH_ST_345KV_5

Tue 04/28/2015 to Tue 04/28/2015
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 03/17/2015

FWD
(Import)
SCH - PJM_HTP **329 MW**
Impacts Total Transfer Capability 331 MW
TTC with All Lines In Service 660 MW

SPRNBK_-W49TH_ST_345_M52

Tue 04/28/2015 to Sun 05/03/2015
0001 Continuous 2300

Work scheduled by: ConEd

UPDATED by CONED 03/17/2015

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4

FWD

Tue 04/28/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015

(Import)

0001 Continuous 2300

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_5

FWD

Sun 05/03/2015 to Sun 05/03/2015 UPDATED by CONED 03/17/2015

(Import)

2230 Continuous 2300

SCH - PJM_HTP **315 MW**
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

SPRNBRK__345KV_RNS5

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_5

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM_HTP **315 MW**
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_7

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM_HTP **315 MW**
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBRK__345_W64

FWD

Mon 05/04/2015 to Tue 05/05/2015

(Import)

0001 Continuous 2000

UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW_345_W99

FWD

Mon 05/04/2015 to Tue 05/05/2015

(Import)

0001 Continuous 2000

UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE 0 MW
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE 0 MW
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE 375 MW
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/04/2015 to Tue 05/12/2015
0600 Continuous 2100

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE 375 MW
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

SCH-NE-NYISO_LIMIT_900

Mon 05/04/2015 to Thu 05/21/2015
0600 Continuous 1700

Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY 1100 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 1400 MW

MOSES_-ADIRNDCK_230_MAI

Mon 05/04/2015 to Fri 05/08/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Mon 05/04/2015 to Fri 05/22/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 1550 MW
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|------------------------------------|------------|----------------|----------------|---------------|-----------------------------------|----------------|
| CHATGUAY-MASSENA__765_7040 | | | | | FWD | REV |
| Mon 05/04/2015 | to | Fri 05/22/2015 | | | (Import) | (Export) |
| 0700 | Continuous | 1530 | | | 0 MW | 0 MW |
| Work scheduled by: NYPA | | | | | Impacts Total Transfer Capability | 1500 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| HOMER C_-WATRCURE_345_30 | | | | | FWD | REV |
| Mon 05/04/2015 | to | Thu 05/28/2015 | UPDATED | by PJM | (Import) | (Export) |
| 0800 | Continuous | 1600 | | | 2200 MW | 1300 MW |
| Work scheduled by: NYSEG | | | | | Impacts Total Transfer Capability | 250 MW |
| | | | | | TTC with All Lines In Service | 2450 MW |
| HUDSONP_-FARRAGUT_345_B3402 | | | | | FWD | REV |
| Tue 05/05/2015 | to | Thu 05/14/2015 | | | (Import) | (Export) |
| 0001 | Continuous | 2300 | | | 2300 MW | 1300 MW |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 150 MW |
| | | | | | TTC with All Lines In Service | 2450 MW |
| SPRNBRK__345KV_RNS5 | | | | | FWD | |
| Tue 05/05/2015 | to | Tue 05/05/2015 | | | (Import) | |
| 1930 | Continuous | 2000 | | | 3200 MW | |
| Work scheduled by: ConEd | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| DUNWODIE-SHORE_RD_345_Y50 | | | | | FWD | |
| Wed 05/06/2015 | to | Thu 05/07/2015 | | | (Import) | |
| 0001 | Continuous | 2359 | | | 800 MW | |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 700 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| SHORE_RD_345_138_BK 1 | | | | | FWD | |
| Wed 05/06/2015 | to | Thu 05/07/2015 | | | (Import) | |
| 0001 | Continuous | 2359 | | | 1350 MW | |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 150 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| SHORE_RD_345_138_BK 2 | | | | | FWD | |
| Wed 05/06/2015 | to | Wed 05/13/2015 | | | (Import) | |
| 0001 | Continuous | 2359 | | | 1350 MW | |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 150 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Wed 05/06/2015 to Wed 05/06/2015
1830 Continuous 1900
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP 315 MW
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Wed 05/06/2015 to Wed 05/06/2015
1830 Continuous 1900
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP 315 MW
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/08/2015 to Fri 05/08/2015
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS4

Fri 05/08/2015 to Fri 05/08/2015
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH 3200 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W65

Fri 05/08/2015 to Sun 05/10/2015
0001 Continuous 2000
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

MARCY____765_345_BK 1

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030
Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1750 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY____765_345_BK 2

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030
Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_765_MSU1

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030

Work scheduled by: NYPA

ARR: 20

FWD
(Import)
CENTRAL EAST - VC **2315 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY_765_MSU1

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030

Work scheduled by: NYPA

ARR: 20

FWD
(Import)
MOSES SOUTH **675 MW**
Impacts Total Transfer Capability 2475 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY_765_MSU1

Sat 05/09/2015 to Sun 05/10/2015
0700 Continuous 2030

Work scheduled by: NYPA

ARR: 20

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY_765_MSU1 & CHATGUAY-MASSENA_765_7040

Sat 05/09/2015 to Sun 05/10/2015
0700 2030

Work scheduled by:

ARR: 20

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

Sat 05/09/2015 to Sun 05/10/2015
0700 2030

Work scheduled by:

ARR: 20

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MILLWOOD-EASTVIEW_345_W82

Sun 05/10/2015 to Sun 05/10/2015
1930 Continuous 2000

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK_345KV_RNS4

Sun 05/10/2015 to Sun 05/10/2015
1930 Continuous 2000

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

FWD

Mon 05/11/2015 to Mon 05/11/2015

(Import)

0001 Continuous 0030

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

PLSNTVLY-WOOD_ST_345_F31

FWD

Mon 05/11/2015 to Tue 05/12/2015

(Import)

0001 Continuous 1800

UPNY CONED

4000 MW

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

MOSES-ADIRNDCK_230_MA1

FWD

Mon 05/11/2015 to Fri 05/15/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

LOWVILLE-BOONVILLE_115_5-LB

FWD

REV

Mon 05/11/2015 to Fri 06/12/2015

(Import) (Export)

0800 Continuous 1800

SCH - HQ_CEDARS

130 MW 40 MW

Impacts Total Transfer Capability 60 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

ARR: 38

EDIC-FRASER_345_EF24-40

FWD

Mon 05/11/2015 to Fri 05/15/2015

(Import)

0900 Continuous 1530

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

PLSNTVLY_345KV_RNS4

FWD

Tue 05/12/2015 to Tue 05/12/2015

(Import)

1730 Continuous 1800

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

PLSNTVLY_345KV_RNS4

FWD

Wed 05/13/2015 to Wed 05/13/2015

(Import)

0001 Continuous 0030

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F31

Wed 05/13/2015 to Wed 05/13/2015
0001 Continuous 2000
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

SHOR_NPX-SHOREHAM_138_NPX_CSC

Wed 05/13/2015 to Sun 05/17/2015
0500 Continuous 1500
Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

PLSNTVLY_345KV_RNS4

Wed 05/13/2015 to Wed 05/13/2015
1930 Continuous 2000
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PORTER_-ROTTDAM_230_31-PR

Fri 05/15/2015 to Sun 05/17/2015
0600 Continuous 1800
Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

HUDSONP_-FARRAGUT_345_C3403

Sat 05/16/2015 to Mon 05/25/2015
0200 Continuous 2300
Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - PJ - NY **2300 MW 1300 MW**
Impacts Total Transfer Capability 150 MW 0 MW
TTC with All Lines In Service 2450 MW 1300 MW

MOSES_-ADIRNDCK_230_MA2

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES__230_L33P

Mon 05/18/2015 to Fri 05/22/2015
0700 Continuous 1530
Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1750 MW 1750 MW**
Impacts Total Transfer Capability 150 MW 150 MW
TTC with All Lines In Service 1900 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-COOPERS___345_UC2-41

Tue 05/19/2015 to Fri 05/22/2015 UPDATED by NYISO 04/10/2015
0900 Daily 1600

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

SCH-HQ-NYISO_LIMIT_1400

Tue 05/19/2015 to Fri 05/22/2015 UPDATED by NYISO 04/10/2015
0900 Daily 1600

Work scheduled by: NYSEG

FWD
(Import)
SCH - HQ - NY **1400 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1500 MW

CLAY___-EDIC___345_1-16

Thu 05/21/2015 to Fri 05/22/2015 UPDATED by NYISO 03/13/2015
0700 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

FROST_BR-LONG_MTN_345_352

Fri 05/22/2015 to Sun 05/31/2015
0600 Continuous 1500

Work scheduled by: ISONE

FWD REV
(Import) (Export)
SCH - NE - NY **1150 MW 1600 MW**
Impacts Total Transfer Capability 250 MW 0 MW
TTC with All Lines In Service 1400 MW 1600 MW

CLAY___-EDIC___345_2-15

Tue 05/26/2015 to Wed 05/27/2015 UPDATED by NGRID 03/13/2015
0700 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

MOSES___-ADIRNDCK_230_MA2

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2000 MW**
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES___230_L34P

Tue 05/26/2015 to Fri 05/29/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1750 MW 1750 MW**
Impacts Total Transfer Capability 150 MW 150 MW
TTC with All Lines In Service 1900 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCKTVRN-RAMAPO___345_77

Sat 05/30/2015 to Sat 06/06/2015
0600 Continuous 2300

Work scheduled by: ORU

FWD
(Import)
CENTRAL EAST - VC 2570 MW
Impacts Total Transfer Capability 405 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MAI

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

PANNELL_-CLAY___345_PC2

Mon 06/01/2015 to Tue 06/02/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL 1300 MW
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

MOSES___-ADIRNDCK_230_MA2

Wed 06/03/2015 to Thu 06/04/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

FRASER___345_FRASER SVC

Mon 06/15/2015 to Fri 06/19/2015
0800 Continuous 1430

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC 2935 MW
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

BECK___-NIAGARA___345_PA302

Thu 06/25/2015 to Fri 06/26/2015
0500 Continuous 1600

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY 1200 MW 1100 MW
Impacts Total Transfer Capability 700 MW 800 MW
TTC with All Lines In Service 1900 MW 1900 MW

MOSES___-ADIRNDCK_230_MAI

Thu 08/13/2015 to Thu 08/13/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Tue 08/18/2015 to Tue 08/18/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-PORTER___230_12-AP

Wed 08/19/2015 to Wed 08/19/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2100 MW
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Thu 08/20/2015 to Thu 08/20/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2100 MW
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

EDIC___-FRASER___345_EF24-40

Mon 08/24/2015 to Fri 08/28/2015
0700 Continuous 1630

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC 2500 MW
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 08/31/2015 to Fri 09/04/2015
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2000 MW
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_BK 2

Mon 09/07/2015 to Fri 09/11/2015
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON___345_303

Mon 09/07/2015 to Fri 09/25/2015
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED 4100 MW
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

Seasonal Limits

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_BK 4

Mon 09/07/2015 to Fri 10/09/2015
0800 Continuous 1530

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - OH - NY | 1900 MW | 1900 MW |
| Impacts Total Transfer Capability | 0 MW | 0 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

MOSES__-ADIRNDCK_230_MA2

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

COOPERS_-MIDDLETP_345_CMT-34

Mon 09/14/2015 to Fri 09/18/2015
0700 Continuous 1600

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2720 MW |
| Impacts Total Transfer Capability | 255 MW |
| TTC with All Lines In Service | 2975 MW |

MOSES__-ADIRNDCK_230_MA1

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

COOPERS_-ROCKTVRN_345_CRT-42

Mon 09/21/2015 to Fri 09/25/2015
0700 Continuous 1600

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2720 MW |
| Impacts Total Transfer Capability | 255 MW |
| TTC with All Lines In Service | 2975 MW |

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NE - NY | 500 MW | 1300 MW |
| Impacts Total Transfer Capability | 900 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

LONG_MTN-PLSNTVLY_345_398

Wed 09/23/2015 to Fri 10/02/2015
0500 Continuous 1700

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

Seasonal Limits

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK____-NIAGARA__345_PA302

Thu 09/24/2015 to Fri 09/25/2015
0500 Continuous 1600

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - OH - NY | 1200 MW | 1100 MW |
| Impacts Total Transfer Capability | 700 MW | 800 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

PLSNTVLE-DUNWODIE_345_W89

Mon 09/28/2015 to Mon 09/28/2015
0001 Continuous 0030

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| UPNY CONED | 4000 MW |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

MOSES____-ADIRNDCK_230_MA2

Mon 09/28/2015 to Fri 10/02/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

BECK____-NIAGARA__345_PA301

Mon 09/28/2015 to Fri 10/02/2015
0800 Continuous 1600

Work scheduled by: NYPA

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - OH - NY | 1200 MW | 1100 MW |
| Impacts Total Transfer Capability | 700 MW | 800 MW |
| TTC with All Lines In Service | 1900 MW | 1900 MW |

COOPERS_-ROCKTVRN_345_CRT-42

Mon 09/28/2015 to Fri 10/02/2015
0900 Daily 1600

Work scheduled by: NYSEG

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2720 MW |
| Impacts Total Transfer Capability | 255 MW |
| TTC with All Lines In Service | 2975 MW |

PLSNTVLE-DUNWODIE_345_W89

Fri 10/02/2015 to Fri 10/02/2015
1830 Continuous 1900

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| UPNY CONED | 4000 MW |
| Impacts Total Transfer Capability | 1100 MW |
| TTC with All Lines In Service | 5100 MW |

CHATGUAY-MASSENA__765_7040

Sat 10/03/2015 to Sun 10/25/2015
0100 Continuous 1730

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| MOSES SOUTH | 1550 MW |
| Impacts Total Transfer Capability | 1600 MW |
| TTC with All Lines In Service | 3150 MW |

UPDATED by NYPA 10/07/2014

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | FWD | REV |
|--|------------|----------------|----------------|----------------|-------------------|-----------------------------------|----------------|
| | | | | | | (Import) | (Export) |
| CHATGUAY-MASSENA__765_7040 | | | | | | | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | | |
| 0100 | Continuous | 1730 | | | | SCH - HQ - NY | 0 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1500 MW |
| | | | | | | TTC with All Lines In Service | 1500 MW |
| MARCY__765_345_BK 1 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | MOSES SOUTH | 1750 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |
| MARCY__765_345_BK 2 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | MOSES SOUTH | 1700 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1450 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |
| MASSENA_-MARCY__765_MSU1 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | CENTRAL EAST - VC | 2315 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 660 MW |
| | | | | | | TTC with All Lines In Service | 2975 MW |
| MASSENA_-MARCY__765_MSU1 | | | | | | FWD | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | |
| 0100 | Continuous | 1730 | | | | MOSES SOUTH | 675 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 2475 MW |
| | | | | | | TTC with All Lines In Service | 3150 MW |
| MASSENA_-MARCY__765_MSU1 | | | | | | FWD | REV |
| Sat 10/03/2015 | to | Sun 10/25/2015 | <u>UPDATED</u> | <u>by NYPA</u> | <u>10/07/2014</u> | (Import) | (Export) |
| 0100 | Continuous | 1730 | | | | SCH - HQ - NY | 475 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 1025 MW |
| | | | | | | TTC with All Lines In Service | 1500 MW |
| MASSENA_-MARCY__765_MSU1 & CHATGUAY-MASSENA__765_7040 | | | | | | | |
| Sat 10/03/2015 | to | Sun 10/25/2015 | | | | MOSES SOUTH | |
| 0100 | | 1730 | | | | Impacts Total Transfer Capability | |
| Work scheduled by: | | | | | | TTC with All Lines In Service | |

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/03/2015 to Sun 10/25/2015
0100 1730

Work scheduled by:

ARR: 20

SCH - HQ - NY

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

FWD REV
(Import) (Export)

850 MW 0 MW

SHOR_NPX-SHOREHAM 138_NPX_CSC

Mon 10/05/2015 to Sun 10/11/2015
0530 Continuous 1800

Work scheduled by: LI

UPDATED by ISONE 07/25/2014

SCH - NPX_CSC

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

FWD REV
(Import) (Export)

0 MW 0 MW

GILBOA -LEEDS 345_GL3

Mon 10/05/2015 to Fri 10/09/2015
0700 Continuous 1600

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability 775 MW

TTC with All Lines In Service 2975 MW

FWD
(Import)

2200 MW

BECK -PACKARD 230_BP76

Mon 10/05/2015 to Fri 10/09/2015
0800 Continuous 1600

Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability 150 MW 700 MW

TTC with All Lines In Service 1900 MW 1900 MW

FWD REV
(Import) (Export)

1750 MW 1200 MW

MALONE -WILLIS 115_1-MW

Tue 10/06/2015 to Tue 10/06/2015
0800 Continuous 1530

Work scheduled by: NYPA

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service 40 MW

REV
(Export)

40 MW

ARR: 20&38

GILBOA -N.SCTLND 345_GNS1

Mon 10/12/2015 to Fri 10/30/2015
0730 Continuous 1500

Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

FWD
(Import)

2520 MW

LEEDS -HURLYAVE 345_301

Mon 10/12/2015 to Fri 10/30/2015
0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

FWD
(Import)

4100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

| | |
|-------------------|--------|
| CENTRAL EAST | 3100MW |
| CENTRAL EAST - VC | 2975MW |
| TOTAL EAST | 6500MW |
| UPNY CONED | 5100MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3150MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS-LINDN_CG_345_G23L & GOETHALS-LINDN_CG_345_G23M

Tue 10/20/2015 to Fri 10/23/2015
0001 2359

Work scheduled by:

| | | |
|-----------------------------------|-------------|---------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 315 MW |
| Impacts Total Transfer Capability | 315 MW | 0 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

CLAY -EDIC 345_2-15

Mon 10/26/2015 to Tue 10/27/2015
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by PA 03/27/2015

| | |
|-----------------------------------|----------------|
| | FWD |
| | (Import) |
| OSWEGO EXPORT | 4850 MW |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 5250 MW |

RAMAPO -BUCHAN_N_345_Y94

Sat 11/07/2015 to Mon 11/09/2015
0001 Continuous 2359

Work scheduled by: ConEd

| | |
|-----------------------------------|----------------|
| | FWD |
| | (Import) |
| UPNY CONED | 4150 MW |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 5100 MW |

ROCKTVRN-RAMAPO 345_77

Sat 11/07/2015 to Fri 11/20/2015
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 12/16/2014

| | |
|-----------------------------------|----------------|
| | FWD |
| | (Import) |
| CENTRAL EAST - VC | 2570 MW |
| Impacts Total Transfer Capability | 405 MW |
| TTC with All Lines In Service | 2975 MW |

ROSETON -ROCKTVRN_345_311

Sat 11/07/2015 to Fri 11/20/2015
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 12/16/2014

| | |
|-----------------------------------|----------------|
| | FWD |
| | (Import) |
| UPNY CONED | 4400 MW |
| Impacts Total Transfer Capability | 700 MW |
| TTC with All Lines In Service | 5100 MW |

LIND_CG -LNDVFT 345_V-3022

Sun 11/08/2015 to Fri 11/13/2015
1400 Continuous 1800

Work scheduled by: PJM

| | | |
|-----------------------------------|-------------|-------------|
| | FWD | REV |
| | (Import) | (Export) |
| SCH - PJM_VFT | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

ROCKTVRN-RAMAPO 345_77

Fri 11/20/2015 to Sat 12/12/2015
1601 Continuous 2359

Work scheduled by: ConEd

| | |
|-----------------------------------|----------------|
| | FWD |
| | (Import) |
| CENTRAL EAST - VC | 2570 MW |
| Impacts Total Transfer Capability | 405 MW |
| TTC with All Lines In Service | 2975 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS-LINDN CG_345_G23L & GOETHALS-LINDN CG_345_G23M

Mon 11/23/2015 to Thu 11/26/2015
0001 2359

Work scheduled by:

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - PJM_VFT | 0 MW | 315 MW |
| Impacts Total Transfer Capability | 315 MW | 0 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

RAMAPO -BUCHAN N_345_Y94

Sun 11/29/2015 to Sat 12/05/2015
0001 Continuous 2359

Work scheduled by: ConEd

| | FWD (Import) |
|-----------------------------------|-----------------|
| UPNY CONED | 4150 MW |
| Impacts Total Transfer Capability | 950 MW |
| TTC with All Lines In Service | 5100 MW |

BERKSHIR-ALPS 345_393

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500

Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - NE - NY | 1300 MW | 1300 MW |
| Impacts Total Transfer Capability | 100 MW | 300 MW |
| TTC with All Lines In Service | 1400 MW | 1600 MW |

BERKSHIR-ALPS 345_393

Mon 11/30/2015 to Fri 12/04/2015
0600 Continuous 1500

Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|-----------------|-----------------|
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

MOSES -ADIRNDCK_230_MAI

Mon 11/30/2015 to Fri 12/04/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD (Import) |
|-----------------------------------|-----------------|
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

MARCY -N.SCTLND_345_18

Wed 12/02/2015 to Wed 12/23/2015 **UPDATED by NGRID 04/17/2015**
0700 Continuous 1500

Work scheduled by: NGrid

| | FWD (Import) |
|-----------------------------------|-----------------|
| CENTRAL EAST - VC | 2090 MW |
| Impacts Total Transfer Capability | 885 MW |
| TTC with All Lines In Service | 2975 MW |

MOSES -ADIRNDCK_230_MAI

Mon 12/07/2015 to Fri 12/11/2015
0700 Continuous 1530

Work scheduled by: NYPA

| | FWD (Import) |
|-----------------------------------|-----------------|
| MOSES SOUTH | 2000 MW |
| Impacts Total Transfer Capability | 1150 MW |
| TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Sunday ,April 19, 2015 to Tuesday ,October 18, 2016

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

FWD

Mon 12/14/2015 to Fri 12/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

2000 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

BECK___-NIAGARA_345_PA302

FWD

REV

Thu 12/17/2015 to Fri 12/18/2015

(Import) (Export)

0500 Continuous 1600

SCH - OH - NY

1400 MW 1250 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

ROCKTVRN-RAMAPO___345_77

FWD

Mon 04/04/2016 to Fri 04/29/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

2570 MW

Work scheduled by: CHGE

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW