

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311					FWD	
Mon 04/06/2015	to	Fri 04/24/2015			(Import)	
0800	Continuous	1600			UPNY CONED	4400 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	5100 MW
LOWVILLE-BOONVILLE_115_5-LB					FWD	REV
Mon 04/13/2015	to	Sat 05/02/2015	<u>UPDATED</u>	<u>by NGRID 04/22/2015</u>	(Import)	(Export)
0800	Continuous	1800			SCH - HQ_CEDARS	199 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
MARCY_-COOPERS_345_UC2-41					FWD	
Fri 04/17/2015	to	Mon 04/20/2015	<u>UPDATED</u>	<u>by NYISO 04/19/2015</u>	(Import)	
1531	Continuous	0659			CENTRAL EAST - VC	2500 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
HUDSONP_-FARRAGUT_345_C3403					FWD	REV
Sun 04/19/2015	to	Wed 04/22/2015	<u>RETURNED</u>	<u>by PJM 04/22/2015</u>	(Import)	(Export)
2011	Continuous	0102			SCH - PJ - NY	2450 MW 1300 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2450 MW 1300 MW
NRTH1385-NOR HBR_138_601					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015	<u>UPDATED</u>	<u>by NYISO 04/16/2015</u>	(Import)	(Export)
0500	Continuous	1700			SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015			(Import)	(Export)
0500		1700			SCH - NPX_1385	0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603					FWD	REV
Mon 04/20/2015	to	Thu 04/30/2015			(Import)	(Export)
0500		1700			SCH - NPX_1385	0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>NRTH1385-NOR HBR__138_602</b>							
Mon 04/20/2015	to	Thu 04/30/2015	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/16/2015</u>	SCH - NPX_1385	<b>100 MW</b>
0500	Continuous	1700				Impacts Total Transfer Capability	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>							
Mon 04/20/2015	to	Thu 04/30/2015				SCH - NPX_1385	<b>0 MW</b>
0500		1700				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603</b>							
Mon 04/20/2015	to	Thu 04/30/2015	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/16/2015</u>	SCH - NPX_1385	<b>100 MW</b>
0500	Continuous	1700				Impacts Total Transfer Capability	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_1385</b>							
Mon 04/20/2015	to	Thu 04/30/2015	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/16/2015</u>	SCH - NPX_1385	<b>0 MW</b>
0500	Continuous	1700				Impacts Total Transfer Capability	200 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
<b>ROCHESTR-PANNELL__345_RP2</b>							
Mon 04/20/2015	to	Fri 04/24/2015				DYSINGER EAST	<b>2300 MW</b>
0700	Continuous	1600				Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<b>LIND_CG_-LNDVFT__345_V-3022</b>							
Tue 04/21/2015	to	Thu 04/23/2015	<u>EXTENDED</u>	<u>by PJM</u>	<u>04/21/2015</u>	SCH - PJM_VFT	<b>0 MW</b>
0900	Continuous	1400				Impacts Total Transfer Capability	315 MW
Work scheduled by: PJM						TTC with All Lines In Service	315 MW
<b>EASTVIEW-SPRNBRK__345_W64</b>							
Wed 04/22/2015	to	Wed 04/22/2015				UPNY CONED	<b>4350 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	750 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W99**

Wed 04/22/2015 to Fri 04/24/2015  
0001 Continuous 1930  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**NEWBRIDGE\_345\_138\_BK\_2**

Wed 04/22/2015 to Thu 04/23/2015  
0530 Continuous 1304  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**BECK\_\_\_\_-NIAGARA\_345\_PA302**

Thu 04/23/2015 to Fri 04/24/2015 **UPDATED by NYPA 04/22/2015**  
0400 Continuous 1700  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1400 MW 1250 MW**  
Impacts Total Transfer Capability 500 MW 650 MW  
TTC with All Lines In Service 1900 MW 1900 MW

**EGRDNCTY\_345\_138\_BK\_2**

Fri 04/24/2015 to Fri 05/08/2015 **FORCED by LI 04/24/2015**  
0001 Continuous 2359  
Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**COOPERS\_-MIDDLETP\_345\_CMT-34**

Sat 04/25/2015 to Sat 04/25/2015 **UPDATED by CH 04/22/2015**  
0700 Daily 1600  
Work scheduled by: CHGE

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_\_-COOPERS\_345\_UC2-41**

Sat 04/25/2015 to Mon 04/27/2015  
2200 Continuous 0700  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**SPRNBK\_-DUNWODIE\_345\_W75**

Sun 04/26/2015 to Sun 04/26/2015  
0001 Continuous 2100  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## OSWEGO\_COMPLEX\_AVR\_O/S

FWD

Sun 04/26/2015 to Sun 04/26/2015

(Import)

0900 Continuous 1100

CENTRAL EAST - VC

2870 MW

Impacts Total Transfer Capability 105 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: Gen

## LEEDS 345 LEEDS SVC

FWD

Mon 04/27/2015 to Fri 05/01/2015

(Import)

0700 Continuous 1500

CENTRAL EAST - VC

2950 MW

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

## FRASER -GILBOA 345\_GF5-35

FWD

Mon 04/27/2015 to Fri 05/08/2015

(Import)

0700 Continuous 1530

UPDATEDby NYPA01/09/2015

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## W49TH\_ST\_345KV\_5

FWD

Tue 04/28/2015 to Tue 04/28/2015

(Import)

0001 Continuous 0030

UPDATEDby CONED03/17/2015

SCH - PJM\_HTP

315 MW

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## SPRNBRK -W49TH\_ST\_345\_M52

FWD

Tue 04/28/2015 to Sun 05/03/2015

(Import)

0001 Continuous 2300

UPDATEDby CONED03/17/2015

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SPRNBRK 345KV\_RNS4

FWD

Tue 04/28/2015 to Sun 05/03/2015

(Import)

0001 Continuous 2300

UPDATEDby CONED03/17/2015

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_5

FWD

Sun 05/03/2015 to Sun 05/03/2015

(Import)

2230 Continuous 2300

UPDATEDby CONED03/17/2015

SCH - PJM\_HTP

315 MW

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_\_345KV\_RNS5

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### W49TH\_ST\_345KV\_5

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

315 MW

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### W49TH\_ST\_345KV\_7

FWD

Mon 05/04/2015 to Mon 05/04/2015

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

315 MW

Impacts Total Transfer Capability 345 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### EASTVIEW-SPRNBK\_\_345\_W64

FWD

Mon 05/04/2015 to Tue 05/05/2015

(Import)

0001 Continuous 2000

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

### MILLWOOD-EASTVIEW\_345\_W99

FWD

Mon 05/04/2015 to Tue 05/05/2015

(Import)

0001 Continuous 2000

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

### CHATGUAY-MASSENA\_\_765\_7040

FWD

Mon 05/04/2015 to Fri 05/22/2015

(Import)

0100 Continuous 1700

UPDATED

by NYPA

04/22/2015

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### CHATGUAY-MASSENA\_\_765\_7040

FWD

REV

Mon 05/04/2015 to Fri 05/22/2015

(Import) (Export)

0100 Continuous 1700

UPDATED

by NYPA

04/22/2015

SCH - HQ - NY

0 MW

0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_Ma1

FWD

Mon 05/04/2015 to Fri 05/08/2015  
0500 Continuous 1530

UPDATEDby NYPA04/24/2015

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

(Import)

Work scheduled by: LI

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

(Import)

Work scheduled by: LI

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

FWD

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

(Import)

Work scheduled by: LI

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

FWD

Mon 05/04/2015 to Tue 05/12/2015  
0600 Continuous 2100

(Import)

Work scheduled by: LI

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SCH-NE-NYISO\_LIMIT\_900

FWD

Mon 05/04/2015 to Thu 05/21/2015  
0600 Continuous 1700

(Import)

Work scheduled by: ISONE

SCH - NE - NY

**1100 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

## CHAT\_DC\_GC2

FWD

Mon 05/04/2015 to Thu 06/04/2015  
0600 Continuous 1800

(Import)

Work scheduled by: HQ

MOSES SOUTH

**2150 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC2

Mon 05/04/2015 to Thu 06/04/2015  
0600 Continuous 1800

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**500 MW**

500 MW

1000 MW

### HOMER C\_-WATRCURE\_345\_30

Mon 05/04/2015 to Thu 05/28/2015  
0800 Continuous 1600

Work scheduled by: NYSEG

UPDATED

by PJM

03/24/2015

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import) (Export)

**2200 MW 1300 MW**

250 MW 0 MW

2450 MW 1300 MW

### HUDSONP\_-FARRAGUT\_345\_B3402

Tue 05/05/2015 to Thu 05/14/2015  
0001 Continuous 2300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import) (Export)

**2300 MW 1300 MW**

150 MW 0 MW

2450 MW 1300 MW

### SPRNBRK\_\_345KV\_RNS5

Tue 05/05/2015 to Tue 05/05/2015  
1930 Continuous 2000

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**3200 MW**

1400 MW

4600 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Wed 05/06/2015 to Thu 05/07/2015  
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**800 MW**

700 MW

1500 MW

### SHORE\_RD\_345\_138\_BK 1

Wed 05/06/2015 to Thu 05/07/2015  
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**1350 MW**

150 MW

1500 MW

### SHORE\_RD\_345\_138\_BK 2

Wed 05/06/2015 to Wed 05/13/2015  
0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**1350 MW**

150 MW

1500 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

Wed 05/06/2015 to Wed 05/06/2015  
1830 Continuous 1900  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Wed 05/06/2015 to Wed 05/06/2015  
1830 Continuous 1900  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Fri 05/08/2015 to Fri 05/08/2015  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**SPRNBRK\_\_345KV\_RNS4**

Fri 05/08/2015 to Fri 05/08/2015  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBRK\_\_345\_W65**

Fri 05/08/2015 to Sun 05/10/2015  
0001 Continuous 2000  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**MARCY\_\_\_\_765\_345\_BK 1**

Sat 05/09/2015 to Sun 05/10/2015 **CANCELLED by NYPA 04/23/2015**  
0700 Continuous 2030  
Work scheduled by: NYPA **ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_\_\_\_765\_345\_BK 2**

Sat 05/09/2015 to Sun 05/10/2015 **CANCELLED by NYPA 04/23/2015**  
0700 Continuous 2030  
Work scheduled by: NYPA **ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1						FWD	
Sat 05/09/2015	to	Sun 05/10/2015	<u>CANCELLED</u>	<u>by NYPA</u>	<u>04/23/2015</u>	(Import)	
0700	Continuous	2030					
Work scheduled by: NYPA			ARR: 20		CENTRAL EAST - VC	2315 MW	
						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	2975 MW
<hr/>							
MASSENA_-MARCY___765_MSU1						FWD	
Sat 05/09/2015	to	Sun 05/10/2015	<u>CANCELLED</u>	<u>by NYPA</u>	<u>04/23/2015</u>	(Import)	
0700	Continuous	2030					
Work scheduled by: NYPA			ARR: 20		MOSES SOUTH	675 MW	
						Impacts Total Transfer Capability	2475 MW
						TTC with All Lines In Service	3150 MW
<hr/>							
MASSENA_-MARCY___765_MSU1						FWD	REV
Sat 05/09/2015	to	Sun 05/10/2015	<u>CANCELLED</u>	<u>by NYPA</u>	<u>04/23/2015</u>	(Import)	(Export)
0700	Continuous	2030				475 MW	1000 MW
Work scheduled by: NYPA			ARR: 20		SCH - HQ - NY	1025 MW	0 MW
						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1000 MW
<hr/>							
MILLWOOD-EASTVIEW_345_W82						FWD	
Sun 05/10/2015	to	Sun 05/10/2015				(Import)	
1930	Continuous	2000					
Work scheduled by: ConEd					UPNY CONED	4350 MW	
						Impacts Total Transfer Capability	750 MW
						TTC with All Lines In Service	5100 MW
<hr/>							
SPRNBK__345KV_RNS4						FWD	
Sun 05/10/2015	to	Sun 05/10/2015				(Import)	
1930	Continuous	2000					
Work scheduled by: ConEd					SPR/DUN-SOUTH	3200 MW	
						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	4600 MW
<hr/>							
PLSNTVLY_345KV_RNS4						FWD	
Mon 05/11/2015	to	Mon 05/11/2015				(Import)	
0001	Continuous	0030					
Work scheduled by: ConEd					UPNY CONED	3800 MW	
						Impacts Total Transfer Capability	1300 MW
						TTC with All Lines In Service	5100 MW
<hr/>							
PLSNTVLY-WOOD_ST__345_F31						FWD	
Mon 05/11/2015	to	Tue 05/12/2015				(Import)	
0001	Continuous	1800					
Work scheduled by: ConEd					UPNY CONED	4000 MW	
						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 05/11/2015 to Fri 05/15/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### EDIC\_\_\_-FRASER\_\_\_345\_EF24-40

Mon 05/11/2015 to Fri 05/15/2015  
0900 Continuous 1530

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### PLSNTVLY\_345KV\_RNS4

Tue 05/12/2015 to Tue 05/12/2015  
1730 Continuous 1800

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

### PLSNTVLY\_345KV\_RNS4

Wed 05/13/2015 to Wed 05/13/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F31

Wed 05/13/2015 to Wed 05/13/2015  
0001 Continuous 2000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### SHOR\_NPX-SHOREHAM\_138\_NPX\_CSC

Wed 05/13/2015 to Sun 05/17/2015  
0500 Continuous 1500

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### PLSNTVLY\_345KV\_RNS4

Wed 05/13/2015 to Wed 05/13/2015  
1930 Continuous 2000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PORTER\_\_-ROTTRDAM\_230\_31-PR

Fri 05/15/2015 to Sun 05/17/2015

0600 Continuous 1800

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

## HUDSONP\_-FARRAGUT\_345\_C3403

Sat 05/16/2015 to Mon 05/25/2015

0200 Continuous 2300

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY

**2300 MW 1300 MW**

Impacts Total Transfer Capability 150 MW 0 MW

TTC with All Lines In Service 2450 MW 1300 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 05/18/2015 to Fri 05/22/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 05/18/2015 to Fri 05/22/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - OH - NY

**1750 MW 1750 MW**

Impacts Total Transfer Capability 150 MW 150 MW

TTC with All Lines In Service 1900 MW 1900 MW

## LOWVILLE-BOONVILLE\_115\_5-LB

Mon 05/18/2015 to Fri 06/12/2015

0800 Continuous 1800

Work scheduled by: NGrid

**UPDATED**

**by NGRID 04/22/2015**

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**130 MW 40 MW**

Impacts Total Transfer Capability 60 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

## MARCY\_\_-COOPERS\_\_345\_UC2-41

Tue 05/19/2015 to Fri 05/22/2015

0900 Daily 1600

Work scheduled by: NYSEG

**UPDATED**

**by NYISO 04/21/2015**

FWD

(Import)

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## SCH-HQ-NYISO\_LIMIT\_1400

Tue 05/19/2015 to Fri 05/22/2015

0900 Daily 1600

Work scheduled by: NYSEG

**UPDATED**

**by NYISO 04/21/2015**

FWD

(Import)

SCH - HQ - NY

**1400 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Thu 05/21/2015 to Fri 05/22/2015  
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NYISO 03/13/2015

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

FWD

(Import)

FROST\_BR-LONG MTN\_345\_352

Fri 05/22/2015 to Sun 05/31/2015  
0600 Continuous 1500

Work scheduled by: ISONE

SCH - NE - NY **1150 MW 1600 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

FWD

(Import)

REV

(Export)

CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Tue 05/26/2015 to Wed 05/27/2015  
0700 Continuous 1600

Work scheduled by: NGrid

UPDATED by NGRID 03/13/2015

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

FWD

(Import)

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

FWD

(Import)

STLAWRNC-MOSES\_\_\_\_230\_L34P

Tue 05/26/2015 to Fri 05/29/2015  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

FWD

(Import)

REV

(Export)

ROCKTVRN-RAMAPO\_\_\_\_345\_77

Sat 05/30/2015 to Sat 06/06/2015  
0600 Continuous 2300

Work scheduled by: ORU

CENTRAL EAST - VC **2570 MW**  
Impacts Total Transfer Capability 405 MW  
TTC with All Lines In Service 2975 MW

FWD

(Import)

MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 06/01/2015 to Tue 06/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

FWD

(Import)

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PANNELL\_-CLAY\_\_\_\_\_345\_PC2**

Mon 06/01/2015 to Tue 06/02/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**WEST CENTRAL 1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Wed 06/03/2015 to Thu 06/04/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2000 MW**  
 Impacts Total Transfer Capability 1150 MW  
 TTC with All Lines In Service 3150 MW

**FRASER\_\_\_\_\_345\_FRASER SVC**

Mon 06/15/2015 to Fri 06/19/2015  
 0800 Continuous 1430

Work scheduled by: NYSEG

FWD  
 (Import)  
**CENTRAL EAST - VC 2935 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW

**BECK\_-NIAGARA\_\_\_\_\_345\_PA302**

Thu 06/25/2015 to Fri 06/26/2015  
 0500 Continuous 1600

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - OH - NY 1200 MW 1100 MW**  
 Impacts Total Transfer Capability 700 MW 800 MW  
 TTC with All Lines In Service 1900 MW 1900 MW

**MOSES\_-ADIRNDCK\_230\_MA1**

Thu 08/13/2015 to Thu 08/13/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2000 MW**  
 Impacts Total Transfer Capability 1150 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Tue 08/18/2015 to Tue 08/18/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2000 MW**  
 Impacts Total Transfer Capability 1150 MW  
 TTC with All Lines In Service 3150 MW

**ADIRNDCK-PORTER\_\_\_\_\_230\_12-AP**

Wed 08/19/2015 to Wed 08/19/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

## Seasonal Limits

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-CHASLAKE\_230\_13

Thu 08/20/2015 to Thu 08/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### EDIC-\_-FRASER\_345\_EF24-40

Mon 08/24/2015 to Fri 08/28/2015  
0700 Continuous 1630

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC 2500 MW  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MOSES-\_-ADIRNDCK\_230\_MA2

Mon 08/31/2015 to Fri 09/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2000 MW  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### MARCY-\_-EDIC\_345\_UE1-7

Tue 09/01/2015 to Sun 09/13/2015  
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 16

FWD  
(Import)  
OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### MARCY\_765\_345\_BK 2

Mon 09/07/2015 to Fri 09/11/2015  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

### HURLYAVE-ROSETON\_345\_303

Mon 09/07/2015 to Fri 09/25/2015  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

### NIAGARA\_345\_230\_BK 4

Mon 09/07/2015 to Fri 10/09/2015  
0800 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1900 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1900 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 09/14/2015 to Fri 09/18/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### COOPERS\_-MIDDLETP\_345\_CMT-34

Mon 09/14/2015 to Fri 09/18/2015  
0700 Continuous 1600  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 09/21/2015 to Fri 09/25/2015  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 09/21/2015 to Fri 09/25/2015  
0700 Continuous 1600  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

### LONG\_MTN-PLSNTVLY\_345\_398

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700  
Work scheduled by: ConEd

FWD	REV
(Import)	(Export)
SCH - NE - NY	<b>500 MW 1300 MW</b>
Impacts Total Transfer Capability	900 MW 300 MW
TTC with All Lines In Service	1400 MW 1600 MW

### LONG\_MTN-PLSNTVLY\_345\_398

Wed 09/23/2015 to Fri 10/02/2015  
0500 Continuous 1700  
Work scheduled by: ConEd

FWD	REV
(Import)	(Export)
SCH - NPX_1385	<b>100 MW 100 MW</b>
Impacts Total Transfer Capability	100 MW 100 MW
TTC with All Lines In Service	200 MW 200 MW

### BECK\_\_\_-NIAGARA\_345\_PA302

Thu 09/24/2015 to Fri 09/25/2015  
0500 Continuous 1600  
Work scheduled by: NYPA

FWD	REV
(Import)	(Export)
SCH - OH - NY	<b>1200 MW 1100 MW</b>
Impacts Total Transfer Capability	700 MW 800 MW
TTC with All Lines In Service	1900 MW 1900 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

## Seasonal Limits

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLE-DUNWODIE\_345\_W89

Mon 09/28/2015 to Mon 09/28/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### MOSES-ADIRNDCK\_230\_MA2

Mon 09/28/2015 to Fri 10/02/2015  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

### BECK-NIAGARA\_345\_PA301

Mon 09/28/2015 to Fri 10/02/2015  
0800 Continuous 1600

Work scheduled by: NYPA

	FWD	REV
(Import)	(Export)	
SCH - OH - NY	<b>1200 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

### COOPERS-ROCKTVRN\_345\_CRT-42

Mon 09/28/2015 to Fri 10/02/2015  
0900 Daily 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

### PLSNTVLE-DUNWODIE\_345\_W89

Fri 10/02/2015 to Fri 10/02/2015  
1830 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014  
0100 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 10/03/2015 to Sun 10/25/2015 UPDATED by NYPA 10/07/2014  
0100 Continuous 1730

Work scheduled by: NYPA

	FWD	REV
(Import)	(Export)	
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_BK 1						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
MARCY____765_345_BK 2						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	1700 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
MASSENA_-MARCY____765_MSU1						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				CENTRAL EAST - VC	2315 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	2975 MW
MASSENA_-MARCY____765_MSU1						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	675 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	2475 MW
						TTC with All Lines In Service	3150 MW
MASSENA_-MARCY____765_MSU1						FWD	REV
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	(Export)
0100	Continuous	1730				SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA_765_7040							
Sat 10/03/2015	to	Sun 10/25/2015				MOSES SOUTH	
0100		1730				Impacts Total Transfer Capability	
Work scheduled by:						TTC with All Lines In Service	
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2						FWD	REV
Sat 10/03/2015	to	Sun 10/25/2015				(Import)	(Export)
0100		1730				SCH - HQ - NY	850 MW 0 MW
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHOR\_NPX-SHOREHAM\_138\_NPX\_CSC

Mon 10/05/2015 to Sun 10/11/2015 **UPDATED by ISONE 07/25/2014**

0530 Continuous 1800

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

### GILBOA\_-LEEDS\_345\_GL3

Mon 10/05/2015 to Fri 10/09/2015

0700 Continuous 1600

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
CENTRAL EAST - VC	<b>2200 MW</b>	
Impacts Total Transfer Capability	775 MW	
TTC with All Lines In Service	2975 MW	

### BECK\_-PACKARD\_230\_BP76

Mon 10/05/2015 to Fri 10/09/2015

0800 Continuous 1600

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1750 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	150 MW	700 MW
TTC with All Lines In Service	1900 MW	1900 MW

### MALONE\_-WILLIS\_115\_1-MW

Tue 10/06/2015 to Tue 10/06/2015

0800 Continuous 1530

Work scheduled by: NYPA

**ARR: 20&38**

		REV
		(Export)
SCH - HQ_CEDARS		<b>40 MW</b>
Impacts Total Transfer Capability		0 MW
TTC with All Lines In Service		40 MW

### GILBOA\_-N.SCTLND\_345\_GNS1

Mon 10/12/2015 to Fri 10/30/2015

0730 Continuous 1500

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
CENTRAL EAST - VC	<b>2520 MW</b>	
Impacts Total Transfer Capability	455 MW	
TTC with All Lines In Service	2975 MW	

### LEEDS\_-HURLYAVE\_345\_301

Mon 10/12/2015 to Fri 10/30/2015

0800 Continuous 1600

Work scheduled by: CHGE

	FWD	REV
	(Import)	(Export)
UPNY CONED	<b>4100 MW</b>	
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	5100 MW	

### GOETHALS-LINDN.CG\_345\_G23L & GOETHALS-LINDN.CG\_345\_G23M

Tue 10/20/2015 to Fri 10/23/2015

0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>315 MW</b>
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,April 25, 2015 to Monday ,October 24, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CLAY -EDIC 345\_2-15**

FWD

Mon 10/26/2015 to Tue 10/27/2015

UPDATEDby PA03/27/2015

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**VOLNEY -MARC 345\_19**

FWD

Mon 11/02/2015 to Fri 11/06/2015

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**VOLNEY -MARC 345\_19**

FWD

Mon 11/02/2015 to Fri 11/06/2015

(Import)

0500 Continuous 1530

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**RAMAPO -BUCHAN\_N 345\_Y94**

FWD

Sat 11/07/2015 to Mon 11/09/2015

(Import)

0001 Continuous 2359

UPNY CONED

**4150 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**ROCKTVRN-RAMAPO 345\_77**

FWD

Sat 11/07/2015 to Fri 11/20/2015

(Import)

0800 Continuous 1600

UPDATEDby CH12/16/2014

CENTRAL EAST - VC

**2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

**ROSETON -ROCKTVRN 345\_311**

FWD

Sat 11/07/2015 to Fri 11/20/2015

(Import)

0800 Continuous 1600

UPDATEDby CH12/16/2014

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**LIND\_CG -LNDVFT 345\_V-3022**

FWD

REV

Sun 11/08/2015 to Fri 11/13/2015

(Import) (Export)

1400 Continuous 1800

SCH - PJM\_VFT

**0 MW****0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCKTVRN-RAMAPO\_\_\_345\_77

Fri 11/20/2015 to Sat 12/12/2015

1601 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

## GOETHALS-LINDN.CG\_345\_G23L &amp; GOETHALS-LINDN.CG\_345\_G23M

Mon 11/23/2015 to Thu 11/26/2015

0001 2359

Work scheduled by:

FWD

REV

(Import) (Export)

SCH - PJM\_VFT

0 MW 315 MW

Impacts Total Transfer Capability 315 MW 0 MW

TTC with All Lines In Service 315 MW 315 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Sun 11/29/2015 to Sat 12/05/2015

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4150 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 11/30/2015 to Fri 12/04/2015

0600 Continuous 1500

Work scheduled by: NGrid

FWD

REV

(Import) (Export)

SCH - NE - NY

1300 MW 1300 MW

Impacts Total Transfer Capability 100 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Mon 11/30/2015 to Fri 12/04/2015

0600 Continuous 1500

Work scheduled by: NGrid

FWD

REV

(Import) (Export)

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 11/30/2015 to Fri 12/04/2015

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2000 MW

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

## MARCY\_\_-N.SCTLND\_345\_18

Wed 12/02/2015 to Wed 12/23/2015

0700 Continuous 1500

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

2090 MW

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

UPDATED by NGRID 04/17/2015

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 12/07/2015 to Fri 12/11/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 12/14/2015 to Fri 12/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**BECK\_\_\_-NIAGARA\_345\_PA302**

FWD

REV

Thu 12/17/2015 to Fri 12/18/2015

(Import) (Export)

0500 Continuous 1600

SCH - OH - NY

**1400 MW 1250 MW**

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

---

**MARCY\_\_\_-EDIC\_\_\_345\_UE1-7**

FWD

Mon 01/04/2016 to Mon 02/29/2016

(Import)

0500 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 16**


---

**MARCY\_\_\_-COOPERS\_345\_UC2-41**

FWD

Mon 03/28/2016 to Sun 04/17/2016

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

---

**ROCKTVRN-RAMAPO\_\_\_345\_77**

FWD

Mon 04/04/2016 to Fri 04/29/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

---

**EDIC\_\_\_-FRASER\_\_\_345\_EF24-40**

FWD

Mon 05/23/2016 to Tue 05/24/2016

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Saturday ,April 25, 2015 to Monday ,October 24, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_-COOPERS\_\_345\_UC2-41

FWD

Fri 05/27/2016 to Sat 05/28/2016

( Import )

0500 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA