

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_BK 2**Fri 04/24/2015 to Sun 06/07/2015 **EXT FORCE** **by LI** **06/05/2015**

0001 Continuous 0300

Work scheduled by: LI

FWD

(Import)

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

**CHAT\_DC\_GC2**Mon 05/04/2015 to Thu 06/11/2015 **UPDATED** **by HQ** **06/04/2015**

0600 Continuous 2200

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**Mon 05/04/2015 to Thu 06/11/2015 **UPDATED** **by HQ** **06/04/2015**

0600 Continuous 2200

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

**HOMER C\_-MAINS\_NY\_345\_47**Mon 05/04/2015 to Fri 06/05/2015 **UPDATED** **by NYSEG** **06/05/2015**

0800 Continuous 2359

Work scheduled by: NYSEG

FWD

(Import) (Export)

SCH - PJ - NY

**2200 MW 1300 MW**

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 2300 MW 1300 MW

**LOWVILLE-BOONVILLE\_115\_5-LB**Mon 05/18/2015 to Sat 06/13/2015 **EXTENDED** **by NGRID** **06/03/2015**

0800 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**130 MW 40 MW**

Impacts Total Transfer Capability 60 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**FROST\_BR-LONG\_MTN\_345\_352**Fri 05/22/2015 to Sun 05/31/2015 **UPDATED** **by ISONE** **05/19/2015**

0600 Continuous 1559

Work scheduled by: ISONE

FWD

(Import) (Export)

SCH - NE - NY

**1150 MW 1600 MW**

Impacts Total Transfer Capability 250 MW 0 MW

TTC with All Lines In Service 1400 MW 1600 MW

**W49TH\_ST-E13THSTA\_345\_M55**Sat 05/30/2015 to Mon 06/01/2015 **EXTENDED** **by CONED** **05/31/2015**

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 05, 2015 to Sunday ,December 04, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EFISHKIL-WOOD\_ST\_\_345\_F39

Sun 05/31/2015 to Sun 05/31/2015  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

Sun 05/31/2015 to Sun 05/31/2015  
0001 Continuous 2000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## EFISHKIL-WOOD\_ST\_\_345\_F39

Sun 05/31/2015 to Sun 05/31/2015  
1930 Continuous 2000

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 06/01/2015 to Wed 06/03/2015  
0700 Continuous 1530

Work scheduled by: NYPA

**EXTENDED by NYPA 05/20/2015**

FWD  
(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

## E13THSTA-FARRAGUT\_345\_46

Mon 06/01/2015 to Mon 06/01/2015  
1830 Continuous 1900

Work scheduled by: ConEd

**EXTENDED by CONED 05/31/2015**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## W49TH\_ST\_345KV\_6

Mon 06/01/2015 to Mon 06/01/2015  
1830 Continuous 1900

Work scheduled by: ConEd

**EXTENDED by CONED 05/31/2015**

FWD  
(Import)  
SCH - PJM\_HTP **320 MW**  
Impacts Total Transfer Capability 340 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_5

Tue 06/02/2015 to Tue 06/02/2015  
0001 Continuous 0030

Work scheduled by: ConEd

**UPDATED by CONED 05/31/2015**

FWD  
(Import)  
SCH - PJM\_HTP **320 MW**  
Impacts Total Transfer Capability 340 MW  
TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

FWD

Tue 06/02/2015 to Tue 06/02/2015 UPDATED by CONED 05/31/2015

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**320 MW**

Impacts Total Transfer Capability 340 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SCRIBA -VOLNEY 345 20-SV**

FWD

Tue 06/02/2015 to Tue 06/02/2015

(Import)

0800 Daily(No Weekends) 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**SCH-HQ-NYISO\_LIMIT\_900**

FWD

Tue 06/02/2015 to Thu 06/04/2015 UPDATED by HQ 06/04/2015

(Import)

2200 Continuous 0059

SCH - HQ - NY

**900 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**SCH-HQ-NYISO\_LIMIT\_1450**

FWD

Wed 06/03/2015 to Thu 06/04/2015 UPDATED by HQ 06/04/2015

(Import)

0100 Continuous 1759

SCH - HQ - NY

**1450 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**W49TH\_ST\_345KV\_5**

FWD

Wed 06/03/2015 to Wed 06/03/2015 UPDATED by CONED 05/31/2015

(Import)

1830 Continuous 1900

SCH - PJM\_HTP

**320 MW**

Impacts Total Transfer Capability 340 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Wed 06/03/2015 to Wed 06/03/2015 UPDATED by CONED 05/31/2015

(Import)

1830 Continuous 1900

SCH - PJM\_HTP

**320 MW**

Impacts Total Transfer Capability 340 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**MOSES -ADIRNDCK\_230\_MAZ**

FWD

Thu 06/04/2015 to Sat 06/06/2015 UPDATED by NYPA 05/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DENNISON-ROSEMNTB\_115\_2-RD**

Thu 06/04/2015 to Thu 06/04/2015

0830 Daily(No Weekends) 1530

Work scheduled by: NGrid

**ARR: 38**FWD REV  
(Import) (Export)

SCH - HQ\_CEDARS **95 MW 40 MW**  
 Impacts Total Transfer Capability 95 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**SCH-HQ-NYISO\_LIMIT\_1350**

Thu 06/04/2015 to Thu 06/04/2015

1800 Continuous 1859

Work scheduled by: HQ

**UPDATED by HQ 06/04/2015**FWD  
(Import)

SCH - HQ - NY **1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**W49TH\_ST\_345KV\_5**

Thu 06/04/2015 to Thu 06/04/2015

1830 Continuous 1900

Work scheduled by: ConEd

**UPDATED by CONED 05/31/2015**FWD  
(Import)

SCH - PJM\_HTP **320 MW**  
 Impacts Total Transfer Capability 340 MW  
 TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_7**

Thu 06/04/2015 to Thu 06/04/2015

1830 Continuous 1900

Work scheduled by: ConEd

**UPDATED by CONED 05/31/2015**FWD  
(Import)

SCH - PJM\_HTP **320 MW**  
 Impacts Total Transfer Capability 340 MW  
 TTC with All Lines In Service 660 MW

**SCH-HQ-NYISO\_LIMIT\_1400**

Thu 06/04/2015 to Thu 06/04/2015

1900 Continuous 2200

Work scheduled by: HQ

**UPDATED by HQ 06/04/2015**FWD  
(Import)

SCH - HQ - NY **1400 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 1500 MW

**OSWEGO\_-VOLNEY\_345\_12-OV**

Fri 06/05/2015 to Fri 06/05/2015

0800 Daily(No Weekends) 1530

Work scheduled by: NGrid

**UPDATED by NG 06/03/2015**FWD  
(Import)

OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**DENNISON-SANDSTON\_115\_5-DS**

Fri 06/05/2015 to Fri 06/05/2015

0830 Daily(No Weekends) 1530

Work scheduled by: NGrid

**ARR: 38**FWD REV  
(Import) (Export)

SCH - HQ\_CEDARS **150 MW 40 MW**  
 Impacts Total Transfer Capability 40 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 05, 2015 to Sunday ,December 04, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SANDSTON-COLTON__115_5-SC</b>					FWD	REV
Fri 06/05/2015 to Fri 06/05/2015					(Import)	(Export)
0830 Daily(No Weekends) 1530					SCH - HQ_CEDARS	<b>150 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	40 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Fri 06/05/2015 to Sun 06/07/2015					(Import)	
2000 Continuous 2330					UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<b>MARCY__-COOPERS__345_UC2-41</b>					FWD	
Fri 06/05/2015 to Mon 06/08/2015					(Import)	
2200 Continuous 0700					CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>SCH-HQ-NYISO_LIMIT_1400</b>					FWD	
Fri 06/05/2015 to Mon 06/08/2015					(Import)	
2200 Continuous 0700					SCH - HQ - NY	<b>1400 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1500 MW
<b>SCH-HQ-NYISO_LIMIT_900</b>					FWD	
Sat 06/06/2015 to Sat 06/06/2015					(Import)	
0800 Continuous 1059					SCH - HQ - NY	<b>900 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1500 MW
<b>SCH-HQ-NYISO_LIMIT_1450</b>					FWD	
Sat 06/06/2015 to Mon 06/08/2015					(Import)	
1100 Continuous 1700					SCH - HQ - NY	<b>1450 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1500 MW
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>					FWD	REV
Mon 06/08/2015 to Fri 06/19/2015					(Import)	(Export)
0500 Continuous 1700					SCH - OH - NY	<b>1700 MW 1850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	200 MW 50 MW
					TTC with All Lines In Service	1900 MW 1900 MW

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**STONYRDG-HILLSIDE\_230\_72**

FWD

Mon 06/08/2015 to Wed 06/10/2015

**CANCELLED by NYSEG 06/02/2015**

(Import)

0700 Continuous 1530

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYSEG

**OSWEGO -VOLNEY\_345\_11-OV**

FWD

Mon 06/08/2015 to Mon 06/08/2015

(Import)

0800 Daily(No Weekends) 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_80**

FWD

Tue 06/09/2015 to Tue 06/09/2015

(Import)

0800 Continuous 1700

SCH - HQ\_CEDARS

**80 MW**

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 190 MW

Work scheduled by: HQ

**BROWNFLS-TAYLORVL\_115\_3-BT**

FWD

REV

Tue 06/09/2015 to Tue 06/09/2015

(Import) (Export)

0830 Daily(No Weekends) 1530

SCH - HQ\_CEDARS

**70 MW****40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

**ARR: 38****ILCTLIMIT\_115KV\_DENNI\_R8105\_TIE\_B**

FWD

REV

Wed 06/10/2015 to Wed 06/10/2015

(Import) (Export)

0830 Daily(No Weekends) 1530

SCH - HQ\_CEDARS

**110 MW****40 MW**

Impacts Total Transfer Capability 80 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

**BECK -NIAGARA\_345\_PA301**

FWD

REV

Fri 06/12/2015 to Fri 06/12/2015

(Import) (Export)

0500 Continuous 1700

**UPDATED by NYPA 05/14/2015**

SCH - OH - NY

**1200 MW****1100 MW**

Impacts Total Transfer Capability 700 MW 800 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**ELBRIDGE-LAFAYTTE\_345\_17-LE**

FWD

Fri 06/12/2015 to Fri 06/12/2015

(Import)

0730 Daily(No Weekends) 0800

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**ARR: 75**

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**OSWEGO\_\_ -ELBRIDGE\_345\_17-EO**

Fri 06/12/2015 to Fri 06/12/2015

0730 Daily(No Weekends) 1530

Work scheduled by: NGrid

**ARR: 75**

FWD

(Import)

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**ELBRIDGE-LAFAYTTE\_345\_17-LE**

Fri 06/12/2015 to Fri 06/12/2015

1500 Daily(No Weekends) 1530

Work scheduled by: NGrid

**ARR: 75**

FWD

(Import)

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**SPRNBK\_-TREMONT\_345\_X28**

Sat 06/13/2015 to Sat 06/13/2015

0001 Continuous 1900

Work scheduled by: ConEd

**UPDATED****by NYISO 06/03/2015**

FWD

(Import)

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

**SCRIBA\_-VOLNEY\_345\_21-SV**

Sat 06/13/2015 to Sat 06/13/2015

0600 Daily 1400

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**BULYMO\_-BOONVILLE\_115\_6**

Sun 06/14/2015 to Sun 06/14/2015

0600 Daily 1800

Work scheduled by: NGrid

**ARR: 38**

FWD

REV

(Import) (Export)

SCH - HQ\_CEDARS

**130 MW 40 MW**

Impacts Total Transfer Capability 60 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

**LOWVILLE-BOONVILLE\_115\_5-LB**

Mon 06/15/2015 to Sat 06/20/2015

0730 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

FWD

REV

(Import) (Export)

SCH - HQ\_CEDARS

**130 MW 40 MW**

Impacts Total Transfer Capability 60 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

**TAYLORVL-LOWVILLE\_115\_5-TL**

Mon 06/15/2015 to Sat 06/20/2015

0730 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

FWD

REV

(Import) (Export)

SCH - HQ\_CEDARS

**130 MW 40 MW**

Impacts Total Transfer Capability 60 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER\_\_\_345\_FRASER SVC**

FWD

Mon 06/15/2015 to Fri 06/19/2015

(Import)

0800 Continuous 1430

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

Work scheduled by: NYSEG

TTC with All Lines In Service 2975 MW

**BECK\_\_\_-NIAGARA\_\_\_345\_PA302**

FWD

REV

Thu 06/25/2015 to Fri 06/26/2015

(Import) (Export)

0500 Continuous 1600

SCH - OH - NY

**1200 MW 1100 MW**

Impacts Total Transfer Capability 700 MW 800 MW

Work scheduled by: NYPA

TTC with All Lines In Service 1900 MW 1900 MW

**STLAWRNC-MOSES\_\_\_230\_L34P**

FWD

REV

Mon 07/13/2015 to Sat 07/18/2015

(Import) (Export)

0700 Continuous 1530

SCH - OH - NY

**1750 MW 1750 MW**

Impacts Total Transfer Capability 150 MW 150 MW

Work scheduled by: NYPA

TTC with All Lines In Service 1900 MW 1900 MW

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 07/20/2015 to Thu 07/23/2015

(Import)

0830 Continuous 1400

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

Work scheduled by: NYSEG

TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Thu 08/13/2015 to Thu 08/13/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

Work scheduled by: NYPA

TTC with All Lines In Service 3150 MW

**FRASER\_\_\_-COOPERS\_\_\_345\_33**

FWD

Mon 08/17/2015 to Wed 11/11/2015

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

Work scheduled by: NYSEG

TTC with All Lines In Service 2975 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 08/18/2015 to Tue 08/18/2015

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

Work scheduled by: NYPA

TTC with All Lines In Service 3150 MW



**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ADIRNDCK-PORTER\_\_230\_12-AP**

FWD

Wed 08/19/2015 to Wed 08/19/2015  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**ADIRNDCK-CHASLAKE\_230\_13**

FWD

Thu 08/20/2015 to Thu 08/20/2015  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**EDIC\_\_ -FRASER\_\_345\_EF24-40**

FWD

Mon 08/24/2015 to Fri 08/28/2015  
0700 Continuous 1630

Work scheduled by: NYPA

**UPDATED by NYSEG 05/13/2015**

(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

**MOSES\_\_ -ADIRNDCK\_230\_MA2**

FWD

Mon 08/31/2015 to Fri 09/04/2015  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_\_ -EDIC\_\_345\_UE1-7**

FWD

Tue 09/01/2015 to Sun 09/13/2015  
0500 Continuous 1530

Work scheduled by: NYPA

**ARR: 16**

(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

**MARCY\_\_765\_345\_BK 2**

FWD

Mon 09/07/2015 to Fri 09/11/2015  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Mon 09/07/2015 to Fri 09/25/2015  
0800 Continuous 1600

Work scheduled by: CHGE

(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345\_230\_BK 4**

Mon 09/07/2015 to Fri 10/09/2015  
 0800 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1900 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 09/14/2015 to Fri 09/18/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

**COOPERS\_-MIDDLETP\_345\_CMT-34**

Mon 09/14/2015 to Fri 09/18/2015  
 0700 Continuous 1600

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2720 MW</b>
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 09/21/2015 to Fri 09/25/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

Mon 09/21/2015 to Fri 09/25/2015  
 0700 Continuous 1600

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2720 MW</b>
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

**LONG\_MTN-PLSNTVLY\_345\_398**

Wed 09/23/2015 to Fri 10/02/2015  
 0500 Continuous 1700

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	<b>500 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	900 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW

**LONG\_MTN-PLSNTVLY\_345\_398**

Wed 09/23/2015 to Fri 10/02/2015  
 0500 Continuous 1700

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BECK\_\_\_\_-NIAGARA\_\_345\_PA302**

Thu 09/24/2015 to Fri 09/25/2015  
 0500 Continuous 1600

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1200 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Mon 09/28/2015 to Mon 09/28/2015  
 0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

Mon 09/28/2015 to Fri 10/02/2015  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

**BECK\_\_\_\_-NIAGARA\_\_345\_PA301**

Mon 09/28/2015 to Fri 10/02/2015  
 0800 Continuous 1600

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1200 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

Mon 09/28/2015 to Fri 10/02/2015  
 0900 Daily 1600

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2720 MW</b>
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Fri 10/02/2015 to Fri 10/02/2015  
 1830 Continuous 1900

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/03/2015 to Sun 10/25/2015  
 0100 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 10/07/2014**

	FWD
	(Import)
MOSES SOUTH	<b>1550 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>CHATGUAY-MASSENA 765_7040</b>							
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>		
0100	Continuous	1730				SCH - HQ - NY	<b>0 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW
<b>MARCY 765_345_BK 1</b>						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY 765_345_BK 2</b>						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY 765_MSU1</b>						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				CENTRAL EAST - VC	<b>2315 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA -MARCY 765_MSU1</b>						FWD	
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA -MARCY 765_MSU1</b>						FWD	REV
Sat 10/03/2015	to	Sun 10/25/2015	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2014</u>	(Import)	(Export)
0100	Continuous	1730				SCH - HQ - NY	<b>475 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW
						TTC with All Lines In Service	1500 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>						FWD	
Sat 10/03/2015	to	Sun 10/25/2015				(Import)	
0100		1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230\_MMS1 & MOSES -MASSENA 230\_MMS2

Sat 10/03/2015 to Sun 10/25/2015  
 0100 1730

Work scheduled by:

**ARR: 20**

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
 (Import) (Export)

**850 MW 0 MW**

650 MW 1000 MW

1500 MW 1000 MW

SHOR\_NPX-SHOREHAM 138\_NPX\_CSC

Mon 10/05/2015 to Sun 10/11/2015  
 0530 Continuous 1800

Work scheduled by: LI

**UPDATED**

**by ISONE 07/25/2014**

SCH - NPX\_CSC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
 (Import) (Export)

**0 MW 0 MW**

330 MW 330 MW

330 MW 330 MW

GILBOA -LEEDS 345\_GL3

Mon 10/05/2015 to Fri 10/09/2015  
 0700 Continuous 1600

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**2200 MW**

775 MW

2975 MW

BECK -PACKARD 230\_BP76

Mon 10/05/2015 to Fri 10/09/2015  
 0800 Continuous 1600

Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
 (Import) (Export)

**1750 MW 1300 MW**

150 MW 600 MW

1900 MW 1900 MW

MALONE -WILLIS 115\_1-MW

Tue 10/06/2015 to Tue 10/06/2015  
 0800 Continuous 1530

Work scheduled by: NYPA

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV  
 (Export)

**40 MW**

0 MW

40 MW

**ARR: 20&38**

GILBOA -N.SCTLND 345\_GNS1

Mon 10/12/2015 to Fri 10/30/2015  
 0730 Continuous 1500

Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**2520 MW**

455 MW

2975 MW

LEEDS -HURLYAVE 345\_301

Mon 10/12/2015 to Fri 10/30/2015  
 0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
 (Import)

**4100 MW**

1000 MW

5100 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 05, 2015 to Sunday ,December 04, 2016

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**GOETHALS-LINDN CG 345\_G23L & GOETHALS-LINDN CG 345\_G23M**

Tue 10/20/2015 to Fri 10/23/2015  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>315 MW</b>
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

---

**GOETHALS-LINDN CG 345\_G23L & GOETHALS-LINDN CG 345\_G23M**

Sun 10/25/2015 to Sun 10/25/2015  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>315 MW</b>
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

---

**CLAY -EDIC 345\_2-15**

Mon 10/26/2015 to Tue 10/27/2015  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by PA 03/27/2015

	FWD
	(Import)
OSWEGO EXPORT	<b>4850 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

---

**VOLNEY -MARCY 345\_19**

Mon 11/02/2015 to Fri 11/06/2015  
0500 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2825 MW</b>
Impacts Total Transfer Capability	150 MW
TTC with All Lines In Service	2975 MW

---

**VOLNEY -MARCY 345\_19**

Mon 11/02/2015 to Fri 11/06/2015  
0500 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	<b>4900 MW</b>
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	5250 MW

---

**RAMAPO -BUCHAN N 345\_Y94**

Sat 11/07/2015 to Mon 11/09/2015  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4150 MW</b>
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	5100 MW

---

**ROCKTVRN-RAMAPO 345\_77**

Sat 11/07/2015 to Fri 11/20/2015  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
CENTRAL EAST - VC	<b>2570 MW</b>
Impacts Total Transfer Capability	405 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 05, 2015 to Sunday ,December 04, 2016

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROSETON\_-ROCKTVRN\_345\_311

Sat 11/07/2015 to Fri 11/20/2015  
0800 Continuous 1600

UPDATED by CH 12/16/2014

Work scheduled by: CHGE

UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

FWD

(Import)

## LIND\_CG\_-LNDVFT\_345\_V-3022

Sun 11/08/2015 to Fri 11/13/2015  
1400 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

FWD

(Import) (Export)

## FRASER\_-GILBOA\_345\_GF5-35

Thu 11/12/2015 to Tue 12/01/2015  
0800 Continuous 1600

Work scheduled by: NYSEG

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

FWD

(Import)

## ROCKTVRN-RAMAPO\_345\_77

Fri 11/20/2015 to Sat 12/12/2015  
1601 Continuous 2359

Work scheduled by: ConEd

CENTRAL EAST - VC **2570 MW**  
Impacts Total Transfer Capability 405 MW  
TTC with All Lines In Service 2975 MW

FWD

(Import)

## GOETHALS-LINDN\_CG\_345\_G23L &amp; GOETHALS-LINDN\_CG\_345\_G23M

Mon 11/23/2015 to Thu 11/26/2015  
0001 2359

Work scheduled by:

SCH - PJM\_VFT **0 MW** **315 MW**  
Impacts Total Transfer Capability 315 MW 0 MW  
TTC with All Lines In Service 315 MW 315 MW

FWD

(Import) (Export)

## RAMAPO\_-BUCHAN\_N\_345\_Y94

Sun 11/29/2015 to Sat 12/05/2015  
0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED **4150 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 5100 MW

FWD

(Import)

## BERKSHIR-ALPS\_345\_393

Mon 11/30/2015 to Fri 12/04/2015  
0600 Continuous 1500

Work scheduled by: NGrid

SCH - NE - NY **1300 MW** **1300 MW**  
Impacts Total Transfer Capability 100 MW 300 MW  
TTC with All Lines In Service 1400 MW 1600 MW

FWD

(Import) (Export)

**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS 345_393</b>				FWD	REV
Mon 11/30/2015	to	Fri 12/04/2015		(Import)	(Export)
0600	Continuous	1500		SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<b>MOSES -ADIRNDCK_230_MAI</b>				FWD	
Mon 11/30/2015	to	Fri 12/04/2015		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW
				TTC with All Lines In Service	3150 MW
<b>MARCY -N.SCTLND_345_18</b>				FWD	
Wed 12/02/2015	to	Wed 12/23/2015	<b>UPDATED by NGRID 04/17/2015</b>	(Import)	
0700	Continuous	1500		CENTRAL EAST - VC	<b>2090 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
<b>MOSES -ADIRNDCK_230_MAI</b>				FWD	
Mon 12/07/2015	to	Fri 12/11/2015		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES -ADIRNDCK_230_MAI</b>				FWD	
Mon 12/14/2015	to	Fri 12/18/2015		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1150 MW
				TTC with All Lines In Service	3150 MW
<b>BECK -NIAGARA 345_PA302</b>				FWD	REV
Thu 12/17/2015	to	Fri 12/18/2015		(Import)	(Export)
0500	Continuous	1600		SCH - OH - NY	<b>1400 MW 1250 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	500 MW 650 MW
				TTC with All Lines In Service	1900 MW 1900 MW
<b>MARCY -EDIC 345_UE1-7</b>				FWD	
Mon 01/04/2016	to	Mon 02/29/2016		(Import)	
0500	Continuous	1530		OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW

**ARR: 16**



**NYISO TRANSFER LIMITATIONS**

Friday ,June 05, 2015 to Sunday ,December 04, 2016

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER\_\_-COOPERS\_\_345\_33**

FWD

Mon 01/04/2016 to Mon 01/25/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

Work scheduled by: NYSEG

TTC with All Lines In Service 2975 MW

**OAKDALE\_-FRASER\_\_345\_32**

FWD

Mon 02/01/2016 to Sun 02/21/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

Work scheduled by: NYSEG

TTC with All Lines In Service 2975 MW

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Thu 02/25/2016 to Fri 02/26/2016

(Import)

0800 Continuous 1559

UPDATEDby CHGE05/06/2015

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

Work scheduled by: CHGE

TTC with All Lines In Service 2975 MW

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Sat 03/05/2016 to Sun 03/06/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

Work scheduled by: NYSEG

TTC with All Lines In Service 2975 MW

**EDIC\_\_-N.SCTLND\_345\_14-EN**

FWD

Mon 03/07/2016 to Sun 03/27/2016

(Import)

0600 Continuous 1600

CENTRAL EAST - VC

**2240 MW**

Impacts Total Transfer Capability 735 MW

Work scheduled by: NGrid

TTC with All Lines In Service 2975 MW

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Sat 03/12/2016 to Sun 03/13/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

Work scheduled by: NYSEG

TTC with All Lines In Service 2975 MW

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

FWD

Mon 03/14/2016 to Sun 03/27/2016

(Import)

0600 Continuous 1600

UPDATEDby CHGE05/06/2015

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

Work scheduled by: CHGE

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 05, 2015 to Sunday ,December 04, 2016

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_-COOPERS\_\_\_345\_UC2-41

Mon 03/28/2016 to Sun 04/17/2016

0500 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

### ROCKTVRN-RAMAPO\_\_\_345\_77

Mon 04/04/2016 to Fri 04/29/2016

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

CENTRAL EAST - VC **2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

### EDIC\_\_\_-FRASER\_\_\_345\_EF24-40

Mon 04/18/2016 to Sun 05/15/2016

0700 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

### FRASER\_\_\_-COOPERS\_\_\_345\_33

Mon 04/18/2016 to Sun 05/22/2016

0800 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC **2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

### EDIC\_\_\_-FRASER\_\_\_345\_EF24-40

Mon 05/23/2016 to Tue 05/24/2016

0500 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

### MARCY\_\_\_-COOPERS\_\_\_345\_UC2-41

Fri 05/27/2016 to Sat 05/28/2016

0500 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

### FRASER\_\_\_-COOPERS\_\_\_345\_33

Tue 05/31/2016 to Wed 06/01/2016

0700 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC **2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW