

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HOMER C_-FIVEMILE_345_37</b>						FWD	REV
Mon 11/30/2015	to	Wed 12/23/2015	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/23/2015</u>	(Import)	(Export)
0700	Continuous	1600				<b>2600 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid					SCH - PJ - NY		
					Impacts Total Transfer Capability	0 MW	0 MW
					TTC with All Lines In Service	2600 MW	1300 MW
<b>MARCY_-N.SCTLND_345_18</b>						FWD	
Fri 12/04/2015	to	Wed 12/23/2015	<u>UPDATED</u>	<u>by NGRID</u>	<u>11/25/2015</u>	(Import)	
0700	Continuous	1500				<b>2090 MW</b>	
Work scheduled by: NGrid					CENTRAL EAST - VC		
					Impacts Total Transfer Capability	885 MW	
					TTC with All Lines In Service	2975 MW	
<b>FIVEMILE-STOLLERD_345_29</b>						FWD	REV
Wed 12/09/2015	to	Tue 12/29/2015	<u>UPDATED</u>	<u>by NGRID</u>	<u>12/23/2015</u>	(Import)	(Export)
1130	Continuous	1730				<b>2600 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid					SCH - PJ - NY		
					Impacts Total Transfer Capability	0 MW	0 MW
					TTC with All Lines In Service	2600 MW	1300 MW
<b>SPRNBK_345KV_RNS5</b>						FWD	
Fri 12/11/2015	to	Sat 12/19/2015	<u>EXTENDED</u>	<u>by CONED</u>	<u>12/18/2015</u>	(Import)	
0001	Continuous	2330				<b>3200 MW</b>	
Work scheduled by: ConEd					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
<b>RAMAPO_-BUCHAN_N_345_Y94</b>						FWD	
Wed 12/16/2015	to	Mon 12/21/2015	<u>UPDATED</u>	<u>by CONED</u>	<u>12/18/2015</u>	(Import)	
0001	Continuous	2359				<b>4150 MW</b>	
Work scheduled by: ConEd					UPNY CONED		
					Impacts Total Transfer Capability	950 MW	
					TTC with All Lines In Service	5100 MW	
<b>PLSNTVLY_345KV_RNS5</b>						FWD	
Sun 12/20/2015	to	Sun 12/20/2015				(Import)	
0700	Daily	0730				<b>3800 MW</b>	
Work scheduled by: NGrid					UPNY CONED		
					Impacts Total Transfer Capability	1300 MW	
					TTC with All Lines In Service	5100 MW	
<b>LEEDS_-PLSNTVLY_345_92</b>						FWD	
Sun 12/20/2015	to	Sun 12/20/2015				(Import)	
0700	Daily	1900				<b>3800 MW</b>	
Work scheduled by: NGrid					UPNY CONED		
					Impacts Total Transfer Capability	1300 MW	
					TTC with All Lines In Service	5100 MW	

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS5**

FWD

Sun 12/20/2015 to Sun 12/20/2015  
1830 Daily 1900

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**CHAT\_DC\_GC2**

FWD

Mon 12/21/2015 to Mon 12/21/2015  
0530 Continuous 1800

(Import)

Work scheduled by: HQ

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

REV

Mon 12/21/2015 to Mon 12/21/2015  
0530 Continuous 1800

(Export)

Work scheduled by: HQ

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

**SCH-HQ-NYISO\_LIMIT\_1150**

FWD

Mon 12/21/2015 to Mon 12/21/2015  
0530 Continuous 1800

(Import)

Work scheduled by: HQ

SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

**ATHENS\_\_-PLSNTVLY\_345\_91**

FWD

Mon 12/21/2015 to Mon 12/21/2015  
0630 Daily 1730

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/21/2015 to Mon 12/21/2015  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2000 MW**  
Impacts Total Transfer Capability 1150 MW  
TTC with All Lines In Service 3150 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_100**

FWD

Mon 12/21/2015 to Mon 12/21/2015  
0800 Continuous 1600

(Import)

Work scheduled by: HQ

SCH - HQ\_CEDARS **100 MW**  
Impacts Total Transfer Capability 99 MW  
TTC with All Lines In Service 199 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

Tue 12/22/2015 to Tue 12/22/2015  
0001 Continuous 2000  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

**EGRDNCTY\_345\_138\_BK 1**

Tue 12/22/2015 to Tue 12/22/2015 **FORCED** **by LI** **12/21/2015**  
0800 Continuous 1200  
Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Wed 12/23/2015 to Wed 12/23/2015  
0001 Continuous 0559  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Wed 12/23/2015 to Wed 12/23/2015  
0001 Continuous 0559  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**EGRDNCTY\_345\_138\_BK 2**

Wed 12/23/2015 to Wed 12/23/2015 **FORCED** **by LI** **12/21/2015**  
0800 Continuous 1200  
Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Sun 12/27/2015 to Sun 12/27/2015 **CANCELLED** **by ConEd** **12/24/2015**  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

**EFISHKIL-WOOD\_ST\_345\_F39**

Sun 12/27/2015 to Sun 12/27/2015 **CANCELLED** **by ConEd** **12/24/2015**  
0001 Continuous 2100  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Sun 12/27/2015 to Sun 12/27/2015 **CANCELLED** **by ConEd** **12/24/2015**

(Import)

2030 Continuous 2100

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Mon 12/28/2015 to Wed 12/30/2015 **CANCELLED** **by ConEd** **12/22/2015**

(Import)

0001 Continuous 2100

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_5**

FWD

Mon 12/28/2015 to Sat 01/02/2016 **UPDATED** **by CONED** **12/22/2015**

(Import)

0001 Continuous 1900

SCH - PJM\_HTP

**325 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**CHAT\_DC\_GC1**

FWD

Mon 12/28/2015 to Tue 12/29/2015 **UPDATED** **by HQ** **12/18/2015**

(Import)

0530 Continuous 1800

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1**

REV

Mon 12/28/2015 to Tue 12/29/2015 **UPDATED** **by HQ** **12/18/2015**

(Export)

0530 Continuous 1800

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**SCH-HQ-NYISO\_LIMIT\_1200**

FWD

Mon 12/28/2015 to Tue 12/29/2015 **UPDATED** **by HQ** **12/18/2015**

(Import)

0530 Continuous 1800

SCH - HQ - NY

**1200 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**ATHENS\_-PLSNTVLY\_345\_91**

FWD

Mon 12/28/2015 to Wed 12/30/2015

(Import)

0630 Continuous 1930

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: NGrid

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_-COOPERS\_\_345\_UCC2-41**

FWD

Mon 12/28/2015 to Mon 12/28/2015

(Import)

0730 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**MOTTHAVN-RAINEY\_\_345\_Q11**

FWD

Sat 01/02/2016 to Sun 01/03/2016

(Import)

0001 Continuous 2330

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MARCY\_\_-EDIC\_\_345\_UE1-7**

FWD

Mon 01/04/2016 to Mon 02/29/2016

(Import)

0500 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 16****MOSES\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 01/04/2016 to Fri 01/08/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**OSWEGO\_\_-ELBRIDGE\_345\_17**

FWD

Mon 01/04/2016 to Mon 01/04/2016

(Import)

0800 Daily(No Weekends) 0830

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**ARR: 75****ELBRIDGE-LAFAYTTE\_345\_17-LE**

FWD

Mon 01/04/2016 to Mon 01/04/2016

(Import)

0800 Daily(No Weekends) 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**ARR: 75****FRASER\_\_-COOPERS\_\_345\_33**

FWD

Mon 01/04/2016 to Fri 03/04/2016

(Import)

0800 Continuous 1500

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**UPDATED****by NYSEG 12/22/2015**

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**OSWEGO\_\_-ELBRIDGE\_345\_17**

FWD

Mon 01/04/2016 to Mon 01/04/2016

(Import)

1500 Daily(No Weekends) 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

Work scheduled by: NGrid

**ARR: 75**

TTC with All Lines In Service 5250 MW

**MALONE\_\_-WILLIS\_\_115\_MW1-910**

REV

Tue 01/05/2016 to Tue 01/05/2016

(Export)

0700 Continuous 1530

SCH - HQ\_CEDARS

**60 MW**

Impacts Total Transfer Capability 40 MW

Work scheduled by: NYPA

**ARR: 20&38**

TTC with All Lines In Service 100 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Tue 01/05/2016 to Tue 01/05/2016

(Import)

0730 Continuous 1730

**UPDATED****by RGE****12/18/2015**

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

Work scheduled by: RGE

TTC with All Lines In Service 2250 MW

**N.SCTLND-LEEDS\_\_\_\_345\_93**

FWD

Wed 01/06/2016 to Wed 01/06/2016

(Import)

0730 Daily(No Weekends) 1530

**UPDATED****by NGRID****12/17/2015**

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

Work scheduled by: NGrid

TTC with All Lines In Service 2975 MW

**BRANCHBG-HOPATCON\_500\_5060**

FWD

REV

Thu 01/07/2016 to Thu 01/07/2016

(Import) (Export)

0200 Continuous 1700

SCH - PJ - NY

**2100 MW 1000 MW**

Impacts Total Transfer Capability 500 MW 300 MW

Work scheduled by: PJM

TTC with All Lines In Service 2600 MW 1300 MW

**BRANCHBG-HOPATCON\_500\_5060**

FWD

Thu 01/07/2016 to Thu 01/07/2016

(Import)

0200 Continuous 1700

TOTAL EAST

**6400 MW**

Impacts Total Transfer Capability 100 MW

Work scheduled by: PJM

TTC with All Lines In Service 6500 MW

**BRANCHBG-HOPATCON\_500\_5060**

FWD

Thu 01/07/2016 to Thu 01/07/2016

(Import)

0200 Continuous 1700

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

Work scheduled by: PJM

TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Fri 01/08/2016 to Fri 01/08/2016 **UPDATED** **by CONED** **12/22/2015**

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Fri 01/08/2016 to Fri 01/08/2016 **UPDATED** **by CONED** **12/22/2015**

(Import)

0001 Continuous 2359

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Fri 01/08/2016 to Fri 01/08/2016 **UPDATED** **by CONED** **12/22/2015**

(Import)

2330 Continuous 2359

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 2**

FWD

Mon 01/11/2016 to Tue 01/19/2016 **UPDATED** **by LIPA** **11/02/2015**

(Import)

0001 Continuous 2359

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**MOSES\_-ADIRNDCK\_230\_MA2**

FWD

Mon 01/11/2016 to Fri 01/15/2016 **UPDATED** **by NYPA** **12/18/2015**

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOTTHAVN-RAINEY\_345\_Q12**

FWD

Sat 01/16/2016 to Sun 01/17/2016

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Mon 01/18/2016 to Fri 01/22/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_BK 1**

FWD

Mon 01/25/2016 to Mon 01/25/2016

(Import)

0001 Continuous 2359

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 01/25/2016 to Fri 01/29/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**EGRDNCTY\_345\_138\_BK 2**

FWD

Tue 01/26/2016 to Tue 01/26/2016

(Import)

0001 Continuous 2359

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

**N.SCTLND-LEEDS\_\_345\_94**

FWD

Tue 01/26/2016 to Wed 01/27/2016

(Import)

0730 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/01/2016 to Sat 02/06/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**OAKDALE\_-FRASER\_\_345\_32**

FWD

Mon 02/01/2016 to Sun 02/21/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Tue 02/02/2016 to Thu 02/04/2016

(Import)

0800 Continuous 1600

**UPDATED****by CHGE****10/19/2015**

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 02/08/2016 to Sat 02/13/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/15/2016 to Fri 02/19/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY\_\_\_345\_STATCOM SVC**

FWD

Mon 02/15/2016 to Tue 03/01/2016

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/22/2016 to Sat 02/27/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Thu 02/25/2016 to Fri 02/26/2016

(Import)

0800 Continuous 1559

**UPDATED****by CHGE****05/06/2015**

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/29/2016 to Fri 03/04/2016

(Import)

0700 Continuous 1530

**UPDATED****by NYPA****08/29/2015**

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**PANNELL\_-CLAY\_\_\_345\_1**

FWD

Tue 03/01/2016 to Wed 03/02/2016

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER -GILBOA 345\_GF5-35**

FWD

Tue 03/01/2016 to Fri 03/04/2016

**CANCELLED by NYPA 12/22/2015**

(Import)

0801 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**PANNELL -CLAY 345\_2**

FWD

Thu 03/03/2016 to Fri 03/04/2016

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA 765\_7040**

FWD

Sat 03/05/2016 to Sun 03/06/2016

(Import)

0100 Continuous 1730

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA 765\_7040**

FWD

REV

Sat 03/05/2016 to Sun 03/06/2016

(Import) (Export)

0100 Continuous 1730

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**MASSENA -MARCY 765\_MSU1**

FWD

Sat 03/05/2016 to Sun 03/06/2016

(Import)

0100 Continuous 1730

CENTRAL EAST - VC

**2315 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 20****MASSENA -MARCY 765\_MSU1**

FWD

Sat 03/05/2016 to Sun 03/06/2016

(Import)

0100 Continuous 1730

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 20****MASSENA -MARCY 765\_MSU1**

FWD

REV

Sat 03/05/2016 to Sun 03/06/2016

(Import) (Export)

0100 Continuous 1730

SCH - HQ - NY

**475 MW****1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**ARR: 20**

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sat 03/05/2016 to Sun 03/06/2016  
 0100 1730

Work scheduled by:

**ARR: 20**

FWD  
 (Import)  
**MOSES SOUTH 500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2**

Sat 03/05/2016 to Sun 03/06/2016  
 0100 1730

Work scheduled by:

**ARR: 20**

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY 850 MW 0 MW**  
 Impacts Total Transfer Capability 650 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**COOPERS\_-MIDDLETP\_345\_CMT-34**

Sat 03/05/2016 to Sun 03/06/2016  
 0800 Continuous 1600

Work scheduled by: NYSEG

FWD  
 (Import)  
**CENTRAL EAST - VC 2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

**N.SCTLND-ALPS\_345\_2**

Mon 03/07/2016 to Mon 03/14/2016  
 0600 Continuous 1600

Work scheduled by: NGrid

FWD REV  
 (Import) (Export)  
**SCH - NE - NY 900 MW 1600 MW**  
 Impacts Total Transfer Capability 500 MW 0 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

**N.SCTLND-ALPS\_345\_2**

Mon 03/07/2016 to Mon 03/14/2016  
 0600 Continuous 1600

Work scheduled by: NGrid

FWD REV  
 (Import) (Export)  
**SCH - NPX\_1385 100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

**N.SCTLND-LEEDS\_345\_93**

Mon 03/07/2016 to Mon 03/14/2016  
 0600 Continuous 1600

Work scheduled by: NGrid

FWD  
 (Import)  
**CENTRAL EAST - VC 2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**EDIC\_-N.SCTLND\_345\_14**

Mon 03/07/2016 to Sun 03/27/2016  
 0600 Continuous 1600

Work scheduled by: NGrid

FWD  
 (Import)  
**CENTRAL EAST - VC 2240 MW**  
 Impacts Total Transfer Capability 735 MW  
 TTC with All Lines In Service 2975 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/07/2016 to Fri 03/11/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-ROCHESTR\_345\_NR2**

FWD

Mon 03/07/2016 to Wed 03/09/2016

(Import)

1000 Continuous 1700

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Thu 03/10/2016 to Fri 03/11/2016

(Import)

0500 Continuous 1700

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**COOPERS\_-MIDDLETP\_345\_CMT-34**

FWD

Sat 03/12/2016 to Sun 03/13/2016

(Import)

0800 Continuous 1600

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**FROST\_BR-LONG\_MTN\_345\_352**

FWD

REV

Sun 03/13/2016 to Sun 03/13/2016

(Import) (Export)

0600 Continuous 1530

SCH - NE - NY

**1300 MW 1600 MW**

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by: ISONE

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

FWD

Mon 03/14/2016 to Sun 03/27/2016

(Import)

0600 Continuous 1600

UPDATEDby CHGE05/06/2015

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

**CLAY\_\_\_-EDIC\_\_\_345\_1-16**

FWD

Mon 03/14/2016 to Tue 03/15/2016

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/14/2016 to Sat 03/19/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**BECK\_\_\_-PACKARD\_230\_BP76**

FWD

REV

Tue 03/15/2016 to Tue 03/15/2016

(Import) (Export)

0645 Daily(No Weekends) 1600

SCH - OH - NY

**1600 MW 1650 MW**

Impacts Total Transfer Capability 300 MW 250 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NGrid

**CLAY\_\_\_-EDIC\_\_\_345\_2-15**

FWD

Wed 03/16/2016 to Thu 03/17/2016

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB**

FWD

REV

Fri 03/18/2016 to Fri 03/18/2016

(Import) (Export)

0700 Continuous 1530

SCH - OH - NY

**1600 MW 1650 MW**

Impacts Total Transfer Capability 300 MW 250 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/21/2016 to Sat 03/26/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_\_\_345\_RP1**

FWD

Mon 03/21/2016 to Tue 03/22/2016

(Import)

1000 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_\_\_345\_RP2**

FWD

Wed 03/23/2016 to Thu 03/24/2016

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

FWD

Mon 03/28/2016 to Tue 03/29/2016

(Import)

0500 Continuous 0500

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MARCY\_-COOPERS\_345\_UCC2-41**

FWD

Mon 03/28/2016 to Sun 04/17/2016

(Import)

0500 Continuous 1530

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MAI**

FWD

Mon 03/28/2016 to Sat 04/02/2016

(Import)

0700 Continuous 1530

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MOSES\_-ADIRNDCK\_230\_MAI**

FWD

Mon 04/04/2016 to Sat 04/09/2016

(Import)

0700 Continuous 1530

MOSES SOUTH **2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ROCKTVRN-RAMAPO\_345\_77**

FWD

Mon 04/04/2016 to Fri 04/29/2016

(Import)

0800 Continuous 1559

**UPDATED by CHGE 11/13/2015**CENTRAL EAST - VC **2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: CHGE

**W49TH\_ST\_345KV\_7**

FWD

Sun 04/10/2016 to Sun 04/10/2016

(Import)

0001 Continuous 0030

SCH - PJM\_HTP **329 MW**

Impacts Total Transfer Capability 331 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Sun 04/10/2016 to Sun 04/10/2016

(Import)

0001 Continuous 0030

SCH - PJM\_HTP **329 MW**

Impacts Total Transfer Capability 331 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sun 04/10/2016 to Sat 04/16/2016

0001 Continuous 1800

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**MOSES -ADIRNDCK\_230\_MAI**

Mon 04/11/2016 to Fri 04/15/2016

0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED****by PA****08/27/2015**

FWD

(Import)

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

**BECK -NIAGARA\_230\_PA27**

Fri 04/15/2016 to Fri 04/15/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - OH - NY

**1900 MW 1900 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 1900 MW 1900 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 04/16/2016 to Sun 04/17/2016

0100 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 04/16/2016 to Sun 04/17/2016

0100 Continuous 1530

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - HQ - NY

**0 MW 0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

**MASSENA -MARC\_765\_MSU1**

Sat 04/16/2016 to Sun 04/17/2016

0100 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2315 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

**ARR: 20****MASSENA -MARC\_765\_MSU1**

Sat 04/16/2016 to Sun 04/17/2016

0100 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

**ARR: 20**

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>	FWD	REV
Sat 04/16/2016 to Sun 04/17/2016	(Import)	(Export)
0100 Continuous 1530	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	1025 MW 0 MW
<b>ARR: 20</b>	TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>	FWD	
Sat 04/16/2016 to Sun 04/17/2016	(Import)	
0100 1530	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	2650 MW
<b>ARR: 20</b>	TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>	FWD	REV
Sat 04/16/2016 to Sun 04/17/2016	(Import)	(Export)
0100 1530	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:	Impacts Total Transfer Capability	650 MW 1000 MW
<b>ARR: 20</b>	TTC with All Lines In Service	1500 MW 1000 MW
<b>W49TH_ST_345KV_7</b>	FWD	
Sat 04/16/2016 to Sat 04/16/2016	(Import)	
1730 Continuous 1800	SCH - PJM_HTP	<b>329 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	331 MW
	TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>	FWD	
Sat 04/16/2016 to Sat 04/16/2016	(Import)	
1730 Continuous 1800	SCH - PJM_HTP	<b>329 MW</b>
Work scheduled by: ConEd	Impacts Total Transfer Capability	331 MW
	TTC with All Lines In Service	660 MW
<b>EDIC_-FRASER_345_EF24-40</b>	FWD	
Mon 04/18/2016 to Sun 05/15/2016	(Import)	
0500 Continuous 1600	CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYSEG	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>	FWD	
Mon 04/18/2016 to Sat 04/23/2016	(Import)	
0700 Continuous 1530	MOSES SOUTH	<b>2000 MW</b>
Work scheduled by: NYPA	Impacts Total Transfer Capability	1150 MW
	TTC with All Lines In Service	3150 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_-COOPERS\_\_345\_33

Mon 04/18/2016 to Sun 05/22/2016

0800 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

## HOMER C\_-FIVEMILE\_345\_37

Wed 04/20/2016 to Thu 05/19/2016

0800 Continuous 1600

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 04/25/2016 to Fri 04/29/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

## BERKSHIR-ALPS\_\_\_\_345\_393

Mon 04/25/2016 to Mon 04/25/2016

0830 Daily(No Weekends) 1030

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NE - NY

**1300 MW 1300 MW**

Impacts Total Transfer Capability 100 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_\_\_\_345\_393

Mon 04/25/2016 to Mon 04/25/2016

0830 Daily(No Weekends) 1030

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## ROCKTVRN-RAMAPO\_\_\_\_345\_77

Fri 04/29/2016 to Sat 05/14/2016

1600 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

CENTRAL EAST - VC

**2570 MW**

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

## LINDN\_CG-LNDVFT\_\_\_\_345\_V-3022

Sun 05/01/2016 to Fri 05/06/2016

1300 Continuous 1800

Work scheduled by: PJM

FWD

(Import) (Export)

SCH - PJM\_VFT

**0 MW 0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/02/2016 to Fri 05/06/2016

0001 Continuous 1800

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/02/2016 to Fri 05/06/2016

0001 Continuous 1800

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NIAGARA\_-KINTIGH\_345\_NS1-38**

Mon 05/02/2016 to Fri 05/06/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

Sat 05/07/2016 to Sat 05/07/2016

1600 Daily 1800

Work scheduled by: NGrid

FWD

REV

(Import) (Export)

SCH - NE - NY

**950 MW 1000 MW**

Impacts Total Transfer Capability 450 MW 600 MW

TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-ALPS\_\_\_\_\_345\_393**

Sat 05/07/2016 to Sat 05/07/2016

1600 Daily 1800

Work scheduled by: NGrid

FWD

REV

(Import) (Export)

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

**GILBOA\_-N.SCTLND\_345\_GNS-1**

Mon 05/09/2016 to Fri 05/13/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2520 MW**

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

**RAMAPO\_-BUCHAN\_N\_345\_Y94**

Thu 05/12/2016 to Sat 05/14/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4150 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**COOPERS\_-ROCKTVRN\_345\_CRT-42**

FWD

Mon 05/16/2016 to Fri 05/20/2016

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ROSETON\_-ROCKTVRN\_345\_311**

FWD

Mon 05/16/2016 to Fri 06/03/2016

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**EDIC\_-FRASER\_345\_EF24-40**

FWD

Mon 05/23/2016 to Tue 05/24/2016

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**LEEDS\_345\_LEEDS SVC**

FWD

Mon 05/23/2016 to Fri 06/10/2016

(Import)

0730 Continuous 1500

CENTRAL EAST - VC

**2950 MW**

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

**MARCY\_-COOPERS\_345\_UCC2-41**

FWD

Fri 05/27/2016 to Sat 05/28/2016

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**FRASER\_-COOPERS\_345\_33**

FWD

Tue 05/31/2016 to Wed 06/01/2016

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**NIAGARA\_-KINTIGH\_345\_NS1-38**

FWD

Fri 06/03/2016 to Fri 06/03/2016

(Import)

0700 Continuous 1530

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FRASER -GILBOA 345\_GF5-35**

Sat 06/04/2016 to Fri 06/10/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**MOSES -ADIRNDCK 230\_MA1**

Mon 06/27/2016 to Wed 06/29/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2000 MW**  
 Impacts Total Transfer Capability 1150 MW  
 TTC with All Lines In Service 3150 MW

**MARCY -COOPERS 345\_UCC2-41**

Sun 08/28/2016 to Wed 08/31/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**GILBOA -LEEDS 345\_GL3**

Mon 09/05/2016 to Fri 09/09/2016  
 0800 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2200 MW**  
 Impacts Total Transfer Capability 775 MW  
 TTC with All Lines In Service 2975 MW

**MARCY 765\_345\_BK 2**

Tue 09/06/2016 to Sun 09/11/2016  
 0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**MOSES -ADIRNDCK 230\_MA1**

Mon 09/12/2016 to Sat 09/17/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2000 MW**  
 Impacts Total Transfer Capability 1150 MW  
 TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON 345\_303**

Mon 09/12/2016 to Fri 09/30/2016  
 0800 Continuous 1600

Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_BK 4						FWD	REV
						(Import)	(Export)
Wed 09/14/2016	to	Thu 09/15/2016	<u>UPDATED</u>	<u>by PA</u>	<u>09/18/2015</u>	SCH - OH - NY	<b>1900 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	0 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1900 MW
BECK____-NIAGARA__345_PA301						FWD	REV
						(Import)	(Export)
Fri 09/16/2016	to	Fri 09/16/2016				SCH - OH - NY	<b>1200 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	700 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1900 MW
FITZPTRK-EDIC____345_FE-1						FWD	
						(Import)	
Mon 09/19/2016	to	Sun 10/02/2016				OSWEGO EXPORT	<b>4800 MW</b>
0630	Continuous	1800				Impacts Total Transfer Capability	450 MW
Work scheduled by: NGrid						TTC with All Lines In Service	5250 MW
MOSES____-ADIRNDCK_230_MA1						FWD	
						(Import)	
Mon 09/19/2016	to	Sat 09/24/2016				MOSES SOUTH	<b>2000 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	1150 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
BECK____-NIAGARA__230_PA27						FWD	REV
						(Import)	(Export)
Mon 09/19/2016	to	Sun 11/06/2016				SCH - OH - NY	<b>1900 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	0 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1900 MW
NRTH1385-NOR HBR__138_601						FWD	REV
						(Import)	(Export)
Mon 09/26/2016	to	Fri 09/30/2016				SCH - NPX_1385	<b>100 MW</b>
0700	Continuous	1600				Impacts Total Transfer Capability	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602						FWD	REV
						(Import)	(Export)
Mon 09/26/2016	to	Fri 09/30/2016				SCH - NPX_1385	<b>0 MW</b>
0700		1600				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
 0700 1600

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**NRTH1385-NOR HBR\_\_138\_602**

Mon 09/26/2016 to Fri 09/30/2016  
 0700 Continuous 1600

Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
 0700 1600

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
 0700 Continuous 1600

Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

**NRTH1385-NRTHPORT\_138\_1385**

Mon 09/26/2016 to Fri 09/30/2016  
 0700 Continuous 1600

Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 09/26/2016 to Sat 10/01/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	<b>2000 MW</b>
Impacts Total Transfer Capability	1150 MW
TTC with All Lines In Service	3150 MW

**MARCY\_\_-COOPERS\_\_345\_UCC2-41**

Mon 10/03/2016 to Sun 10/09/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 10/04/2016 to Fri 10/07/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**LEEDS\_\_\_-HURLYAVE\_345\_301**

FWD

Mon 10/10/2016 to Fri 11/04/2016

(Import)

0700 Continuous 1600

UPDATEDby NGRID 07/09/2015

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: NGrid

**LEEDS\_\_\_345KV\_R94301**

FWD

Mon 10/10/2016 to Fri 11/04/2016

(Import)

0700 Continuous 1600

UPDATEDby NGRID 07/09/2015

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: NGrid

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 10/11/2016 to Fri 10/14/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA\_\_\_765\_7040**

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

UPDATEDby NYPA 10/08/2015

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA\_\_\_765\_7040**

FWD

REV

Sat 10/15/2016 to Sat 10/29/2016

(Import) (Export)

0100 Continuous 1730

UPDATEDby NYPA 10/08/2015

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**MASSENA\_-MARCY\_\_\_765\_MSU1**

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

UPDATEDby NYPA 10/08/2015

CENTRAL EAST - VC

**2315 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 20**

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>					FWD	
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2015</u>	(Import)
0100	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>500 MW</b>
					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
					ARR: 20	
<b>MASSENA_-MARCY_765_MSU1</b>					FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2015</u>	(Import) (Export)
0100	Continuous	1730				
Work scheduled by: NYPA					SCH - HQ - NY	<b>475 MW 1000 MW</b>
					Impacts Total Transfer Capability	1025 MW 0 MW
					TTC with All Lines In Service	1500 MW 1000 MW
					ARR: 20	
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>					FWD	
Sat 10/15/2016	to	Sat 10/29/2016				(Import)
0100		1730				
Work scheduled by:					MOSES SOUTH	<b>500 MW</b>
					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
					ARR: 20	
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>					FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016				(Import) (Export)
0100		1730				
Work scheduled by:					SCH - HQ - NY	<b>850 MW 0 MW</b>
					Impacts Total Transfer Capability	650 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
					ARR: 20	
<b>MARCY_765_345_BK 2</b>					FWD	
Mon 10/24/2016	to	Fri 10/28/2016				(Import)
0700	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
					ARR: 19	
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
Mon 10/31/2016	to	Sat 11/05/2016				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	<b>2000 MW</b>
					Impacts Total Transfer Capability	1150 MW
					TTC with All Lines In Service	3150 MW
<b>LEEDS_-PLSNTVLY_345_92</b>					FWD	
Mon 11/07/2016	to	Wed 12/07/2016	<u>UPDATED</u>	<u>by CONED</u>	<u>09/16/2015</u>	(Import)
0001	Continuous	2359				
Work scheduled by: NGrid					UPNY CONED	<b>3800 MW</b>
					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLY\_345KV\_RNS5**

FWD

Mon 11/07/2016 to Wed 12/07/2016 **UPDATED by CONED 09/16/2015**

(Import)

0001 Continuous 2359

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/07/2016 to Thu 11/10/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

**BECK\_\_-NIAGARA\_345\_PA301**

FWD

REV

Mon 11/14/2016 to Fri 11/18/2016

(Import) (Export)

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

**1400 MW 1250 MW**

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/14/2016 to Sat 11/19/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/21/2016 to Wed 11/23/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 11/28/2016 to Fri 12/02/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/05/2016 to Fri 12/09/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,December 24, 2015 to Saturday ,June 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/12/2016 to Fri 12/16/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 12/12/2016 to Fri 12/30/2016

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/19/2016 to Thu 12/22/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2000 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA