

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56					FWD	
Fri 01/01/2016	to	Sun 05/01/2016	<u>EXT FORCE</u>	<u>by PJM</u>	<u>01/22/2016</u>	(Import)
1308	Continuous	2359				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	660 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
MARCY -EDIC 345 UE1-7					FWD	
Mon 01/04/2016	to	Fri 02/26/2016	<u>UPDATED</u>	<u>by NG</u>	<u>02/10/2016</u>	(Import)
0500	Continuous	0830				5250 MW
Work scheduled by: NYPA					OSWEGO EXPORT	0 MW
					Impacts Total Transfer Capability	5250 MW
					TTC with All Lines In Service	5250 MW
FRASER -COOPERS 345_33					FWD	
Mon 01/04/2016	to	Fri 03/04/2016	<u>UPDATED</u>	<u>by NYSEG</u>	<u>01/29/2016</u>	(Import)
0800	Continuous	1500				2395 MW
Work scheduled by: NYSEG					CENTRAL EAST - VC	580 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	2975 MW
W49TH_ST-E13THSTA_345_M54					FWD	
Thu 01/21/2016	to	Mon 03/14/2016	<u>EXT FORCE</u>	<u>by CE</u>	<u>02/03/2016</u>	(Import)
0255	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	4600 MW
OAKDALE -FRASER 345_32					FWD	
Mon 02/01/2016	to	Sun 02/21/2016				(Import)
0800	Continuous	1600				2650 MW
Work scheduled by: NYSEG					CENTRAL EAST - VC	325 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	2975 MW
SCH-HQ-NYISO_LIMIT_1450					FWD	
Thu 02/04/2016	to	Fri 02/12/2016	<u>UPDATED</u>	<u>by HQ</u>	<u>02/03/2016</u>	(Import)
0001	Continuous	2100				1450 MW
Work scheduled by: HQ					SCH - HQ - NY	50 MW
					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	1500 MW
HUDSONP -FARRAGUT_345_B3402					FWD	REV
Fri 02/05/2016	to	Fri 02/12/2016	<u>FORCED</u>	<u>by CONED</u>	<u>02/05/2016</u>	(Import) (Export)
1015	Continuous	2359				2600 MW 1300 MW
Work scheduled by: ConEd					SCH - PJ - NY	0 MW 0 MW
					Impacts Total Transfer Capability	2600 MW 1300 MW
					TTC with All Lines In Service	2600 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday, August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOTTHAVN-RAINEY\_\_\_345\_Q11

Sat 02/06/2016 to Sat 02/06/2016 CANCELLED by ConEd 02/05/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## SCH-HQ-NYISO\_LIMIT\_1300

Sun 02/07/2016 to Sun 02/07/2016 RETURNED by NYISO 02/07/2016

0500 Continuous 1344

Work scheduled by: NGrid

FWD  
(Import)  
SCH - HQ - NY **1300 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1500 MW

## VOLNEY\_\_-MARCY\_\_\_345\_19

Sun 02/07/2016 to Sun 02/07/2016 RETURNED by NYISO 02/07/2016

0530 Continuous 1339

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

## VOLNEY\_\_-MARCY\_\_\_345\_19

Sun 02/07/2016 to Sun 02/07/2016 RETURNED by NYISO 02/07/2016

0530 Continuous 1339

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 02/08/2016 to Sat 02/13/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## VOLNEY\_\_-CLAY\_\_\_345\_6

Wed 02/10/2016 to Thu 02/11/2016

0730 Continuous 1700

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## MOTTHAVN-RAINEY\_\_\_345\_Q11

Sat 02/13/2016 to Sat 02/13/2016 UPDATED by CONED 02/09/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## OSWEGO\_COMPLEX\_AVR\_O/S

Sun 02/14/2016 to Sun 02/14/2016  
0900 Continuous 1100

Work scheduled by: Gen

FWD  
(Import)  
CENTRAL EAST - VC **2870 MW**  
Impacts Total Transfer Capability 105 MW  
TTC with All Lines In Service 2975 MW

## MOSES-ADIRNDCK\_230\_MAI

Tue 02/16/2016 to Fri 02/19/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MARCY-345\_STATCOM SVC

Tue 02/16/2016 to Tue 03/01/2016 UPDATED by PA 01/13/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## CHAT\_DC\_GC1

Wed 02/17/2016 to Wed 02/17/2016  
0500 Continuous 0600

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Wed 02/17/2016 to Wed 02/17/2016  
0500 Continuous 0600

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Wed 02/17/2016 to Wed 02/17/2016  
0500 0600

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Wed 02/17/2016 to Wed 02/17/2016  
0500 0600

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, February 10, 2016 to Friday , August 11, 2017

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC2**

FWD

Wed 02/17/2016 to Wed 02/17/2016  
0500 Continuous 0600

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC2**

REV

Wed 02/17/2016 to Wed 02/17/2016  
0500 Continuous 0600

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**SCH-HQ-NYISO\_LIMIT\_800**

FWD

Wed 02/17/2016 to Wed 02/17/2016  
0500 Continuous 0600

(Import)

SCH - HQ - NY

**800 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**SCH-HQ-NYISO\_LIMIT\_1450**

FWD

Wed 02/17/2016 to Thu 02/18/2016  
0900 Continuous 1700

(Import)

SCH - HQ - NY

**1450 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1**

FWD

Fri 02/19/2016 to Fri 02/19/2016  
0500 Continuous 0600

(Import)

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1**

REV

Fri 02/19/2016 to Fri 02/19/2016  
0500 Continuous 0600

(Export)

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

FWD

Fri 02/19/2016 to Fri 02/19/2016  
0500 Continuous 0600

(Import)

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Fri 02/19/2016 to Fri 02/19/2016  
0500 0600

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHAT\_DC\_GC2

Fri 02/19/2016 to Fri 02/19/2016  
0500 Continuous 0600

Work scheduled by: HQ

	FWD (Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

### CHAT\_DC\_GC2

Fri 02/19/2016 to Fri 02/19/2016  
0500 Continuous 0600

Work scheduled by: HQ

	REV (Export)
SCH - HQ - NY	<b>500 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

### SCH-HQ-NYISO\_LIMIT\_800

Fri 02/19/2016 to Fri 02/19/2016  
0500 Continuous 0600

Work scheduled by: HQ

	FWD (Import)
SCH - HQ - NY	<b>800 MW</b>
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1500 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MAI

Sun 02/21/2016 to Fri 02/26/2016  
0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED by PA 02/10/2016**

	FWD (Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### HOPATCON-RAMAPO\_\_\_500\_5018

Mon 02/22/2016 to Sat 02/27/2016  
0001 Continuous 1900

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	500 MW	300 MW
TTC with All Lines In Service	2600 MW	1300 MW

### HOPATCON-RAMAPO\_\_\_500\_5018

Mon 02/22/2016 to Sat 02/27/2016  
0001 Continuous 1900

Work scheduled by: ConEd

	FWD (Import)
TOTAL EAST	<b>6400 MW</b>
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	6500 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOPATCON-RAMAPO\_\_\_500\_5018

Mon 02/22/2016 to Sat 02/27/2016

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

## RAMAPO\_\_\_345\_345\_PAR3500

Mon 02/22/2016 to Sat 02/27/2016

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY

**2400 MW 1300 MW**

Impacts Total Transfer Capability 200 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

## RAMAPO\_\_\_345\_345\_PAR4500

Mon 02/22/2016 to Sat 02/27/2016

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY

**2400 MW 1300 MW**

Impacts Total Transfer Capability 200 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

## RAMAPO\_\_\_500\_345\_BK 1500

Mon 02/22/2016 to Sat 02/27/2016

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY

**2100 MW 1000 MW**

Impacts Total Transfer Capability 500 MW 300 MW

TTC with All Lines In Service 2600 MW 1300 MW

## RAMAPO\_\_\_500\_345\_BK 1500

Mon 02/22/2016 to Sat 02/27/2016

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import)

TOTAL EAST

**6400 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 6500 MW

## RAMAPO\_\_\_500\_345\_BK 1500

Mon 02/22/2016 to Sat 02/27/2016

0001 Continuous 1900

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

## COOPERS\_-MIDDLETP\_345\_CMT-34

Thu 02/25/2016 to Fri 02/26/2016

0800 Continuous 1559

Work scheduled by: CHGE

FWD

(Import)

UPDATED

by CHGE

05/06/2015

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO-NYISO_LIMIT_1100</b>					FWD	
Mon 02/29/2016	to	Mon 02/29/2016			(Import)	
0600	Continuous	1700		SCH - OH - NY	<b>1400 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1900 MW
<b>SCH-IMO-NYISO_LIMIT_900</b>					FWD	
Tue 03/01/2016	to	Tue 03/01/2016			(Import)	
0600	Continuous	1700		SCH - OH - NY	<b>1200 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1900 MW
<b>PANNELL_-CLAY____345_1</b>					FWD	
Tue 03/01/2016	to	Wed 03/02/2016			(Import)	
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>MOSES_-ADIRNDCK_230_MA1</b>					FWD	
Tue 03/01/2016	to	Fri 03/04/2016	<b>UPDATED</b>	<b>by NYPA</b>	(Import)	
0700	Continuous	1530			<b>2300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>WATRCURE-OAKDALE__345_31</b>					FWD	REV
Wed 03/02/2016	to	Wed 03/02/2016			(Import)	(Export)
0800	Continuous	1630		SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2600 MW
<b>PANNELL_-CLAY____345_2</b>					FWD	
Thu 03/03/2016	to	Fri 03/04/2016			(Import)	
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
<b>GILBOA_-N.SCTLND_345_GNS-1</b>					FWD	
Thu 03/03/2016	to	Thu 03/03/2016			(Import)	
0800	Daily(No Weekends)	1230		CENTRAL EAST - VC	<b>2520 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday, August 11, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_\_345\_FRASER SVC

Thu 03/03/2016 to Thu 03/03/2016  
0900 Continuous 1330

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 20

FWD  
(Import)  
CENTRAL EAST - VC **2315 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 2975 MW

## MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 20

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by: NYPA

ARR: 20

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

## MASSENA\_-MARCY\_\_\_765\_MSU1 &amp; CHATGUAY-MASSENA\_\_\_765\_7040

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by:

ARR: 20

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday, August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES -MASSENA\_230\_MMS1 & MOSES -MASSENA\_230\_MMS2

Sat 03/05/2016 to Sun 03/06/2016  
0100 1730

Work scheduled by:

ARR: 20

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## ATHENS -PLSNTVLY\_345\_91

Sat 03/05/2016 to Sun 03/06/2016  
0700 Continuous 1700

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

## COOPERS -MIDDLETP\_345\_CMT-34

Sat 03/05/2016 to Sun 03/06/2016  
0800 Continuous 1600

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2720 MW
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

## MARCY -COOPERS\_345\_UCC2-41

Sun 03/06/2016 to Mon 03/07/2016  
1800 Continuous 0559

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

## EASTVIEW-SPRNBK\_345\_W79

Mon 03/07/2016 to Mon 03/07/2016  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 03/07/2016 to Fri 03/18/2016  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	750 MW
TTC with All Lines In Service	5100 MW

## RAMAPO -BUCHAN\_N\_345\_Y94

Mon 03/07/2016 to Tue 04/05/2016  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4150 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N.SCTLND-ALPS_____345_2</b>			FWD	REV
Mon 03/07/2016	to	Mon 03/14/2016	(Import)	(Export)
0600	Continuous	1600	SCH - NE - NY	<b>900 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1400 MW
<b>N.SCTLND-ALPS_____345_2</b>			FWD	REV
Mon 03/07/2016	to	Mon 03/14/2016	(Import)	(Export)
0600	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
<b>N.SCTLND-LEEDS_____345_93</b>			FWD	
Mon 03/07/2016	to	Mon 03/14/2016	(Import)	
0600	Continuous	1600	CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW
<b>EDIC_____N.SCTLND_345_14</b>			FWD	
Mon 03/07/2016	to	Sun 03/27/2016	(Import)	
0600	Continuous	1600	CENTRAL EAST - VC	<b>2240 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	735 MW
			TTC with All Lines In Service	2975 MW
<b>MOSES____-ADIRNDCK_230_MA2</b>			FWD	
Mon 03/07/2016	to	Fri 03/11/2016	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>EASTVIEW-SPRNBRK____345_W79</b>			FWD	
Tue 03/08/2016	to	Mon 03/14/2016	(Import)	
0001	Continuous	1930	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	750 MW
			TTC with All Lines In Service	5100 MW
<b>NIAGARA_-ROCHESTR_345_NR2</b>			FWD	
Wed 03/09/2016	to	Thu 03/10/2016	(Import)	
0700	Continuous	1700	DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EGRDNCTY_345_138_BK 1</b>					FWD	
Thu 03/10/2016	to	Sat 03/19/2016	<u>UPDATED</u>	<u>by LI</u>	<u>01/28/2016</u>	(Import)
0001	Continuous	2359				
Work scheduled by: LI					CONED - LIPA	<b>1250 MW</b>
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>NIAGARA_-KINTIGH_345_NS1-38</b>					FWD	
Fri 03/11/2016	to	Sat 03/12/2016				(Import)
0500	Continuous	1700				
Work scheduled by: NYPA					DYSINGER EAST	<b>1700 MW</b>
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>COOPERS_-MIDDLETP_345_CMT-34</b>					FWD	
Sat 03/12/2016	to	Sun 03/13/2016				(Import)
0800	Continuous	1600				
Work scheduled by: NYSEG					CENTRAL EAST - VC	<b>2720 MW</b>
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>FROST_BR-LONG_MTN_345_352</b>					FWD	REV
Sun 03/13/2016	to	Sun 03/13/2016				(Import) (Export)
0600	Continuous	1530				
Work scheduled by: ISONE					SCH - NE - NY	<b>1300 MW 1600 MW</b>
					Impacts Total Transfer Capability	100 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>COOPERS_-ROCKTVRN_345_CRT-42</b>					FWD	
Mon 03/14/2016	to	Sun 03/27/2016	<u>UPDATED</u>	<u>by CHGE</u>	<u>05/06/2015</u>	(Import)
0600	Continuous	1600				
Work scheduled by: CHGE					CENTRAL EAST - VC	<b>2720 MW</b>
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>BECK_-PACKARD_230_BP76</b>					FWD	REV
Mon 03/14/2016	to	Mon 03/14/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/09/2016</u>	(Import) (Export)
0645	Daily(No Weekends)	1630				
Work scheduled by: NGrid					SCH - OH - NY	<b>1600 MW 1650 MW</b>
					Impacts Total Transfer Capability	300 MW 250 MW
					TTC with All Lines In Service	1900 MW 1900 MW
<b>CLAY_-EDIC_345_1-16</b>					FWD	
Mon 03/14/2016	to	Tue 03/15/2016				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					OSWEGO EXPORT	<b>4850 MW</b>
					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 03/14/2016 to Sat 03/19/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH 2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## EASTVIEW-SPRNBK\_345\_W79

Tue 03/15/2016 to Thu 03/17/2016

0001 Continuous 1930

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED 4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

## CLAY\_\_\_-EDIC\_\_\_345\_2-15

Wed 03/16/2016 to Thu 03/17/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT 4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

## SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Fri 03/18/2016 to Fri 03/18/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - OH - NY 1600 MW 1650 MW

Impacts Total Transfer Capability 300 MW 250 MW

TTC with All Lines In Service 1900 MW 1900 MW

## EGRDNCTY\_345\_138\_BK 2

Mon 03/21/2016 to Wed 03/30/2016

0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 01/28/2016

FWD

(Import)

CONED - LIPA 1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

## HURLYAVE-ROSETON\_345\_303

Mon 03/21/2016 to Fri 03/25/2016

0700 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED 4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 03/21/2016 to Sat 03/26/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH 2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, February 10, 2016 to Friday , August 11, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROCHESTR-PANNELL\_\_345\_RP1**

Mon 03/21/2016 to Tue 03/22/2016  
 1000 Continuous 1700

Work scheduled by: NYPA

FWD  
 (Import)  
**DYSINGER EAST 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Wed 03/23/2016 to Tue 04/05/2016  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**ROCHESTR-PANNELL\_\_345\_RP2**

Wed 03/23/2016 to Thu 03/24/2016  
 0500 Continuous 1700

Work scheduled by: NYPA

FWD  
 (Import)  
**DYSINGER EAST 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**FROST\_BR-LONG\_MTN\_345\_352**

Sun 03/27/2016 to Sun 03/27/2016  
 0600 Continuous 1530

Work scheduled by: ISONE

FWD REV  
 (Import) (Export)  
**SCH - NE - NY 1300 MW 1600 MW**  
 Impacts Total Transfer Capability 100 MW 0 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

**MARCY\_\_COOPERS\_\_345\_UCC2-41**

Mon 03/28/2016 to Sun 04/17/2016  
 0500 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_345\_STATCOM SVC**

Mon 03/28/2016 to Sun 04/17/2016  
 0600 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_765\_345\_BK 1**

Mon 03/28/2016 to Sun 04/17/2016  
 0600 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>OSWEGO__-ELBRIDGE_345_17</b>					FWD		
Tue 03/29/2016	to	Tue 03/29/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/05/2016</u>	(Import)	
0730	Daily(No Weekends)	0800				OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid			<b>ARR: 75</b>			Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
<b>ELBRIDGE-LAFAYTTE_345_17-LE</b>					FWD		
Tue 03/29/2016	to	Tue 03/29/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/05/2016</u>	(Import)	
0730	Daily(No Weekends)	1700				OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid			<b>ARR: 75</b>			Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
<b>OSWEGO__-ELBRIDGE_345_17</b>					FWD		
Tue 03/29/2016	to	Tue 03/29/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/05/2016</u>	(Import)	
1630	Daily(No Weekends)	1700				OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid			<b>ARR: 75</b>			Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
<b>COLTON__-HIGLEY__115_1</b>					FWD	REV	
Sun 04/03/2016	to	Sun 04/10/2016				(Import)	(Export)
0700	Continuous	1900				SCH - HQ_CEDARS	<b>130 MW 100 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>			Impacts Total Transfer Capability	69 MW 0 MW
						TTC with All Lines In Service	199 MW 100 MW
<b>SUGARISL-COLTON__115_4</b>					FWD	REV	
Sun 04/03/2016	to	Sun 04/10/2016				(Import)	(Export)
0700	Continuous	1900				SCH - HQ_CEDARS	<b>150 MW 100 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>			Impacts Total Transfer Capability	49 MW 0 MW
						TTC with All Lines In Service	199 MW 100 MW
<b>SUGARISL-COLTON__115_4 &amp; PYRITES_-COLTON__115_7 &amp; COLTON__-HIGLEY__115_1</b>					FWD	REV	
Sun 04/03/2016	to	Sun 04/10/2016				(Import)	(Export)
0700		1900				SCH - HQ_CEDARS	<b>110 MW 60 MW</b>
Work scheduled by:			<b>ARR: 38</b>			Impacts Total Transfer Capability	89 MW 40 MW
						TTC with All Lines In Service	199 MW 100 MW
<b>NRTH1385-NOR HBR__138_601</b>					FWD	REV	
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/02/2016</u>	(Import)	(Export)
0001	Continuous	2359				SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday, August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016		(Import)	(Export)
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016		(Import)	(Export)
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u> <u>by NYISO</u> <u>02/02/2016</u>	(Import)	(Export)
0001	Continuous	2359		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016		(Import)	(Export)
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u> <u>by NYISO</u> <u>02/02/2016</u>	(Import)	(Export)
0001	Continuous	2359		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_1385				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u> <u>by NYISO</u> <u>02/02/2016</u>	(Import)	(Export)
0001	Continuous	2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
PANNELL_-CLAY____345_2				FWD	
Mon 04/04/2016	to	Mon 04/04/2016		(Import)	
0730	Continuous	1500		WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCKTVRN-RAMAPO___345_77						FWD	
Mon 04/04/2016	to	Fri 04/29/2016	<u>UPDATED</u>	<u>by CHGE</u>	<u>11/13/2015</u>	(Import)	
0800	Continuous	1559				CENTRAL EAST - VC	<b>2570 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability	405 MW
						TTC with All Lines In Service	2975 MW
HUDSONP_-FARRAGUT_345_C3403						FWD	REV
Fri 04/08/2016	to	Sat 05/07/2016	<u>UPDATED</u>	<u>by PJM</u>	<u>01/07/2016</u>	(Import)	(Export)
0200	Continuous	1600				SCH - PJ - NY	<b>2600 MW 1300 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	0 MW 0 MW
						TTC with All Lines In Service	2600 MW 1300 MW
GOETHALS-LINDN_CG_345_G23L & GOETHALS-LINDN_CG_345_G23M						FWD	REV
Mon 04/11/2016	to	Mon 04/25/2016				(Import)	(Export)
0001		2359				SCH - PJM_VFT	<b>0 MW 315 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	315 MW 0 MW
						TTC with All Lines In Service	315 MW 315 MW
BECK___-NIAGARA_230_PA27						FWD	REV
Fri 04/15/2016	to	Fri 04/15/2016				(Import)	(Export)
0700	Continuous	1530				SCH - OH - NY	<b>1900 MW 1900 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	0 MW 0 MW
						TTC with All Lines In Service	1900 MW 1900 MW
EDIC___-FRASER___345_EF24-40						FWD	
Mon 04/18/2016	to	Sun 05/15/2016				(Import)	
0500	Continuous	1600				CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
MOSES___-ADIRNDCK_230_MA2						FWD	
Mon 04/18/2016	to	Fri 04/22/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/27/2016</u>	(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
FRASER___-COOPERS___345_33						FWD	
Mon 04/18/2016	to	Sun 05/22/2016				(Import)	
0800	Continuous	1600				CENTRAL EAST - VC	<b>2395 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	580 MW
						TTC with All Lines In Service	2975 MW



**NYISO TRANSFER LIMITATIONS**

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HOMER C\_-FIVEMILE\_345\_37**

Wed 04/20/2016 to Thu 05/19/2016  
0800 Continuous 1600

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 04/23/2016 to Sun 04/24/2016  
0100 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/27/2016**

	FWD
	(Import)
MOSES SOUTH	<b>1550 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 04/23/2016 to Sun 04/24/2016  
0100 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/27/2016**

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sat 04/23/2016 to Sun 04/24/2016  
0100 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/27/2016****ARR: 20**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2315 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	2975 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sat 04/23/2016 to Sun 04/24/2016  
0100 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/27/2016****ARR: 20**

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

**MASSENA\_-MARCY\_765\_MSU1**

Sat 04/23/2016 to Sun 04/24/2016  
0100 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 01/27/2016****ARR: 20**

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sat 04/23/2016 to Sun 04/24/2016  
0100 Continuous 1530

Work scheduled by:

**ARR: 20**

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2					FWD	REV
Sat 04/23/2016	to	Sun 04/24/2016			(Import)	(Export)
0100		1530			SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	650 MW 1000 MW
ARR: 20					TTC with All Lines In Service	1500 MW 1000 MW
BERKSHIR-ALPS___345_393					FWD	REV
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u> <u>01/15/2016</u>	(Import)	(Export)
0700	Daily(No Weekends)	0900			SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS___345_393					FWD	REV
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u> <u>01/15/2016</u>	(Import)	(Export)
0700	Daily(No Weekends)	0900			SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
SCH-NYISO-NE_LIMIT_400						REV
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u> <u>01/15/2016</u>		(Export)
0700	Daily(No Weekends)	0900			SCH - NE - NY	<b>600 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1600 MW
MOSES___-ADIRNDCK_230_MA2					FWD	
Mon 04/25/2016	to	Fri 04/29/2016			(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
BERKSHIR-ALPS___345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Mon 04/25/2016	to	Mon 04/25/2016			(Import)	(Export)
0800		0900			SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Mon 04/25/2016	to	Sat 05/07/2016			(Import)	(Export)
0800	Continuous	1600			SCH - NE - NY	<b>1400 MW 1450 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	0 MW 150 MW
					TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-NORTHFLD_345_312</b>				FWD	REV
Mon 04/25/2016	to	Sat 05/07/2016		(Import)	(Export)
0800	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
<b>SCH-NE-NYISO_LIMIT_500</b>				FWD	
Mon 04/25/2016	to	Sat 05/07/2016		(Import)	
0800	Continuous	1600	SCH - NE - NY	<b>700 MW</b>	
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW	
			TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_700</b>					REV
Mon 04/25/2016	to	Sat 05/07/2016			(Export)
0800	Continuous	1600	SCH - NE - NY		<b>900 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability		700 MW
			TTC with All Lines In Service		1600 MW
<b>ROCKTVRN-RAMAPO___345_77</b>				FWD	
Fri 04/29/2016	to	Sat 05/14/2016		(Import)	
1600	Continuous	2359	CENTRAL EAST - VC	<b>2570 MW</b>	
Work scheduled by: ConEd			Impacts Total Transfer Capability	405 MW	
			TTC with All Lines In Service	2975 MW	
<b>LINDN_CG-LNDVFT___345_V-3022</b>				FWD	REV
Sun 05/01/2016	to	Fri 05/06/2016		(Import)	(Export)
1300	Continuous	1800	SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD	
Mon 05/02/2016	to	Fri 05/06/2016		(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>0 MW</b>	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD	
Mon 05/02/2016	to	Fri 05/06/2016		(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>0 MW</b>	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_-KINTIGH\_345\_NS1-38

Mon 05/02/2016 to Fri 05/06/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

### BROWNFLS-TAYLORVL\_115\_4

Tue 05/03/2016 to Fri 05/27/2016  
0700 Continuous 1800

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

### BERKSHIR-ALPS\_345\_393

Sat 05/07/2016 to Sat 05/07/2016  
1600 Daily 1800

Work scheduled by: NGrid

UPDATED by NE 01/15/2016

FWD REV  
(Import) (Export)  
SCH - NE - NY **950 MW 1000 MW**  
Impacts Total Transfer Capability 450 MW 600 MW  
TTC with All Lines In Service 1400 MW 1600 MW

### BERKSHIR-ALPS\_345\_393

Sat 05/07/2016 to Sat 05/07/2016  
1600 Daily 1800

Work scheduled by: NGrid

UPDATED by NE 01/15/2016

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

### SCH-NYISO-NE\_LIMIT\_400

Sat 05/07/2016 to Sat 05/07/2016  
1600 Daily 1800

Work scheduled by: NGrid

UPDATED by NE 01/15/2016

REV  
(Export)  
SCH - NE - NY **600 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1600 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 05/09/2016 to Fri 05/13/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/09/2016 to Sat 05/14/2016  
0700 Continuous 1900

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Thu 05/12/2016 to Sat 05/14/2016  
0001 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4150 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 5100 MW

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 05/16/2016 to Fri 05/20/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## ROSETON\_-ROCKTVRN\_345\_311

Mon 05/16/2016 to Fri 06/03/2016  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

## EDIC\_\_\_\_-FRASER\_\_\_\_345\_EF24-40

Mon 05/23/2016 to Tue 05/24/2016  
0500 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## LEEDS\_\_\_\_345\_LEEDS SVC

Mon 05/23/2016 to Fri 06/10/2016  
0730 Continuous 1500  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2950 MW**  
Impacts Total Transfer Capability 25 MW  
TTC with All Lines In Service 2975 MW

## NINEMILE-CLAY\_\_\_\_345\_8

Tue 05/24/2016 to Fri 05/27/2016  
0700 Continuous 1700  
Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5150 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 5250 MW

## MAINESBG-WATRCURE\_345\_30

Tue 05/24/2016 to Wed 05/25/2016  
0800 Continuous 1600  
Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2200 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	2300 MW	1300 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMRC\_NY-MAINS\_NY\_345\_47

Thu 05/26/2016 to Fri 05/27/2016  
0800 Continuous 1600

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2200 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	2300 MW	1300 MW

### MARCY\_\_-COOPERS\_\_345\_UCC2-41

Fri 05/27/2016 to Sat 05/28/2016  
0500 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2500 MW</b>
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

### BROWNFLS-TAYLORVL\_115\_3

Tue 05/31/2016 to Wed 06/15/2016  
0600 Continuous 1700

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

### FRASER\_\_-COOPERS\_\_345\_33

Tue 05/31/2016 to Wed 06/01/2016  
0700 Continuous 1600

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2395 MW</b>
Impacts Total Transfer Capability	580 MW
TTC with All Lines In Service	2975 MW

### NIAGARA\_-KINTIGH\_\_345\_NS1-38

Fri 06/03/2016 to Fri 06/03/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

### FRASER\_-GILBOA\_\_345\_GF5-35

Sat 06/04/2016 to Fri 06/10/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

### BECK\_\_-NIAGARA\_\_345\_PA302

Mon 06/06/2016 to Fri 06/17/2016  
0700 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 01/21/2016

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1200 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	700 MW	800 MW
TTC with All Lines In Service	1900 MW	1900 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COLTON__-FLATROCK_115_2				FWD	REV
Sun 06/12/2016 to Sun 06/12/2016				(Import)	(Export)
0530	Continuous	1730		SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
HANAWAFL-COLTON__115_5				FWD	REV
Sun 06/12/2016 to Sun 06/12/2016				(Import)	(Export)
0530	Continuous	1730		SCH - HQ_CEDARS	150 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	40 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
PARISHVL-COLTON__115_3 & MCINTYRE-COLTON__115_8 & HANAWAFL-COLTON__115_5 & COLTON__-FLATROCK_115_2				FWD	REV
Sun 06/12/2016 to Sun 06/12/2016				(Import)	(Export)
0530		1730		SCH - HQ_CEDARS	80 MW 40 MW
Work scheduled by:				Impacts Total Transfer Capability	110 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
COLTON__-FLATROCK_115_2				FWD	REV
Thu 06/16/2016 to Sat 06/18/2016				(Import)	(Export)
0600	Continuous	1700		SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
COLTON__-FLATROCK_115_2				FWD	REV
Sun 06/19/2016 to Sun 06/19/2016				(Import)	(Export)
0530	Continuous	1730	UPDATED by NGRID 02/04/2016	SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
HANAWAFL-COLTON__115_5				FWD	REV
Sun 06/19/2016 to Sun 06/19/2016				(Import)	(Export)
0530	Continuous	1730	UPDATED by NGRID 02/04/2016	SCH - HQ_CEDARS	150 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	40 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday, August 11, 2017

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PARISHVL-COLTON__115_3 & MCINTYRE-COLTON__115_8 & HANAWAFL-COLTON__115_5 & COLTON__-FLATROCK_115_2				FWD	REV	
				(Import)	(Export)	
Sun 06/19/2016	to	Sun 06/19/2016		SCH - HQ_CEDARS	80 MW	40 MW
0530		1730		Impacts Total Transfer Capability	110 MW	0 MW
				TTC with All Lines In Service	190 MW	40 MW
Work scheduled by:				ARR: 38		
MOSES__-ADIRNDCK_230_MA1				FWD		
				(Import)		
Mon 06/27/2016	to	Wed 06/29/2016		MOSES SOUTH	2100 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	1050 MW	
				TTC with All Lines In Service	3150 MW	
Work scheduled by: NYPA						
MARCY__-COOPERS__345_UCC2-41				FWD		
				(Import)		
Sun 08/28/2016	to	Wed 08/31/2016		CENTRAL EAST - VC	2500 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	475 MW	
				TTC with All Lines In Service	2975 MW	
Work scheduled by: NYPA						
GILBOA__-LEEDS__345_GL3				FWD		
				(Import)		
Mon 09/05/2016	to	Fri 09/09/2016		CENTRAL EAST - VC	2200 MW	
0800	Continuous	1530		Impacts Total Transfer Capability	775 MW	
				TTC with All Lines In Service	2975 MW	
Work scheduled by: NYPA						
MARCY__765_345_BK 2				FWD		
				(Import)		
Tue 09/06/2016	to	Sun 09/11/2016		MOSES SOUTH	1700 MW	
0700	Continuous	1730		Impacts Total Transfer Capability	1450 MW	
				TTC with All Lines In Service	3150 MW	
Work scheduled by: NYPA				ARR: 19		
KINTIGH__-ROCHESTR_345_SR1-39				FWD		
				(Import)		
Mon 09/12/2016	to	Fri 09/16/2016	UPDATED by NYISO 01/20/2016	DYSINGER EAST	1700 MW	
0700	Continuous	1630		Impacts Total Transfer Capability	1450 MW	
				TTC with All Lines In Service	3150 MW	
Work scheduled by: NYPA						
MOSES__-ADIRNDCK_230_MA1				FWD		
				(Import)		
Mon 09/12/2016	to	Sat 09/17/2016		MOSES SOUTH	2100 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	1050 MW	
				TTC with All Lines In Service	3150 MW	
Work scheduled by: NYPA						



# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

Mon 09/12/2016 to Fri 09/30/2016  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## NIAGARA\_\_345\_230\_BK 4

Wed 09/14/2016 to Thu 09/15/2016  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by PA 09/18/2015

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1900 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## BECK\_\_\_\_-NIAGARA\_\_345\_PA301

Fri 09/16/2016 to Fri 09/16/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1100 MW**  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## FITZPTRK-EDIC\_\_\_\_345\_FE-1

Mon 09/19/2016 to Wed 09/21/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 09/19/2016 to Sat 09/24/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## BECK\_\_\_\_-NIAGARA\_\_230\_PA27

Mon 09/19/2016 to Sun 11/06/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1900 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## NRTH1385-NOR HBR\_\_138\_601

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday, August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602**

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NRTHPORT\_138\_1385**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 09/26/2016 to Sat 10/01/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MARCY\_\_\_-COOPERS\_\_\_345\_UCC2-41

Mon 10/03/2016 to Sun 10/09/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Tue 10/04/2016 to Fri 10/07/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 10/10/2016 to Fri 11/04/2016 **UPDATED by NGRID 07/09/2015**  
0700 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## LEEDS\_\_\_345KV\_R94301

Mon 10/10/2016 to Fri 11/04/2016 **UPDATED by NGRID 07/09/2015**  
0700 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Tue 10/11/2016 to Fri 10/14/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Sat 10/15/2016 to Sat 10/29/2016 **UPDATED by NYPA 10/08/2015**  
0100 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_\_765\_7040

Sat 10/15/2016 to Sat 10/29/2016 **UPDATED by NYPA 10/08/2015**  
0100 Continuous 1730

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARC_765_MSU1						FWD	
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2015</u>	(Import)	
0100	Continuous	1730				CENTRAL EAST - VC	<b>2315 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	2975 MW
ARR: 20							
MASSENA_-MARC_765_MSU1						FWD	
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2015</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
ARR: 20							
MASSENA_-MARC_765_MSU1						FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/08/2015</u>	(Import)	(Export)
0100	Continuous	1730				SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
ARR: 20							
MASSENA_-MARC_765_MSU1 & CHATGUAY-MASSENA_765_7040						FWD	
Sat 10/15/2016	to	Sat 10/29/2016				(Import)	
0100		1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
ARR: 20							
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2						FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016				(Import)	(Export)
0100		1730				SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	650 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
ARR: 20							
MARC_765_345_BK 2						FWD	
Mon 10/24/2016	to	Fri 10/28/2016				(Import)	
0700	Continuous	1730				MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
ARR: 19							
MOSES_-ADIRNDCK_230_MA2						FWD	
Mon 10/31/2016	to	Sat 11/05/2016				(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMRC\_NY-MAINS\_NY\_345\_47

Fri 11/04/2016 to Fri 11/04/2016  
0600 Continuous 1600

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

### LEEDS\_\_\_-PLSNTVLY\_345\_92

Mon 11/07/2016 to Wed 12/07/2016  
0001 Continuous 2359

Work scheduled by: NGrid

UPDATED by CONED 09/16/2015

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

### PLSNTVLY\_345KV\_RNS5

Mon 11/07/2016 to Wed 12/07/2016  
0001 Continuous 2359

Work scheduled by: NGrid

UPDATED by CONED 09/16/2015

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/07/2016 to Thu 11/10/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### BECK\_\_\_-NIAGARA\_345\_PA301

Mon 11/14/2016 to Fri 11/18/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1400 MW	1250 MW
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/14/2016 to Sat 11/19/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/21/2016 to Wed 11/23/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 10, 2016 to Friday , August 11, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/28/2016 to Fri 12/02/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/05/2016 to Fri 12/09/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/12/2016 to Fri 12/16/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35

Mon 12/12/2016 to Fri 12/30/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/19/2016 to Thu 12/22/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 03/06/2017 to Fri 03/31/2017  
0600 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW