

**NYISO TRANSFER LIMITATIONS**

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Fri 01/01/2016 to Sun 05/01/2016

EXT FORCE by PJM 01/22/2016

(Import)

1308 Continuous 2359

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**MARCY -EDIC 345 UE1-7**

FWD

Mon 01/04/2016 to Fri 02/26/2016

UPDATED by NG 02/10/2016

(Import)

0500 Continuous 0830

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 16****FRASER -COOPERS 345\_33**

FWD

Mon 01/04/2016 to Thu 03/03/2016

UPDATED by NYSEG 02/15/2016

(Import)

0800 Continuous 1500

CENTRAL EAST - VC

**2395 MW**

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**W49TH\_ST-E13THSTA\_345\_M54**

FWD

Thu 01/21/2016 to Mon 03/14/2016

EXT FORCE by CE 02/03/2016

(Import)

0255 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**OAKDALE -FRASER 345\_32**

FWD

Mon 02/01/2016 to Tue 02/23/2016

EXTENDED by NYSEG 02/23/2016

(Import)

0800 Continuous 1659

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

**SCH-HQ-NYISO\_LIMIT\_1200**

FWD

Sun 02/14/2016 to Fri 02/19/2016

UPDATED by HQ 02/19/2016

(Import)

2100 Continuous 1408

SCH - HQ - NY

**1200 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**MOSES -ADIRNDCK\_230\_MAI**

FWD

Tue 02/16/2016 to Fri 02/19/2016

MOSES SOUTH

**2300 MW**

0700 Continuous 1530

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-HQ-NYISO\_LIMIT\_1450**

Wed 02/17/2016 to Thu 02/18/2016  
0900 Continuous 1700

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1450 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 1500 MW

**SCH-NE-NYISO\_LIMIT\_1100**

Thu 02/18/2016 to Thu 02/18/2016  
0800 Continuous 1500

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1300 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1400 MW

**SCH-HQ-NYISO\_LIMIT\_700**

Thu 02/18/2016 to Thu 02/18/2016 UPDATED by HQ 02/17/2016  
2100 Continuous 2359

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **700 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1500 MW

**SCH-NYISO-HQ\_LIMIT\_0**

Thu 02/18/2016 to Fri 02/19/2016 UPDATED by HQ 02/17/2016  
2100 Continuous 0100

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **0 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1000 MW

**SPRNBK\_-TREMONT\_345\_X28**

Sat 02/20/2016 to Sun 02/21/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

**MOSES\_-ADIRNDCK\_230\_MAI**

Sun 02/21/2016 to Fri 02/26/2016 UPDATED by PA 02/10/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**HOPATCON-RAMAPO\_500\_5018**

Tue 02/23/2016 to Sun 02/28/2016 UPDATED by NYISO 02/23/2016  
1700 Continuous 1900

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2100 MW 1000 MW**  
Impacts Total Transfer Capability 500 MW 300 MW  
TTC with All Lines In Service 2600 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018						FWD	
Tue 02/23/2016	to	Sun 02/28/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/23/2016</u>	(Import)	
1700	Continuous	1900				TOTAL EAST	<b>6400 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	6500 MW
HOPATCON-RAMAPO___500_5018						FWD	
Tue 02/23/2016	to	Sun 02/28/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/23/2016</u>	(Import)	
1700	Continuous	1900				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
RAMAPO___345_345_PAR3500						FWD	REV
Tue 02/23/2016	to	Sun 02/28/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/23/2016</u>	(Import)	(Export)
1700	Continuous	1900				SCH - PJ - NY	<b>2400 MW 1300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	200 MW 0 MW
						TTC with All Lines In Service	2600 MW 1300 MW
RAMAPO___345_345_PAR4500						FWD	REV
Tue 02/23/2016	to	Sun 02/28/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/23/2016</u>	(Import)	(Export)
1700	Continuous	1900				SCH - PJ - NY	<b>2400 MW 1300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	200 MW 0 MW
						TTC with All Lines In Service	2600 MW 1300 MW
RAMAPO___500_345_BK 1500						FWD	REV
Tue 02/23/2016	to	Sun 02/28/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/23/2016</u>	(Import)	(Export)
1700	Continuous	1900				SCH - PJ - NY	<b>2100 MW 1000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	500 MW 300 MW
						TTC with All Lines In Service	2600 MW 1300 MW
RAMAPO___500_345_BK 1500						FWD	
Tue 02/23/2016	to	Sun 02/28/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/23/2016</u>	(Import)	
1700	Continuous	1900				TOTAL EAST	<b>6400 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	6500 MW
RAMAPO___500_345_BK 1500						FWD	
Tue 02/23/2016	to	Sun 02/28/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/23/2016</u>	(Import)	
1700	Continuous	1900				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1

Tue 02/23/2016 to Tue 02/23/2016  
2200 Continuous 2359

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Tue 02/23/2016 to Tue 02/23/2016  
2200 Continuous 2359

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Tue 02/23/2016 to Tue 02/23/2016  
2200 2359

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Tue 02/23/2016 to Tue 02/23/2016  
2200 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Tue 02/23/2016 to Tue 02/23/2016  
2200 Continuous 2359

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Tue 02/23/2016 to Tue 02/23/2016  
2200 Continuous 2359

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-HQ-NYISO\_LIMIT\_800

Tue 02/23/2016 to Tue 02/23/2016  
2200 Continuous 2359

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ-NYISO\_LIMIT\_1350

FWD

Wed 02/24/2016 to Wed 02/24/2016  
0900 Continuous 1700

CANCELLED by HQ 02/23/2016

Work scheduled by: HQ

SCH - HQ - NY **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### COOPERS\_-MIDDLETP\_345\_CMT-34

FWD

Thu 02/25/2016 to Fri 02/26/2016  
0800 Continuous 1559

CANCELLED by NYSEG 02/23/2016

Work scheduled by: CHGE

CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

### DUNWODIE-MOTTHAVN\_345\_71

FWD

Sat 02/27/2016 to Sat 02/27/2016  
0001 Continuous 1530

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SCH-HQ-NYISO\_LIMIT\_1250

FWD

Sat 02/27/2016 to Sat 02/27/2016  
0700 Continuous 0859

UPDATED by HQ 02/23/2016

Work scheduled by: HQ

SCH - HQ - NY **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### SCH-NYISO-HQ\_LIMIT\_500

REV

Sat 02/27/2016 to Sat 02/27/2016  
0700 Continuous 0859

UPDATED by HQ 02/23/2016

Work scheduled by: HQ

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### SCH-HQ-NYISO\_LIMIT\_1250

FWD

Sat 02/27/2016 to Sat 02/27/2016  
1700 Continuous 1759

UPDATED by HQ 02/23/2016

Work scheduled by: HQ

SCH - HQ - NY **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### SCH-NYISO-HQ\_LIMIT\_500

REV

Sat 02/27/2016 to Sat 02/27/2016  
1700 Continuous 1759

UPDATED by HQ 02/23/2016

Work scheduled by: HQ

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1100**

FWD

Mon 02/29/2016 to Mon 02/29/2016

(Import)

0600 Continuous 1700

Work scheduled by: NGrid

SCH - OH - NY

**1400 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1900 MW

**SCH-IMO-NYISO\_LIMIT\_900**

FWD

Tue 03/01/2016 to Tue 03/01/2016

(Import)

0600 Continuous 1700

Work scheduled by: NGrid

SCH - OH - NY

**1200 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1900 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

FWD

Tue 03/01/2016 to Wed 03/02/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA02/17/2016

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**MOSES\_-ADIRNDCK\_230\_MA1**

FWD

Tue 03/01/2016 to Fri 03/04/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA02/09/2016

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**VOLNEY\_-CLAY\_\_\_\_345\_6**

FWD

Wed 03/02/2016 to Thu 03/03/2016

(Import)

0730 Continuous 1700

Work scheduled by: NGrid

UPDATEDby NGRID02/23/2016

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**WATRCURE-OAKDALE\_345\_31**

FWD

REV

Wed 03/02/2016 to Thu 03/03/2016

(Import) (Export)

0800 Continuous 1630

Work scheduled by: NYSEG

UPDATEDby NYSEG02/16/2016

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Thu 03/03/2016 to Fri 03/04/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

Thu 03/03/2016 to Thu 03/03/2016  
0800 Daily(No Weekends) 1230  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## FRASER\_\_345\_FRASER SVC

Thu 03/03/2016 to Thu 03/03/2016  
0900 Continuous 1330  
Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-N.SCTLND\_345\_18

Fri 03/04/2016 to Fri 03/04/2016 **UPDATED by NYISO 02/17/2016**  
0800 Daily(No Weekends) 1159  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

## N.SCTLND-LEEDS\_\_345\_94

Fri 03/04/2016 to Fri 03/04/2016  
1200 Daily(No Weekends) 1600  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## MASSENA\_-MARCY\_\_765\_MSU1

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2315 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 2975 MW

ARR: 20

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MASSENA\_-MARCY\_765\_MSU1**

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 20**

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

---

**MASSENA\_-MARCY\_765\_MSU1**

Sat 03/05/2016 to Sun 03/06/2016  
0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 20**

FWD REV  
(Import) (Export)  
SCH - HQ - NY **475 MW 1000 MW**  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

---

**MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040**

Sat 03/05/2016 to Sun 03/06/2016  
0100 1730

Work scheduled by:

**ARR: 20**

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2**

Sat 03/05/2016 to Sun 03/06/2016  
0100 1730

Work scheduled by:

**ARR: 20**

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

---

**ATHENS\_-PLSNTVLY\_345\_91**

Sat 03/05/2016 to Sun 03/06/2016  
0700 Continuous 1700

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

---

**COOPERS\_-MIDDLETP\_345\_CMT-34**

Sat 03/05/2016 to Sun 03/06/2016  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

---

**MARCY\_-COOPERS\_345\_UCC2-41**

Sun 03/06/2016 to Mon 03/07/2016  
1800 Continuous 0559

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EASTVIEW-SPRNBK\_\_345\_W79

Mon 03/07/2016 to Mon 03/07/2016  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 03/07/2016 to Fri 03/18/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Mon 03/07/2016 to Tue 04/05/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4150 MW  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 5100 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Mon 03/07/2016 to Mon 03/14/2016  
0600 Continuous 1600

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - NE - NY 900 MW 1600 MW  
Impacts Total Transfer Capability 500 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Mon 03/07/2016 to Mon 03/14/2016  
0600 Continuous 1600

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## N.SCTLND-LEEDS\_\_\_\_345\_93

Mon 03/07/2016 to Mon 03/14/2016  
0600 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC 2650 MW  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## EDIC\_\_\_\_-N.SCTLND\_345\_14

Mon 03/07/2016 to Sun 03/27/2016  
0600 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC 2240 MW  
Impacts Total Transfer Capability 735 MW  
TTC with All Lines In Service 2975 MW

UPDATED by NG 02/11/2016

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 03/07/2016 to Fri 03/11/2016  
0700 Continuous 1730

UPDATEDby NYPA02/23/2016

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## EASTVIEW-SPRNBK\_345\_W79

FWD

Tue 03/08/2016 to Mon 03/14/2016  
0001 Continuous 1930

(Import)

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

FWD

Wed 03/09/2016 to Thu 03/10/2016  
0700 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## EGRDNCTY\_345\_138\_BK 1

FWD

Thu 03/10/2016 to Sat 03/19/2016  
0001 Continuous 2359

UPDATEDby LI01/28/2016

(Import)

Work scheduled by: LI

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

FWD

Fri 03/11/2016 to Sat 03/12/2016  
0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST

**1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## COOPERS\_-MIDDLETP\_345\_CMT-34

FWD

Sat 03/12/2016 to Sun 03/13/2016  
0800 Continuous 1600

CANCELLEDby NYSEG02/23/2016

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

## FROST\_BR-LONG\_MTN\_345\_352

FWD

REV

Sun 03/13/2016 to Sun 03/13/2016  
0600 Continuous 1530

(Import) (Export)

Work scheduled by: ISONE

SCH - NE - NY

**1300 MW 1600 MW**

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 03/14/2016 to Sun 03/27/2016 UPDATED by CHGE 05/06/2015

0600 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## BECK\_-PACKARD\_230\_BP76

Mon 03/14/2016 to Mon 03/14/2016 UPDATED by NGRID 02/09/2016

0645 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - OH - NY **1600 MW 1650 MW**  
Impacts Total Transfer Capability 300 MW 250 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## CLAY\_-EDIC\_345\_1-16

Mon 03/14/2016 to Tue 03/15/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 03/14/2016 to Sat 03/19/2016 UPDATED by NYPA 02/23/2016

0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## EASTVIEW-SPRNBRK\_345\_W79

Tue 03/15/2016 to Thu 03/17/2016

0001 Continuous 1930

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

## CLAY\_-EDIC\_345\_2-15

Wed 03/16/2016 to Thu 03/17/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Fri 03/18/2016 to Fri 03/18/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1600 MW 1650 MW**  
Impacts Total Transfer Capability 300 MW 250 MW  
TTC with All Lines In Service 1900 MW 1900 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD

Sat 03/19/2016 to Sat 03/19/2016

(Import)

0001 Continuous 2359

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

## PLSNTVLY\_345KV\_RNS5

FWD

Sat 03/19/2016 to Sat 03/19/2016

(Import)

0001 Continuous 2359

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

## W49TH\_ST\_345KV\_6

FWD

Mon 03/21/2016 to Mon 03/21/2016

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

340 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

FWD

Mon 03/21/2016 to Mon 03/21/2016

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

340 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

## EGRDNCTY\_345\_138\_BK 2

FWD

Mon 03/21/2016 to Wed 03/30/2016

(Import)

0001 Continuous 2359

UPDATEDby LI01/28/2016

CONED - LIPA

1250 MW

Work scheduled by: LI

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 03/21/2016 to Thu 03/24/2016

(Import)

0700 Continuous 1730

UPDATEDby NYPA02/23/2016

MOSES SOUTH

2300 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## HURLYAVE-ROSETON\_\_\_345\_303

FWD

Mon 03/21/2016 to Fri 03/25/2016

(Import)

0700 Continuous 1600

UPNY CONED

4100 MW

Work scheduled by: CHGE

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**ROCHESTR-PANNELL\_\_345\_RP1**

FWD

Mon 03/21/2016 to Tue 03/22/2016

(Import)

1000 Continuous 1700

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Wed 03/23/2016 to Tue 04/05/2016

(Import)

0001 Continuous 2359

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

---

**ROCHESTR-PANNELL\_\_345\_RP2**

FWD

Wed 03/23/2016 to Thu 03/24/2016

(Import)

0500 Continuous 1700

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**W49TH\_ST\_345KV\_6**

FWD

Sat 03/26/2016 to Sat 03/26/2016

(Import)

1700 Continuous 1900

SCH - PJM\_HTP **340 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

---

**W49TH\_ST\_345KV\_8**

FWD

Sat 03/26/2016 to Sat 03/26/2016

(Import)

1700 Continuous 1900

SCH - PJM\_HTP **340 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

---

**FROST\_BR-LONG\_MTN\_345\_352**

FWD

REV

Sun 03/27/2016 to Sun 03/27/2016

(Import) (Export)

0600 Continuous 1530

SCH - NE - NY **1300 MW 1600 MW**

Impacts Total Transfer Capability 100 MW 0 MW

TTC with All Lines In Service 1400 MW 1600 MW

Work scheduled by: ISONE

---

**W49TH\_ST\_345KV\_5**

FWD

Mon 03/28/2016 to Mon 03/28/2016

(Import)

0001 Continuous 0030

SCH - PJM\_HTP **330 MW**

Impacts Total Transfer Capability 330 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

UPDATEDby CE02/22/2016

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_7**

FWD

Mon 03/28/2016 to Mon 03/28/2016 UPDATED by CE 02/22/2016

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**330 MW**

Impacts Total Transfer Capability 330 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**FITZPTRK-EDIC 345\_FE-1**

FWD

Mon 03/28/2016 to Tue 03/29/2016 UPDATED by NYISO 02/22/2016

(Import)

0500 Continuous 1700

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**MARCY -COOPERS 345\_UCC2-41**

FWD

Mon 03/28/2016 to Sun 04/17/2016

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MARCY 345\_STATCOM SVC**

FWD

Mon 03/28/2016 to Sun 04/17/2016

(Import)

0600 Continuous 1530

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MARCY 765\_345\_BK 1**

FWD

Mon 03/28/2016 to Sun 04/17/2016

(Import)

0600 Continuous 1530

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****W49TH\_ST\_345KV\_5**

FWD

Tue 03/29/2016 to Tue 03/29/2016 UPDATED by CE 02/22/2016

(Import)

0630 Continuous 0700

SCH - PJM\_HTP

**330 MW**

Impacts Total Transfer Capability 330 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Tue 03/29/2016 to Tue 03/29/2016 UPDATED by CE 02/22/2016

(Import)

0630 Continuous 0700

SCH - PJM\_HTP

**330 MW**

Impacts Total Transfer Capability 330 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>OSWEGO__-ELBRIDGE_345_17</b>					FWD	
Thu 03/31/2016	to	Thu 03/31/2016	<u>UPDATED</u>	<u>by NGRID</u> <u>02/18/2016</u>	(Import)	
0730	Daily(No Weekends)	0800			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid			ARR: 75		Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>ELBRIDGE-LAFAYTTE_345_17-LE</b>					FWD	
Thu 03/31/2016	to	Thu 03/31/2016	<u>UPDATED</u>	<u>by NGRID</u> <u>02/18/2016</u>	(Import)	
0730	Daily(No Weekends)	1700			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid			ARR: 75		Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>OSWEGO__-ELBRIDGE_345_17</b>					FWD	
Thu 03/31/2016	to	Thu 03/31/2016	<u>UPDATED</u>	<u>by NGRID</u> <u>02/18/2016</u>	(Import)	
1630	Daily(No Weekends)	1700			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid			ARR: 75		Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>COLTON__-HIGLEY__115_1</b>					FWD	REV
Sun 04/03/2016	to	Sun 04/10/2016			(Import)	(Export)
0700	Continuous	1900			SCH - HQ_CEDARS	<b>130 MW 100 MW</b>
Work scheduled by: NGrid			ARR: 38		Impacts Total Transfer Capability	69 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<b>SUGARISL-COLTON__115_4</b>					FWD	REV
Sun 04/03/2016	to	Sun 04/10/2016			(Import)	(Export)
0700	Continuous	1900			SCH - HQ_CEDARS	<b>150 MW 100 MW</b>
Work scheduled by: NGrid			ARR: 38		Impacts Total Transfer Capability	49 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<b>SUGARISL-COLTON__115_4 &amp; PYRITES_-COLTON__115_7 &amp; COLTON__-HIGLEY__115_1</b>					FWD	REV
Sun 04/03/2016	to	Sun 04/10/2016			(Import)	(Export)
0700		1900			SCH - HQ_CEDARS	<b>110 MW 60 MW</b>
Work scheduled by:			ARR: 38		Impacts Total Transfer Capability	89 MW 40 MW
					TTC with All Lines In Service	199 MW 100 MW
<b>NRTH1385-NOR HBR__138_601</b>					FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u>	<u>by NYISO</u> <u>02/02/2016</u>	(Import)	(Export)
0001	Continuous	2359			SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602

Mon 04/04/2016 to Mon 04/04/2016  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603

Mon 04/04/2016 to Mon 04/04/2016  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_602

Mon 04/04/2016 to Mon 04/04/2016 UPDATED by NYISO 02/02/2016  
0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 04/04/2016 to Mon 04/04/2016  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_603

Mon 04/04/2016 to Mon 04/04/2016 UPDATED by NYISO 02/02/2016  
0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT\_138\_1385

Mon 04/04/2016 to Mon 04/04/2016 UPDATED by NYISO 02/02/2016  
0001 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

ROCKTVRN-RAMAPO\_\_345\_77

Mon 04/04/2016 to Fri 04/29/2016 UPDATED by CHGE 11/13/2015  
0800 Continuous 1559

Work scheduled by: CHGE

	FWD
	(Import)
CENTRAL EAST - VC	2570 MW
Impacts Total Transfer Capability	405 MW
TTC with All Lines In Service	2975 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**CLAY -EDIC 345\_2-15**

Tue 04/05/2016 to Wed 04/06/2016  
0700 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

---

**HUDSONP -FARRAGUT 345\_C3403**

Fri 04/08/2016 to Sat 05/07/2016  
0200 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 01/07/2016

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2600 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2600 MW 1300 MW

---

**GOETHALS-LINDN CG 345\_G23L & GOETHALS-LINDN CG 345\_G23M**

Mon 04/11/2016 to Mon 04/25/2016  
0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 315 MW**  
Impacts Total Transfer Capability 315 MW 0 MW  
TTC with All Lines In Service 315 MW 315 MW

---

**BECK -NIAGARA 230\_PA27**

Fri 04/15/2016 to Fri 04/15/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1900 MW 1900 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**ROCHESTR-PANNELL 345\_RP2**

Sat 04/16/2016 to Sun 04/17/2016  
0700 Continuous 1800

Work scheduled by: RGE

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**EDIC -FRASER 345\_EF24-40**

Mon 04/18/2016 to Sun 05/15/2016  
0500 Continuous 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

---

**MOSES -ADIRNDCK 230\_MA2**

Mon 04/18/2016 to Fri 04/22/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASER\_\_-COOPERS\_\_345\_33

Mon 04/18/2016 to Sun 05/22/2016

0800 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC

2395 MW

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

## HOMER C\_-FIVEMILE\_345\_37

Wed 04/20/2016 to Thu 05/19/2016

0800 Continuous 1600

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - PJ - NY

2600 MW 1300 MW

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 04/23/2016 to Sun 04/24/2016

0100 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA01/27/2016

FWD

(Import)

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 04/23/2016 to Sun 04/24/2016

0100 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA01/27/2016

FWD

(Import) (Export)

SCH - HQ - NY

0 MW 0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

Sat 04/23/2016 to Sun 04/24/2016

0100 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA01/27/2016

ARR: 20

FWD

(Import)

CENTRAL EAST - VC

2315 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

Sat 04/23/2016 to Sun 04/24/2016

0100 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA01/27/2016

ARR: 20

FWD

(Import)

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

Sat 04/23/2016 to Sun 04/24/2016

0100 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA01/27/2016

ARR: 20

FWD

(Import) (Export)

SCH - HQ - NY

475 MW 1000 MW

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

**CENTRAL EAST** 3100MW  
**CENTRAL EAST - VC** 2975MW  
**TOTAL EAST** 6500MW  
**UPNY CONED** 5100MW  
**SPR/DUN-SOUTH** 4600MW  
**DYSINGER EAST** 3150MW  
**MOSES SOUTH** 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_ 765\_MSU1 & CHATGUAY-MASSENA\_ 765\_7040

Sat 04/23/2016 to Sun 04/24/2016  
 0100 1530

Work scheduled by:

ARR: 20

FWD  
 (Import)  
**MOSES SOUTH** 500 MW  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_-MASSENA\_ 230\_MMS1 & MOSES\_-MASSENA\_ 230\_MMS2

Sat 04/23/2016 to Sun 04/24/2016  
 0100 1530

Work scheduled by:

ARR: 20

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY** 850 MW 0 MW  
 Impacts Total Transfer Capability 650 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

BERKSHIR-ALPS\_ 345\_393

Mon 04/25/2016 to Mon 04/25/2016  
 0700 Daily(No Weekends) 0900

Work scheduled by: NGrid

UPDATED by NE 01/15/2016

FWD REV  
 (Import) (Export)  
**SCH - NE - NY** 1300 MW 1300 MW  
 Impacts Total Transfer Capability 100 MW 300 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

BERKSHIR-ALPS\_ 345\_393

Mon 04/25/2016 to Mon 04/25/2016  
 0700 Daily(No Weekends) 0900

Work scheduled by: NGrid

UPDATED by NE 01/15/2016

FWD REV  
 (Import) (Export)  
**SCH - NPX\_1385** 100 MW 100 MW  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

SCH-NYISO-NE\_LIMIT\_400

Mon 04/25/2016 to Mon 04/25/2016  
 0700 Daily(No Weekends) 0900

Work scheduled by: NGrid

UPDATED by NE 01/15/2016

REV  
 (Export)  
**SCH - NE - NY** 600 MW  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 1600 MW

MOSES\_-ADIRNDCK\_ 230\_MA2

Mon 04/25/2016 to Fri 04/29/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH** 2300 MW  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

BERKSHIR-ALPS\_ 345\_393 & BERKSHIR-NORTHFLD\_345\_312

Mon 04/25/2016 to Mon 04/25/2016  
 0800 0900

Work scheduled by:

FWD REV  
 (Import) (Export)  
**SCH - NE - NY** 1300 MW 1300 MW  
 Impacts Total Transfer Capability 100 MW 300 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BERKSHIR-NORTHFLD\_345\_312

Mon 04/25/2016 to Sat 05/07/2016  
0800 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	1400 MW	1450 MW
Impacts Total Transfer Capability	0 MW	150 MW
TTC with All Lines In Service	1400 MW	1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 04/25/2016 to Sat 05/07/2016  
0800 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## SCH-NE-NYISO\_LIMIT\_500

Mon 04/25/2016 to Sat 05/07/2016  
0800 Continuous 1600

Work scheduled by: ISONE

	FWD (Import)
SCH - NE - NY	700 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1400 MW

## SCH-NYISO-NE\_LIMIT\_700

Mon 04/25/2016 to Sat 05/07/2016  
0800 Continuous 1600

Work scheduled by: ISONE

	REV (Export)
SCH - NE - NY	900 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1600 MW

## ROCKTVRN-RAMAPO\_\_\_345\_77

Fri 04/29/2016 to Sat 05/14/2016  
1600 Continuous 2359

Work scheduled by: ConEd

	FWD (Import)
CENTRAL EAST - VC	2570 MW
Impacts Total Transfer Capability	405 MW
TTC with All Lines In Service	2975 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Sat 04/30/2016 to Sun 05/01/2016  
0700 Continuous 1800

Work scheduled by: RGE

	FWD (Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Sun 05/01/2016 to Fri 05/06/2016  
1300 Continuous 1800

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 05/02/2016 to Fri 05/06/2016  
0001 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE 0 MW  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/02/2016 to Fri 05/06/2016  
0001 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE 0 MW  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NIAGARA\_-KINTIGH\_345\_NSl-38**

Mon 05/02/2016 to Fri 05/06/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**PANNELL\_-CLAY\_345\_2**

Mon 05/02/2016 to Mon 05/02/2016  
0730 Continuous 1500

Work scheduled by: NYPA

**UPDATED by RGE 02/16/2016**

FWD  
(Import)  
WEST CENTRAL 1300 MW  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**BROWNFLS-TAYLORVL\_115\_4**

Tue 05/03/2016 to Fri 05/27/2016  
0700 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 70 MW 40 MW  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**BERKSHIR-ALPS\_345\_393**

Sat 05/07/2016 to Sat 05/07/2016  
1600 Daily 1800

Work scheduled by: NGrid

**UPDATED by NE 01/15/2016**

FWD REV  
(Import) (Export)  
SCH - NE - NY 950 MW 1000 MW  
Impacts Total Transfer Capability 450 MW 600 MW  
TTC with All Lines In Service 1400 MW 1600 MW

**BERKSHIR-ALPS\_345\_393**

Sat 05/07/2016 to Sat 05/07/2016  
1600 Daily 1800

Work scheduled by: NGrid

**UPDATED by NE 01/15/2016**

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-NE\_LIMIT\_400

Sat 05/07/2016 to Sat 05/07/2016 UPDATED by NE 01/15/2016  
1600 Daily 1800

Work scheduled by: NGrid

SCH - NE - NY  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1600 MW

REV  
(Export)

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

Mon 05/09/2016 to Fri 05/13/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/09/2016 to Sat 05/14/2016  
0700 Continuous 1900

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Thu 05/12/2016 to Sat 05/14/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4150 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 5100 MW

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 05/16/2016 to Fri 05/27/2016 EXTENDED by NYPA 02/17/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## ROSETON\_-ROCKTVRN\_345\_311

Mon 05/16/2016 to Fri 06/03/2016  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

## EDIC\_\_-FRASER\_\_345\_EF24-40

Mon 05/23/2016 to Tue 05/24/2016  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_\_345\_LEEDS SVC

Mon 05/23/2016 to Fri 06/10/2016

0730 Continuous 1500

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

2950 MW

Impacts Total Transfer Capability 25 MW

TTC with All Lines In Service 2975 MW

## NINEMILE-CLAY\_\_\_\_345\_8

Tue 05/24/2016 to Fri 05/27/2016

0700 Continuous 1700

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT

5150 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 5250 MW

## MAINESBG-WATRCURE\_345\_30

Tue 05/24/2016 to Wed 05/25/2016

0800 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

REV

(Export)

SCH - PJ - NY

2200 MW

1300 MW

Impacts Total Transfer Capability 100 MW

0 MW

TTC with All Lines In Service 2300 MW

1300 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Thu 05/26/2016 to Fri 05/27/2016

0800 Continuous 1600

Work scheduled by: PJM

FWD

(Import)

REV

(Export)

SCH - PJ - NY

2200 MW

1300 MW

Impacts Total Transfer Capability 100 MW

0 MW

TTC with All Lines In Service 2300 MW

1300 MW

## MARCY\_\_\_\_-COOPERS\_\_345\_UCC2-41

Fri 05/27/2016 to Sat 05/28/2016

0500 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## BROWNFLS-TAYLORVL\_115\_3

Tue 05/31/2016 to Wed 06/15/2016

0600 Continuous 1700

Work scheduled by: NGrid

FWD

(Import)

REV

(Export)

SCH - HQ\_CEDARS

70 MW

40 MW

Impacts Total Transfer Capability 120 MW

0 MW

TTC with All Lines In Service 190 MW

40 MW

ARR: 38

## FRASER\_\_\_\_-COOPERS\_\_345\_33

Tue 05/31/2016 to Wed 06/01/2016

0700 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC

2395 MW

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NIAGARA\_-KINTIGH\_\_345\_NS1-38**

Fri 06/03/2016 to Fri 06/03/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**FRASER\_-GILBOA\_\_345\_GF5-35**

Sat 06/04/2016 to Fri 06/10/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

---

**BECK\_-NIAGARA\_\_345\_PA302**

Mon 06/06/2016 to Fri 06/17/2016  
0700 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 01/21/2016

FWD REV  
(Import) (Export)  
SCH - OH - NY **1200 MW 1100 MW**  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

---

**COLTON\_-FLATROCK\_115\_2**

Sun 06/12/2016 to Sun 06/12/2016  
0530 Continuous 1730

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **100 MW 40 MW**  
Impacts Total Transfer Capability 90 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**HANAWAFL-COLTON\_\_115\_5**

Sun 06/12/2016 to Sun 06/12/2016  
0530 Continuous 1730

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **150 MW 40 MW**  
Impacts Total Transfer Capability 40 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**PARISHVL-COLTON\_\_115\_3 & MCINTYRE-COLTON\_\_115\_8 & HANAWAFL-COLTON\_\_115\_5 & COLTON\_-FLATROCK\_115\_2**

Sun 06/12/2016 to Sun 06/12/2016  
0530 1730

Work scheduled by:

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **80 MW 40 MW**  
Impacts Total Transfer Capability 110 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**COLTON\_-FLATROCK\_115\_2**

Thu 06/16/2016 to Sat 06/18/2016  
0600 Continuous 1700

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **100 MW 40 MW**  
Impacts Total Transfer Capability 90 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---



# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV
Thu 06/16/2016 to Sun 06/26/2016					(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>COLTON__-FLATROCK_115_2</b>					FWD	REV
Sun 06/19/2016 to Sun 06/19/2016					(Import)	(Export)
0530	Continuous	1730	<u>UPDATED</u>	<u>by NGRID 02/04/2016</u>	SCH - HQ_CEDARS	<b>100 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>HANAWAFL-COLTON__115_5</b>					FWD	REV
Sun 06/19/2016 to Sun 06/19/2016					(Import)	(Export)
0530	Continuous	1730	<u>UPDATED</u>	<u>by NGRID 02/04/2016</u>	SCH - HQ_CEDARS	<b>150 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	40 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>PARISHVL-COLTON__115_3 &amp; MCINTYRE-COLTON__115_8 &amp; HANAWAFL-COLTON__115_5 &amp; COLTON__-FLATROCK_115_2</b>					FWD	REV
Sun 06/19/2016 to Sun 06/19/2016					(Import)	(Export)
0530		1730			SCH - HQ_CEDARS	<b>80 MW</b> <b>40 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	110 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>MOSES__-ADIRNDCK_230_Ma1</b>					FWD	
Mon 06/27/2016 to Wed 06/29/2016					(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV
Thu 06/30/2016 to Fri 07/01/2016					(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV
Tue 07/05/2016 to Sat 07/09/2016					(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 07/11/2016	to	Mon 08/01/2016		(Import)	(Export)
0600	Continuous	1700		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Tue 08/02/2016	to	Thu 08/25/2016		(Import)	(Export)
0600	Continuous	1700		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Fri 08/26/2016	to	Fri 09/02/2016		(Import)	(Export)
0600	Continuous	1700		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>MARCY__-COOPERS__345_UCC2-41</b>				FWD	
Sun 08/28/2016	to	Wed 08/31/2016		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
<b>GILBOA__-LEEDS__345_GL3</b>				FWD	
Mon 09/05/2016	to	Fri 09/09/2016		(Import)	
0800	Continuous	1530		CENTRAL EAST - VC	<b>2200 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	775 MW
				TTC with All Lines In Service	2975 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Tue 09/06/2016	to	Sun 09/11/2016		(Import)	(Export)
0600	Continuous	1700		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>MARCY__765_345_BK 2</b>				FWD	
Tue 09/06/2016	to	Sun 09/11/2016		(Import)	
0700	Continuous	1730		MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## KINTIGH\_-ROCHESTR\_345\_SR1-39

FWD

Mon 09/12/2016 to Fri 09/16/2016  
0700 Continuous 1630

UPDATED by NYISO 01/20/2016

Work scheduled by: NYPA

DYSINGER EAST 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_-ADIRNDCK\_230\_MAI

FWD

Mon 09/12/2016 to Sat 09/17/2016  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## HURLYAVE-ROSETON\_345\_303

FWD

Mon 09/12/2016 to Fri 09/30/2016  
0800 Continuous 1600

Work scheduled by: CHGE

(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## NIAGARA\_345\_230\_BK 4

FWD

REV

Wed 09/14/2016 to Thu 09/15/2016  
0700 Continuous 1530

UPDATED by PA 09/18/2015

Work scheduled by: NYPA

(Import) (Export)  
SCH - OH - NY 1900 MW 1900 MW  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## BECK\_-NIAGARA\_345\_PA301

FWD

REV

Fri 09/16/2016 to Fri 09/16/2016  
0700 Continuous 1530

Work scheduled by: NYPA

(Import) (Export)  
SCH - OH - NY 1200 MW 1100 MW  
Impacts Total Transfer Capability 700 MW 800 MW  
TTC with All Lines In Service 1900 MW 1900 MW

## FITZPTRK-EDIC\_345\_FE-1

FWD

Mon 09/19/2016 to Wed 09/21/2016  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
OSWEGO EXPORT 4800 MW  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

## MOSES\_-ADIRNDCK\_230\_MAI

FWD

Mon 09/19/2016 to Sat 09/24/2016  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
MOSES SOUTH 2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BECK____-NIAGARA__230_PA27</b>			FWD	REV
Mon 09/19/2016	to	Sun 11/06/2016	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	<b>1900 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	1900 MW
<b>NRTH1385-NOR HBR__138_601</b>			FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016	(Import)	(Export)
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>			FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016	(Import)	(Export)
0700		1600	SCH - NPX_1385	<b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>			FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016	(Import)	(Export)
0700		1600	SCH - NPX_1385	<b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602</b>			FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016	(Import)	(Export)
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>			FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016	(Import)	(Export)
0700		1600	SCH - NPX_1385	<b>0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603</b>			FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016	(Import)	(Export)
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NRTHPORT_138_1385				FWD	REV
Mon 09/26/2016 to Fri 09/30/2016				(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
MOSES -ADIRNDCK_230_MA1				FWD	
Mon 09/26/2016 to Sat 10/01/2016				(Import)	
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
MARCY -COOPERS_345_UCC2-41				FWD	
Mon 10/03/2016 to Sun 10/09/2016				(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
MOSES -ADIRNDCK_230_MA2				FWD	
Tue 10/04/2016 to Fri 10/07/2016				(Import)	
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
LEEDS -HURLYAVE_345_301				FWD	
Mon 10/10/2016 to Fri 11/04/2016				(Import)	
0700	Continuous	1600	UPDATED by NGRID 07/09/2015	UPNY CONED	4100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
LEEDS 345KV_R94301				FWD	
Mon 10/10/2016 to Fri 11/04/2016				(Import)	
0700	Continuous	1600	UPDATED by NGRID 07/09/2015	UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5100 MW
MOSES -ADIRNDCK_230_MA2				FWD	
Tue 10/11/2016 to Fri 10/14/2016				(Import)	
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/15/2016 to Sat 10/29/2016 **UPDATED** **by NYPA** **10/08/2015**  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

---

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/15/2016 to Sat 10/29/2016 **UPDATED** **by NYPA** **10/08/2015**  
 0100 Continuous 1730

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **0 MW** **0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sat 10/15/2016 to Sat 10/29/2016 **UPDATED** **by NYPA** **10/08/2015**  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 20**

FWD  
 (Import)  
 CENTRAL EAST - VC **2315 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 2975 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sat 10/15/2016 to Sat 10/29/2016 **UPDATED** **by NYPA** **10/08/2015**  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 20**

FWD  
 (Import)  
 MOSES SOUTH **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sat 10/15/2016 to Sat 10/29/2016 **UPDATED** **by NYPA** **10/08/2015**  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 20**

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **475 MW** **1000 MW**  
 Impacts Total Transfer Capability 1025 MW 0 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

---

**MASSENA\_-MARCY\_\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/15/2016 to Sat 10/29/2016  
 0100 1730

Work scheduled by:

**ARR: 20**

FWD  
 (Import)  
 MOSES SOUTH **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

---

**MOSES\_-MASSENA\_\_230\_MMS1 & MOSES\_-MASSENA\_\_230\_MMS2**

Sat 10/15/2016 to Sat 10/29/2016  
 0100 1730

Work scheduled by:

**ARR: 20**

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **850 MW** **0 MW**  
 Impacts Total Transfer Capability 650 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_BK 2</b>				FWD		
Mon 10/24/2016	to	Fri 10/28/2016		(Import)		
0700	Continuous	1730		MOSES SOUTH	<b>1700 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW	
<b>ARR: 19</b>				TTC with All Lines In Service	3150 MW	
<b>MOSES___-ADIRNDCK_230_MA2</b>				FWD		
Mon 10/31/2016	to	Sat 11/05/2016		(Import)		
0700	Continuous	1530		MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	
<b>HOMRC_NY-MAINS_NY_345_47</b>				FWD	REV	
Fri 11/04/2016	to	Fri 11/04/2016		(Import)	(Export)	
0600	Continuous	1600		SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	0 MW	0 MW
				TTC with All Lines In Service	2600 MW	1300 MW
<b>LEEDS___-PLSNTVLY_345_92</b>				FWD		
Mon 11/07/2016	to	Wed 12/07/2016	<b>UPDATED</b>	(Import)		
0001	Continuous	2359	<b>by CONED 09/16/2015</b>	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: NGrid				Impacts Total Transfer Capability	1300 MW	
				TTC with All Lines In Service	5100 MW	
<b>PLSNTVLY_345KV_RNS5</b>				FWD		
Mon 11/07/2016	to	Wed 12/07/2016	<b>UPDATED</b>	(Import)		
0001	Continuous	2359	<b>by CONED 09/16/2015</b>	UPNY CONED	<b>3800 MW</b>	
Work scheduled by: NGrid				Impacts Total Transfer Capability	1300 MW	
				TTC with All Lines In Service	5100 MW	
<b>MOSES___-ADIRNDCK_230_MA2</b>				FWD		
Mon 11/07/2016	to	Thu 11/10/2016		(Import)		
0700	Continuous	1530		MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	
<b>MAINESBG-WATRCURE_345_30</b>				FWD	REV	
Mon 11/07/2016	to	Fri 12/09/2016	<b>UPDATED</b>	(Import)	(Export)	
0800	Continuous	1600	<b>by NYSEG 02/16/2016</b>	SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	0 MW	0 MW
				TTC with All Lines In Service	2600 MW	1300 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BECK\_\_\_\_-NIAGARA\_\_345\_PA301

Mon 11/14/2016 to Fri 11/18/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1400 MW	1250 MW
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/14/2016 to Sat 11/19/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/21/2016 to Wed 11/23/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/28/2016 to Fri 12/02/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/05/2016 to Fri 12/09/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/12/2016 to Fri 12/16/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## FRASER\_\_\_\_-GILBOA\_\_345\_GF5-35

Mon 12/12/2016 to Fri 12/30/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW



**NYISO TRANSFER LIMITATIONS**

Tuesday ,February 23, 2016 to Thursday ,August 24, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 12/19/2016 to Thu 12/22/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

FITZPTRK-EDIC\_\_\_\_345\_FE-1

FWD

Mon 03/06/2017 to Fri 03/31/2017

(Import)

0600 Continuous 1900

OSWEGO EXPORT

**4800 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW