

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONTP-W49TH\_ST\_345\_Y56

FWD

Fri 01/01/2016 to Sun 05/01/2016 EXT FORCE by PJM 01/22/2016

(Import)

1308 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## W49TH\_ST-E13THSTA\_345\_M54

FWD

Thu 01/21/2016 to Sat 03/26/2016 EXT FORCE by CONED 03/23/2016

(Import)

0255 Continuous 1530

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

FWD

Mon 03/07/2016 to Tue 04/05/2016 UPDATED by CONED 03/21/2016

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED

4150 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

## EDIC\_\_\_\_-N.SCTLND\_345\_14

FWD

Wed 03/09/2016 to Tue 03/29/2016 UPDATED by NG 03/03/2016

(Import)

0600 Continuous 1559

Work scheduled by: NGrid

CENTRAL EAST - VC

2240 MW

Impacts Total Transfer Capability 735 MW

TTC with All Lines In Service 2975 MW

## SCH-HQ-NYISO\_LIMIT\_1450

FWD

Sat 03/19/2016 to Thu 03/31/2016

(Import)

0001 Continuous 1759

Work scheduled by: HQ

SCH - HQ - NY

1450 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_BK 2

FWD

Mon 03/21/2016 to Sat 03/26/2016 UPDATED by LI 03/10/2016

(Import)

0001 Continuous 0221

Work scheduled by: LI

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

## SCH-IMO-NYISO\_LIMIT\_800

FWD

Mon 03/21/2016 to Sat 04/02/2016 UPDATED by NYISO 03/18/2016

(Import)

0600 Continuous 1800

Work scheduled by: NGrid

SCH - OH - NY

1100 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1900 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HURLYAVE-ROSETON\_\_345\_303

Mon 03/21/2016 to Wed 03/23/2016  
 0700 Continuous 1600

Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 03/21/2016 to Thu 03/24/2016  
 0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 02/23/2016

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Mon 03/21/2016 to Wed 03/30/2016  
 1107 Continuous 2300

Work scheduled by: ConEd

EXT FORCE by CE 03/25/2016

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1100 MW  
 TTC with All Lines In Service 5100 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Wed 03/23/2016 to Tue 04/05/2016  
 0001 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 03/21/2016

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

## SCH-IMO\_NY\_NIAG\_NRTH\_BUS\_W/BB

Wed 03/23/2016 to Wed 03/23/2016  
 0500 Continuous 1600

Work scheduled by: NYPA

UPDATED by NYPA 03/16/2016

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1600 MW 1650 MW**  
 Impacts Total Transfer Capability 300 MW 250 MW  
 TTC with All Lines In Service 1900 MW 1900 MW

## ROCHESTR-PANNELL\_\_345\_RP2

Wed 03/23/2016 to Thu 03/24/2016  
 0500 Continuous 1700

Work scheduled by: NYPA

CANCELLED by NYPA 03/23/2016

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

## COOPERS\_-MIDDLETP\_345\_CMT-34

Wed 03/23/2016 to Fri 03/25/2016  
 0700 Continuous 1859

Work scheduled by: NYSEG

UPDATED by NY 03/23/2016

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1

Thu 03/24/2016 to Thu 03/24/2016  
0001 Continuous 0100  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Thu 03/24/2016 to Thu 03/24/2016  
0001 Continuous 0100  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Thu 03/24/2016 to Thu 03/24/2016  
0001 0100  
Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Thu 03/24/2016 to Thu 03/24/2016  
0001 0100  
Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Thu 03/24/2016 to Thu 03/24/2016  
0001 Continuous 0100  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Thu 03/24/2016 to Thu 03/24/2016  
0001 Continuous 0100  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-HQ-NYISO\_LIMIT\_900

Thu 03/24/2016 to Thu 03/24/2016  
0001 Continuous 0100  
Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **900 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FROST_BR-LONG_MTN_345_352						FWD	REV
						(Import)	(Export)
Sat 03/26/2016	to	Sat 03/26/2016	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/18/2016</u>	SCH - NE - NY	<b>1300 MW</b>
0600	Continuous	1530				Impacts Total Transfer Capability	100 MW
Work scheduled by: ISONE						TTC with All Lines In Service	1400 MW
							1600 MW
COOPERS_-ROCKTVRN_345_CRT-42						FWD	
						(Import)	
Sat 03/26/2016	to	Fri 04/08/2016	<u>UPDATED</u>	<u>by NYSEG</u>	<u>03/26/2016</u>	CENTRAL EAST - VC	<b>2720 MW</b>
0700	Continuous	1600				Impacts Total Transfer Capability	255 MW
Work scheduled by: CHGE						TTC with All Lines In Service	2975 MW
W49TH_ST_345KV_5						FWD	
						(Import)	
Mon 03/28/2016	to	Mon 03/28/2016	<u>CANCELLED</u>	<u>by ConEd</u>	<u>03/24/2016</u>	SCH - PJM_HTP	<b>310 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	350 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7						FWD	
						(Import)	
Mon 03/28/2016	to	Mon 03/28/2016	<u>CANCELLED</u>	<u>by ConEd</u>	<u>03/24/2016</u>	SCH - PJM_HTP	<b>310 MW</b>
0001	Continuous	0030				Impacts Total Transfer Capability	350 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_600						FWD	
						(Import)	
Mon 03/28/2016	to	Thu 03/31/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/25/2016</u>	SCH - OH - NY	<b>900 MW</b>
0900	Continuous	1600				Impacts Total Transfer Capability	1000 MW
Work scheduled by: PJM						TTC with All Lines In Service	1900 MW
W49TH_ST_345KV_5						FWD	
						(Import)	
Tue 03/29/2016	to	Tue 03/29/2016	<u>UPDATED</u>	<u>by CE</u>	<u>03/26/2016</u>	SCH - PJM_HTP	<b>310 MW</b>
0001	Continuous	0200				Impacts Total Transfer Capability	350 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW
W49TH_ST_345KV_7						FWD	
						(Import)	
Tue 03/29/2016	to	Tue 03/29/2016	<u>UPDATED</u>	<u>by CE</u>	<u>03/26/2016</u>	SCH - PJM_HTP	<b>310 MW</b>
0001	Continuous	0200				Impacts Total Transfer Capability	350 MW
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

FWD

Tue 03/29/2016 to Tue 03/29/2016 **CANCELLED** **by ConEd** **03/24/2016**

(Import)

0630 Continuous 0700

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Tue 03/29/2016 to Tue 03/29/2016 **CANCELLED** **by ConEd** **03/24/2016**

(Import)

0630 Continuous 0700

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**FITZPTRK-EDIC\_\_\_\_345\_FE-1**

FWD

Wed 03/30/2016 to Thu 03/31/2016 **UPDATED** **by NYISO** **02/22/2016**

(Import)

0500 Continuous 1659

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**MARCY\_\_\_\_-COOPERS\_\_345\_UCC2-41**

FWD

Wed 03/30/2016 to Tue 04/19/2016 **UPDATED** **by NYISO** **03/10/2016**

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MARCY\_\_\_\_345\_STATCOM SVC**

FWD

Wed 03/30/2016 to Tue 04/19/2016 **UPDATED** **by NYISO** **03/10/2016**

(Import)

0600 Continuous 1530

CENTRAL EAST - VC

**2925 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**MARCY\_\_\_\_765\_345\_BK 1**

FWD

Wed 03/30/2016 to Tue 04/19/2016 **UPDATED** **by NYISO** **03/10/2016**

(Import)

0600 Continuous 1530

MOSES SOUTH

**1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 19****W49TH\_ST\_345KV\_5**

FWD

Thu 03/31/2016 to Thu 03/31/2016 **UPDATED** **by CE** **03/26/2016**

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST\_345KV\_7

Thu 03/31/2016 to Thu 03/31/2016 UPDATED by CE 03/26/2016  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**310 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW

## OSWEGO\_\_-ELBRIDGE\_345\_17

Thu 03/31/2016 to Thu 03/31/2016 UPDATED by NGRID 02/18/2016  
0730 Daily(No Weekends) 0800

Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
**5250 MW**  
OSWEGO EXPORT  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## FLATROCK-BROWNFLS\_115\_2

Thu 03/31/2016 to Thu 03/31/2016  
0730 Daily(No Weekends) 1530

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
**130 MW 100 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 69 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

## ELBRIDGE-LAFAYTTE\_345\_17-LE

Thu 03/31/2016 to Thu 03/31/2016 UPDATED by NGRID 02/18/2016  
0730 Daily(No Weekends) 1700

Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
**5250 MW**  
OSWEGO EXPORT  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## OSWEGO\_\_-ELBRIDGE\_345\_17

Thu 03/31/2016 to Thu 03/31/2016 UPDATED by NGRID 02/18/2016  
1630 Daily(No Weekends) 1700

Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
**5250 MW**  
OSWEGO EXPORT  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## ILCTLIMIT\_115KV\_ALCOA\_R8105\_TIE\_B

Fri 04/01/2016 to Fri 04/01/2016  
0800 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD  
(Import)  
**3100 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 3150 MW

## ILCTLIMIT\_115KV\_ALCOA\_R8105\_TIE\_B

Fri 04/01/2016 to Fri 04/01/2016  
0800 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
**100 MW 60 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 99 MW 40 MW  
TTC with All Lines In Service 199 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDEN\_\_ -GOETHALS\_230\_A2253

Sat 04/02/2016 to Sat 04/02/2016  
0200 Continuous 1900

UPDATED by PJM 12/21/2015

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

## COLTON\_\_ -HIGLEY\_\_ 115\_1

Sun 04/03/2016 to Sun 04/10/2016  
1300 Continuous 1900

UPDATED by NGRID 03/22/2016

Work scheduled by: NGrid

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>130 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	69 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

## SUGARISL-COLTON\_\_ 115\_4

Sun 04/03/2016 to Sun 04/10/2016  
1300 Continuous 1900

UPDATED by NGRID 03/22/2016

Work scheduled by: NGrid

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>150 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	49 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

## SUGARISL-COLTON\_\_ 115\_4 & PYRITES\_-COLTON\_\_ 115\_7 & COLTON\_\_ -HIGLEY\_\_ 115\_1

Sun 04/03/2016 to Sun 04/10/2016  
1300 1900

UPDATED by NGRID 03/22/2016

Work scheduled by:

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>110 MW</b>	<b>60 MW</b>
Impacts Total Transfer Capability	89 MW	40 MW
TTC with All Lines In Service	199 MW	100 MW

## NRTH1385-NOR HBR\_\_ 138\_601

Mon 04/04/2016 to Mon 04/04/2016  
0001 Continuous 2359

UPDATED by NYISO 02/02/2016

Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## NRTH1385-NOR HBR\_\_ 138\_601 & NRTH1385-NOR HBR\_\_ 138\_602

Mon 04/04/2016 to Mon 04/04/2016  
0001 2359

UPDATED by NYISO 02/02/2016

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## NRTH1385-NOR HBR\_\_ 138\_601 & NRTH1385-NOR HBR\_\_ 138\_603

Mon 04/04/2016 to Mon 04/04/2016  
0001 2359

UPDATED by NYISO 02/02/2016

Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,March 28, 2016 to Wednesday,September27, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>NRTH1385-NOR HBR__138_602</b>							
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/02/2016</u>	SCH - NPX_1385	<b>100 MW</b>
0001	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>							
Mon 04/04/2016	to	Mon 04/04/2016				SCH - NPX_1385	<b>0 MW</b>
0001		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_603</b>							
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/02/2016</u>	SCH - NPX_1385	<b>100 MW</b>
0001	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_1385</b>							
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>02/02/2016</u>	SCH - NPX_1385	<b>0 MW</b>
0001	Continuous	2359				Impacts Total Transfer Capability	200 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
<b>SCH-NYISO-HQ_CEDARS_LIMIT_0</b>							
Mon 04/04/2016	to	Thu 04/14/2016				SCH - HQ_CEDARS	<b>0 MW</b>
0730	Continuous	1630				Impacts Total Transfer Capability	100 MW
Work scheduled by: HQ						TTC with All Lines In Service	100 MW
<b>ROCKTVRN-RAMAPO__345_77</b>							
Mon 04/04/2016	to	Fri 04/29/2016	<u>UPDATED</u>	<u>by CHGE</u>	<u>11/13/2015</u>	CENTRAL EAST - VC	<b>2570 MW</b>
0800	Continuous	1559				Impacts Total Transfer Capability	405 MW
Work scheduled by: CHGE						TTC with All Lines In Service	2975 MW
<b>CLAY__-EDIC__345_2-15</b>							
Tue 04/05/2016	to	Fri 04/08/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/18/2016</u>	OSWEGO EXPORT	<b>4850 MW</b>
0700	Continuous	1600				Impacts Total Transfer Capability	400 MW
Work scheduled by: NGrid						TTC with All Lines In Service	5250 MW



# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BROWNFLS-TAYLORVL\_115\_3

Wed 04/06/2016 to Thu 04/07/2016  
0730 Continuous 1800

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	100 MW
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

## PLSNTVLY\_345KV\_RNS4

Mon 04/11/2016 to Sun 04/17/2016  
0001 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
UPNY CONED	3800 MW	
Impacts Total Transfer Capability	1300 MW	
TTC with All Lines In Service	5100 MW	

## GOETHALS-LINDN\_CG\_345\_G23L &amp; GOETHALS-LINDN\_CG\_345\_G23M

Mon 04/11/2016 to Mon 04/25/2016  
0001 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	315 MW
Impacts Total Transfer Capability	315 MW	0 MW
TTC with All Lines In Service	315 MW	315 MW

## WATRCURE-OAKDALE\_345\_31

Mon 04/11/2016 to Thu 04/14/2016  
0800 Continuous 1630

Work scheduled by: NYSEG

UPDATED by NYSEG 03/01/2016

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

## HUDSONP\_-FARRAGUT\_345\_C3403

Wed 04/13/2016 to Fri 05/13/2016  
0200 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 01/07/2016

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

## BECK\_-NIAGARA\_230\_PA27

Fri 04/15/2016 to Fri 04/15/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1900 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1900 MW	1900 MW

## W49TH\_ST\_345KV\_6

Sat 04/16/2016 to Fri 04/29/2016  
0001 Continuous 2300

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Sat 04/16/2016 to Fri 04/29/2016  
0001 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### ROCHESTR-PANNELL\_345\_RP2

Sat 04/16/2016 to Sun 04/17/2016  
0700 Continuous 1800

Work scheduled by: RGE

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_-ADIRNDCK\_230\_MA2

Mon 04/18/2016 to Fri 04/22/2016  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 01/27/2016

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### FRASER\_-COOPERS\_345\_33

Mon 04/18/2016 to Sun 05/22/2016  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

### EDIC\_-FRASER\_345\_EF24-40

Wed 04/20/2016 to Tue 05/17/2016  
0500 Continuous 1700

Work scheduled by: NGrid

UPDATED by NGRID 03/22/2016

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### HOMER C\_-FIVEMILE\_345\_37

Wed 04/20/2016 to Thu 05/19/2016  
0800 Continuous 1600

Work scheduled by: NGrid

UPDATED by NYISO 02/24/2016

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2600 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2600 MW 1300 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 04/23/2016 to Sun 04/24/2016  
0100 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 03/22/2016

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>						FWD	REV
Sat 04/23/2016	to	Sun 04/24/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/22/2016</u>	(Import)	(Export)
0100	Continuous	1900				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: NYPA						SCH - HQ - NY	
						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Sat 04/23/2016	to	Sat 04/23/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/22/2016</u>	(Import)	
0500	Continuous	1100				<b>2315 MW</b>	
Work scheduled by: NYPA				<b>ARR: 20</b>		CENTRAL EAST - VC	
						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Sat 04/23/2016	to	Sat 04/23/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/22/2016</u>	(Import)	
0500	Continuous	1100				<b>500 MW</b>	
Work scheduled by: NYPA				<b>ARR: 20</b>		MOSES SOUTH	
						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	REV
Sat 04/23/2016	to	Sat 04/23/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/22/2016</u>	(Import)	(Export)
0500	Continuous	1100				<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA				<b>ARR: 20</b>		SCH - HQ - NY	
						Impacts Total Transfer Capability	1025 MW
						TTC with All Lines In Service	1500 MW
<b>MASSENA_-MARCY__765_MSU1 &amp; CHATGUAY-MASSENA__765_7040</b>						FWD	
Sat 04/23/2016	to	Sat 04/23/2016				(Import)	
0500		1100				<b>500 MW</b>	
Work scheduled by:				<b>ARR: 20</b>		MOSES SOUTH	
						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>BERKSHIR-ALPS__345_393</b>						FWD	REV
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u>	<u>01/15/2016</u>	(Import)	(Export)
0700	Daily(No Weekends)	0900				<b>1300 MW</b>	<b>1300 MW</b>
Work scheduled by: NGrid						SCH - NE - NY	
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-ALPS__345_393</b>						FWD	REV
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u>	<u>01/15/2016</u>	(Import)	(Export)
0700	Daily(No Weekends)	0900				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid						SCH - NPX_1385	
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-NE\_LIMIT\_400

Mon 04/25/2016 to Mon 04/25/2016

UPDATEDby NE01/15/2016

0700 Daily(No Weekends) 0900

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**600 MW**

1000 MW

1600 MW

## MOSES-ADIRNDCK\_230\_MA2

Mon 04/25/2016 to Fri 04/29/2016

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**2300 MW**

850 MW

3150 MW

## BERKSHIR-ALPS\_345\_393 &amp; BERKSHIR-NORTHFLD\_345\_312

Mon 04/25/2016 to Mon 04/25/2016

0800 0900

Work scheduled by:

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

REV

(Export)

**1300 MW****1300 MW**

100 MW

300 MW

1400 MW

1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 04/25/2016 to Sat 05/07/2016

0800 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

REV

(Export)

**1400 MW****1450 MW**

0 MW

150 MW

1400 MW

1600 MW

## BERKSHIR-NORTHFLD\_345\_312

Mon 04/25/2016 to Sat 05/07/2016

0800 Continuous 1600

Work scheduled by: ISONE

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

REV

(Export)

**100 MW****100 MW**

100 MW

100 MW

200 MW

200 MW

## SCH-NE-NYISO\_LIMIT\_500

Mon 04/25/2016 to Sat 05/07/2016

0800 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**700 MW**

700 MW

1400 MW

## SCH-NYISO-NE\_LIMIT\_700

Mon 04/25/2016 to Sat 05/07/2016

0800 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**900 MW**

700 MW

1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCKTVRN-RAMAPO\_\_\_345\_77

Fri 04/29/2016 to Sat 05/14/2016

1600 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Sat 04/30/2016 to Sun 05/01/2016

0700 Continuous 1800

Work scheduled by: RGE

FWD

(Import)

DYSINGER EAST

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Sun 05/01/2016 to Fri 05/06/2016

1300 Continuous 1800

Work scheduled by: PJM

FWD

(Import) (Export)

SCH - PJM\_VFT

0 MW

0 MW

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/02/2016 to Fri 05/06/2016

0001 Continuous 1800

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/02/2016 to Fri 05/06/2016

0001 Continuous 1800

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

## NIAGARA\_-KINTIGH\_\_\_345\_NS1-38

Mon 05/02/2016 to Fri 05/06/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## PANNELL\_-CLAY\_\_\_345\_2

Mon 05/02/2016 to Mon 05/02/2016

0730 Continuous 1500

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Tue 05/03/2016 to Wed 05/04/2016 CANCELLED by ConEd 03/28/2016

0001 Continuous 2300

Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	2300 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2300 MW	1300 MW

## BROWNFLS-TAYLORVL\_115\_4

Tue 05/03/2016 to Fri 05/27/2016

0700 Continuous 1800

Work scheduled by: NGrid

ARR: 38

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Sat 05/07/2016 to Sat 05/07/2016 UPDATED by NE 01/15/2016

1600 Daily 1800

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NE - NY	950 MW	1000 MW
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Sat 05/07/2016 to Sat 05/07/2016 UPDATED by NE 01/15/2016

1600 Daily 1800

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## SCH-NYISO-NE\_LIMIT\_400

Sat 05/07/2016 to Sat 05/07/2016 UPDATED by NE 01/15/2016

1600 Daily 1800

Work scheduled by: NGrid

	REV (Export)
SCH - NE - NY	600 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	1600 MW

## GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 05/09/2016 to Fri 05/13/2016

0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	2520 MW
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/09/2016 to Sat 05/14/2016

0700 Continuous 1900

Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Thu 05/12/2016 to Sat 05/14/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4150 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 5100 MW

## FROST\_BR-LONG\_MTN\_345\_352

Sat 05/14/2016 to Sat 05/14/2016

0600 Continuous 1600

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY **1150 MW 1600 MW**  
Impacts Total Transfer Capability 250 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Sun 05/15/2016 to Sun 05/15/2016

0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## EFISHKIL-WOOD\_ST\_\_345\_F38

Sun 05/15/2016 to Wed 05/18/2016

0001 Continuous 2330

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

Sun 05/15/2016 to Wed 05/18/2016

0001 Continuous 2330

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## COOPERS\_-ROCKTVRN\_345\_CRT-42

Mon 05/16/2016 to Fri 05/27/2016

0700 Continuous 1530

Work scheduled by: NYPA

EXTENDED by NYPA 02/17/2016

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## ROSETON\_-ROCKTVRN\_345\_311

Mon 05/16/2016 to Fri 06/03/2016

0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLE-DUNWODIE\_345\_W89

Wed 05/18/2016 to Wed 05/18/2016  
2300 Continuous 2330  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Thu 05/19/2016 to Sun 05/22/2016  
0001 Continuous 2100  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

Mon 05/23/2016 to Mon 05/23/2016  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLE-DUNWODIE\_345\_W90

Mon 05/23/2016 to Wed 05/25/2016  
0001 Continuous 2100  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## LEEDS\_\_\_\_345\_LEEDS SVC

Mon 05/23/2016 to Fri 06/10/2016  
0730 Continuous 1500  
Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2950 MW**  
Impacts Total Transfer Capability 25 MW  
TTC with All Lines In Service 2975 MW

## MAINESBG-WATRCURE\_345\_30

Mon 05/23/2016 to Mon 05/23/2016  
0900 Continuous 1159  
Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2200 MW 1300 MW**  
Impacts Total Transfer Capability 100 MW 0 MW  
TTC with All Lines In Service 2300 MW 1300 MW

## NINEMILE-CLAY\_\_\_\_345\_8

Tue 05/24/2016 to Fri 05/27/2016  
0700 Continuous 1700  
Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **5150 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 5250 MW



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MAINESBG-WATRCURE\_345\_30

Tue 05/24/2016 to Wed 05/25/2016  
0800 Continuous 1600

Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY	2200 MW	1300 MW
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	2300 MW	1300 MW

## EDIC -FRASER\_345\_EF24-40

Wed 05/25/2016 to Thu 05/26/2016  
0500 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 03/18/2016

	FWD (Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

## WOOD\_ST -PLSNTVLE\_345\_Y87

Wed 05/25/2016 to Wed 05/25/2016  
2030 Continuous 2100

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

## WOOD\_ST -PLSNTVLE\_345\_Y87

Thu 05/26/2016 to Thu 05/26/2016  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

## EFISHKIL-WOOD\_ST\_345\_F39

Thu 05/26/2016 to Sat 05/28/2016  
0001 Continuous 2100

Work scheduled by: ConEd

	FWD (Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Thu 05/26/2016 to Fri 05/27/2016  
0800 Continuous 1600

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	2200 MW	1300 MW
Impacts Total Transfer Capability	100 MW	0 MW
TTC with All Lines In Service	2300 MW	1300 MW

## MARCY -COOPERS\_345\_UCC2-41

Fri 05/27/2016 to Sat 05/28/2016  
0500 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

Sat 05/28/2016 to Sat 05/28/2016  
 2030 Continuous 2100

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED 4000 MW  
 Impacts Total Transfer Capability 1100 MW  
 TTC with All Lines In Service 5100 MW

## PLSNTVLY-WOOD\_ST\_345\_F31

Sun 05/29/2016 to Sun 05/29/2016  
 0001 Continuous 2100

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED 4000 MW  
 Impacts Total Transfer Capability 1100 MW  
 TTC with All Lines In Service 5100 MW

## BROWNFLS-TAYLORVL\_115\_3

Tue 05/31/2016 to Wed 06/15/2016  
 0600 Continuous 1700

Work scheduled by: NGrid

ARR: 38

FWD

(Import) (Export)

SCH - HQ\_CEDARS 70 MW 40 MW  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

## FRASER\_-COOPERS\_345\_33

Tue 05/31/2016 to Wed 06/01/2016  
 0700 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC 2395 MW  
 Impacts Total Transfer Capability 580 MW  
 TTC with All Lines In Service 2975 MW

## NIAGARA\_-KINTIGH\_345\_NS1-38

Fri 06/03/2016 to Fri 06/03/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST 1700 MW  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

## FRASER\_-GILBOA\_345\_GF5-35

Sat 06/04/2016 to Fri 06/10/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC 2650 MW  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

## BECK\_-NIAGARA\_345\_PA302

Mon 06/06/2016 to Fri 06/17/2016  
 0700 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 01/21/2016

FWD

(Import) (Export)

SCH - OH - NY 1200 MW 1100 MW  
 Impacts Total Transfer Capability 700 MW 800 MW  
 TTC with All Lines In Service 1900 MW 1900 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COLTON__-FLATROCK_115_2				FWD	REV
Sun 06/12/2016	to	Sun 06/12/2016		(Import)	(Export)
0530	Continuous	1730		SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
HANAWAFL-COLTON__115_5				FWD	REV
Sun 06/12/2016	to	Sun 06/12/2016		(Import)	(Export)
0530	Continuous	1730		SCH - HQ_CEDARS	150 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	40 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
PARISHVL-COLTON__115_3 & MCINTYRE-COLTON__115_8 & COLTON__-FLATROCK_115_2 & HANAWAFL-COLTON__115_5				FWD	REV
Sun 06/12/2016	to	Sun 06/12/2016		(Import)	(Export)
0530		1730		SCH - HQ_CEDARS	80 MW 40 MW
Work scheduled by:				Impacts Total Transfer Capability	110 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
COLTON__-FLATROCK_115_2				FWD	REV
Thu 06/16/2016	to	Sat 06/18/2016		(Import)	(Export)
0600	Continuous	1700		SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
Thu 06/16/2016	to	Sun 06/26/2016		(Import)	(Export)
0600	Continuous	1700		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
COLTON__-FLATROCK_115_2				FWD	REV
Sun 06/19/2016	to	Sun 06/19/2016	UPDATED by NGRID 02/04/2016	(Import)	(Export)
0530	Continuous	1730		SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
HANAWAFL-COLTON__115_5				FWD	REV
Sun 06/19/2016	to	Sun 06/19/2016	UPDATED by NGRID 02/04/2016	(Import)	(Export)
0530	Continuous	1730		SCH - HQ_CEDARS	150 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	40 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,March 28, 2016 to Wednesday,September27, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PARISHVL-COLTON___115_3 &amp; MCINTYRE-COLTON___115_8 &amp; COLTON___-FLATROCK_115_2 &amp; HANAWAFL-COLTON___115_5</b>			FWD	REV
			(Import)	(Export)
Sun 06/19/2016	to	Sun 06/19/2016	SCH - HQ_CEDARS	<b>80 MW 40 MW</b>
0530		1730	Impacts Total Transfer Capability	110 MW 0 MW
Work scheduled by:			TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>				
<b>MOSES___-ADIRNDCK_230_MAI</b>			FWD	
			(Import)	
Mon 06/27/2016	to	Wed 06/29/2016	MOSES SOUTH	<b>2100 MW</b>
0700	Continuous	1530	Impacts Total Transfer Capability	1050 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_4</b>			FWD	REV
			(Import)	(Export)
Thu 06/30/2016	to	Fri 07/01/2016	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
0600	Continuous	1700	Impacts Total Transfer Capability	120 MW 0 MW
Work scheduled by: NGrid			TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>				
<b>BROWNFLS-TAYLORVL_115_4</b>			FWD	REV
			(Import)	(Export)
Tue 07/05/2016	to	Sat 07/09/2016	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
0600	Continuous	1700	Impacts Total Transfer Capability	120 MW 0 MW
Work scheduled by: NGrid			TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>				
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD	REV
			(Import)	(Export)
Mon 07/11/2016	to	Mon 08/01/2016	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
0600	Continuous	1700	Impacts Total Transfer Capability	120 MW 0 MW
Work scheduled by: NGrid			TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>				
<b>BROWNFLS-TAYLORVL_115_4</b>			FWD	REV
			(Import)	(Export)
Tue 08/02/2016	to	Thu 08/25/2016	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
0600	Continuous	1700	Impacts Total Transfer Capability	120 MW 0 MW
Work scheduled by: NGrid			TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>				
<b>BROWNFLS-TAYLORVL_115_3</b>			FWD	REV
			(Import)	(Export)
Fri 08/26/2016	to	Fri 09/02/2016	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
0600	Continuous	1700	Impacts Total Transfer Capability	120 MW 0 MW
Work scheduled by: NGrid			TTC with All Lines In Service	190 MW 40 MW
<b>ARR: 38</b>				

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MARCY\_\_\_-COOPERS\_\_345\_UCC2-41**

Sun 08/28/2016 to Wed 08/31/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

---

**GILBOA\_\_\_-LEEDS\_\_\_\_345\_GL3**

Mon 09/05/2016 to Fri 09/09/2016  
0800 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2200 MW**  
Impacts Total Transfer Capability 775 MW  
TTC with All Lines In Service 2975 MW

---

**BROWNFLS-TAYLORVL\_115\_3**

Tue 09/06/2016 to Sun 09/11/2016  
0600 Continuous 1700

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**MARCY\_\_\_765\_345\_BK 2**

Tue 09/06/2016 to Sun 09/11/2016  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

Mon 09/12/2016 to Fri 09/16/2016  
0700 Continuous 1630

Work scheduled by: NYPA

**UPDATED by NYISO 01/20/2016**

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 09/12/2016 to Sat 09/17/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**HURLYAVE-ROSETON\_\_345\_303**

Mon 09/12/2016 to Fri 09/30/2016  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_BK 4					FWD	REV
					(Import)	(Export)
Wed 09/14/2016	to	Thu 09/15/2016	<u>UPDATED</u>	<u>by PA</u>	<u>09/18/2015</u>	
0700	Continuous	1530				
Work scheduled by: NYPA					SCH - OH - NY	1900 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
BECK____-NIAGARA__345_PA301					FWD	REV
					(Import)	(Export)
Fri 09/16/2016	to	Fri 09/16/2016				
0700	Continuous	1530			SCH - OH - NY	1200 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1900 MW
MOSES____-ADIRNDCK_230_MA1					FWD	
					(Import)	
Mon 09/19/2016	to	Sat 09/24/2016				
0700	Continuous	1530			MOSES SOUTH	2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
BECK____-NIAGARA__230_PA27					FWD	REV
					(Import)	(Export)
Mon 09/19/2016	to	Sun 11/06/2016				
0700	Continuous	1530			SCH - OH - NY	1900 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1900 MW
NRTH1385-NOR HBR__138_601					FWD	REV
					(Import)	(Export)
Mon 09/26/2016	to	Fri 09/30/2016				
0700	Continuous	1600			SCH - NPX_1385	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602					FWD	REV
					(Import)	(Export)
Mon 09/26/2016	to	Fri 09/30/2016				
0700		1600			SCH - NPX_1385	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603					FWD	REV
					(Import)	(Export)
Mon 09/26/2016	to	Fri 09/30/2016				
0700		1600			SCH - NPX_1385	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NRTH1385-NOR HBR\_\_138\_602**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NRTHPORT\_138\_1385**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 09/26/2016 to Sat 10/01/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

---

**MARCY\_\_-COOPERS\_\_345\_UCC2-41**

Mon 10/03/2016 to Sun 10/09/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Tue 10/04/2016 to Fri 10/07/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_\_-HURLYAVE\_345\_301

FWD

Mon 10/10/2016 to Fri 11/04/2016

UPDATEDby NGRID 07/09/2015

(Import)

0700 Continuous 1600

Work scheduled by: NGrid

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

## LEEDS\_\_\_\_345KV\_R94301

FWD

Mon 10/10/2016 to Fri 11/04/2016

UPDATEDby NGRID 07/09/2015

(Import)

0700 Continuous 1600

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Tue 10/11/2016 to Fri 10/14/2016

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_\_\_765\_7040

FWD

Sat 10/15/2016 to Sat 10/29/2016

UPDATEDby NYPA 10/08/2015

(Import)

0100 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_\_\_765\_7040

FWD

REV

Sat 10/15/2016 to Sat 10/29/2016

UPDATEDby NYPA 10/08/2015

(Import) (Export)

0100 Continuous 1730

Work scheduled by: NYPA

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_\_\_\_-MARCY\_\_\_\_765\_MSU1

FWD

Sat 10/15/2016 to Sat 10/29/2016

UPDATEDby NYPA 10/08/2015

(Import)

0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 20**

CENTRAL EAST - VC

**2315 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

## MASSENA\_\_\_\_-MARCY\_\_\_\_765\_MSU1

FWD

Sat 10/15/2016 to Sat 10/29/2016

UPDATEDby NYPA 10/08/2015

(Import)

0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 20**

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>MASSENA_-MARCY_765_MSU1</b>						
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u> <u>10/08/2015</u>	SCH - HQ - NY	<b>475 MW</b>
0100	Continuous	1730			Impacts Total Transfer Capability	1025 MW
Work scheduled by: NYPA			<b>ARR: 20</b>		TTC with All Lines In Service	1500 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						
Sat 10/15/2016	to	Sat 10/29/2016			MOSES SOUTH	<b>500 MW</b>
0100		1730			Impacts Total Transfer Capability	2650 MW
Work scheduled by:			<b>ARR: 20</b>		TTC with All Lines In Service	3150 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						
Sat 10/15/2016	to	Sat 10/29/2016			SCH - HQ - NY	<b>850 MW</b>
0100		1730			Impacts Total Transfer Capability	650 MW
Work scheduled by:			<b>ARR: 20</b>		TTC with All Lines In Service	1500 MW
<b>MARCY_765_345_BK 2</b>						
Mon 10/24/2016	to	Fri 10/28/2016			MOSES SOUTH	<b>1700 MW</b>
0700	Continuous	1730			Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA			<b>ARR: 19</b>		TTC with All Lines In Service	3150 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>						
Mon 10/31/2016	to	Sat 11/05/2016			MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530			Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA					TTC with All Lines In Service	3150 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>						
Fri 11/04/2016	to	Fri 11/04/2016			SCH - PJ - NY	<b>2600 MW</b>
0600	Continuous	1600			Impacts Total Transfer Capability	0 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	2600 MW
<b>LEEDS_-PLSNTVLY_345_92</b>						
Mon 11/07/2016	to	Wed 12/07/2016	<u>UPDATED</u>	<u>by CONED</u> <u>09/16/2015</u>	UPNY CONED	<b>3800 MW</b>
0001	Continuous	2359			Impacts Total Transfer Capability	1300 MW
Work scheduled by: NGrid					TTC with All Lines In Service	5100 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RNS5

FWD

Mon 11/07/2016 to Wed 12/07/2016 UPDATED by CONED 09/16/2015

(Import)

0001 Continuous 2359

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: NGrid

## MOSES\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 11/07/2016 to Thu 11/10/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MAINESBG-WATRCURE\_345\_30

FWD

REV

Mon 11/07/2016 to Fri 12/09/2016 UPDATED by NYSEG 02/16/2016

(Import) (Export)

0800 Continuous 1600

SCH - PJ - NY

2600 MW 1300 MW

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

Work scheduled by: PJM

## BECK\_\_-NIAGARA\_345\_PA301

FWD

REV

Mon 11/14/2016 to Fri 11/18/2016

(Import) (Export)

0700 Continuous 1530

SCH - OH - NY

1400 MW 1250 MW

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

Work scheduled by: NYPA

## MOSES\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 11/14/2016 to Sat 11/19/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MOSES\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 11/21/2016 to Wed 11/23/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## MOSES\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 11/28/2016 to Fri 12/02/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/05/2016 to Fri 12/09/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**GILBOA\_\_\_-N.SCTLND\_345\_GNS-1**

FWD

Thu 12/08/2016 to Fri 12/16/2016

(Import)

0600 Continuous 1800

CENTRAL EAST - VC

**2520 MW**

Impacts Total Transfer Capability 455 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

---

**MARCY\_\_\_-N.SCTLND\_345\_18**

FWD

Thu 12/08/2016 to Fri 12/16/2016

(Import)

0600 Continuous 1800

CENTRAL EAST - VC

**2090 MW**

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

---

**N.SCTLND-LEEDS\_\_\_345\_94**

FWD

Thu 12/08/2016 to Fri 12/16/2016

(Import)

0600 Continuous 1800

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/12/2016 to Fri 12/16/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

FWD

Sat 12/17/2016 to Fri 12/30/2016

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 12/19/2016 to Thu 12/22/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FITZPTRK-EDIC\_\_\_\_\_345\_FE-1**

Mon 03/06/2017 to Fri 03/31/2017

0600 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 05/01/2017 to Fri 05/26/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**BROWNFLS-TAYLORVL\_115\_4**

Tue 05/30/2017 to Sat 06/24/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 06/26/2017 to Sat 07/01/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**BROWNFLS-TAYLORVL\_115\_3**

Wed 07/05/2017 to Sat 07/22/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 07/24/2017 to Sat 08/19/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 08/21/2017 to Fri 09/01/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD

(Import) (Export)

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,March 28, 2016 to Wednesday,September27, 2017

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_3**

Tue 09/05/2017 to Sat 09/16/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 09/18/2017 to Sat 10/14/2017

0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW