

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

FWD

Fri 01/01/2016 to Sun 05/01/2016

EXT FORCE **by PJM** **01/22/2016**

(Import)

1308 Continuous 2359

SCH - PJM_HTP

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

MARCY -EDIC 345 UE1-7

FWD

Mon 01/04/2016 to Fri 02/26/2016

UPDATED **by NG** **02/10/2016**

(Import)

0500 Continuous 0830

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 16**FRASER -COOPERS 345_33**

FWD

Mon 01/04/2016 to Thu 03/03/2016

UPDATED **by NYSEG** **02/15/2016**

(Import)

0800 Continuous 1459

CENTRAL EAST - VC

2395 MW

Impacts Total Transfer Capability 580 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

W49TH_ST-E13THSTA_345_M54

FWD

Thu 01/21/2016 to Mon 03/14/2016

EXT FORCE **by CE** **02/03/2016**

(Import)

0255 Continuous 2359

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

MOSES -ADIRNDCK_230_MA1

FWD

Sun 02/21/2016 to Fri 02/26/2016

UPDATED **by PA** **02/10/2016**

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

RAMAPO 500_345_BK 1500

FWD

REV

Tue 02/23/2016 to Sat 02/27/2016

EXTENDED **by CE** **02/25/2016**

(Import) (Export)

1700 Continuous 2302

SCH - PJ - NY

2100 MW 1000 MW

Impacts Total Transfer Capability 500 MW 300 MW

TTC with All Lines In Service 2600 MW 1300 MW

Work scheduled by: ConEd

RAMAPO 500_345_BK 1500

FWD

Tue 02/23/2016 to Sat 02/27/2016

EXTENDED **by CE** **02/25/2016**

(Import)

1700 Continuous 2302

TOTAL EAST

6400 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 6500 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___500_345_BK 1500						FWD	
Tue 02/23/2016	to	Sat 02/27/2016	<u>EXTENDED</u>	<u>by CE</u>	<u>02/25/2016</u>	(Import)	
1700	Continuous	2302				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO___500_5018						FWD	REV
Tue 02/23/2016	to	Sat 02/27/2016	<u>EXTENDED</u>	<u>by CE</u>	<u>02/25/2016</u>	(Import)	(Export)
1700	Continuous	2335				SCH - PJ - NY	2100 MW 1000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	500 MW 300 MW
						TTC with All Lines In Service	2600 MW 1300 MW
HOPATCON-RAMAPO___500_5018						FWD	
Tue 02/23/2016	to	Sat 02/27/2016	<u>EXTENDED</u>	<u>by CE</u>	<u>02/25/2016</u>	(Import)	
1700	Continuous	2335				TOTAL EAST	6400 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	6500 MW
HOPATCON-RAMAPO___500_5018						FWD	
Tue 02/23/2016	to	Sat 02/27/2016	<u>EXTENDED</u>	<u>by CE</u>	<u>02/25/2016</u>	(Import)	
1700	Continuous	2335				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
RAMAPO___345_345_PAR3500						FWD	REV
Tue 02/23/2016	to	Sat 02/27/2016	<u>EXTENDED</u>	<u>by CE</u>	<u>02/25/2016</u>	(Import)	(Export)
1700	Continuous	2343				SCH - PJ - NY	2400 MW 1300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	200 MW 0 MW
						TTC with All Lines In Service	2600 MW 1300 MW
RAMAPO___345_345_PAR4500						FWD	REV
Tue 02/23/2016	to	Sat 02/27/2016	<u>EXTENDED</u>	<u>by CE</u>	<u>02/25/2016</u>	(Import)	(Export)
1700	Continuous	2344				SCH - PJ - NY	2400 MW 1300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	200 MW 0 MW
						TTC with All Lines In Service	2600 MW 1300 MW
DUNWODIE-MOTTHAVN_345_71						FWD	
Sat 02/27/2016	to	Sat 02/27/2016				(Import)	
0001	Continuous	1530				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1400

Sat 02/27/2016 to Sat 02/27/2016
0700 Continuous 0859

UPDATED

by HQ

02/25/2016

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1400 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1500 MW

SCH-NYISO-HQ_LIMIT_500

Sat 02/27/2016 to Sat 02/27/2016
0700 Continuous 0859

UPDATED

by HQ

02/25/2016

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_1400

Sat 02/27/2016 to Sat 02/27/2016
1700 Continuous 1959

UPDATED

by HQ

02/25/2016

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1400 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1500 MW

SCH-NYISO-HQ_LIMIT_500

Sat 02/27/2016 to Sat 02/27/2016
1700 Continuous 1959

UPDATED

by HQ

02/25/2016

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-IMO-NYISO_LIMIT_1100

Mon 02/29/2016 to Mon 02/29/2016
0600 Continuous 1700

Work scheduled by: NGrid

FWD
(Import)
SCH - OH - NY **1400 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1900 MW

MILLWOOD_345KV_18

Tue 03/01/2016 to Tue 03/01/2016
0001 Continuous 2330

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SCH-IMO-NYISO_LIMIT_900

Tue 03/01/2016 to Tue 03/01/2016
0600 Continuous 1700

Work scheduled by: NGrid

FWD
(Import)
SCH - OH - NY **1200 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1900 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1						FWD
Tue 03/01/2016	to	Tue 03/01/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/17/2016</u>	(Import)
0700	Continuous	1530				WEST CENTRAL
Work scheduled by: NYPA						1300 MW
						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 2250 MW
MOSES_-ADIRNDCK_230_MAI						FWD
Tue 03/01/2016	to	Fri 03/04/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/09/2016</u>	(Import)
0700	Continuous	1530				MOSES SOUTH
Work scheduled by: NYPA						2300 MW
						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
VOLNEY_-CLAY_____345_6						FWD
Wed 03/02/2016	to	Thu 03/03/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/23/2016</u>	(Import)
0730	Continuous	1700				OSWEGO EXPORT
Work scheduled by: NGrid						5250 MW
						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
PANNELL_-CLAY_____345_2						FWD
Thu 03/03/2016	to	Fri 03/04/2016				(Import)
0700	Continuous	1530				WEST CENTRAL
Work scheduled by: NYPA						1300 MW
						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 2250 MW
GILBOA_-N.SCTLND_345_GNS-1						FWD
Thu 03/03/2016	to	Thu 03/03/2016				(Import)
0800	Daily(No Weekends)	1230				CENTRAL EAST - VC
Work scheduled by: NGrid						2520 MW
						Impacts Total Transfer Capability 455 MW
						TTC with All Lines In Service 2975 MW
FRASER_____345_FRASER SVC						FWD
Thu 03/03/2016	to	Thu 03/03/2016				(Import)
0900	Continuous	1330				CENTRAL EAST - VC
Work scheduled by: NYSEG						2935 MW
						Impacts Total Transfer Capability 40 MW
						TTC with All Lines In Service 2975 MW
FRASER_-COOPERS_____345_33						FWD
Thu 03/03/2016	to	Tue 03/08/2016	<u>EXT FORCE</u>	<u>by NYSEG</u>	<u>02/26/2016</u>	(Import)
1500	Continuous	1500				CENTRAL EAST - VC
Work scheduled by: NYSEG						2395 MW
						Impacts Total Transfer Capability 580 MW
						TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

FWD

Fri 03/04/2016 to Fri 03/04/2016 **UPDATED** **by NYISO** **02/17/2016**

(Import)

0800 Daily(No Weekends) 1159

CENTRAL EAST - VC

2090 MW

Impacts Total Transfer Capability 885 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

N.SCTLND-LEEDS___345_94

FWD

Fri 03/04/2016 to Fri 03/04/2016

(Import)

1200 Daily(No Weekends) 1600

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

CHATGUAY-MASSENA___765_7040

FWD

Sat 03/05/2016 to Sun 03/06/2016 **UPDATED** **by NYPA** **02/29/2016**

(Import)

0100 Continuous 1730

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA___765_7040

FWD

REV

Sat 03/05/2016 to Sun 03/06/2016 **UPDATED** **by NYPA** **02/29/2016**

(Import) (Export)

0100 Continuous 1730

SCH - HQ - NY

0 MW**0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

MASSENA_-MARCY___765_MSU1

FWD

Sat 03/05/2016 to Sun 03/06/2016 **UPDATED** **by NYPA** **02/29/2016**

(Import)

0100 Continuous 1730

CENTRAL EAST - VC

2315 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 20**MASSENA_-MARCY___765_MSU1**

FWD

Sat 03/05/2016 to Sun 03/06/2016 **UPDATED** **by NYPA** **02/29/2016**

(Import)

0100 Continuous 1730

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 20**MASSENA_-MARCY___765_MSU1**

FWD

REV

Sat 03/05/2016 to Sun 03/06/2016 **UPDATED** **by NYPA** **02/29/2016**

(Import) (Export)

0100 Continuous 1730

SCH - HQ - NY

475 MW**1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

ARR: 20

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_ 765_MSU1 & CHATGUAY-MASSENA_ 765_7040

FWD

Sat 03/05/2016 to Sun 03/06/2016
0100 1730

(Import)

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

ARR: 20

MOSES_-MASSENA_ 230_MMS1 & MOSES_-MASSENA_ 230_MMS2

FWD

REV

Sat 03/05/2016 to Sun 03/06/2016
0100 1730

(Import) (Export)

SCH - HQ - NY

850 MW 0 MW

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by:

ARR: 20

ATHENS_-PLSNTVLY_ 345_91

FWD

Sat 03/05/2016 to Sun 03/06/2016
0700 Continuous 1700

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: NGrid

COOPERS_-MIDDLETP_ 345_CMT-34

FWD

Sat 03/05/2016 to Sun 03/06/2016
0800 Continuous 1600

(Import)

CANCELLED by NYSEG 02/29/2016

CENTRAL EAST - VC

2720 MW

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

OSWEGO_COMPLEX_AVR_O/S

FWD

Sun 03/06/2016 to Sun 03/06/2016
0900 Continuous 1100

(Import)

CENTRAL EAST - VC

2870 MW

Impacts Total Transfer Capability 105 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: Gen

MARCY_-COOPERS_ 345_UCC2-41

FWD

Sun 03/06/2016 to Mon 03/07/2016
1800 Continuous 0559

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

EASTVIEW-SPRNBK_ 345_W79

FWD

Mon 03/07/2016 to Mon 03/07/2016
0001 Continuous 0030

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

Mon 03/07/2016 to Fri 03/18/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

RAMAPO__-BUCHAN_N_345_Y94

Mon 03/07/2016 to Tue 04/05/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

4150 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 5100 MW

N.SCTLND-ALPS____345_2

Mon 03/07/2016 to Mon 03/14/2016

0600 Continuous 1600

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NE - NY

900 MW 1600 MW

Impacts Total Transfer Capability 500 MW 0 MW

TTC with All Lines In Service 1400 MW 1600 MW

N.SCTLND-ALPS____345_2

Mon 03/07/2016 to Mon 03/14/2016

0600 Continuous 1600

Work scheduled by: NGrid

FWD

(Import) (Export)

SCH - NPX_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

N.SCTLND-LEEDS____345_93

Mon 03/07/2016 to Mon 03/14/2016

0600 Continuous 1600

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

2650 MW

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

EDIC____-N.SCTLND_345_14

Mon 03/07/2016 to Sun 03/27/2016

0600 Continuous 1600

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC

2240 MW

Impacts Total Transfer Capability 735 MW

TTC with All Lines In Service 2975 MW

MOSES____-ADIRNDCK_230_M2

Mon 03/07/2016 to Fri 03/11/2016

0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79

Tue 03/08/2016 to Mon 03/14/2016
0001 Continuous 1930

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

NIAGARA_-ROCHESTR_345_NR2

Wed 03/09/2016 to Thu 03/10/2016
0700 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

EGRDNCTY_345_138_BK 1

Thu 03/10/2016 to Sat 03/19/2016 UPDATED by LI 01/28/2016
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

NIAGARA_-KINTIGH__345_NS1-38

Fri 03/11/2016 to Sat 03/12/2016
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FROST_BR-LONG_MTN_345_352

Sun 03/13/2016 to Sun 03/13/2016
0600 Continuous 1530

Work scheduled by: ISONE

FWD	REV
(Import)	(Export)
SCH - NE - NY	1300 MW 1600 MW
Impacts Total Transfer Capability	100 MW 0 MW
TTC with All Lines In Service	1400 MW 1600 MW

COOPERS_-ROCKTVRN_345_CRT-42

Mon 03/14/2016 to Sun 03/27/2016 UPDATED by CHGE 05/06/2015
0600 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

BECK_____-PACKARD__230_BP76

Mon 03/14/2016 to Mon 03/14/2016 UPDATED by NGRID 02/09/2016
0645 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD	REV
(Import)	(Export)
SCH - OH - NY	1600 MW 1650 MW
Impacts Total Transfer Capability	300 MW 250 MW
TTC with All Lines In Service	1900 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 03/14/2016 to Sat 03/19/2016
0700 Continuous 1730

UPDATEDby NYPA02/23/2016

(Import)

Work scheduled by: NYPA

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

EASTVIEW-SPRNBK__345_W79

FWD

Tue 03/15/2016 to Thu 03/17/2016
0001 Continuous 1930

(Import)

Work scheduled by: ConEd

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

FWD

REV

Fri 03/18/2016 to Fri 03/18/2016
0700 Continuous 1530

(Import) (Export)

Work scheduled by: NYPA

SCH - OH - NY

1600 MW 1650 MW

Impacts Total Transfer Capability 300 MW 250 MW

TTC with All Lines In Service 1900 MW 1900 MW

LEEDS___-PLSNTVLY_345_92

FWD

Sat 03/19/2016 to Sat 03/19/2016
0001 Continuous 2359

(Import)

Work scheduled by: ConEd

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

FWD

Sat 03/19/2016 to Sat 03/19/2016
0001 Continuous 2359

(Import)

Work scheduled by: ConEd

UPNY CONED

3800 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

W49TH_ST_345KV_6

FWD

Mon 03/21/2016 to Mon 03/21/2016
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP

340 MW

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Mon 03/21/2016 to Mon 03/21/2016
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SCH - PJM_HTP

340 MW

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_BK 2

FWD

Mon 03/21/2016 to Wed 03/30/2016

UPDATEDby LI01/28/2016

(Import)

0001 Continuous 2359

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

MOSES -ADIRNDCK_230_MA2

FWD

Mon 03/21/2016 to Thu 03/24/2016

UPDATEDby NYPA02/23/2016

(Import)

0700 Continuous 1730

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

HURLYAVE-ROSETON_345_303

FWD

Mon 03/21/2016 to Fri 03/25/2016

(Import)

0700 Continuous 1600

UPNY CONED

4100 MW

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

ROCHESTR-PANNELL_345_RP1

FWD

Mon 03/21/2016 to Tue 03/22/2016

(Import)

1000 Continuous 1700

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

BUCHAN_N-EASTVIEW_345_W93

FWD

Wed 03/23/2016 to Tue 04/05/2016

(Import)

0001 Continuous 2359

UPNY CONED

4350 MW

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

ROCHESTR-PANNELL_345_RP2

FWD

Wed 03/23/2016 to Thu 03/24/2016

(Import)

0500 Continuous 1700

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

W49TH_ST_345KV_6

FWD

Sat 03/26/2016 to Sat 03/26/2016

(Import)

1700 Continuous 1900

SCH - PJM_HTP

340 MW

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 03/26/2016 to Sat 03/26/2016
1700 Continuous 1900
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **340 MW**
Impacts Total Transfer Capability 320 MW
TTC with All Lines In Service 660 MW

FROST_BR-LONG_MTN_345_352

Sun 03/27/2016 to Sun 03/27/2016
0600 Continuous 1530
Work scheduled by: ISONE

FWD REV
(Import) (Export)
SCH - NE - NY **1300 MW 1600 MW**
Impacts Total Transfer Capability 100 MW 0 MW
TTC with All Lines In Service 1400 MW 1600 MW

W49TH_ST_345KV_5

Mon 03/28/2016 to Mon 03/28/2016 UPDATED by CE 02/22/2016
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **330 MW**
Impacts Total Transfer Capability 330 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Mon 03/28/2016 to Mon 03/28/2016 UPDATED by CE 02/22/2016
0001 Continuous 0030
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **330 MW**
Impacts Total Transfer Capability 330 MW
TTC with All Lines In Service 660 MW

FITZPTRK-EDIC____345_FE-1

Mon 03/28/2016 to Tue 03/29/2016 UPDATED by NYISO 02/22/2016
0500 Continuous 1700
Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **4800 MW**
Impacts Total Transfer Capability 450 MW
TTC with All Lines In Service 5250 MW

MARCY____-COOPERS__345_UCC2-41

Mon 03/28/2016 to Sun 04/17/2016
0500 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY____345_STATCOM SVC

Mon 03/28/2016 to Sun 04/17/2016
0600 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_BK 1

FWD

Mon 03/28/2016 to Sun 04/17/2016

(Import)

0600 Continuous 1530

MOSES SOUTH

1750 MW

Work scheduled by: NYPA

ARR: 19

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

W49TH_ST_345KV_5

FWD

Tue 03/29/2016 to Tue 03/29/2016

(Import)

0630 Continuous 0700

UPDATED**by CE****02/22/2016**

SCH - PJM_HTP

330 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 330 MW

TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

FWD

Tue 03/29/2016 to Tue 03/29/2016

(Import)

0630 Continuous 0700

UPDATED**by CE****02/22/2016**

SCH - PJM_HTP

330 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 330 MW

TTC with All Lines In Service 660 MW

OSWEGO__ -ELBRIDGE_345_17

FWD

Thu 03/31/2016 to Thu 03/31/2016

(Import)

0730 Daily(No Weekends) 0800

UPDATED**by NGRID****02/18/2016**

OSWEGO EXPORT

5250 MW

Work scheduled by: NGrid

ARR: 75

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

ELBRIDGE-LAFAYTTE_345_17-LE

FWD

Thu 03/31/2016 to Thu 03/31/2016

(Import)

0730 Daily(No Weekends) 1700

UPDATED**by NGRID****02/18/2016**

OSWEGO EXPORT

5250 MW

Work scheduled by: NGrid

ARR: 75

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

OSWEGO__ -ELBRIDGE_345_17

FWD

Thu 03/31/2016 to Thu 03/31/2016

(Import)

1630 Daily(No Weekends) 1700

UPDATED**by NGRID****02/18/2016**

OSWEGO EXPORT

5250 MW

Work scheduled by: NGrid

ARR: 75

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

LINDEN__ -GOETHALS_230_A2253

FWD

REV

Sat 04/02/2016 to Sat 04/02/2016

(Import) (Export)

0200 Continuous 1900

UPDATED**by PJM****12/21/2015**

SCH - PJ - NY

2600 MW 1300 MW

Work scheduled by: PJM

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COLTON__-HIGLEY__115_1				FWD	REV
Sun 04/03/2016	to	Sun 04/10/2016		(Import)	(Export)
0700	Continuous	1900		SCH - HQ_CEDARS	130 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	69 MW 0 MW
ARR: 38				TTC with All Lines In Service	199 MW 100 MW
SUGARISL-COLTON__115_4				FWD	REV
Sun 04/03/2016	to	Sun 04/10/2016		(Import)	(Export)
0700	Continuous	1900		SCH - HQ_CEDARS	150 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	49 MW 0 MW
ARR: 38				TTC with All Lines In Service	199 MW 100 MW
SUGARISL-COLTON__115_4 & PYRITES_-COLTON__115_7 & COLTON__-HIGLEY__115_1				FWD	REV
Sun 04/03/2016	to	Sun 04/10/2016		(Import)	(Export)
0700		1900		SCH - HQ_CEDARS	110 MW 60 MW
Work scheduled by:				Impacts Total Transfer Capability	89 MW 40 MW
ARR: 38				TTC with All Lines In Service	199 MW 100 MW
NRTH1385-NOR HBR__138_601				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u> <u>by NYISO</u> <u>02/02/2016</u>	(Import)	(Export)
0001	Continuous	2359		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016		(Import)	(Export)
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016		(Import)	(Export)
0001		2359		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602				FWD	REV
Mon 04/04/2016	to	Mon 04/04/2016	<u>UPDATED</u> <u>by NYISO</u> <u>02/02/2016</u>	(Import)	(Export)
0001	Continuous	2359		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 04/04/2016 to Mon 04/04/2016

0001 2359

Work scheduled by:

SCH - NPX_1385

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

FWD REV
(Import) (Export)

0 MW 0 MW

NRTH1385-NOR HBR__138_603

Mon 04/04/2016 to Mon 04/04/2016

0001 Continuous 2359

Work scheduled by: LI

UPDATED by NYISO 02/02/2016

SCH - NPX_1385

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

FWD REV
(Import) (Export)

100 MW 100 MW

NRTH1385-NRTHPORT_138_1385

Mon 04/04/2016 to Mon 04/04/2016

0001 Continuous 2359

Work scheduled by: LI

UPDATED by NYISO 02/02/2016

SCH - NPX_1385

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

FWD REV
(Import) (Export)

0 MW 0 MW

ROCKTVRN-RAMAPO__345_77

Mon 04/04/2016 to Fri 04/29/2016

0800 Continuous 1559

Work scheduled by: CHGE

UPDATED by CHGE 11/13/2015

CENTRAL EAST - VC

Impacts Total Transfer Capability 405 MW

TTC with All Lines In Service 2975 MW

FWD
(Import)

2570 MW

CLAY__-EDIC__345_2-15

Tue 04/05/2016 to Wed 04/06/2016

0700 Continuous 1600

Work scheduled by: NGrid

OSWEGO EXPORT

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

FWD
(Import)

4850 MW

HUDSONP_-FARRAGUT_345_C3403

Fri 04/08/2016 to Sat 05/07/2016

0200 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 01/07/2016

SCH - PJ - NY

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

FWD REV
(Import) (Export)

2600 MW 1300 MW

GOETHALS-LINDN.CG_345_G23L & GOETHALS-LINDN.CG_345_G23M

Mon 04/11/2016 to Mon 04/25/2016

0001 2359

Work scheduled by:

SCH - PJM_VFT

Impacts Total Transfer Capability 315 MW 0 MW

TTC with All Lines In Service 315 MW 315 MW

FWD REV
(Import) (Export)

0 MW 315 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
WATRCURE-OAKDALE__345_31						
Mon 04/11/2016	to	Tue 04/12/2016	<u>UPDATED</u>	<u>by NYSEG</u> <u>03/01/2016</u>	SCH - PJ - NY	2600 MW
0800	Continuous	1630			Impacts Total Transfer Capability	0 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	2600 MW
BECK__-NIAGARA__230_PA27						
Fri 04/15/2016	to	Fri 04/15/2016			SCH - OH - NY	1900 MW
0700	Continuous	1530			Impacts Total Transfer Capability	0 MW
Work scheduled by: NYPA					TTC with All Lines In Service	1900 MW
ROCHESTR-PANNELL__345_RP2						
Sat 04/16/2016	to	Sun 04/17/2016			DYSINGER EAST	2300 MW
0700	Continuous	1800			Impacts Total Transfer Capability	850 MW
Work scheduled by: RGE					TTC with All Lines In Service	3150 MW
EDIC__-FRASER__345_EF24-40						
Mon 04/18/2016	to	Sun 05/15/2016			CENTRAL EAST - VC	2500 MW
0500	Continuous	1600			Impacts Total Transfer Capability	475 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	2975 MW
MOSES__-ADIRNDCK_230_MA2						
Mon 04/18/2016	to	Fri 04/22/2016	<u>UPDATED</u>	<u>by NYPA</u> <u>01/27/2016</u>	MOSES SOUTH	2300 MW
0700	Continuous	1530			Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA					TTC with All Lines In Service	3150 MW
FRASER__-COOPERS__345_33						
Mon 04/18/2016	to	Sun 05/22/2016			CENTRAL EAST - VC	2395 MW
0800	Continuous	1600			Impacts Total Transfer Capability	580 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	2975 MW
HOMER C_-FIVEMILE_345_37						
Wed 04/20/2016	to	Thu 05/19/2016	<u>UPDATED</u>	<u>by NYISO</u> <u>02/24/2016</u>	SCH - PJ - NY	2600 MW
0800	Continuous	1600			Impacts Total Transfer Capability	0 MW
Work scheduled by: NGrid					TTC with All Lines In Service	2600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA 765_7040

Sat 04/23/2016 to Sun 04/24/2016
 0100 Continuous 1530

UPDATED by NYPA 01/27/2016

Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 1550 MW
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA 765_7040

Sat 04/23/2016 to Sun 04/24/2016
 0100 Continuous 1530

UPDATED by NYPA 01/27/2016

Work scheduled by: NYPA

FWD REV
 (Import) (Export)
SCH - HQ - NY 0 MW 0 MW
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MASSENA -MARCY 765_MSU1

Sat 04/23/2016 to Sun 04/24/2016
 0100 Continuous 1530

UPDATED by NYPA 01/27/2016

Work scheduled by: NYPA

ARR: 20

FWD
 (Import)
CENTRAL EAST - VC 2315 MW
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 2975 MW

MASSENA -MARCY 765_MSU1

Sat 04/23/2016 to Sun 04/24/2016
 0100 Continuous 1530

UPDATED by NYPA 01/27/2016

Work scheduled by: NYPA

ARR: 20

FWD
 (Import)
MOSES SOUTH 500 MW
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA -MARCY 765_MSU1

Sat 04/23/2016 to Sun 04/24/2016
 0100 Continuous 1530

UPDATED by NYPA 01/27/2016

Work scheduled by: NYPA

ARR: 20

FWD REV
 (Import) (Export)
SCH - HQ - NY 475 MW 1000 MW
 Impacts Total Transfer Capability 1025 MW 0 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Sat 04/23/2016 to Sun 04/24/2016
 0100 1530

Work scheduled by:

ARR: 20

FWD
 (Import)
MOSES SOUTH 500 MW
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 04/23/2016 to Sun 04/24/2016
 0100 1530

Work scheduled by:

ARR: 20

FWD REV
 (Import) (Export)
SCH - HQ - NY 850 MW 0 MW
 Impacts Total Transfer Capability 650 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BERKSHIR-ALPS_____345_393						
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u> <u>01/15/2016</u>		
0700	Daily(No Weekends)	0900			SCH - NE - NY	1300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-ALPS_____345_393						
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u> <u>01/15/2016</u>		
0700	Daily(No Weekends)	0900			SCH - NPX_1385	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
SCH-NYISO-NE_LIMIT_400						
Mon 04/25/2016	to	Mon 04/25/2016	<u>UPDATED</u>	<u>by NE</u> <u>01/15/2016</u>		
0700	Daily(No Weekends)	0900			SCH - NE - NY	600 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1600 MW
MOSES____-ADIRNDCK_230_MA2						
Mon 04/25/2016	to	Fri 04/29/2016				
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312						
Mon 04/25/2016	to	Mon 04/25/2016				
0800		0900			SCH - NE - NY	1300 MW
Work scheduled by:					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312						
Mon 04/25/2016	to	Sat 05/07/2016				
0800	Continuous	1600			SCH - NE - NY	1400 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312						
Mon 04/25/2016	to	Sat 05/07/2016				
0800	Continuous	1600			SCH - NPX_1385	100 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_500

Mon 04/25/2016 to Sat 05/07/2016
0800 Continuous 1600
Work scheduled by: ISONE

FWD
(Import)
SCH - NE - NY **700 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_700

Mon 04/25/2016 to Sat 05/07/2016
0800 Continuous 1600
Work scheduled by: ISONE

REV
(Export)
SCH - NE - NY **900 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1600 MW

ROCKTVRN-RAMAPO___345_77

Fri 04/29/2016 to Sat 05/14/2016
1600 Continuous 2359
Work scheduled by: ConEd

FWD
(Import)
CENTRAL EAST - VC **2570 MW**
Impacts Total Transfer Capability 405 MW
TTC with All Lines In Service 2975 MW

NIAGARA_-ROCHESTR_345_NR2

Sat 04/30/2016 to Sun 05/01/2016
0700 Continuous 1800
Work scheduled by: RGE

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

LINDN_CG-LNDVFT___345_V-3022

Sun 05/01/2016 to Fri 05/06/2016
1300 Continuous 1800
Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJM_VFT **0 MW 0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/02/2016 to Fri 05/06/2016
0001 Continuous 1800
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/02/2016 to Fri 05/06/2016
0001 Continuous 1800
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH_345_NS1-38

Mon 05/02/2016 to Fri 05/06/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST 1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

PANNELL_-CLAY_345_2

Mon 05/02/2016 to Mon 05/02/2016

0730 Continuous 1500

Work scheduled by: NYPA

UPDATED

by RGE

02/16/2016

FWD

(Import)

WEST CENTRAL 1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

HUDSONP_-FARRAGUT_345_B3402

Tue 05/03/2016 to Wed 05/04/2016

0001 Continuous 2300

Work scheduled by: ConEd

FWD

(Import) (Export)

SCH - PJ - NY 2300 MW 1300 MW

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2300 MW 1300 MW

HUDSONP_-FARRAGUT_345_B3402 & HUDSONP_-FARRAGUT_345_C3403

Tue 05/03/2016 to Wed 05/04/2016

0001 2300

Work scheduled by:

FWD

(Import) (Export)

SCH - PJ - NY 2300 MW 1300 MW

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2300 MW 1300 MW

BROWNFLS-TAYLORVL_115_4

Tue 05/03/2016 to Fri 05/27/2016

0700 Continuous 1800

Work scheduled by: NGrid

ARR: 38

FWD

(Import) (Export)

SCH - HQ_CEDARS 70 MW 40 MW

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

BERKSHIR-ALPS_345_393

Sat 05/07/2016 to Sat 05/07/2016

1600 Daily 1800

Work scheduled by: NGrid

UPDATED

by NE

01/15/2016

FWD

(Import) (Export)

SCH - NE - NY 950 MW 1000 MW

Impacts Total Transfer Capability 450 MW 600 MW

TTC with All Lines In Service 1400 MW 1600 MW

BERKSHIR-ALPS_345_393

Sat 05/07/2016 to Sat 05/07/2016

1600 Daily 1800

Work scheduled by: NGrid

UPDATED

by NE

01/15/2016

FWD

(Import) (Export)

SCH - NPX_1385 100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_400

Sat 05/07/2016 to Sat 05/07/2016 UPDATED by NE 01/15/2016
1600 Daily 1800

Work scheduled by: NGrid

SCH - NE - NY
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 1600 MW

REV
(Export)

GILBOA__-N.SCTLND_345_GNS-1

Mon 05/09/2016 to Fri 05/13/2016
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/09/2016 to Sat 05/14/2016
0700 Continuous 1900

Work scheduled by: LI

FWD REV
(Import) (Export)
SCH - NPX_CSC **0 MW 0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

RAMAPO__-BUCHAN_N_345_Y94

Thu 05/12/2016 to Sat 05/14/2016
0001 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4150 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 5100 MW

PLSNTVLE-DUNWODIE_345_W89

Sun 05/15/2016 to Sun 05/15/2016
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

EFISHKIL-WOOD_ST__345_F38

Sun 05/15/2016 to Wed 05/18/2016
0001 Continuous 2330

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y86

Sun 05/15/2016 to Wed 05/18/2016
0001 Continuous 2330

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-ROCKTVRN_345_CRT-42

FWD

Mon 05/16/2016 to Fri 05/27/2016
0700 Continuous 1530

EXTENDED by NYPA 02/17/2016

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2720 MW**
Impacts Total Transfer Capability 255 MW
TTC with All Lines In Service 2975 MW

ROSETON_-ROCKTVRN_345_311

FWD

Mon 05/16/2016 to Fri 06/03/2016
0800 Continuous 1600

(Import)

Work scheduled by: CHGE

UPNY CONED **4400 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 5100 MW

PLSNTVLE-DUNWODIE_345_W89

FWD

Wed 05/18/2016 to Wed 05/18/2016
2300 Continuous 2330

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

PLSNTVLE-DUNWODIE_345_W89

FWD

Thu 05/19/2016 to Sun 05/22/2016
0001 Continuous 2100

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y87

FWD

Mon 05/23/2016 to Mon 05/23/2016
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

PLSNTVLE-DUNWODIE_345_W90

FWD

Mon 05/23/2016 to Wed 05/25/2016
0001 Continuous 2100

(Import)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

EDIC_-FRASER_345_EF24-40

FWD

Mon 05/23/2016 to Tue 05/24/2016
0500 Continuous 1530

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS____345_LEEDS SVC

Mon 05/23/2016 to Fri 06/10/2016
 0730 Continuous 1500

Work scheduled by: NGrid

FWD
 (Import)
CENTRAL EAST - VC 2950 MW
 Impacts Total Transfer Capability 25 MW
 TTC with All Lines In Service 2975 MW

NINEMILE-CLAY____345_8

Tue 05/24/2016 to Fri 05/27/2016
 0700 Continuous 1700

Work scheduled by: NGrid

FWD
 (Import)
OSWEGO EXPORT 5150 MW
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 5250 MW

MAINESBG-WATRCURE_345_30

Tue 05/24/2016 to Wed 05/25/2016
 0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV
 (Import) (Export)
SCH - PJ - NY 2200 MW 1300 MW
 Impacts Total Transfer Capability 100 MW 0 MW
 TTC with All Lines In Service 2300 MW 1300 MW

WOOD_ST_-PLSNTVLE_345_Y87

Wed 05/25/2016 to Wed 05/25/2016
 2030 Continuous 2100

Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4000 MW
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

HOMRC_NY-MAINS_NY_345_47

Thu 05/26/2016 to Fri 05/27/2016
 0800 Continuous 1600

Work scheduled by: PJM

FWD REV
 (Import) (Export)
SCH - PJ - NY 2200 MW 1300 MW
 Impacts Total Transfer Capability 100 MW 0 MW
 TTC with All Lines In Service 2300 MW 1300 MW

MARCY____-COOPERS__345_UCC2-41

Fri 05/27/2016 to Sat 05/28/2016
 0500 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2500 MW
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_3

Tue 05/31/2016 to Wed 06/15/2016
 0600 Continuous 1700

Work scheduled by: NGrid

FWD REV
 (Import) (Export)
SCH - HQ_CEDARS 70 MW 40 MW
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

ARR: 38

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__-COOPERS__345_33

Tue 05/31/2016 to Wed 06/01/2016
 0700 Continuous 1600

Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

NIAGARA__-KINTIGH__345_NS1-38

Fri 06/03/2016 to Fri 06/03/2016
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

FRASER__-GILBOA__345_GF5-35

Sat 06/04/2016 to Fri 06/10/2016
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

BECK__-NIAGARA__345_PA302

Mon 06/06/2016 to Fri 06/17/2016
 0700 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 01/21/2016

FWD REV
 (Import) (Export)
 SCH - OH - NY **1200 MW 1100 MW**
 Impacts Total Transfer Capability 700 MW 800 MW
 TTC with All Lines In Service 1900 MW 1900 MW

COLTON__-FLATROCK_115_2

Sun 06/12/2016 to Sun 06/12/2016
 0530 Continuous 1730

Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **100 MW 40 MW**
 Impacts Total Transfer Capability 90 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

HANAWAFL-COLTON__115_5

Sun 06/12/2016 to Sun 06/12/2016
 0530 Continuous 1730

Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **150 MW 40 MW**
 Impacts Total Transfer Capability 40 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

PARISHVL-COLTON__115_3 & MCINTYRE-COLTON__115_8 & COLTON__-FLATROCK_115_2 &
 HANAWAFL-COLTON__115_5

Sun 06/12/2016 to Sun 06/12/2016
 0530 1730

Work scheduled by:

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **80 MW 40 MW**
 Impacts Total Transfer Capability 110 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COLTON__-FLATROCK_115_2					FWD	REV
Thu 06/16/2016 to Sat 06/18/2016					(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					FWD	REV
Thu 06/16/2016 to Sun 06/26/2016					(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
COLTON__-FLATROCK_115_2					FWD	REV
Sun 06/19/2016 to Sun 06/19/2016					(Import)	(Export)
0530	Continuous	1730	<u>UPDATED</u>	<u>by NGRID 02/04/2016</u>	SCH - HQ_CEDARS	100 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	90 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
HANAWAFL-COLTON__115_5					FWD	REV
Sun 06/19/2016 to Sun 06/19/2016					(Import)	(Export)
0530	Continuous	1730	<u>UPDATED</u>	<u>by NGRID 02/04/2016</u>	SCH - HQ_CEDARS	150 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	40 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
PARISHVL-COLTON__115_3 & MCINTYRE-COLTON__115_8 & COLTON__-FLATROCK_115_2 & HANAWAFL-COLTON__115_5					FWD	REV
Sun 06/19/2016 to Sun 06/19/2016					(Import)	(Export)
0530		1730			SCH - HQ_CEDARS	80 MW 40 MW
Work scheduled by:					Impacts Total Transfer Capability	110 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW
MOSES__-ADIRNDCK_230_MAI					FWD	
Mon 06/27/2016 to Wed 06/29/2016					(Import)	
0700	Continuous	1530			MOSES SOUTH	2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_4					FWD	REV
Thu 06/30/2016 to Fri 07/01/2016					(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38					TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_4				FWD	REV
				(Import)	(Export)
Tue 07/05/2016	to	Sat 07/09/2016			
0600	Continuous	1700			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3				FWD	REV
				(Import)	(Export)
Mon 07/11/2016	to	Mon 08/01/2016			
0600	Continuous	1700			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
				(Import)	(Export)
Tue 08/02/2016	to	Thu 08/25/2016			
0600	Continuous	1700			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3				FWD	REV
				(Import)	(Export)
Fri 08/26/2016	to	Fri 09/02/2016			
0600	Continuous	1700			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
MARCY__-COOPERS__345_UCC2-41				FWD	
				(Import)	
Sun 08/28/2016	to	Wed 08/31/2016			
0700	Continuous	1530			
Work scheduled by: NYPA				CENTRAL EAST - VC	2500 MW
				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
GILBOA__-LEEDS__345_GL3				FWD	
				(Import)	
Mon 09/05/2016	to	Fri 09/09/2016			
0800	Continuous	1530			
Work scheduled by: NYPA				CENTRAL EAST - VC	2200 MW
				Impacts Total Transfer Capability	775 MW
				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_3				FWD	REV
				(Import)	(Export)
Tue 09/06/2016	to	Sun 09/11/2016			
0600	Continuous	1700			
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_BK 2					FWD	
Tue 09/06/2016	to	Sun 09/11/2016			(Import)	
0700	Continuous	1730			MOSES SOUTH	1700 MW
Work scheduled by: NYPA			ARR: 19		Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
KINTIGH_-ROCHESTR_345_SRI-39					FWD	
Mon 09/12/2016	to	Fri 09/16/2016	UPDATED	by NYISO 01/20/2016	(Import)	
0700	Continuous	1630			DYSINGER EAST	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MAI					FWD	
Mon 09/12/2016	to	Sat 09/17/2016			(Import)	
0700	Continuous	1530			MOSES SOUTH	2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
HURLYAVE-ROSETON___345_303					FWD	
Mon 09/12/2016	to	Fri 09/30/2016			(Import)	
0800	Continuous	1600			UPNY CONED	4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
NIAGARA___345_230_BK 4					FWD	REV
Wed 09/14/2016	to	Thu 09/15/2016	UPDATED	by PA 09/18/2015	(Import)	(Export)
0700	Continuous	1530			SCH - OH - NY	1900 MW 1900 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	1900 MW 1900 MW
BECK___-NIAGARA___345_PA301					FWD	REV
Fri 09/16/2016	to	Fri 09/16/2016			(Import)	(Export)
0700	Continuous	1530			SCH - OH - NY	1200 MW 1100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	700 MW 800 MW
					TTC with All Lines In Service	1900 MW 1900 MW
FITZPTRK-EDIC___345_FE-1					FWD	
Mon 09/19/2016	to	Wed 09/21/2016			(Import)	
0700	Continuous	1530			OSWEGO EXPORT	4800 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES____-ADIRNDCK_230_MA1				FWD	
Mon 09/19/2016	to	Sat 09/24/2016		(Import)	
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
BECK____-NIAGARA_230_PA27				FWD	REV
Mon 09/19/2016	to	Sun 11/06/2016		(Import)	(Export)
0700	Continuous	1530		SCH - OH - NY	1900 MW 1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	1900 MW 1900 MW
NRTH1385-NOR HBR_138_601				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_603

Mon 09/26/2016 to Fri 09/30/2016
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT_138_1385

Mon 09/26/2016 to Fri 09/30/2016
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

MOSES__-ADIRNDCK_230_MA1

Mon 09/26/2016 to Sat 10/01/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

MARCY__-COOPERS__345_UCC2-41

Mon 10/03/2016 to Sun 10/09/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MOSES__-ADIRNDCK_230_MA2

Tue 10/04/2016 to Fri 10/07/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

LEEDS__-HURLYAVE_345_301

Mon 10/10/2016 to Fri 11/04/2016 UPDATED by NGRID 07/09/2015
0700 Continuous 1600

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

LEEDS__345KV_R94301

Mon 10/10/2016 to Fri 11/04/2016 UPDATED by NGRID 07/09/2015
0700 Continuous 1600

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	1300 MW
TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Tue 10/11/2016 to Fri 10/14/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA___765_7040

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

UPDATED**by NYPA****10/08/2015**

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

CHATGUAY-MASSENA___765_7040

FWD

REV

Sat 10/15/2016 to Sat 10/29/2016

(Import) (Export)

0100 Continuous 1730

UPDATED**by NYPA****10/08/2015**

SCH - HQ - NY

0 MW**0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

MASSENA_-MARCY___765_MSU1

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

UPDATED**by NYPA****10/08/2015**

CENTRAL EAST - VC

2315 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

ARR: 20**MASSENA_-MARCY___765_MSU1**

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

UPDATED**by NYPA****10/08/2015**

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 20**MASSENA_-MARCY___765_MSU1**

FWD

REV

Sat 10/15/2016 to Sat 10/29/2016

(Import) (Export)

0100 Continuous 1730

UPDATED**by NYPA****10/08/2015**

SCH - HQ - NY

475 MW**1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

ARR: 20**MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA___765_7040**

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

MOSES SOUTH

500 MW

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

ARR: 20

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2

Sat 10/15/2016 to Sat 10/29/2016
0100 1730

Work scheduled by:

ARR: 20

SCH - HQ - NY

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

FWD REV
(Import) (Export)

850 MW 0 MW

MARCY___765_345_BK 2

Mon 10/24/2016 to Fri 10/28/2016
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

FWD
(Import)

1700 MW

MOSES___-ADIRNDCK_230_MA2

Mon 10/31/2016 to Sat 11/05/2016
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

FWD
(Import)

2300 MW

HOMRC_NY-MAINS_NY_345_47

Fri 11/04/2016 to Fri 11/04/2016
0600 Continuous 1600

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

FWD REV
(Import) (Export)

2600 MW 1300 MW

LEEDS___-PLSNTVLY_345_92

Mon 11/07/2016 to Wed 12/07/2016
0001 Continuous 2359

Work scheduled by: NGrid

UPDATED by CONED 09/16/2015

UPNY CONED

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

FWD
(Import)

3800 MW

PLSNTVLY_345KV_RNS5

Mon 11/07/2016 to Wed 12/07/2016
0001 Continuous 2359

Work scheduled by: NGrid

UPDATED by CONED 09/16/2015

UPNY CONED

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

FWD
(Import)

3800 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/07/2016 to Thu 11/10/2016
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

FWD
(Import)

2300 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MAINESBG-WATRCURE_345_30

Mon 11/07/2016 to Fri 12/09/2016 **UPDATED by NYSEG 02/16/2016**
0800 Continuous 1600

Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	2600 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

BECK__-NIAGARA_345_PA301

Mon 11/14/2016 to Fri 11/18/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1400 MW	1250 MW
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

MOSES__-ADIRNDCK_230_MA2

Mon 11/14/2016 to Sat 11/19/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 11/21/2016 to Wed 11/23/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 11/28/2016 to Fri 12/02/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/05/2016 to Fri 12/09/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/12/2016 to Fri 12/16/2016
0700 Continuous 1530

Work scheduled by: NYPA

	FWD (Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
CENTRAL EAST - VC 2975MW
TOTAL EAST 6500MW
UPNY CONED 5100MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3150MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35

Mon 12/12/2016 to Fri 12/30/2016
 0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK 230_MA2

Mon 12/19/2016 to Thu 12/22/2016
 0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FITZPTRK-EDIC 345_FE-1

Mon 03/06/2017 to Fri 03/31/2017
 0600 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

OSWEGO EXPORT **4800 MW**
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 5250 MW

BROWNFLS-TAYLORVL 115_3

Mon 05/01/2017 to Fri 05/26/2017
 0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD

REV

(Import) (Export)

SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL 115_4

Tue 05/30/2017 to Sat 06/24/2017
 0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD

REV

(Import) (Export)

SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL 115_3

Mon 06/26/2017 to Sat 07/01/2017
 0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD

REV

(Import) (Export)

SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL 115_3

Wed 07/05/2017 to Sat 07/22/2017
 0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD

REV

(Import) (Export)

SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,March 01, 2016 to Thursday ,August 31, 2017

CENTRAL EAST 3100MW
 CENTRAL EAST - VC 2975MW
 TOTAL EAST 6500MW
 UPNY CONED 5100MW
 SPR/DUN-SOUTH 4600MW
 DYSINGER EAST 3150MW
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_4

Mon 07/24/2017 to Sat 08/19/2017

0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

SCH - HQ_CEDARS

FWD

REV

(Import) (Export)

70 MW 40 MW

Impacts Total Transfer Capability

120 MW 0 MW

TTC with All Lines In Service

190 MW 40 MW

BROWNFLS-TAYLORVL_115_3

Mon 08/21/2017 to Fri 09/01/2017

0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

SCH - HQ_CEDARS

FWD

REV

(Import) (Export)

70 MW 40 MW

Impacts Total Transfer Capability

120 MW 0 MW

TTC with All Lines In Service

190 MW 40 MW