

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_BK 1						FWD
Tue 05/17/2016	to	Sat 07/09/2016	<u>EXT FORCE</u>	<u>by LI</u>	<u>05/23/2016</u>	(Import)
0534	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_BK 2						FWD
Tue 05/17/2016	to	Sat 07/09/2016	<u>EXT FORCE</u>	<u>by LI</u>	<u>05/23/2016</u>	(Import)
0534	Continuous	2359				CONED - LIPA 1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49						FWD
Tue 05/17/2016	to	Sat 07/09/2016	<u>EXT FORCE</u>	<u>by LI</u>	<u>05/23/2016</u>	(Import)
0536	Continuous	2359				CONED - LIPA 775 MW
Work scheduled by: LI						Impacts Total Transfer Capability 725 MW
						TTC with All Lines In Service 1500 MW
COOPERS_-ROCKTVRN_345_CCRT-42						FWD
Fri 05/20/2016	to	Fri 06/17/2016	<u>UPDATED</u>	<u>by CH</u>	<u>05/27/2016</u>	(Import)
0800	Continuous	1600				CENTRAL EAST - VC 2720 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 255 MW
						TTC with All Lines In Service 2975 MW
LEEDS____345_LEEDS SVC						FWD
Mon 05/23/2016	to	Tue 06/14/2016	<u>EXTENDED</u>	<u>by NGRID</u>	<u>06/16/2016</u>	(Import)
0730	Continuous	1600				CENTRAL EAST - VC 2950 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 25 MW
						TTC with All Lines In Service 2975 MW
SCH-NE-NYISO_LIMIT_1000						FWD
Mon 06/06/2016	to	Tue 06/14/2016	<u>UPDATED</u>	<u>by NE</u>	<u>06/02/2016</u>	(Import)
0500	Continuous	1700				SCH - NE - NY 1200 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1400 MW
ROSETON_-ROCKTVRN_345_311						FWD
Mon 06/06/2016	to	Fri 06/24/2016	<u>UPDATED</u>	<u>by CH</u>	<u>04/05/2016</u>	(Import)
0800	Continuous	1600				UPNY CONED 4400 MW
Work scheduled by: CHGE						Impacts Total Transfer Capability 700 MW
						TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-HQ_LIMIT_700</b>							REV	
Mon 06/06/2016	to	Thu 06/16/2016					(Export)	
2200	Daily	0600				SCH - HQ - NY	<b>700 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service	1000 MW	
<b>E13THSTA-FARRAGUT_345_45</b>							FWD	
Sat 06/11/2016	to	Sat 06/11/2016	<u>UPDATED</u>	<u>by CE</u>	<u>06/09/2016</u>		(Import)	
0001	Continuous	0300				SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW	
						TTC with All Lines In Service	4600 MW	
<b>W49TH_ST-E13THSTA_345_M54</b>							FWD	
Sat 06/11/2016	to	Sat 06/11/2016	<u>UPDATED</u>	<u>by CE</u>	<u>06/09/2016</u>		(Import)	
0001	Continuous	0300				SPR/DUN-SOUTH	<b>3800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW	
						TTC with All Lines In Service	4600 MW	
<b>LONG_MTN-PLSNTVLY_345_398</b>							FWD	REV
Sat 06/11/2016	to	Sun 06/12/2016	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/07/2016</u>		(Import)	(Export)
0001	Continuous	1200				SCH - NE - NY	<b>500 MW</b>	<b>1200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	900 MW	400 MW
						TTC with All Lines In Service	1400 MW	1600 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>							FWD	REV
Sat 06/11/2016	to	Sun 06/12/2016	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/07/2016</u>		(Import)	(Export)
0001	Continuous	1200				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
<b>SCH-NYISO-NE_LIMIT_700</b>								REV
Sat 06/11/2016	to	Sun 06/12/2016	<u>UPDATED</u>	<u>by ISONE</u>	<u>06/07/2016</u>			(Export)
0001	Continuous	1200				SCH - NE - NY		<b>900 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability		700 MW
						TTC with All Lines In Service		1600 MW
<b>COLTON_-FLATROCK_115_2</b>							FWD	REV
Sun 06/12/2016	to	Sun 06/12/2016					(Import)	(Export)
0530	Continuous	1730				SCH - HQ_CEDARS	<b>100 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	90 MW	0 MW
						TTC with All Lines In Service	190 MW	40 MW

ARR: 38

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HANAWAFL-COLTON___115_5</b>					FWD	REV
Sun 06/12/2016	to	Sun 06/12/2016			(Import)	(Export)
0530	Continuous	1730			<b>SCH - HQ_CEDARS</b>	<b>150 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	40 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW
<b>PARISHVL-COLTON___115_3 &amp; MCINTYRE-COLTON___115_8 &amp; COLTON_-FLATROCK_115_2 &amp; HANAWAFL-COLTON___115_5</b>					FWD	REV
Sun 06/12/2016	to	Sun 06/12/2016			(Import)	(Export)
0530		1730			<b>SCH - HQ_CEDARS</b>	<b>80 MW 40 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	110 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW
<b>FRASER___345_FRASER SVC</b>					FWD	
Sun 06/12/2016	to	Tue 06/14/2016	<b>EXT FORCE</b>	<b>by NYSEG 06/13/2016</b>	(Import)	
1144	Continuous	1530			<b>CENTRAL EAST - VC</b>	<b>2935 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	2975 MW
<b>SCH-IMO-NYISO_LIMIT_1400</b>					FWD	
Mon 06/13/2016	to	Tue 06/14/2016	<b>UPDATED</b>	<b>by NYPA 06/10/2016</b>	(Import)	
0500	Continuous	1600			<b>SCH - OH - NY</b>	<b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1750 MW
<b>SCH-NYISO-IMO_LIMIT_1100</b>						REV
Mon 06/13/2016	to	Tue 06/14/2016	<b>UPDATED</b>	<b>by NYPA 06/10/2016</b>		(Export)
0500	Continuous	1600			<b>SCH - OH - NY</b>	<b>1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1600 MW
<b>CHASLAKE-PORTER___230_11</b>					FWD	
Mon 06/13/2016	to	Mon 06/13/2016			(Import)	
0730	Daily(No Weekends)	1700			<b>MOSES SOUTH</b>	<b>2100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD	REV
Tue 06/14/2016	to	Fri 06/17/2016	<b>UPDATED</b>	<b>by NGRID 06/08/2016</b>	(Import)	(Export)
0600	Continuous	1700			<b>SCH - HQ_CEDARS</b>	<b>70 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST\_345KV\_6

Tue 06/14/2016 to Tue 06/14/2016 **UPDATED** **by C E** **04/26/2016**  
2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
**315 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

Tue 06/14/2016 to Tue 06/14/2016 **UPDATED** **by C E** **04/26/2016**  
2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
**315 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

## COLTON\_\_-FLATROCK\_115\_2

Thu 06/16/2016 to Sat 06/18/2016  
0600 Continuous 1700

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
**100 MW 40 MW**  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 90 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

## LEEDS\_\_\_\_345KV\_R395

Thu 06/16/2016 to Thu 06/16/2016  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## SPRNBK\_-W49TH\_ST\_345\_M52

Thu 06/16/2016 to Sat 06/18/2016 **FORCED** **by CONED** **06/16/2016**  
1137 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## SCRIBA\_\_-VOLNEY\_\_\_\_345\_20

Fri 06/17/2016 to Fri 06/17/2016 **UPDATED** **by NGRID** **06/15/2016**  
0500 Daily(No Weekends) 1700

Work scheduled by: NGrid

FWD  
(Import)  
**5250 MW**  
OSWEGO EXPORT  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## EASTVIEW-SPRNBK\_\_\_\_345\_W64

Sat 06/18/2016 to Sat 06/18/2016 **UPDATED** **by CONED** **06/09/2016**  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
**4350 MW**  
UPNY CONED  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS5</b>					FWD
Sat 06/18/2016	to	Sat 06/18/2016	<u>UPDATED</u>	<u>by CONED</u> <u>06/09/2016</u>	(Import)
0001	Continuous	0030			
Work scheduled by: ConEd					
					SPR/DUN-SOUTH <b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD
Sat 06/18/2016	to	Sat 06/18/2016	<u>CANCELLED</u>	<u>by ConEd</u> <u>06/16/2016</u>	(Import)
0001	Continuous	0030			
Work scheduled by: ConEd					
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD
Sat 06/18/2016	to	Sat 06/18/2016	<u>UPDATED</u>	<u>by CONED</u> <u>06/09/2016</u>	(Import)
0001	Continuous	1930			
Work scheduled by: ConEd					
					UPNY CONED <b>4350 MW</b>
					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 5100 MW
<b>E13THSTA-FARRAGUT_345_45</b>					FWD
Sat 06/18/2016	to	Sat 06/18/2016	<u>CANCELLED</u>	<u>by ConEd</u> <u>06/16/2016</u>	(Import)
0001	Continuous	2300			
Work scheduled by: ConEd					
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>					FWD
Sat 06/18/2016	to	Sat 06/18/2016	<u>UPDATED</u>	<u>by CONED</u> <u>06/09/2016</u>	(Import)
1900	Continuous	1930			
Work scheduled by: ConEd					
					UPNY CONED <b>4350 MW</b>
					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 5100 MW
<b>SPRNBK__345KV_RNS5</b>					FWD
Sat 06/18/2016	to	Sat 06/18/2016	<u>UPDATED</u>	<u>by CONED</u> <u>06/09/2016</u>	(Import)
1900	Continuous	1930			
Work scheduled by: ConEd					
					SPR/DUN-SOUTH <b>3200 MW</b>
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD
Sat 06/18/2016	to	Sat 06/18/2016	<u>CANCELLED</u>	<u>by ConEd</u> <u>06/16/2016</u>	(Import)
2230	Continuous	2300			
Work scheduled by: ConEd					
					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC1**

FWD

Sun 06/19/2016 to Sun 06/19/2016

(Import)

0001 Continuous 0100

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1**

REV

Sun 06/19/2016 to Sun 06/19/2016

(Export)

0001 Continuous 0100

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

FWD

Sun 06/19/2016 to Sun 06/19/2016

(Import)

0001 0100

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

FWD

REV

Sun 06/19/2016 to Sun 06/19/2016

(Import) (Export)

0001 0100

SCH - HQ - NY

**1370 MW 0 MW**

Impacts Total Transfer Capability 130 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by:

**CHAT\_DC\_GC2**

FWD

Sun 06/19/2016 to Sun 06/19/2016

(Import)

0001 Continuous 0100

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**CHAT\_DC\_GC2**

REV

Sun 06/19/2016 to Sun 06/19/2016

(Export)

0001 Continuous 0100

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**SCH-HQ-NYISO\_LIMIT\_800**

FWD

Sun 06/19/2016 to Sun 06/19/2016

(Import)

0001 Continuous 0100

SCH - HQ - NY

**800 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>COLTON__-FLATROCK_115_2</b>						FWD	REV
Sun 06/19/2016	to	Sun 06/19/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/04/2016</u>	(Import)	(Export)
0530	Continuous	1730					
Work scheduled by: NGrid					ARR: 38		
					SCH - HQ_CEDARS	<b>100 MW</b>	<b>40 MW</b>
					Impacts Total Transfer Capability	90 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>HANAWAFL-COLTON__115_5</b>						FWD	REV
Sun 06/19/2016	to	Sun 06/19/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>02/04/2016</u>	(Import)	(Export)
0530	Continuous	1730					
Work scheduled by: NGrid					ARR: 38		
					SCH - HQ_CEDARS	<b>150 MW</b>	<b>40 MW</b>
					Impacts Total Transfer Capability	40 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>PARISHVL-COLTON__115_3 &amp; MCINTYRE-COLTON__115_8 &amp; COLTON__-FLATROCK_115_2 &amp; HANAWAFL-COLTON__115_5</b>						FWD	REV
Sun 06/19/2016	to	Sun 06/19/2016				(Import)	(Export)
0530		1730					
Work scheduled by:					ARR: 38		
					SCH - HQ_CEDARS	<b>80 MW</b>	<b>40 MW</b>
					Impacts Total Transfer Capability	110 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>						FWD	REV
Mon 06/20/2016	to	Fri 06/24/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/08/2016</u>	(Import)	(Export)
0600	Continuous	1700					
Work scheduled by: NGrid					ARR: 38		
					SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
					Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-HIGLEY__115_1</b>						FWD	REV
Mon 06/20/2016	to	Mon 06/20/2016				(Import)	(Export)
0800	Daily(No Weekends)	1730					
Work scheduled by: NGrid					ARR: 38		
					SCH - HQ_CEDARS	<b>100 MW</b>	<b>40 MW</b>
					Impacts Total Transfer Capability	90 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>COLTON__-HIGLEY__115_1</b>						FWD	REV
Mon 06/20/2016	to	Mon 06/20/2016				(Import)	(Export)
0800	Daily(No Weekends)	1730					
Work scheduled by: NGrid					ARR: 38		
					SCH - HQ_CEDARS	<b>100 MW</b>	<b>40 MW</b>
					Impacts Total Transfer Capability	90 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>SCH-HQ-NYISO_LIMIT_0</b>						FWD	
Mon 06/20/2016	to	Tue 06/21/2016	<u>UPDATED</u>	<u>by HQ</u>	<u>06/15/2016</u>	(Import)	
2300	Continuous	0659					
Work scheduled by: HQ							
					SCH - HQ - NY	<b>0 MW</b>	
					Impacts Total Transfer Capability	1500 MW	
					TTC with All Lines In Service	1500 MW	

**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_1400**

FWD

Wed 06/22/2016 to Wed 06/22/2016  
 0600 Continuous 1100

(Import)

Work scheduled by: NYPA

SCH - OH - NY

**1700 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1750 MW

**SCH-NYISO-IMO\_LIMIT\_1100**

REV

Wed 06/22/2016 to Wed 06/22/2016  
 0600 Continuous 1100

(Export)

Work scheduled by: NYPA

SCH - OH - NY

**1400 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1600 MW

**SCH-NYISO-HQ\_LIMIT\_0**

REV

Wed 06/22/2016 to Wed 06/22/2016  
 0700 Continuous 1659

(Export)

Work scheduled by: HQ

UPDATEDby HQ06/15/2016

SCH - HQ - NY

**0 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 1000 MW

**SCH-NYISO-IMO\_LIMIT\_1200**

REV

Thu 06/23/2016 to Thu 06/23/2016  
 0600 Continuous 1100

(Export)

Work scheduled by: NYPA

SCH - OH - NY

**1500 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 1600 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

FWD

Mon 06/27/2016 to Wed 06/29/2016  
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

UPDATEDby NYPA06/06/2016

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

**BROWNFLS-TAYLORVL\_115\_4**

FWD

REV

Thu 06/30/2016 to Fri 07/01/2016  
 0600 Continuous 1700

(Import) (Export)

Work scheduled by: NGrid

**ARR: 38**

SCH - HQ\_CEDARS

**70 MW****40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

**BROWNFLS-TAYLORVL\_115\_4**

FWD

REV

Tue 07/05/2016 to Sat 07/09/2016  
 0600 Continuous 1700

(Import) (Export)

Work scheduled by: NGrid

**ARR: 38**

SCH - HQ\_CEDARS

**70 MW****40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW



**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROCHESTR-PANNELL\_\_345\_RP2**

Sat 07/09/2016 to Sun 07/10/2016  
 0600 Continuous 1800  
 Work scheduled by: RGE

FWD  
 (Import)  
**DYSINGER EAST 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Sun 07/10/2016 to Sun 07/10/2016  
 0001 Continuous 1530  
 Work scheduled by: ConEd

FWD  
 (Import)  
**CONED - LIPA 800 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 1**

Sun 07/10/2016 to Sun 07/10/2016  
 0001 Continuous 1530  
 Work scheduled by: ConEd

FWD  
 (Import)  
**CONED - LIPA 1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Sun 07/10/2016 to Sun 07/10/2016  
 0001 Continuous 1530  
 Work scheduled by: ConEd

FWD  
 (Import)  
**CONED - LIPA 1350 MW**  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 1500 MW

**ADIRNDCK-CHASLAKE\_230\_13**

Tue 07/12/2016 to Tue 07/12/2016  
 0800 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**BROWNFLS-TAYLORVL\_115\_3**

Wed 07/13/2016 to Fri 07/15/2016 **UPDATED by NGRID 05/05/2016**  
 0600 Continuous 1700  
 Work scheduled by: NGrid **ARR: 38**

FWD REV  
 (Import) (Export)  
**SCH - HQ\_CEDARS 70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**STONYRDG-HILLSIDE\_230\_72**

Wed 07/13/2016 to Wed 07/13/2016  
 0800 Continuous 1500  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**DYSINGER EAST 2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROCHESTR-PANNELL\_\_345\_RP2**

Sat 07/16/2016 to Sun 07/17/2016  
0600 Continuous 1800

Work scheduled by: RGE

FWD  
(Import)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 07/18/2016 to Fri 07/22/2016  
0600 Continuous 1700

Work scheduled by: NGrid

**UPDATED by NGRID 05/05/2016****ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Sat 07/23/2016 to Sun 07/24/2016  
0600 Continuous 1800

Work scheduled by: RGE

**UPDATED by NYISO 05/26/2016**

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 07/25/2016 to Fri 07/29/2016  
0600 Continuous 1700

Work scheduled by: NGrid

**UPDATED by NGRID 05/05/2016****ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

**FRASER\_\_345\_FRASER SVC**

Mon 07/25/2016 to Fri 07/29/2016  
0830 Continuous 1400

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

Sat 07/30/2016 to Sun 07/31/2016  
0600 Continuous 1800

Work scheduled by: RGE

**UPDATED by NYISO 05/26/2016**

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 08/01/2016 to Fri 08/05/2016  
0600 Continuous 1700

Work scheduled by: NGrid

**UPDATED by NGRID 05/05/2016****ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_4</b>						FWD	REV
Mon 08/08/2016	to	Fri 08/12/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/05/2016</u>	(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid				<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>						FWD	REV
Mon 08/15/2016	to	Fri 08/19/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/05/2016</u>	(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid				<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>						FWD	REV
Mon 08/22/2016	to	Fri 08/26/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/05/2016</u>	(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid				<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>						FWD	REV
Fri 08/26/2016	to	Fri 09/02/2016				(Import)	(Export)
0600	Continuous	1700			SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid				<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
<b>MARCY___-FRASANNX_345_UCC2-41</b>						FWD	
Sun 08/28/2016	to	Wed 08/31/2016				(Import)	
0700	Continuous	1530			CENTRAL EAST - VC	<b>2500 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW	
					TTC with All Lines In Service	2975 MW	
<b>BECK___-NIAGARA_345_PA302</b>						FWD	REV
Mon 08/29/2016	to	Fri 09/09/2016				(Import)	(Export)
0800	Continuous	1530			SCH - OH - NY	<b>1200 MW</b>	<b>1100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	550 MW	500 MW
					TTC with All Lines In Service	1750 MW	1600 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD	REV
Sun 09/04/2016	to	Mon 09/05/2016	<u>UPDATED</u>	<u>by LI</u>	<u>04/26/2016</u>	(Import)	(Export)
0700	Continuous	1700			SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW	330 MW
					TTC with All Lines In Service	330 MW	330 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**GILBOA -LEEDS 345\_GL3**

Mon 09/05/2016 to Fri 09/09/2016  
 0800 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2200 MW**  
 Impacts Total Transfer Capability 775 MW  
 TTC with All Lines In Service 2975 MW

**BROWNFLS-TAYLORVL\_115\_3**

Tue 09/06/2016 to Sun 09/11/2016  
 0600 Continuous 1700

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**MARCY 765\_345\_BK 2**

Tue 09/06/2016 to Sun 09/11/2016  
 0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**KINTIGH -ROCHESTR\_345\_SR1-39**

Mon 09/12/2016 to Fri 09/16/2016  
 0700 Continuous 1630

Work scheduled by: NYPA

**UPDATED by NYISO 01/20/2016**

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**MOSES -ADIRNDCK\_230\_MAI**

Mon 09/12/2016 to Sat 09/17/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**CLRKSCRN-OAKDALE\_345\_36**

Mon 09/12/2016 to Thu 09/15/2016  
 0800 Continuous 1630

Work scheduled by: NYSEG

**UPDATED by NYSEG 05/17/2016**

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 09/12/2016 to Fri 09/30/2016  
 0800 Continuous 1600

Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_BK 4						FWD	REV
						(Import)	(Export)
Wed 09/14/2016	to	Thu 09/15/2016	<u>UPDATED</u>	<u>by PA</u>	<u>09/18/2015</u>		
0700	Continuous	1530					
Work scheduled by: NYPA						SCH - OH - NY	1750 MW
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1750 MW
BECK____-NIAGARA__345_PA301						FWD	REV
						(Import)	(Export)
Fri 09/16/2016	to	Fri 09/16/2016					
0700	Continuous	1530					
Work scheduled by: NYPA						SCH - OH - NY	1200 MW
						Impacts Total Transfer Capability	550 MW
						TTC with All Lines In Service	1750 MW
MOSES____-ADIRNDCK_230_MA1						FWD	
						(Import)	
Mon 09/19/2016	to	Sat 09/24/2016					
0700	Continuous	1530					
Work scheduled by: NYPA						MOSES SOUTH	2100 MW
						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	3150 MW
BECK____-NIAGARA__230_PA27						FWD	REV
						(Import)	(Export)
Mon 09/19/2016	to	Sun 11/06/2016					
0700	Continuous	1530					
Work scheduled by: NYPA						SCH - OH - NY	1750 MW
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1750 MW
EDIC____-N.SCTLND_345_14						FWD	
						(Import)	
Mon 09/26/2016	to	Tue 09/27/2016					
0530	Continuous	1530					
Work scheduled by: NGrid						CENTRAL EAST - VC	2240 MW
						Impacts Total Transfer Capability	735 MW
						TTC with All Lines In Service	2975 MW
NRTH1385-NOR HBR__138_601						FWD	REV
						(Import)	(Export)
Mon 09/26/2016	to	Fri 09/30/2016					
0700	Continuous	1600					
Work scheduled by: LI						SCH - NPX_1385	100 MW
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602						FWD	REV
						(Import)	(Export)
Mon 09/26/2016	to	Fri 09/30/2016					
0700		1600					
Work scheduled by:						SCH - NPX_1385	0 MW
						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NOR HBR\_\_138\_603**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

---

**NRTH1385-NRTHPORT\_138\_1385**

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

---

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 09/26/2016 to Sat 10/01/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

---

**SPRNBK\_\_345KV\_RNS5**

Sun 10/02/2016 to Sun 10/02/2016  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3200 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

**UPDATED by CONED 06/14/2016**

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-W49TH_ST_345_M51</b>					FWD	
Sun 10/02/2016	to	Tue 10/11/2016	<u>UPDATED</u>	<u>by CONED</u> <u>06/14/2016</u>	(Import)	
0001	Continuous	2359			SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>MARCY_-FRASANNX_345_UCC2-41</b>					FWD	
Mon 10/03/2016	to	Sun 10/09/2016			(Import)	
0700	Continuous	1530			CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
Tue 10/04/2016	to	Fri 10/07/2016			(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>NRTH1385-NOR HBR_138_601</b>					FWD	REV
Mon 10/10/2016	to	Mon 10/17/2016			(Import)	(Export)
0600	Continuous	1700			SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>LEEDS_-HURLYAVE_345_301</b>					FWD	
Mon 10/10/2016	to	Fri 11/04/2016	<u>UPDATED</u>	<u>by NGRID</u> <u>07/09/2015</u>	(Import)	
0700	Continuous	1600			UPNY CONED	<b>4100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
<b>LEEDS_345KV_R94301</b>					FWD	
Mon 10/10/2016	to	Fri 11/04/2016	<u>UPDATED</u>	<u>by NGRID</u> <u>07/09/2015</u>	(Import)	
0700	Continuous	1600			UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
<b>MOSES_-ADIRNDCK_230_MA2</b>					FWD	
Tue 10/11/2016	to	Fri 10/14/2016			(Import)	
0700	Continuous	1530			MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-W49TH_ST_345_M51						FWD	
Wed 10/12/2016	to	Thu 10/13/2016				(Import)	
0001	Continuous	2359			SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
SPRNBK_345KV_RNS5						FWD	
Wed 10/12/2016	to	Thu 10/13/2016				(Import)	
0001	Continuous	2359			SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
SPRNBK_-W49TH_ST_345_M52						FWD	
Fri 10/14/2016	to	Sun 10/23/2016				(Import)	
0001	Continuous	2359			SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
CHATGUAY-MASSENA_765_7040						FWD	
Sat 10/15/2016	to	Sat 10/29/2016	UPDATED	by NYPA	10/08/2015	(Import)	
0100	Continuous	1730			MOSES SOUTH	1550 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW	
					TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA_765_7040						FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016	UPDATED	by NYPA	10/08/2015	(Import)	(Export)
0100	Continuous	1730			SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW	1000 MW
					TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_-MARCY_765_MSU1						FWD	
Sat 10/15/2016	to	Sat 10/29/2016	UPDATED	by NYPA	10/08/2015	(Import)	
0100	Continuous	1730			CENTRAL EAST - VC	2265 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW	
					TTC with All Lines In Service	2975 MW	
MASSENA_-MARCY_765_MSU1						FWD	
Sat 10/15/2016	to	Sat 10/29/2016	UPDATED	by NYPA	10/08/2015	(Import)	
0100	Continuous	1730			MOSES SOUTH	500 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	2650 MW	
					TTC with All Lines In Service	3150 MW	



# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>						FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/08/2015</b>	(Import)	(Export)
0100	Continuous	1730				<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA			<b>ARR: 20</b>		SCH - HQ - NY	Impacts Total Transfer Capability	1025 MW 0 MW
					TTC with All Lines In Service	1500 MW	1000 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 10/15/2016	to	Sat 10/29/2016				(Import)	
0100		1730				<b>500 MW</b>	
Work scheduled by:			<b>ARR: 20</b>		MOSES SOUTH	Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW	
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>						FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016				(Import)	(Export)
0100		1730				<b>850 MW</b>	<b>0 MW</b>
Work scheduled by:			<b>ARR: 20</b>		SCH - HQ - NY	Impacts Total Transfer Capability	650 MW 1000 MW
					TTC with All Lines In Service	1500 MW	1000 MW
<b>WATRCURE-OAKDALE_345_31</b>						FWD	REV
Mon 10/17/2016	to	Fri 10/21/2016				(Import)	(Export)
0700	Continuous	1600				<b>2050 MW</b>	<b>1300 MW</b>
Work scheduled by: NYSEG					SCH - PJ - NY	Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2050 MW	1300 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD	REV
Mon 10/17/2016	to	Sat 10/22/2016				(Import)	(Export)
0700	Continuous	1900				<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI					SCH - NPX_CSC	Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW	330 MW
<b>W49TH_ST_345KV_5</b>						FWD	
Wed 10/19/2016	to	Sun 10/23/2016				(Import)	
0001	Continuous	2359				<b>310 MW</b>	
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	660 MW	
<b>SPRNBK_345KV_RNS4</b>						FWD	
Fri 10/21/2016	to	Sat 10/22/2016				(Import)	
0001	Continuous	2359				<b>3200 MW</b>	
Work scheduled by: ConEd					SPR/DUN-SOUTH	Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW	

**NYISO TRANSFER LIMITATIONS**

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WATRCURE-OAKDALE\_\_345\_31**

Mon 10/24/2016 to Fri 10/28/2016  
0700 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY 2050 MW 1300 MW  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2050 MW 1300 MW

**MARCY\_\_765\_345\_BK 2**

Mon 10/24/2016 to Fri 10/28/2016  
0700 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 10/31/2016 to Sat 11/05/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**

Fri 11/04/2016 to Fri 11/04/2016  
0600 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY 2600 MW 1300 MW  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2600 MW 1300 MW

**LEEDS\_\_-PLSNTVLY\_345\_92**

Mon 11/07/2016 to Wed 12/07/2016  
0001 Continuous 2359

Work scheduled by: NGrid

**UPDATED by CONED 05/13/2016**

FWD  
(Import)  
UPNY CONED 3800 MW  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**PLSNTVLY\_345KV\_RNS5**

Mon 11/07/2016 to Wed 12/07/2016  
0001 Continuous 2359

Work scheduled by: NGrid

**UPDATED by CONED 05/13/2016**

FWD  
(Import)  
UPNY CONED 3800 MW  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 11/07/2016 to Thu 11/10/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MAINESBG-WATRCURE\_345\_30

Mon 11/07/2016 to Fri 12/09/2016 UPDATED by NYSEG 02/16/2016  
0800 Continuous 1600

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

## PLSNTVLY-WOOD\_ST\_345\_F30

Tue 11/08/2016 to Tue 11/08/2016 UPDATED by CONED 05/13/2016  
0001 Continuous 2359

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

## BECK\_\_\_\_-NIAGARA\_345\_PA301

Mon 11/14/2016 to Fri 11/18/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1400 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/14/2016 to Sat 11/19/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/21/2016 to Wed 11/23/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/28/2016 to Fri 12/02/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/05/2016 to Fri 12/09/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022				FWD	REV
Mon 12/05/2016	to	Wed 12/07/2016		(Import)	(Export)
0800	Continuous	1800		SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
PLSNTVLY-WOOD_ST___345_F30				FWD	
Tue 12/06/2016	to	Tue 12/06/2016	<u>UPDATED</u> <u>by CONED</u> <u>05/13/2016</u>	(Import)	
0001	Continuous	2359		UPNY CONED	4000 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
GILBOA___-N.SCTLND_345_GNS-1				FWD	
Thu 12/08/2016	to	Fri 12/16/2016		(Import)	
0600	Continuous	1800		CENTRAL EAST - VC	2520 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW
MARCY___-N.SCTLND_345_18				FWD	
Thu 12/08/2016	to	Fri 12/16/2016		(Import)	
0600	Continuous	1800		CENTRAL EAST - VC	2090 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
N.SCTLND-LEEDS___345_94				FWD	
Thu 12/08/2016	to	Fri 12/16/2016		(Import)	
0600	Continuous	1800		CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
MOSES___-ADIRNDCK_230_MA2				FWD	
Mon 12/12/2016	to	Fri 12/16/2016		(Import)	
0700	Continuous	1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
FRASER___-GILBOA___345_GF5-35				FWD	
Sat 12/17/2016	to	Fri 12/30/2016		(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2650 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

FWD

Mon 12/19/2016 to Thu 12/22/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**FITZPTRK-EDIC\_345\_FE-1**

FWD

Mon 03/06/2017 to Fri 03/31/2017

(Import)

0600 Continuous 1900

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**BROWNFLS-TAYLORVL\_115\_3**

FWD

REV

Mon 05/01/2017 to Fri 05/26/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

**ARR: 38****ROSETON-ROCKTVRN\_345\_311**

FWD

Mon 05/08/2017 to Fri 05/26/2017

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: CHGE

**BROWNFLS-TAYLORVL\_115\_4**

FWD

REV

Tue 05/30/2017 to Sat 06/24/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

**ARR: 38****BROWNFLS-TAYLORVL\_115\_3**

FWD

REV

Mon 06/26/2017 to Sat 07/01/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

**ARR: 38****BROWNFLS-TAYLORVL\_115\_3**

FWD

REV

Wed 07/05/2017 to Sat 07/22/2017

(Import) (Export)

0600 Continuous 1900

SCH - HQ\_CEDARS

**70 MW 40 MW**

Impacts Total Transfer Capability 120 MW 0 MW

TTC with All Lines In Service 190 MW 40 MW

Work scheduled by: NGrid

**ARR: 38**

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_4**

Mon 07/24/2017 to Sat 08/19/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 08/21/2017 to Fri 09/01/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**BROWNFLS-TAYLORVL\_115\_3**

Tue 09/05/2017 to Sat 09/16/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**HURLYAVE-ROSETON\_\_345\_303**

Mon 09/11/2017 to Fri 09/29/2017  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 09/18/2017 to Sat 10/14/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 10/16/2017 to Sat 11/11/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**LEEDS\_\_-HURLYAVE\_345\_301**

Mon 10/16/2017 to Fri 11/03/2017  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,June 16, 2016 to Saturday ,December 16, 2017

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL\_115\_4

FWD	REV
(Import)	(Export)

Mon 11/13/2017 to Fri 11/30/2018

0600 Continuous 1900

SCH - HQ\_CEDARS 100 MW 100 MW

Impacts Total Transfer Capability 99 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

Work scheduled by: NGrid

ARR: 38