

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EGRDNCTY_345_138_BK 1</b>					FWD	
Tue 05/17/2016	to	Sat 07/09/2016	<u>EXT FORCE</u>	<u>by LI</u>	<u>05/23/2016</u>	(Import)
0534	Continuous	2359				
Work scheduled by: LI					CONED - LIPA	<b>1250 MW</b>
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>EGRDNCTY_345_138_BK 2</b>					FWD	
Tue 05/17/2016	to	Sat 07/09/2016	<u>EXT FORCE</u>	<u>by LI</u>	<u>05/23/2016</u>	(Import)
0534	Continuous	2359				
Work scheduled by: LI					CONED - LIPA	<b>1250 MW</b>
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
<b>SPRNBK_-EGRDNCTR_345_Y49</b>					FWD	
Tue 05/17/2016	to	Sat 07/09/2016	<u>EXT FORCE</u>	<u>by LI</u>	<u>05/23/2016</u>	(Import)
0536	Continuous	2359				
Work scheduled by: LI					CONED - LIPA	<b>775 MW</b>
					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
<b>HOPATCON-RAMAPO___500_5018</b>					FWD	REV
Fri 06/24/2016	to	Tue 06/28/2016	<u>EXT FORCE</u>	<u>by CONED</u>	<u>06/27/2016</u>	(Import) (Export)
1927	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>1900 MW 1000 MW</b>
					Impacts Total Transfer Capability	150 MW 300 MW
					TTC with All Lines In Service	2050 MW 1300 MW
<b>HOPATCON-RAMAPO___500_5018</b>					FWD	
Fri 06/24/2016	to	Tue 06/28/2016	<u>EXT FORCE</u>	<u>by CONED</u>	<u>06/27/2016</u>	(Import)
1927	Continuous	2359				
Work scheduled by: ConEd					TOTAL EAST	<b>6400 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	6500 MW
<b>HOPATCON-RAMAPO___500_5018</b>					FWD	
Fri 06/24/2016	to	Tue 06/28/2016	<u>EXT FORCE</u>	<u>by CONED</u>	<u>06/27/2016</u>	(Import)
1927	Continuous	2359				
Work scheduled by: ConEd					UPNY CONED	<b>4000 MW</b>
					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<b>RAMAPO___500_345_BK 1500</b>					FWD	REV
Fri 06/24/2016	to	Tue 06/28/2016	<u>EXT FORCE</u>	<u>by CONED</u>	<u>06/27/2016</u>	(Import) (Export)
1927	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>1900 MW 1000 MW</b>
					Impacts Total Transfer Capability	150 MW 300 MW
					TTC with All Lines In Service	2050 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_\_500\_345\_BK 1500

Fri 06/24/2016 to Tue 06/28/2016 EXT FORCE by CONED 06/27/2016

1927 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
TOTAL EAST **6400 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 6500 MW

### RAMAPO\_\_\_500\_345\_BK 1500

Fri 06/24/2016 to Tue 06/28/2016 EXT FORCE by CONED 06/27/2016

1927 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### RAMAPO\_\_\_345\_345\_PAR4500

Fri 06/24/2016 to Tue 06/28/2016 EXT FORCE by CONED 06/27/2016

1940 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1700 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	350 MW	0 MW
TTC with All Lines In Service	2050 MW	1300 MW

### RAMAPO\_\_\_345\_345\_PAR3500

Fri 06/24/2016 to Thu 09/01/2016 EXT FORCE by CONED 06/27/2016

1940 Continuous 2359

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1700 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	350 MW	0 MW
TTC with All Lines In Service	2050 MW	1300 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 06/27/2016 to Wed 06/29/2016 UPDATED by NYPA 06/30/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### SCH-PJM-NYISO\_LIMIT\_1400

Mon 06/27/2016 to Thu 09/01/2016 EXT FORCE by CONED 06/27/2016

1630 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **1700 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 2050 MW

### HUDSONTP-W49TH\_ST\_345\_Y56

Tue 06/28/2016 to Sun 07/31/2016 EXT FORCE by PJM 06/29/2016

1052 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-HIGLEY___115_1</b>					FWD	REV
Thu 06/30/2016 to Thu 06/30/2016					(Import)	(Export)
0600 Daily(No Weekends) 1400					SCH - HQ_CEDARS	<b>100 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	90 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW
<b>COLTON_-HIGLEY___115_1</b>					FWD	REV
Thu 06/30/2016 to Thu 06/30/2016					(Import)	(Export)
0600 Daily(No Weekends) 1400					SCH - HQ_CEDARS	<b>100 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	90 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV
Thu 06/30/2016 to Fri 07/01/2016					(Import)	(Export)
0600 Continuous 1700					SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW
<b>FITZPTRK-EDIC___345_FE-1</b>					FWD	
Fri 07/01/2016 to Fri 07/01/2016					(Import)	
0800 Continuous 2000					OSWEGO EXPORT	<b>4800 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	5250 MW
<b>FITZPTRK-EDIC___345_FE-1</b>					FWD	
Mon 07/04/2016 to Mon 07/04/2016					(Import)	
1500 Continuous 2000					OSWEGO EXPORT	<b>4800 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	5250 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	REV
Tue 07/05/2016 to Sat 07/09/2016					(Import)	(Export)
0600 Continuous 1700					SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>					TTC with All Lines In Service	190 MW 40 MW
<b>SCH-HQ-NYISO_LIMIT_0</b>					FWD	
Tue 07/05/2016 to Wed 07/06/2016					(Import)	
2100 Continuous 0700					SCH - HQ - NY	<b>0 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	1500 MW

**NYISO TRANSFER LIMITATIONS**

Saturday ,July 02, 2016 to Monday ,January 01, 2018

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-IMO-NYISO\_LIMIT\_700**

FWD

Wed 07/06/2016 to Wed 07/06/2016 **UPDATED by NYISO 06/29/2016**

(Import)

0500 Continuous 1600

SCH - OH - NY

**1000 MW**

Impacts Total Transfer Capability 750 MW

TTC with All Lines In Service 1750 MW

Work scheduled by: NYPA

**ROCHESTR-PANNELL\_345\_RP2**

FWD

Sat 07/09/2016 to Sun 07/10/2016

(Import)

0600 Continuous 1800

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: RGE

**E13THSTA-FARRAGUT\_345\_46**

FWD

Sat 07/09/2016 to Sat 07/09/2016

(Import)

2200 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Sat 07/09/2016 to Sat 07/09/2016

(Import)

2200 Continuous 2359

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE-SHORE\_RD\_345\_Y50**

FWD

Sun 07/10/2016 to Sun 07/10/2016

(Import)

0001 Continuous 1530

CONED - LIPA

**800 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 1**

FWD

Sun 07/10/2016 to Sun 07/10/2016

(Import)

0001 Continuous 1530

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

**SHORE\_RD\_345\_138\_BK 2**

FWD

Sun 07/10/2016 to Sun 07/10/2016

(Import)

0001 Continuous 1530

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BROWNFLS-TAYLORVL_115_3</b>							
Mon 07/11/2016	to	Fri 07/15/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/21/2016</u>	SCH - HQ_CEDARS	<b>70 MW</b>
0600	Continuous	1700				Impacts Total Transfer Capability	120 MW
Work scheduled by: NGrid						TTC with All Lines In Service	190 MW
							40 MW
<b>STONYRDG-HILLSIDE_230_72</b>						FWD	
						(Import)	
Wed 07/13/2016	to	Wed 07/13/2016				DYSINGER EAST	<b>2850 MW</b>
0800	Continuous	1500				Impacts Total Transfer Capability	300 MW
Work scheduled by: NYSEG						TTC with All Lines In Service	3150 MW
<b>ROCHESTR-PANNELL_345_RP2</b>						FWD	
						(Import)	
Sat 07/16/2016	to	Sun 07/17/2016	<u>UPDATED</u>	<u>by RGE</u>	<u>07/01/2016</u>	DYSINGER EAST	<b>2300 MW</b>
0600	Continuous	1800				Impacts Total Transfer Capability	850 MW
Work scheduled by: RGE						TTC with All Lines In Service	3150 MW
<b>ADIRNDCK-CHASLAKE_230_13</b>						FWD	
						(Import)	
Tue 07/19/2016	to	Tue 07/19/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>06/21/2016</u>	MOSES SOUTH	<b>2100 MW</b>
0800	Continuous	1700				Impacts Total Transfer Capability	1050 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_3</b>						FWD	REV
						(Import)	(Export)
Wed 07/20/2016	to	Fri 07/22/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/21/2016</u>	SCH - HQ_CEDARS	<b>70 MW</b>
0600	Continuous	1700				Impacts Total Transfer Capability	120 MW
Work scheduled by: NGrid						TTC with All Lines In Service	190 MW
							40 MW
<b>PANNELL_-CLAY_345_2</b>						FWD	
						(Import)	
Sat 07/23/2016	to	Sun 07/24/2016	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/26/2016</u>	WEST CENTRAL	<b>1300 MW</b>
0600	Continuous	1800				Impacts Total Transfer Capability	950 MW
Work scheduled by: RGE						TTC with All Lines In Service	2250 MW
<b>BROWNFLS-TAYLORVL_115_3</b>						FWD	REV
						(Import)	(Export)
Mon 07/25/2016	to	Fri 07/29/2016	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/21/2016</u>	SCH - HQ_CEDARS	<b>70 MW</b>
0600	Continuous	1700				Impacts Total Transfer Capability	120 MW
Work scheduled by: NGrid						TTC with All Lines In Service	190 MW
							40 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER___345_FRASER SVC					FWD	
Mon 07/25/2016	to	Fri 07/29/2016			(Import)	
0830	Continuous	1400		CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	40 MW	
				TTC with All Lines In Service	2975 MW	
PANNELL_-CLAY___345_2					FWD	
Sat 07/30/2016	to	Sun 07/31/2016	<u>UPDATED</u>	<u>by NYISO 05/26/2016</u>	(Import)	
0600	Continuous	1800		WEST CENTRAL	1300 MW	
Work scheduled by: RGE				Impacts Total Transfer Capability	950 MW	
				TTC with All Lines In Service	2250 MW	
BROWNFLS-TAYLORVL_115_4					FWD	
Mon 08/01/2016	to	Fri 08/05/2016	<u>UPDATED</u>	<u>by NGRID 05/05/2016</u>	(Import)	
0600	Continuous	1700		SCH - HQ_CEDARS	70 MW	
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW	
				TTC with All Lines In Service	190 MW	
BROWNFLS-TAYLORVL_115_4					FWD	
Mon 08/08/2016	to	Fri 08/12/2016	<u>UPDATED</u>	<u>by NGRID 05/05/2016</u>	(Import)	
0600	Continuous	1700		SCH - HQ_CEDARS	70 MW	
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW	
				TTC with All Lines In Service	190 MW	
MAINESBG-WATRCURE_345_30					FWD	
Thu 08/11/2016	to	Thu 08/11/2016			(Import)	
0900	Continuous	1200		SCH - PJ - NY	2050 MW	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	0 MW	
				TTC with All Lines In Service	2050 MW	
BROWNFLS-TAYLORVL_115_4					FWD	
Mon 08/15/2016	to	Fri 08/19/2016	<u>UPDATED</u>	<u>by NGRID 05/05/2016</u>	(Import)	
0600	Continuous	1700		SCH - HQ_CEDARS	70 MW	
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW	
				TTC with All Lines In Service	190 MW	
BROWNFLS-TAYLORVL_115_4					FWD	
Mon 08/22/2016	to	Fri 08/26/2016	<u>UPDATED</u>	<u>by NGRID 05/05/2016</u>	(Import)	
0600	Continuous	1700		SCH - HQ_CEDARS	70 MW	
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW	
				TTC with All Lines In Service	190 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BROWNFLS-TAYLORVL\_115\_3

Fri 08/26/2016 to Fri 09/02/2016  
0600 Continuous 1700

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## MARCY -FRASANNX\_345\_UCC2-41

Sun 08/28/2016 to Wed 08/31/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

## BECK -NIAGARA\_345\_PA302

Mon 08/29/2016 to Fri 09/09/2016  
0800 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	900 MW	800 MW
Impacts Total Transfer Capability	850 MW	800 MW
TTC with All Lines In Service	1750 MW	1600 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Sun 09/04/2016 to Mon 09/05/2016  
0700 Continuous 1700

Work scheduled by: LI

UPDATED by LI 04/26/2016

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

## GILBOA -LEEDS\_345\_GL3

Mon 09/05/2016 to Fri 09/09/2016  
0800 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2200 MW
Impacts Total Transfer Capability	775 MW
TTC with All Lines In Service	2975 MW

## BROWNFLS-TAYLORVL\_115\_3

Tue 09/06/2016 to Sun 09/11/2016  
0600 Continuous 1700

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## MARCY 765\_345\_BK 2

Tue 09/06/2016 to Sun 09/11/2016  
0700 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-LADENTWN\_345\_W72**

Sat 09/10/2016 to Sat 09/10/2016  
0001 Continuous 2359  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

**KINTIGH\_-ROCHESTR\_345\_SR1-39**

Mon 09/12/2016 to Fri 09/16/2016  
0700 Continuous 1630  
Work scheduled by: NYPA

**UPDATED by NYISO 01/20/2016**

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_-ADIRNDCK\_230\_MAl**

Mon 09/12/2016 to Sat 09/17/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**CLRKSCRN-OAKDALE\_\_345\_36**

Mon 09/12/2016 to Thu 09/15/2016  
0800 Continuous 1630  
Work scheduled by: NYSEG

**UPDATED by NYSEG 05/17/2016**

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**HURLYAVE-ROSETON\_\_345\_303**

Mon 09/12/2016 to Fri 09/30/2016  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

**NIAGARA\_\_345\_230\_BK 4**

Wed 09/14/2016 to Thu 09/15/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

**UPDATED by PA 09/18/2015**

FWD	REV
(Import)	(Export)
SCH - OH - NY	<b>1750 MW 1300 MW</b>
Impacts Total Transfer Capability	0 MW 300 MW
TTC with All Lines In Service	1750 MW 1600 MW

**BECK\_\_\_\_-NIAGARA\_\_345\_PA301**

Fri 09/16/2016 to Fri 09/16/2016  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD	REV
(Import)	(Export)
SCH - OH - NY	<b>900 MW 800 MW</b>
Impacts Total Transfer Capability	850 MW 800 MW
TTC with All Lines In Service	1750 MW 1600 MW



# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 09/19/2016 to Sat 09/24/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### BECK\_\_\_-NIAGARA\_230\_PA27

Mon 09/19/2016 to Sun 11/06/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1600 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1750 MW 1600 MW

### EDIC\_\_\_-N.SCTLND\_345\_14

Mon 09/26/2016 to Tue 09/27/2016  
0530 Continuous 1530

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2240 MW**  
Impacts Total Transfer Capability 735 MW  
TTC with All Lines In Service 2975 MW

### NRTH1385-NOR HBR\_\_138\_601

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

### NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

### NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603

Mon 09/26/2016 to Fri 09/30/2016  
0700 1600

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

### NRTH1385-NOR HBR\_\_138\_602

Mon 09/26/2016 to Fri 09/30/2016  
0700 Continuous 1600

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 5100MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 09/26/2016 to Fri 09/30/2016  
 0700 1600

Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 0 MW 0 MW  
 Impacts Total Transfer Capability 200 MW 200 MW  
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NOR HBR\_\_138\_603

Mon 09/26/2016 to Fri 09/30/2016  
 0700 Continuous 1600

Work scheduled by: LI

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 100 MW 100 MW  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

NRTH1385-NRTHPORT\_138\_1385

Mon 09/26/2016 to Fri 09/30/2016  
 0700 Continuous 1600

Work scheduled by: LI

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 0 MW 0 MW  
 Impacts Total Transfer Capability 200 MW 200 MW  
 TTC with All Lines In Service 200 MW 200 MW

MOSES\_\_-ADIRNDCK\_230\_MAI

Mon 09/26/2016 to Sat 10/01/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH 2100 MW  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

SPRNBRK\_\_345KV\_RNS5

Sun 10/02/2016 to Sun 10/02/2016 UPDATED by CONED 06/14/2016  
 0001 Continuous 0030

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH 3200 MW  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

SPRNBRK\_-W49TH\_ST\_345\_M51

Sun 10/02/2016 to Tue 10/11/2016 UPDATED by CONED 06/14/2016  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH 3200 MW  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

MARCY\_\_-FRASANNX\_345\_UCC2-41

Mon 10/03/2016 to Sun 10/09/2016  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC 2500 MW  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 10/04/2016 to Fri 10/07/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**NRTH1385-NOR HBR\_\_\_138\_601**

Mon 10/10/2016 to Mon 10/17/2016  
0600 Continuous 1700

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

---

**LEEDS\_\_\_-HURLYAVE\_345\_301**

Mon 10/10/2016 to Fri 11/04/2016  
0700 Continuous 1600

Work scheduled by: NGrid

**UPDATED by NGRID 07/09/2015**

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

---

**LEEDS\_\_\_345KV\_R94301**

Mon 10/10/2016 to Fri 11/04/2016  
0700 Continuous 1600

Work scheduled by: NGrid

**UPDATED by NGRID 07/09/2015**

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Tue 10/11/2016 to Fri 10/14/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**SPRNBRK\_-W49TH\_ST\_345\_M51**

Wed 10/12/2016 to Thu 10/13/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

---

**SPRNBRK\_\_\_345KV\_RNS5**

Wed 10/12/2016 to Thu 10/13/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

FWD

Fri 10/14/2016 to Fri 10/14/2016

(Import)

0001 Continuous 0030

SCH - PJM\_HTP

**350 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SPRNBRK\_-W49TH\_ST\_345\_M52**

FWD

Fri 10/14/2016 to Sun 10/23/2016

(Import)

0001 Continuous 2359

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**CHATGUAY-MASSENA\_765\_7040**

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

**UPDATED****by NYPA****10/08/2015**

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CHATGUAY-MASSENA\_765\_7040**

FWD

REV

Sat 10/15/2016 to Sat 10/29/2016

(Import) (Export)

0100 Continuous 1730

**UPDATED****by NYPA****10/08/2015**

SCH - HQ - NY

**0 MW****0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**MASSENA\_-MARCY\_765\_MSU1**

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

**UPDATED****by NYPA****10/08/2015**

CENTRAL EAST - VC

**2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 20****MASSENA\_-MARCY\_765\_MSU1**

FWD

Sat 10/15/2016 to Sat 10/29/2016

(Import)

0100 Continuous 1730

**UPDATED****by NYPA****10/08/2015**

MOSES SOUTH

**500 MW**

Impacts Total Transfer Capability 2650 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**ARR: 20****MASSENA\_-MARCY\_765\_MSU1**

FWD

REV

Sat 10/15/2016 to Sat 10/29/2016

(Import) (Export)

0100 Continuous 1730

**UPDATED****by NYPA****10/08/2015**

SCH - HQ - NY

**475 MW****1000 MW**

Impacts Total Transfer Capability 1025 MW 0 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: NYPA

**ARR: 20**

**NYISO TRANSFER LIMITATIONS**

Saturday ,July 02, 2016 to Monday ,January 01, 2018

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 5100MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_ 765\_MSU1 & CHATGUAY-MASSENA\_ 765\_7040

Sat 10/15/2016 to Sat 10/29/2016  
 0100 1730

Work scheduled by:

ARR: 20

FWD  
 (Import)  
 MOSES SOUTH 500 MW  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_-MASSENA\_ 230\_MMS1 & MOSES\_-MASSENA\_ 230\_MMS2

Sat 10/15/2016 to Sat 10/29/2016  
 0100 1730

Work scheduled by:

ARR: 20

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY 850 MW 0 MW  
 Impacts Total Transfer Capability 650 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

WATRCURE-OAKDALE\_ 345\_31

Mon 10/17/2016 to Fri 10/21/2016  
 0700 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY 2050 MW 1300 MW  
 Impacts Total Transfer Capability 0 MW 0 MW  
 TTC with All Lines In Service 2050 MW 1300 MW

SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/17/2016 to Sat 10/22/2016  
 0700 Continuous 1900

Work scheduled by: LI

FWD REV  
 (Import) (Export)  
 SCH - NPX\_CSC 0 MW 0 MW  
 Impacts Total Transfer Capability 330 MW 330 MW  
 TTC with All Lines In Service 330 MW 330 MW

W49TH\_ST\_345KV\_5

Wed 10/19/2016 to Sun 10/23/2016  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJM\_HTP 350 MW  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 660 MW

SPRNBRK\_ 345KV\_RNS4

Fri 10/21/2016 to Sat 10/22/2016  
 0001 Continuous 2359

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH 3200 MW  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

WATRCURE-OAKDALE\_ 345\_31

Mon 10/24/2016 to Fri 10/28/2016  
 0700 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY 2050 MW 1300 MW  
 Impacts Total Transfer Capability 0 MW 0 MW  
 TTC with All Lines In Service 2050 MW 1300 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_BK 2				FWD		
Mon 10/24/2016	to	Fri 10/28/2016		(Import)		
0700	Continuous	1730		MOSES SOUTH	1700 MW	
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1450 MW	
				TTC with All Lines In Service	3150 MW	
NRTH1385-NOR HBR__138_602				FWD	REV	
Wed 10/26/2016	to	Wed 11/02/2016		(Import)	(Export)	
0600	Continuous	1700		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW
MOSES____-ADIRNDCK_230_MA2				FWD		
Mon 10/31/2016	to	Sat 11/05/2016		(Import)		
0700	Continuous	1530		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	
HOMRC_NY-MAINS_NY_345_47				FWD	REV	
Fri 11/04/2016	to	Fri 11/04/2016		(Import)	(Export)	
0600	Continuous	1600		SCH - PJ - NY	2600 MW	1300 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	0 MW	0 MW
				TTC with All Lines In Service	2600 MW	1300 MW
LEEDS____-PLSNTVLY_345_92				FWD		
Mon 11/07/2016	to	Wed 12/07/2016	UPDATED by CONED 05/13/2016	(Import)		
0001	Continuous	2359		UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	1300 MW	
				TTC with All Lines In Service	5100 MW	
PLSNTVLY_345KV_RNS5				FWD		
Mon 11/07/2016	to	Wed 12/07/2016	UPDATED by CONED 05/13/2016	(Import)		
0001	Continuous	2359		UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	1300 MW	
				TTC with All Lines In Service	5100 MW	
MOSES____-ADIRNDCK_230_MA2				FWD		
Mon 11/07/2016	to	Thu 11/10/2016		(Import)		
0700	Continuous	1530		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MAINESBG-WATRCURE\_345\_30

Mon 11/07/2016 to Fri 12/09/2016 UPDATED by NYSEG 02/16/2016  
0800 Continuous 1600

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2600 MW</b>	<b>1300 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2600 MW	1300 MW

### PLSNTVLY-WOOD\_ST\_345\_F30

Tue 11/08/2016 to Tue 11/08/2016 UPDATED by CONED 05/13/2016  
0001 Continuous 2359

Work scheduled by: NGrid

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

### BECK\_\_\_\_-NIAGARA\_345\_PA301

Mon 11/14/2016 to Fri 11/18/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>1400 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	500 MW	650 MW
TTC with All Lines In Service	1900 MW	1900 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/14/2016 to Sat 11/19/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/21/2016 to Wed 11/23/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/28/2016 to Fri 12/02/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/05/2016 to Fri 12/09/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Mon 12/05/2016 to Wed 12/07/2016

0800 Continuous 1800

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

## PLSNTVLY-WOOD\_ST\_\_\_345\_F30

Tue 12/06/2016 to Tue 12/06/2016

0001 Continuous 2359

Work scheduled by: NGrid

UPDATED by CONED 05/13/2016

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

## GILBOA\_\_\_-N.SCTLND\_345\_GNS-1

Thu 12/08/2016 to Fri 12/16/2016

0600 Continuous 1800

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	<b>2520 MW</b>
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

## MARCY\_\_\_-N.SCTLND\_345\_18

Thu 12/08/2016 to Fri 12/16/2016

0600 Continuous 1800

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	<b>2090 MW</b>
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

## N.SCTLND-LEEDS\_\_\_345\_94

Thu 12/08/2016 to Fri 12/16/2016

0600 Continuous 1800

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/12/2016 to Fri 12/16/2016

0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35

Sat 12/17/2016 to Fri 12/30/2016

0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2650 MW</b>
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/19/2016 to Thu 12/22/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

---

**FITZPTRK-EDIC\_\_\_\_\_345\_FE-1**

Mon 03/06/2017 to Fri 03/31/2017  
0600 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

---

**BROWNFLS-TAYLORVL\_115\_3**

Mon 05/01/2017 to Fri 05/26/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 05/08/2017 to Fri 05/26/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

---

**BROWNFLS-TAYLORVL\_115\_4**

Tue 05/30/2017 to Sat 06/24/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**BROWNFLS-TAYLORVL\_115\_3**

Mon 06/26/2017 to Sat 07/01/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

---

**BROWNFLS-TAYLORVL\_115\_3**

Wed 07/05/2017 to Sat 07/22/2017  
0600 Continuous 1900

Work scheduled by: NGrid

**ARR: 38**

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 07/24/2017	to	Sat 08/19/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 08/21/2017	to	Fri 09/01/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Tue 09/05/2017	to	Sat 09/16/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>HURLYAVE-ROSETON__345_303</b>				FWD	
Mon 09/11/2017	to	Fri 09/29/2017		(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 09/18/2017	to	Sat 10/14/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 10/16/2017	to	Sat 11/11/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid			<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>LEEDS__-HURLYAVE_345_301</b>				FWD	
Mon 10/16/2017	to	Fri 11/03/2017		(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Saturday ,July 02, 2016 to Monday ,January 01, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL\_115\_4

FWD	REV
(Import)	(Export)

Mon 11/13/2017 to Fri 11/30/2018

0600 Continuous 1900

SCH - HQ\_CEDARS 100 MW 100 MW

Impacts Total Transfer Capability 99 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

Work scheduled by: NGrid

ARR: 38