

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Tue 02/01/2011 to Mon 10/03/2016  
0000 Continuous 0659

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

### RAMAPO\_345\_345\_PAR3500

Fri 06/24/2016 to Thu 12/15/2016  
1940 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 08/05/2016

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1700 MW 1300 MW**  
Impacts Total Transfer Capability 350 MW 0 MW  
TTC with All Lines In Service 2050 MW 1300 MW

### HUDSONTP-W49TH\_ST\_345\_Y56

Tue 06/28/2016 to Sat 10/15/2016  
1052 Continuous 2359

Work scheduled by: ConEd

EXT FORCE by PJM 09/09/2016

FWD  
(Import)  
SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### EGRDNCTY\_345\_138\_AT1

Sat 07/30/2016 to Tue 09/20/2016  
1301 Continuous 1500

Work scheduled by: LI

EXT FORCE by LI 09/09/2016

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### EGRDNCTY\_345\_138\_AT2

Sat 07/30/2016 to Tue 09/20/2016  
1301 Continuous 1500

Work scheduled by: LI

EXT FORCE by LI 09/09/2016

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### SPRNBRK\_-EGRDNCTR\_345\_Y49

Sat 07/30/2016 to Tue 09/20/2016  
1505 Continuous 1500

Work scheduled by: LI

EXT FORCE by LI 09/09/2016

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Tue 09/06/2016 to Thu 10/20/2016  
0700 Continuous 1800

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ\_CEDARS **0 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 40 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## COOPERS\_-ROCKTVRN\_345\_CCRT-42

Sat 09/10/2016 to Sun 09/25/2016 EXTENDED by NYPA 09/21/2016  
0500 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Thu 09/15/2016 to Sun 09/18/2016 EXT FORCE by NYSEG 09/17/2016  
2243 Continuous 2359

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2050 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2050 MW 1300 MW

## SPRNBK\_-TREMONT\_345\_X28

Fri 09/16/2016 to Sun 09/18/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## PANNELL\_-CLAY\_345\_1

Sat 09/17/2016 to Sun 09/18/2016  
0600 Continuous 1800

Work scheduled by: RGE

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## BECK\_-NIAGARA\_230\_PA27

Mon 09/19/2016 to Sun 11/06/2016 UPDATED by NYPA 09/14/2016  
0500 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1600 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1750 MW 1600 MW

## MOSES\_-ADIRNDCK\_230\_MA1

Mon 09/19/2016 to Fri 09/23/2016 CANCELLED by NYPA 09/19/2016  
0700 Daily 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## SCH-IMO-NYISO\_LIMIT\_500

Mon 09/19/2016 to Fri 09/23/2016  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
SCH - OH - NY **800 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 1750 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 09/19/2016 to Sat 09/24/2016  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 09/19/2016 to Sat 09/24/2016  
0700 Daily 1730

Work scheduled by: NYPA

**CANCELLED by NYISO 09/19/2016**

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 09/19/2016 to Mon 09/19/2016  
0823 Continuous 1530

Work scheduled by: NYPA

**CANCELLED by NYISO 09/19/2016**

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

---

**SCH-NYISO-NE\_LIMIT\_800**

Mon 09/19/2016 to Sat 09/24/2016  
1400 Continuous 1500

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

---

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Wed 09/21/2016 to Wed 09/21/2016  
0001 Continuous 0400

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

---

**NEWBRDGE-DUFFYAVE\_345\_501**

Wed 09/21/2016 to Wed 09/21/2016  
0001 Continuous 0400

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

---

**LINDEN\_-GOETHALS\_230\_A2253**

Thu 09/22/2016 to Sat 10/01/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2050 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2050 MW 1300 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1					FWD	
Sat 09/24/2016	to	Sun 09/25/2016	<u>UPDATED</u>	<u>by RGE</u>	<u>09/22/2016</u>	(Import)
0600	Continuous	1800				
Work scheduled by: RGE					WEST CENTRAL	1300 MW
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL_____345_RP1					FWD	
Sat 09/24/2016	to	Sun 09/25/2016	<u>UPDATED</u>	<u>by RGE</u>	<u>09/22/2016</u>	(Import)
0600	Continuous	1800				
Work scheduled by: RGE					DYSINGER EAST	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
EDIC_____N.SCTLND_345_14					FWD	
Mon 09/26/2016	to	Tue 09/27/2016				(Import)
0530	Continuous	1530				
Work scheduled by: NGrid					CENTRAL EAST - VC	2240 MW
					Impacts Total Transfer Capability	735 MW
					TTC with All Lines In Service	2975 MW
EDIC_____N.SCTLND_345_14 & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Mon 09/26/2016	to	Tue 09/27/2016				(Import)
0530		1530				
Work scheduled by:					CENTRAL EAST - VC	2005 MW
					Impacts Total Transfer Capability	970 MW
					TTC with All Lines In Service	2975 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Mon 09/26/2016	to	Mon 09/26/2016			(Import)	(Export)
0700	Daily(No Weekends)	0759			SCH - NE - NY	950 MW 1000 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	450 MW 600 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Mon 09/26/2016	to	Mon 09/26/2016			(Import)	(Export)
0700	Daily(No Weekends)	0759			SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Mon 09/26/2016	to	Mon 09/26/2016			(Import)	(Export)
0700		0759			SCH - NE - NY	950 MW 1000 MW
Work scheduled by:					Impacts Total Transfer Capability	450 MW 600 MW
					TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS_____345_393 & NRTH1385-NOR HBR__138_601				FWD	REV
Mon 09/26/2016	to	Mon 09/26/2016		(Import)	(Export)
0700		0759		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			ARR: 78	Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393 & NRTH1385-NOR HBR__138_602				FWD	REV
Mon 09/26/2016	to	Mon 09/26/2016		(Import)	(Export)
0700		0759		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			ARR: 78	Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 09/26/2016	to	Mon 09/26/2016		(Import)	(Export)
0700		0759		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			ARR: 78	Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_601				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_602				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_1385				FWD	REV
Mon 09/26/2016	to	Fri 09/30/2016		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-NORTHFLD_345_312				FWD	REV
Mon 09/26/2016	to	Sat 10/01/2016		(Import)	(Export)
0700	Continuous	1559		SCH - NE - NY	1050 MW 1200 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	350 MW 400 MW
				TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Mon 09/26/2016	to	Sat 10/01/2016			(Import)	(Export)
0700	Continuous	1559			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>CHASLAKE-PORTER_230_11</b>					FWD	
Mon 09/26/2016	to	Mon 09/26/2016	<u>UPDATED</u>	<u>by NGRID</u> <u>09/22/2016</u>	(Import)	
0730	Daily(No Weekends)	1800			MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES_-ADIRNDCK_230_MA1</b>					FWD	
Tue 09/27/2016	to	Sat 10/01/2016	<u>UPDATED</u>	<u>by NYPA</u> <u>09/06/2016</u>	(Import)	
0700	Continuous	1730			MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
<b>BERKSHIR-ALPS_345_393</b>					FWD	REV
Sat 10/01/2016	to	Sat 10/01/2016			(Import)	(Export)
1500	Daily	1559			SCH - NE - NY	<b>950 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	450 MW
ARR: 78					TTC with All Lines In Service	1400 MW
<b>BERKSHIR-ALPS_345_393</b>					FWD	REV
Sat 10/01/2016	to	Sat 10/01/2016			(Import)	(Export)
1500	Daily	1559			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
ARR: 78					TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS_345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Sat 10/01/2016	to	Sat 10/01/2016			(Import)	(Export)
1500		1559			SCH - NE - NY	<b>950 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	450 MW
ARR: 78					TTC with All Lines In Service	1400 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Sun 10/02/2016	to	Sun 10/02/2016	<u>UPDATED</u>	<u>by CONED</u> <u>08/26/2016</u>	(Import)	
0001	Continuous	0030			SCH - PJM_HTP	<b>310 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_-W49TH\_ST\_345\_M52

Sun 10/02/2016 to Tue 10/11/2016 **UPDATED by CONED 08/26/2016**

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## OSWEGO\_COMPLEX\_AVR\_O/S

Sun 10/02/2016 to Sun 10/02/2016

0900 Continuous 1100

Work scheduled by: Gen

FWD  
(Import)  
CENTRAL EAST - VC **2870 MW**  
Impacts Total Transfer Capability 105 MW  
TTC with All Lines In Service 2975 MW

## OSWEGO\_COMPLEX\_AVR\_O/S & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Sun 10/02/2016 to Sun 10/02/2016

0900 1100

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2635 MW**  
Impacts Total Transfer Capability 340 MW  
TTC with All Lines In Service 2975 MW

## SCH-NYISO-IMO\_NIAGARA\_CB\_3002

Mon 10/03/2016 to Fri 10/14/2016 **UPDATED by NYISO 09/20/2016**

0600 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1300 MW 1150 MW**  
Impacts Total Transfer Capability 450 MW 450 MW  
TTC with All Lines In Service 1750 MW 1600 MW

## MOSES\_-ADIRNDCK\_230\_MAI

Mon 10/03/2016 to Fri 10/07/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_345\_UCC2-41

Mon 10/03/2016 to Sun 10/09/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_-FRASANNX\_345\_UCC2-41

Mon 10/03/2016 to Sun 10/09/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DENNISON-ROSEMNTA\_115\_1/11

Mon 10/03/2016 to Sun 10/09/2016  
0800 Continuous 1700

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	40 MW
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## MAINESBG-WATRCURE\_345\_30

Mon 10/03/2016 to Mon 10/03/2016  
0830 Continuous 1430

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2050 MW	1300 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 10/03/2016 to Tue 10/04/2016  
1000 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## COOPERS\_-MIDDLETP\_345\_CCRT-34

Tue 10/04/2016 to Tue 10/04/2016  
0800 Continuous 1500

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2720 MW
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

## W49TH\_ST\_345KV\_5

Fri 10/07/2016 to Tue 10/11/2016  
0001 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 08/26/2016

	FWD
	(Import)
SCH - PJM_HTP	310 MW
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	660 MW

## FROST\_BR-LONG MTN\_345\_352

Sat 10/08/2016 to Sun 10/09/2016  
0600 Continuous 1600

Work scheduled by: ISONE

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1150 MW	1600 MW
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	1400 MW	1600 MW

## SPRNBK\_345KV\_RNS4

Sun 10/09/2016 to Mon 10/10/2016  
0001 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 08/26/2016

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601				FWD	REV
Mon 10/10/2016	to	Mon 10/24/2016		(Import)	(Export)
0700	Continuous	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
LEEDS__-HURLYAVE_345_301				FWD	
Mon 10/10/2016	to	Fri 11/04/2016	<u>UPDATED</u> <u>by NGRID</u> <u>07/09/2015</u>	(Import)	
0700	Continuous	1600		UPNY CONED	4100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
LEEDS__345KV_R94301				FWD	
Mon 10/10/2016	to	Fri 11/04/2016	<u>UPDATED</u> <u>by NGRID</u> <u>07/09/2015</u>	(Import)	
0700	Continuous	1600		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5100 MW
LAFAYTTE-CLRKSCRN_345_4-46				FWD	
Mon 10/10/2016	to	Fri 10/14/2016		(Import)	
0800	Continuous	1530		CENTRAL EAST - VC	2650 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD	
Tue 10/11/2016	to	Fri 10/14/2016		(Import)	
0600	Continuous	1800		SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501				FWD	
Tue 10/11/2016	to	Fri 10/14/2016		(Import)	
0600	Continuous	1800		SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
Tue 10/11/2016	to	Fri 10/14/2016		(Import)	
0700	Continuous	1530		MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DENNISON-ROSEMNTB\_115\_2/22

Tue 10/11/2016 to Sun 10/16/2016  
0800 Continuous 1700

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	40 MW
Impacts Total Transfer Capability	95 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## W49TH\_ST-E13THSTA\_345\_M55

Wed 10/12/2016 to Wed 10/12/2016  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 09/01/2016

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

## W49TH\_ST\_345KV\_6

Wed 10/12/2016 to Wed 10/12/2016  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 09/01/2016

	FWD
	(Import)
SCH - PJM_HTP	320 MW
Impacts Total Transfer Capability	340 MW
TTC with All Lines In Service	660 MW

## E13THSTA-FARRAGUT\_345\_46

Wed 10/12/2016 to Fri 10/21/2016  
0001 Continuous 2359

Work scheduled by: ConEd

UPDATED by CONED 09/01/2016

	FWD
	(Import)
SPR/DUN-SOUTH	3800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 10/15/2016 to Sat 10/29/2016  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 09/08/2016

	FWD
	(Import)
MOSES SOUTH	1550 MW
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 10/15/2016 to Sat 10/29/2016  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 09/08/2016

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/15/2016 to Sat 10/29/2016  
0100 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 09/08/2016

ARR: 20

	FWD
	(Import)
CENTRAL EAST - VC	2265 MW
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>					FWD		
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/08/2016</u>	(Import)	
0100	Continuous	1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA					ARR: 20	Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>						FWD	REV
Sat 10/15/2016	to	Sat 10/29/2016	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/08/2016</u>	(Import)	(Export)
0100	Continuous	1730				SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA					ARR: 20	Impacts Total Transfer Capability	1025 MW 0 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>						FWD	
Sat 10/15/2016	to	Sat 10/29/2016				(Import)	
0100		1730				MOSES SOUTH	<b>500 MW</b>
Work scheduled by:					ARR: 20	Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW
<b>FROST_BR-LONG_MTN_345_352</b>						FWD	REV
Sat 10/15/2016	to	Sat 10/15/2016	<u>UPDATED</u>	<u>by NE</u>	<u>08/17/2016</u>	(Import)	(Export)
0600	Continuous	1800				SCH - NE - NY	<b>1150 MW 1600 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	250 MW 0 MW
						TTC with All Lines In Service	1400 MW 1600 MW
<b>FROST_BR-LONG_MTN_345_352 &amp; NRTH1385-NOR HBR_138_601</b>						FWD	REV
Sat 10/15/2016	to	Sat 10/15/2016				(Import)	(Export)
0600		1800				SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	200 MW 200 MW
						TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NE-NYISO_LIMIT_900</b>						FWD	
Sat 10/15/2016	to	Sat 10/15/2016	<u>UPDATED</u>	<u>by NE</u>	<u>08/17/2016</u>	(Import)	
0600	Continuous	1800				SCH - NE - NY	<b>1100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1400 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b>						FWD	
Sun 10/16/2016	to	Sat 10/29/2016				(Import)	
1600		1730				CENTRAL EAST - VC	<b>2080 MW</b>
Work scheduled by:					ARR: 20	Impacts Total Transfer Capability	895 MW
						TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Sun 10/16/2016	to	Sat 02/01/2020			(Import)	
1600	Continuous	0000			CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
MARCY_____765_345_AT1					FWD	
Mon 10/17/2016	to	Sat 10/22/2016	<u>UPDATED</u>	<u>by NYPA</u> <u>09/08/2016</u>	(Import)	
0100	Continuous	1900			MOSES SOUTH	1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MOSES____-MASSENA_230_MMS1 & MOSES____-MASSENA_230_MMS2					FWD	REV
Mon 10/17/2016	to	Sat 10/22/2016			(Import)	(Export)
0100		1900			SCH - HQ - NY	850 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	650 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MARCY_____765_345_AT2					FWD	
Mon 10/17/2016	to	Fri 10/28/2016	<u>UPDATED</u>	<u>by NYPA</u> <u>09/08/2016</u>	(Import)	
0100	Continuous	1530			MOSES SOUTH	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Mon 10/17/2016	to	Mon 10/17/2016	<u>UPDATED</u>	<u>by ISONE</u> <u>07/19/2016</u>	(Import)	(Export)
0700	Daily(No Weekends)	0759			SCH - NE - NY	950 MW 1000 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	450 MW 600 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Mon 10/17/2016	to	Mon 10/17/2016	<u>UPDATED</u>	<u>by ISONE</u> <u>07/19/2016</u>	(Import)	(Export)
0700	Daily(No Weekends)	0759			SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Mon 10/17/2016	to	Mon 10/17/2016			(Import)	(Export)
0700		0759			SCH - NE - NY	950 MW 1000 MW
Work scheduled by:					Impacts Total Transfer Capability	450 MW 600 MW
					TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS____345_393 & NRTH1385-NOR HBR__138_601				FWD	REV
Mon 10/17/2016	to	Mon 10/17/2016		(Import)	(Export)
0700		0759		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
ARR: 78				TTC with All Lines In Service	200 MW 200 MW
SCH-NYISO-NE_LIMIT_500					REV
Mon 10/17/2016	to	Mon 10/17/2016	UPDATED by ISONE 07/19/2016		(Export)
0700	Daily(No Weekends)	0759		SCH - NE - NY	700 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	900 MW
				TTC with All Lines In Service	1600 MW
WATRCURE-OAKDALE__345_31				FWD	REV
Mon 10/17/2016	to	Fri 10/21/2016		(Import)	(Export)
0700	Continuous	1600		SCH - PJ - NY	2050 MW 1300 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2050 MW 1300 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 10/17/2016	to	Sat 10/22/2016		(Import)	(Export)
0700	Continuous	1900		SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW
BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_601				FWD	REV
Mon 10/17/2016	to	Mon 10/24/2016		(Import)	(Export)
0700		1600		SCH - NPX_1385	0 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	200 MW 200 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-NORTHFLD_345_312				FWD	REV
Mon 10/17/2016	to	Sat 11/19/2016		(Import)	(Export)
0700	Continuous	1559		SCH - NE - NY	1050 MW 1200 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	350 MW 400 MW
				TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312				FWD	REV
Mon 10/17/2016	to	Sat 11/19/2016		(Import)	(Export)
0700	Continuous	1559		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_500

Mon 10/17/2016 to Wed 10/19/2016  
0800 Continuous 0559

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **700 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_900

Mon 10/17/2016 to Wed 10/19/2016  
0800 Continuous 0559

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393 &amp; NRTH1385-NOR HBR\_138\_601

Wed 10/19/2016 to Mon 10/24/2016  
0600 1600

Work scheduled by:

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **0 MW 0 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Wed 10/19/2016 to Sat 10/29/2016  
0600 Continuous 1759

Work scheduled by: ISONE

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY **950 MW 1000 MW**  
Impacts Total Transfer Capability 450 MW 600 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393

Wed 10/19/2016 to Sat 10/29/2016  
0600 Continuous 1759

Work scheduled by: ISONE

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## BERKSHIR-ALPS\_\_\_\_\_345\_393 &amp; BERKSHIR-NORTHFLD\_345\_312

Wed 10/19/2016 to Sat 10/29/2016  
0600 1759

Work scheduled by:

ARR: 78

FWD REV  
(Import) (Export)  
SCH - NE - NY **950 MW 1000 MW**  
Impacts Total Transfer Capability 450 MW 600 MW  
TTC with All Lines In Service 1400 MW 1600 MW

## SCH-NYISO-NE\_LIMIT\_400

Wed 10/19/2016 to Sat 10/29/2016  
0600 Continuous 1759

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **600 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST-E13THSTA\_345\_M55

Fri 10/21/2016 to Fri 10/21/2016 UPDATED by CONED 09/01/2016

2330 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## W49TH\_ST\_345KV\_6

Fri 10/21/2016 to Fri 10/21/2016 UPDATED by CONED 09/01/2016

2330 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**320 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 340 MW  
TTC with All Lines In Service 660 MW

## SPRNBRK\_-W49TH\_ST\_345\_M51

Sat 10/22/2016 to Sun 10/23/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## SPRNBRK\_\_345KV\_RNS5

Sat 10/22/2016 to Sun 10/23/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## SPRNBRK\_-W49TH\_ST\_345\_M51

Mon 10/24/2016 to Sat 10/29/2016

0001 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
**3200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## LINDEN\_-GOETHALS\_230\_A2253

Mon 10/24/2016 to Wed 11/02/2016 UPDATED by PJM 05/25/2016

0200 Continuous 1900

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
**2050 MW 1300 MW**  
SCH - PJ - NY  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2050 MW 1300 MW

## WATRCURE-OAKDALE\_\_345\_31

Mon 10/24/2016 to Fri 10/28/2016

0700 Continuous 1600

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
**2050 MW 1300 MW**  
SCH - PJ - NY  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2050 MW 1300 MW



CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N.SCTLND-ALPS_____345_2</b>			FWD	REV
Tue 10/25/2016 to Tue 10/25/2016			(Import)	(Export)
0600	Daily(No Weekends)	1600	SCH - NE - NY	<b>750 MW 1350 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	650 MW 250 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<b>N.SCTLND-ALPS_____345_2</b>			FWD	REV
Tue 10/25/2016 to Tue 10/25/2016			(Import)	(Export)
0600	Daily(No Weekends)	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; NRTH1385-NOR HBR__138_603</b>			FWD	REV
Wed 10/26/2016 to Sat 10/29/2016			(Import)	(Export)
0700		1759	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by: <b>ARR: 78</b>			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-NORTHFLD_345_312 &amp; NRTH1385-NOR HBR__138_603</b>			FWD	REV
Wed 10/26/2016 to Wed 11/09/2016			(Import)	(Export)
0700		1600	SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR__138_603</b>			FWD	REV
Wed 10/26/2016 to Wed 11/09/2016			(Import)	(Export)
0700	Continuous	1600	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>SCH-NE-NYISO_LIMIT_500</b>			FWD	
Sat 10/29/2016 to Sat 11/19/2016			(Import)	
1800	Continuous	1459	SCH - NE - NY	<b>700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_900</b>				REV
Sat 10/29/2016 to Sat 11/19/2016				(Export)
1800	Continuous	1459	SCH - NE - NY	<b>1100 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_\_345KV\_RNS5

FWD

Sat 10/29/2016 to Sat 10/29/2016

(Import)

1830 Continuous 1900

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

FWD

Mon 10/31/2016 to Mon 10/31/2016

(Import)

0001 Continuous 0030

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W90

FWD

Mon 10/31/2016 to Wed 11/02/2016

(Import)

0001 Continuous 2100

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 5100 MW

Work scheduled by: ConEd

### MOSES\_\_-ADIRNDCK\_230\_MA2

FWD

Mon 10/31/2016 to Sat 11/05/2016

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### OAKDALE\_-FRASER\_\_345\_32

FWD

Mon 10/31/2016 to Fri 11/04/2016

(Import)

0830 Continuous 1430

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

### COOPERS\_-ROCKTVRN\_345\_CCRT-42

FWD

Tue 11/01/2016 to Tue 11/15/2016

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2720 MW**

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

### HOMRC\_NY-MAINS\_NY\_345\_47

FWD

REV

Wed 11/02/2016 to Fri 11/04/2016

(Import) (Export)

0600 Continuous 1600

UPDATED

by PJM

07/19/2016

SCH - PJ - NY

**2600 MW 1300 MW**

Impacts Total Transfer Capability 0 MW 0 MW

TTC with All Lines In Service 2600 MW 1300 MW

Work scheduled by: NYSEG

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y87

Wed 11/02/2016 to Wed 11/02/2016  
2030 Continuous 2100

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## MOTTHAVN-RAINEY\_345\_Q11

Sat 11/05/2016 to Mon 11/07/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## LEEDS\_-PLSNTVLY\_345\_92

Mon 11/07/2016 to Wed 12/07/2016 UPDATED by CONED 05/13/2016  
0001 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLY\_345KV\_RNS5

Mon 11/07/2016 to Wed 12/07/2016 UPDATED by CONED 05/13/2016  
0001 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 11/07/2016 to Thu 11/10/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## FIVEMILE-STOLLERD\_345\_29

Mon 11/07/2016 to Mon 11/28/2016  
0700 Continuous 1500

Work scheduled by: NYSEG

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2600 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2600 MW 1300 MW

## PLSNTVLY-WOOD\_ST\_345\_F30

Tue 11/08/2016 to Tue 11/08/2016 UPDATED by CONED 05/13/2016  
0001 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE-MOTTHAVN\_345\_71

Wed 11/09/2016 to Tue 11/15/2016

0001 Continuous 2359

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## BERKSHIR-NORTHFLD\_345\_312 &amp; NRTH1385-NOR HBR\_138\_602

Fri 11/11/2016 to Sat 11/19/2016

0700 1559

Work scheduled by:

FWD

(Import) (Export)

SCH - NPX\_1385

0 MW 0 MW

Impacts Total Transfer Capability 200 MW 200 MW

TTC with All Lines In Service 200 MW 200 MW

## NRTH1385-NOR HBR\_138\_602

Fri 11/11/2016 to Fri 11/25/2016

0700 Continuous 1600

Work scheduled by: LI

FWD

(Import) (Export)

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## BECK\_-NIAGARA\_345\_PA301

Mon 11/14/2016 to Fri 11/18/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - OH - NY

1400 MW 1250 MW

Impacts Total Transfer Capability 500 MW 650 MW

TTC with All Lines In Service 1900 MW 1900 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 11/14/2016 to Sat 11/19/2016

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## BERKSHIR-ALPS\_345\_393

Sat 11/19/2016 to Sat 11/19/2016

1500 Daily 1559

Work scheduled by: NGrid

ARR: 78

FWD

(Import) (Export)

SCH - NE - NY

1300 MW 1300 MW

Impacts Total Transfer Capability 100 MW 300 MW

TTC with All Lines In Service 1400 MW 1600 MW

## BERKSHIR-ALPS\_345\_393

Sat 11/19/2016 to Sat 11/19/2016

1500 Daily 1559

Work scheduled by: NGrid

ARR: 78

FWD

(Import) (Export)

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BERKSHIR-ALPS\_\_\_\_345\_393 & BERKSHIR-NORTHFLD\_345\_312

Sat 11/19/2016 to Sat 11/19/2016  
1500 1559

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	1300 MW	1300 MW
Impacts Total Transfer Capability	100 MW	300 MW
TTC with All Lines In Service	1400 MW	1600 MW

## BERKSHIR-ALPS\_\_\_\_345\_393 & NRTH1385-NOR HBR\_138\_602

Sat 11/19/2016 to Sat 11/19/2016  
1500 1559

Work scheduled by:

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

## SCH-NYISO-NE\_LIMIT\_700

Sat 11/19/2016 to Sat 11/19/2016  
1500 Daily 1559

Work scheduled by: NGrid

	REV
	(Export)
SCH - NE - NY	900 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1600 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/21/2016 to Wed 11/23/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/28/2016 to Fri 12/02/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/05/2016 to Fri 12/09/2016  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## LINDN.CG-LNDVFT\_\_\_\_345\_V-3022

Mon 12/05/2016 to Wed 12/07/2016  
0800 Continuous 1800

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-WOOD\_ST\_\_345\_F30

Tue 12/06/2016 to Tue 12/06/2016 **UPDATED by CONED 05/13/2016**  
0001 Continuous 2359

Work scheduled by: NGrid

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

Thu 12/08/2016 to Fri 12/16/2016  
0600 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
**CENTRAL EAST - VC 2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-N.SCTLND\_345\_18

Thu 12/08/2016 to Fri 12/16/2016  
0600 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
**CENTRAL EAST - VC 2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-N.SCTLND\_345\_18 & ILCTLIMIT MARCY\_SO\_COMP\_I/S

Thu 12/08/2016 to Fri 12/16/2016  
0600 1800

Work scheduled by:

FWD  
(Import)  
**CENTRAL EAST - VC 1855 MW**  
Impacts Total Transfer Capability 1120 MW  
TTC with All Lines In Service 2975 MW

## N.SCTLND-LEEDS\_\_\_\_345\_94

Thu 12/08/2016 to Fri 12/16/2016  
0600 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
**CENTRAL EAST - VC 2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Sun 12/11/2016 to Tue 12/13/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLY\_345KV\_RNS4

Sun 12/11/2016 to Tue 12/13/2016  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/12/2016 to Fri 12/16/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35

Sat 12/17/2016 to Fri 12/30/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/19/2016 to Thu 12/22/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### PLSNTVLY-WOOD\_ST\_\_\_345\_F31

Mon 12/26/2016 to Wed 01/04/2017  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

### PLSNTVLY\_345KV\_RNS4

Mon 12/26/2016 to Wed 01/04/2017  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/26/2016 to Wed 12/28/2016  
0700 Daily 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MAI

Tue 01/03/2017 to Fri 01/06/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 01/09/2017 to Fri 01/13/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MAINESBG-WATRCURE\_345\_30

Mon 01/09/2017 to Fri 02/03/2017

0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 09/01/2016

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2600 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2600 MW 1300 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 01/16/2017 to Fri 01/20/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## PLSNTVLY-WOOD\_ST\_345\_F31

Thu 01/19/2017 to Sat 01/21/2017

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLY\_345KV\_RNS4

Thu 01/19/2017 to Sat 01/21/2017

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 01/23/2017 to Fri 01/27/2017

0700 Continuous 1530

Work scheduled by: NYPA

CANCELLED by NYISO 09/21/2016

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 01/23/2017 to Fri 01/27/2017

0700 Daily 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW



CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Tue 01/24/2017 to Wed 01/25/2017  
0900 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

## PLSNTVLY\_345KV\_RNS4

Tue 01/24/2017 to Wed 01/25/2017  
0900 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 01/30/2017 to Fri 02/03/2017  
0700 Daily 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 01/30/2017 to Fri 02/03/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**CANCELLED by NYISO 09/21/2016**

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## LEEDS\_\_345\_LEEDS SVC

Mon 01/30/2017 to Fri 02/24/2017  
0800 Continuous 1600

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2950 MW**  
Impacts Total Transfer Capability 25 MW  
TTC with All Lines In Service 2975 MW

## LEEDS\_\_345\_LEEDS SVC &amp; ILCTLIMT\_MARCY\_SO\_COMP\_I/S

Mon 01/30/2017 to Fri 02/24/2017  
0800 1600

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2715 MW**  
Impacts Total Transfer Capability 260 MW  
TTC with All Lines In Service 2975 MW

## NRTH1385-NOR HBR\_\_138\_601

Mon 02/06/2017 to Tue 02/07/2017  
0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602

Mon 02/06/2017 to Tue 02/07/2017  
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603

Mon 02/06/2017 to Tue 02/07/2017  
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_602

Mon 02/06/2017 to Tue 02/07/2017  
0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Mon 02/06/2017 to Tue 02/07/2017  
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_603

Mon 02/06/2017 to Tue 02/07/2017  
0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT\_138\_1385

Mon 02/06/2017 to Tue 02/07/2017  
0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 02/06/2017 to Fri 02/10/2017  
0700 Daily 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAl**

FWD

Mon 02/13/2017 to Fri 02/17/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MOSES\_\_\_-ADIRNDCK\_230\_MAl**

FWD

Tue 02/21/2017 to Fri 02/24/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**MARCY\_\_\_-EDIC\_\_\_345\_UE1-7**

FWD

Mon 02/27/2017 to Tue 02/28/2017

(Import)

0600 Continuous 1630

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 16**


---

**MOSES\_\_\_-ADIRNDCK\_230\_MAl**

FWD

Mon 02/27/2017 to Fri 03/03/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

---

**VOLNEY\_\_\_-MARCY\_\_\_345\_19**

FWD

Wed 03/01/2017 to Thu 03/02/2017

(Import)

0600 Continuous 1630

CENTRAL EAST - VC

**2825 MW**

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

---

**VOLNEY\_\_\_-MARCY\_\_\_345\_19**

FWD

Wed 03/01/2017 to Thu 03/02/2017

(Import)

0600 Continuous 1630

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

---

**VOLNEY\_\_\_-MARCY\_\_\_345\_19 & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

FWD

Wed 03/01/2017 to Thu 03/02/2017

(Import)

0600 1630

CENTRAL EAST - VC

**2590 MW**

Impacts Total Transfer Capability 385 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

---

**FITZPTRK-EDIC\_\_\_\_\_345\_FE-1**

FWD

Mon 03/06/2017 to Fri 03/31/2017

(Import)

0600 Continuous 1900

OSWEGO EXPORT

**4800 MW**

Work scheduled by: NGrid

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

---

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 03/06/2017 to Fri 03/10/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/13/2017 to Sat 03/18/2017

(Import)

0700 Daily 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

---

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/20/2017 to Sat 03/25/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

---

**MARCY\_\_\_\_345KV\_STA\_CSC**

FWD

Mon 03/27/2017 to Mon 03/27/2017

(Import)

0500 Continuous 1630

CENTRAL EAST - VC

**2925 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2975 MW

---

**MARCY\_\_\_\_345KV\_STA\_CSC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S**

FWD

Mon 03/27/2017 to Mon 03/27/2017

(Import)

0500 1630

CENTRAL EAST - VC

**2690 MW**

Work scheduled by:

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 2975 MW

---

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Mon 03/27/2017 to Sat 04/01/2017

(Import)

0700 Daily 1530

MOSES SOUTH

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 04/03/2017 to Sat 04/08/2017  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### COOPERS\_-ROCKTVRN\_345\_CCRT-42

Mon 04/10/2017 to Mon 04/24/2017  
0630 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 04/10/2017 to Thu 04/13/2017  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### MARCY\_\_\_345KV\_STA\_CSC

Wed 04/12/2017 to Thu 04/13/2017  
0500 Continuous 1630  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

### MARCY\_\_\_345KV\_STA\_CSC & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Wed 04/12/2017 to Thu 04/13/2017  
0500 1630  
Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

### MARION\_-FARRAGUT\_345\_C3403

Sun 04/16/2017 to Mon 05/15/2017 UPDATED by PJM 04/13/2016  
0001 Continuous 2359  
Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2600 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2600 MW 1300 MW

### MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 04/17/2017 to Sat 04/22/2017  
0700 Daily 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Mon 04/24/2017 to Tue 04/25/2017  
0630 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### STLAWRNC-MOSES\_\_\_\_230\_L34P

Mon 04/24/2017 to Fri 04/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **1750 MW 1750 MW**  
Impacts Total Transfer Capability 150 MW 150 MW  
TTC with All Lines In Service 1900 MW 1900 MW

### MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

Mon 04/24/2017 to Sat 04/29/2017  
0700 Daily 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### BROWNFLS-TAYLORVL\_115\_3

Mon 05/01/2017 to Fri 05/26/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

### PANNELL\_-CLAY\_\_\_\_345\_2

Mon 05/01/2017 to Fri 05/05/2017  
0630 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### ROSETON\_-ROCKTVRN\_345\_311

Mon 05/08/2017 to Fri 05/26/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

### FRASER\_\_\_\_-GILBOA\_\_\_\_345\_GF5-35

Mon 05/15/2017 to Fri 05/19/2017  
0630 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Tue 05/30/2017 to Sat 06/24/2017				(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 06/26/2017 to Sat 07/01/2017				(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Wed 07/05/2017 to Sat 07/22/2017				(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 07/24/2017 to Sat 08/19/2017				(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 08/21/2017 to Fri 09/01/2017				(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Tue 09/05/2017 to Sat 09/16/2017				(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service	190 MW 40 MW
<b>HURLYAVE-ROSETON__345_303</b>				FWD	
Mon 09/11/2017 to Fri 09/29/2017				(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BROWNFLS-TAYLORVL\_115\_4**

Mon 09/18/2017 to Fri 10/13/2017  
0600 Continuous 1600

Work scheduled by: NGrid

**ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

**GILBOA\_\_-N.SCTLND\_345\_GNS-1**

Mon 09/18/2017 to Fri 10/06/2017  
0630 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2520 MW</b>
Impacts Total Transfer Capability	455 MW
TTC with All Lines In Service	2975 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1550 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MARCY\_\_\_\_765\_345\_AT1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1750 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

**MARCY\_\_\_\_765\_345\_AT2**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**MASSENA\_-MARCY\_\_\_\_765\_MSU1**

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 20**

	FWD
	(Import)
CENTRAL EAST - VC	<b>2265 MW</b>
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 20

FWD  
(Import)  
MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 20

FWD REV  
(Import) (Export)  
SCH - HQ - NY 475 MW 1000 MW  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

ARR: 20

FWD  
(Import)  
MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_765\_MSU1 & ILCTLINT\_MARCY\_SO\_COMP\_I/S

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

ARR: 20

FWD  
(Import)  
CENTRAL EAST - VC 2080 MW  
Impacts Total Transfer Capability 895 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

ARR: 20

FWD REV  
(Import) (Export)  
SCH - HQ - NY 850 MW 0 MW  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## LEEDS\_-HURLYAVE\_345\_301

Mon 10/16/2017 to Fri 11/03/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## BROWNFLS-TAYLORVL\_115\_3

Mon 10/30/2017 to Sat 11/11/2017  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 09/01/2016

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 70 MW 40 MW  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,September22, 2016 to Saturday ,March 24, 2018

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BROWNFLS-TAYLORVL\_115\_4

Mon 11/13/2017 to Thu 11/30/2017 UPDATED by NGRID 08/25/2016  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD REV  
(Import) (Export)

100 MW 100 MW

99 MW 0 MW

199 MW 100 MW

### MOSES-ADIRNDCK\_230\_MA1

Mon 12/04/2017 to Fri 12/08/2017  
0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2300 MW

850 MW

3150 MW

### MOSES-ADIRNDCK\_230\_MA2

Mon 12/11/2017 to Fri 12/15/2017  
0700 Daily 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2300 MW

850 MW

3150 MW

### MOSES-ADIRNDCK\_230\_MA2

Mon 12/18/2017 to Fri 12/22/2017  
0700 Daily 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD  
(Import)

2300 MW

850 MW

3150 MW