

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>RAMAPO___345_345_PAR3500</b>							
Fri 06/24/2016	to	Thu 06/01/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	SCH - PJ - NY	<b>2200 MW</b>
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>						FWD	
Sun 10/30/2016	to	Sat 04/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	(Import)	
0728	Continuous	2359				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>						FWD	
Thu 11/24/2016	to	Mon 05/01/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	(Import)	
1500	Continuous	2359				SCH - PJM_HTP	<b>0 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
<b>FRASER___345_FRASER SVC</b>						FWD	
Thu 12/08/2016	to	Sat 01/28/2017	<u>EXT FORCE</u>	<u>by NY</u>	<u>01/27/2017</u>	(Import)	
0001	Continuous	2359				CENTRAL EAST - VC	<b>2935 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	40 MW
						TTC with All Lines In Service	2975 MW
<b>E13THSTA-FARRAGUT_345_46</b>						FWD	
Tue 12/20/2016	to	Mon 04/10/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>	(Import)	
0001	Continuous	2300				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>W49TH_ST-E13THSTA_345_M55</b>						FWD	
Tue 12/20/2016	to	Mon 04/10/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>01/27/2017</u>	(Import)	
0001	Continuous	2300				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>FITZPTRK-EDIC___345_FE-1</b>						FWD	
Sat 01/14/2017	to	Tue 02/07/2017	<u>UPDATED</u>	<u>by PA</u>	<u>01/05/2017</u>	(Import)	
0200	Continuous	1200				CENTRAL EAST - VC	<b>2825 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC_____345_FE-1</b>					FWD	
Sat 01/14/2017	to	Tue 02/07/2017	<u>UPDATED</u>	<u>by PA</u>	<u>01/05/2017</u>	(Import)
0200	Continuous	1200				
Work scheduled by: NYPA					OSWEGO EXPORT	<b>4800 MW</b>
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	5250 MW
<b>SCH-IMO-NYISO_LIMIT_1200</b>					FWD	
Thu 01/19/2017	to	Tue 02/21/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>01/13/2017</u>	(Import)
1900	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	<b>1500 MW</b>
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1750 MW
<b>FROST_BR-LONG_MTN_345_352</b>					FWD	REV
Fri 01/20/2017	to	Sat 01/28/2017			(Import)	(Export)
0700	Continuous	1600				
Work scheduled by: ISONE					SCH - NE - NY	<b>1300 MW 1600 MW</b>
					Impacts Total Transfer Capability	100 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>SCH-NE-NYISO_LIMIT_900</b>					FWD	
Fri 01/20/2017	to	Sat 01/28/2017			(Import)	
0700	Continuous	1600				
Work scheduled by: ISONE					SCH - NE - NY	<b>1100 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1400 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD	
Mon 01/23/2017	to	Fri 01/27/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					MOSES SOUTH	<b>2300 MW</b>
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>BULYMO__-BOONVILLE_115_6</b>					FWD	REV
Fri 01/27/2017	to	Fri 01/27/2017			(Import)	(Export)
0700	Daily(No Weekends)	1700				
Work scheduled by: NGrid					SCH - HQ_CEDARS	<b>199 MW 100 MW</b>
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<b>ROTTDAM-EASTOVER_230_38</b>					FWD	REV
Fri 01/27/2017	to	Fri 01/27/2017	<u>FORCED</u>	<u>by NGRID</u>	<u>01/26/2017</u>	(Import)
0700	Daily(No Weekends)	2000				(Export)
Work scheduled by: NGrid					SCH - NE - NY	<b>1400 MW 1400 MW</b>
					Impacts Total Transfer Capability	0 MW 200 MW
					TTC with All Lines In Service	1400 MW 1600 MW

ARR: 38

ARR: 77

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES____-ADIRNDCK_230_MA2</b>						FWD	
Mon 01/30/2017	to	Fri 02/03/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)	
0700	Continuous	1530				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>LEEDS____345_LEEDS SVC</b>						FWD	
Mon 01/30/2017	to	Fri 02/24/2017				(Import)	
0800	Continuous	1600				CENTRAL EAST - VC	<b>2950 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	25 MW
						TTC with All Lines In Service	2975 MW
<b>CHAT_DC_GC1</b>						FWD	
Mon 01/30/2017	to	Wed 02/01/2017	<u>FORCED</u>	<u>by HQ</u>	<u>01/31/2017</u>	(Import)	
2002	Continuous	1800				MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>						REV	
Mon 01/30/2017	to	Wed 02/01/2017	<u>FORCED</u>	<u>by HQ</u>	<u>01/31/2017</u>	(Export)	
2002	Continuous	1800				SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
<b>BERKSHIR-ALPS____345_393</b>						FWD	REV
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>	(Import)	(Export)
0800	Continuous	1700				SCH - NE - NY	<b>1300 MW 1300 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW 300 MW
						TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-ALPS____345_393</b>						FWD	REV
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>	(Import)	(Export)
0800	Continuous	1700				SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
<b>N.SCTLND-ALPS____345_2</b>						FWD	REV
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>	(Import)	(Export)
0800	Continuous	1700				SCH - NE - NY	<b>900 MW 1600 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	500 MW 0 MW
						TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>N.SCTLND-ALPS_____345_2</b>							
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>	SCH - NPX_1385	<b>100 MW</b>
0800	Continuous	1700				Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
<b>SCH-NYISO-NE_LIMIT_600</b>							REV
Thu 02/02/2017	to	Thu 02/02/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>01/31/2017</u>	SCH - NE - NY	<b>800 MW</b>
0800	Continuous	1700				Impacts Total Transfer Capability	800 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1600 MW
<b>MARCY_____765_345_AT2</b>						FWD	
Sat 02/04/2017	to	Sat 02/04/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/01/2017</u>	MOSES SOUTH	<b>1700 MW</b>
0500	Continuous	1530				Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<b>MOSES____-ADIRNDCK_230_MA2</b>						FWD	
Mon 02/06/2017	to	Fri 02/10/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530				Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW
<b>NRTH1385-NOR HBR__138_601</b>						FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017		<u>by LI</u>	<u>01/11/2017</u>	SCH - NPX_1385	<b>100 MW</b>
0700	Continuous	2359				Impacts Total Transfer Capability	100 MW
Work scheduled by: LI						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>						FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017				SCH - NPX_1385	<b>0 MW</b>
0700		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>						FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017				SCH - NPX_1385	<b>0 MW</b>
0700		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	(Import)	(Export)
0700	Continuous	2359			SCH - NPX_1385	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017			(Import)	(Export)
0700		2359			SCH - NPX_1385	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR__138_603					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	(Import)	(Export)
0700	Continuous	2359			SCH - NPX_1385	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_1385					FWD	REV
Mon 02/06/2017	to	Sat 02/25/2017	<u>by LI</u>	<u>01/11/2017</u>	(Import)	(Export)
0700	Continuous	2359			SCH - NPX_1385	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
LEEDS__345_LEEDS SVC & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Tue 02/07/2017	to	Fri 02/24/2017			(Import)	
1300		1600			CENTRAL EAST - VC	2715 MW
Work scheduled by:					Impacts Total Transfer Capability	260 MW
					TTC with All Lines In Service	2975 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Tue 02/07/2017	to	Mon 03/06/2017			(Import)	
1300	Continuous	0559			CENTRAL EAST - VC	2740 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
CHAT_DC_GC1					FWD	
Wed 02/08/2017	to	Thu 02/09/2017	<u>CANCELLED</u>	<u>by HQ</u>	(Import)	
2000	Continuous	0600		<u>02/01/2017</u>	MOSES SOUTH	2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC1**

REV

Wed 02/08/2017 to Thu 02/09/2017  
2000 Continuous 0600

**CANCELLED by HQ 02/01/2017**

(Export)

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

**BROWNFLS-TAYLORVL\_115\_4**

FWD

REV

Sat 02/11/2017 to Sat 02/11/2017  
0600 Daily 1900

(Import) (Export)

Work scheduled by: NGrid

**ARR: 38**

SCH - HQ\_CEDARS

**100 MW 100 MW**

Impacts Total Transfer Capability

99 MW 0 MW

TTC with All Lines In Service

199 MW 100 MW

**BECK\_\_\_\_-NIAGARA\_345\_PA302**

FWD

REV

Mon 02/13/2017 to Mon 02/13/2017  
0400 Continuous 1700

(Import) (Export)

Work scheduled by: IESO

SCH - OH - NY

**1100 MW 950 MW**

Impacts Total Transfer Capability

650 MW 950 MW

TTC with All Lines In Service

1750 MW 1900 MW

**GILBOA\_\_\_\_-LEEDS\_\_\_\_345\_GL3**

FWD

Mon 02/13/2017 to Tue 02/14/2017  
0600 Continuous 1600

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC

**2200 MW**

Impacts Total Transfer Capability

775 MW

TTC with All Lines In Service

2975 MW

**LEEDS\_\_\_\_345KV\_R395**

FWD

Mon 02/13/2017 to Tue 02/14/2017  
0600 Continuous 1600

(Import)

Work scheduled by: NGrid

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability

1300 MW

TTC with All Lines In Service

5100 MW

**MOSES\_\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Mon 02/13/2017 to Fri 02/17/2017  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

**BROWNFLS-TAYLORVL\_115\_3**

FWD

REV

Sat 02/18/2017 to Sat 02/18/2017  
0600 Daily 1900

(Import) (Export)

Work scheduled by: NGrid

**ARR: 38**

SCH - HQ\_CEDARS

**100 MW 100 MW**

Impacts Total Transfer Capability

99 MW 0 MW

TTC with All Lines In Service

199 MW 100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BECK\_\_\_\_-NIAGARA\_\_230\_PA27

Tue 02/21/2017 to Sat 02/25/2017  
0645 Continuous 1700

Work scheduled by: IESO

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1750 MW	1900 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	1750 MW	1900 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Tue 02/21/2017 to Fri 02/24/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## BROWNFLS-TAYLORVL\_115\_4

Sat 02/25/2017 to Sat 02/25/2017  
0600 Daily 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	100 MW
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 02/27/2017 to Fri 03/03/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## COOPERS\_-ROCKTVRN\_345\_CCRT-42

Wed 03/01/2017 to Wed 03/15/2017  
0500 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2720 MW
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

## BROWNFLS-TAYLORVL\_115\_3

Sat 03/04/2017 to Sat 03/04/2017  
0600 Daily 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	100 MW
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

## W49TH\_ST\_345KV\_8

Mon 03/06/2017 to Sat 03/11/2017  
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 01/27/2017

	FWD
	(Import)
SCH - PJM_HTP	315 MW
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EDIC - FRASER 345 EF24-40

Mon 03/06/2017 to Fri 03/17/2017  
0630 Continuous 1700

Work scheduled by: NYPA

UPDATED by NY 12/02/2016

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## MOSES - ADIRNDCK 230 MA1

Mon 03/06/2017 to Fri 03/10/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## BROWNFLS-TAYLORVL 115\_4

Sat 03/11/2017 to Sat 03/11/2017  
0600 Daily 1900

Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **100 MW 100 MW**  
Impacts Total Transfer Capability 99 MW 0 MW  
TTC with All Lines In Service 199 MW 100 MW

## NIAGARA - ROCHESTR 345 NR2

Mon 03/13/2017 to Wed 03/15/2017  
0500 Continuous 1900

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

## BECK - NIAGARA 345 PA302

Mon 03/13/2017 to Fri 03/17/2017  
0700 Continuous 1600

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY **1100 MW 950 MW**  
Impacts Total Transfer Capability 650 MW 950 MW  
TTC with All Lines In Service 1750 MW 1900 MW

## MOSES - ADIRNDCK 230 MA2

Mon 03/13/2017 to Sat 03/18/2017  
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## MILLWOOD 345KV\_18

Tue 03/14/2017 to Fri 03/17/2017  
0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

ILCTLIMIT MARCY_SO_COMP_I/S					FWD	
Fri 03/17/2017	to	Mon 03/20/2017			(Import)	
1700	Continuous	0559		CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW	
				TTC with All Lines In Service	2975 MW	
LADENTWN-BUCHAN_S_345_Y88					FWD	
Sat 03/18/2017	to	Mon 03/20/2017			(Import)	
0001	Continuous	2359		UPNY CONED	4150 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	950 MW	
				TTC with All Lines In Service	5100 MW	
NINEMILE-CLAY_____345_8					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>01/25/2017</u>	
0001	Continuous	0400			OSWEGO EXPORT	
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW	
				TTC with All Lines In Service	5250 MW	
FRASANNX-COOPERS__345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/27/2016</u>	
0600	Continuous	1630			CENTRAL EAST - VC	
Work scheduled by: NYPA				Impacts Total Transfer Capability	475 MW	
				TTC with All Lines In Service	2975 MW	
MARCY____-FRASANNX_345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/27/2016</u>	
0600	Continuous	1630			CENTRAL EAST - VC	
Work scheduled by: NYPA				Impacts Total Transfer Capability	475 MW	
				TTC with All Lines In Service	2975 MW	
MOSES____-ADIRNDCK_230_MA2					FWD	
Mon 03/20/2017	to	Sat 03/25/2017			(Import)	
0700	Continuous	1530		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	
BERKSHIR-ALPS_____345_393					FWD	
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NG</u>	<u>12/27/2016</u>	
0800	Daily(No Weekends)	0900			SCH - NE - NY	
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW	
				TTC with All Lines In Service	1400 MW	
					REV	
					(Import) (Export)	
					1300 MW 1300 MW	
					300 MW	
					1600 MW	

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS_____345_393</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NG</u>	<u>12/27/2016</u>	(Import) (Export)
0800	Daily(No Weekends)	0900				
Work scheduled by: NGrid					ARR: 78	
					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017				(Import) (Export)
0800		0900				
Work scheduled by:					ARR: 78	
					SCH - NE - NY	<b>1300 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				
Work scheduled by: ISONE						
					SCH - NE - NY	<b>1400 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017				(Import) (Export)
0800	Continuous	1600				
Work scheduled by: ISONE						
					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>ILCTLIMIT_MARCY_SO_COMP_I/S</b>					FWD	
Fri 03/24/2017	to	Mon 04/17/2017				(Import)
1700	Continuous	0900				
Work scheduled by: NYISO						
					CENTRAL EAST - VC	<b>2740 MW</b>
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY_____345KV_CSC</b>					FWD	
Mon 03/27/2017	to	Thu 04/13/2017				(Import)
0500	Continuous	1630				
Work scheduled by: NYPA						
					CENTRAL EAST - VC	<b>2925 MW</b>
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY_____345KV_CSC &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b>					FWD	
Mon 03/27/2017	to	Thu 04/13/2017				(Import)
0500		1630				
Work scheduled by:						
					CENTRAL EAST - VC	<b>2690 MW</b>
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 03/27/2017 to Sat 04/01/2017 UPDATED by NYPA 10/23/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35

Mon 03/27/2017 to Fri 04/07/2017  
0900 Continuous 1430

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Sun 04/02/2017 to Fri 04/07/2017  
1400 Continuous 1800

Work scheduled by: PJM

FWD	REV
(Import)	(Export)
SCH - PJM_VFT <b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability 315 MW	315 MW
TTC with All Lines In Service 315 MW	315 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 04/03/2017 to Sat 04/08/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Mon 04/03/2017 to Fri 04/14/2017 UPDATED by PJM 01/26/2017  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD	REV
(Import)	(Export)
SCH - PJ - NY <b>2300 MW</b>	<b>1450 MW</b>
Impacts Total Transfer Capability 0 MW	0 MW
TTC with All Lines In Service 2300 MW	1450 MW

## MAINESBG-WATRCURE\_345\_30

Mon 04/03/2017 to Fri 04/14/2017 UPDATED by PJM 01/26/2017  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD	REV
(Import)	(Export)
SCH - PJ - NY <b>2200 MW</b>	<b>1450 MW</b>
Impacts Total Transfer Capability 100 MW	0 MW
TTC with All Lines In Service 2300 MW	1450 MW

## W49TH\_ST\_345KV\_6

Wed 04/05/2017 to Sun 04/09/2017 UPDATED by CONED 01/27/2017  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## COOPERS\_-ROCKTVRN\_345\_CCRT-42

Mon 04/10/2017 to Mon 04/24/2017  
0630 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_-ADIRNDCK\_230\_MAI

Mon 04/10/2017 to Thu 04/13/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## W49TH\_ST\_345KV\_6

Mon 04/10/2017 to Mon 04/10/2017 UPDATED by CONED 01/27/2017  
2230 Continuous 2300

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 04/17/2017 to Sat 04/22/2017  
0500 Continuous 1600

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## MOSES\_-ADIRNDCK\_230\_MA2

Mon 04/17/2017 to Sat 04/22/2017 UPDATED by NYPA 10/23/2016  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## FRASER\_-COOPERS\_345\_33

Mon 04/17/2017 to Fri 04/21/2017 UPDATED by NY 01/12/2017  
0900 Continuous 1400

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2395 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 2975 MW

## MARION\_-FARRAGUT\_345\_C3403

Fri 04/21/2017 to Sat 05/20/2017 UPDATED by CE 01/28/2017  
0001 Continuous 2359

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2300 MW 1450 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2300 MW 1450 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 04/21/2017 to Mon 11/06/2017				(Import)	
1400	Continuous	0559		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
BERKSHIR-ALPS 345_393				FWD	REV
Sat 04/22/2017 to Sat 04/22/2017				(Import)	(Export)
1500	Daily	1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 300 MW
ARR: 78				TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS 345_393				FWD	REV
Sat 04/22/2017 to Sat 04/22/2017				(Import)	(Export)
1500	Daily	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
ARR: 78				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD_345_312				FWD	REV
Sat 04/22/2017 to Sat 04/22/2017				(Import)	(Export)
1500		1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:				Impacts Total Transfer Capability	100 MW 300 MW
ARR: 78				TTC with All Lines In Service	1400 MW 1600 MW
CLAY -EDIC 345_1-16				FWD	
Mon 04/24/2017 to Tue 04/25/2017				(Import)	
0630	Continuous	1530		OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
STLAWRNC-MOSES 230_L34P				FWD	REV
Mon 04/24/2017 to Fri 04/28/2017				(Import)	(Export)
0700	Continuous	1530		SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	1750 MW 1900 MW
MOSES -ADIRNDCK_230_MA2				FWD	
Mon 04/24/2017 to Sat 04/29/2017				(Import)	
0700	Continuous	1530	UPDATED by NYPA 10/23/2016	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE_345_138_BK_1</b>						FWD
Wed 04/26/2017	to	Sun 04/30/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>						FWD
Wed 04/26/2017	to	Sun 04/30/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	2359				SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 285 MW
						TTC with All Lines In Service 660 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>						FWD
Wed 04/26/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	1800				SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>						FWD
Wed 04/26/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>01/31/2017</u>	(Import)
0001	Continuous	1800				SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
<b>NIAGARA_-ROCHESTR_345_NR2</b>						FWD
Fri 04/28/2017	to	Fri 04/28/2017				(Import)
0700	Continuous	1530				DYSINGER EAST <b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW
<b>MARCY_-N.SCTLND_345_18</b>						FWD
Mon 05/01/2017	to	Fri 05/05/2017				(Import)
0600	Continuous	1630				CENTRAL EAST - VC <b>2090 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 885 MW
						TTC with All Lines In Service 2975 MW
<b>MARCY_-N.SCTLND_345_18 &amp; ILCTLIMIT_MARCY_SO_COMP_I/S</b>						FWD
Mon 05/01/2017	to	Fri 05/05/2017				(Import)
0600		1630				CENTRAL EAST - VC <b>1855 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 1120 MW
						TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BROWNFLS-TAYLORVL\_115\_3

Mon 05/01/2017 to Fri 05/26/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## PANNELL -CLAY\_345\_2

Mon 05/01/2017 to Fri 05/05/2017  
0630 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

## ROCHESTR-PANNELL\_345\_RP2

Mon 05/08/2017 to Wed 05/10/2017  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## ROSETON -ROCKTVRN\_345\_311

Mon 05/08/2017 to Fri 05/26/2017  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4400 MW
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	5100 MW

## FRASER -GILBOA\_345\_GF5-35

Mon 05/15/2017 to Fri 05/19/2017  
0630 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

## FRASER\_345\_FRASER SVC

Mon 05/15/2017 to Fri 05/19/2017  
0900 Continuous 1430

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2935 MW
Impacts Total Transfer Capability	40 MW
TTC with All Lines In Service	2975 MW

## FRASER\_345\_FRASER SVC &amp; ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Mon 05/15/2017 to Fri 05/19/2017  
0900 1430

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	2700 MW
Impacts Total Transfer Capability	275 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## RAMAPO\_\_-LADENTWN\_345\_W72

Tue 05/16/2017 to Tue 05/16/2017  
0001 Continuous 2330  
Work scheduled by: ORU

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

## MARCY\_\_\_\_765\_345\_AT1

Mon 05/22/2017 to Fri 05/26/2017  
0500 Continuous 1630  
Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

## LINDEN\_\_-GOETHALS\_230\_A2253

Fri 05/26/2017 to Sat 05/27/2017  
0001 Continuous 2359  
Work scheduled by: PJM

UPDATED by CE 02/01/2017

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2050 MW 1300 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2050 MW 1300 MW

## MARCY\_\_-N.SCTLND\_345\_18

Sat 05/27/2017 to Sat 05/27/2017  
0500 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

## MARCY\_\_-N.SCTLND\_345\_18 & ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Sat 05/27/2017 to Sat 05/27/2017  
0500 1530  
Work scheduled by:

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1855 MW**  
Impacts Total Transfer Capability 1120 MW  
TTC with All Lines In Service 2975 MW

## BROWNFLS-TAYLORVL\_115\_4

Tue 05/30/2017 to Sat 06/24/2017  
0600 Continuous 1900  
Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

## BROWNFLS-TAYLORVL\_115\_3

Mon 06/26/2017 to Sat 07/01/2017  
0600 Continuous 1900  
Work scheduled by: NGrid

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BROWNFLS-TAYLORVL\_115\_3

Wed 07/05/2017 to Sat 07/22/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## BROWNFLS-TAYLORVL\_115\_4

Mon 07/24/2017 to Sat 08/19/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## MARCY\_\_\_-N.SCTLND\_345\_18

Sat 08/05/2017 to Sat 08/05/2017  
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	<b>2090 MW</b>
Impacts Total Transfer Capability	885 MW
TTC with All Lines In Service	2975 MW

## MARCY\_\_\_-N.SCTLND\_345\_18 &amp; ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Sat 08/05/2017 to Sat 08/05/2017  
0500 1530

Work scheduled by:

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	<b>1855 MW</b>
Impacts Total Transfer Capability	1120 MW
TTC with All Lines In Service	2975 MW

## MARCY\_\_\_765\_345\_AT2

Sat 08/05/2017 to Sat 08/05/2017  
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

## BROWNFLS-TAYLORVL\_115\_3

Mon 08/21/2017 to Fri 09/01/2017  
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

## MARCY\_\_\_765\_345\_AT2

Tue 09/05/2017 to Sun 09/10/2017  
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Tue 09/05/2017 to Sat 09/16/2017				(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
<b>HURLYAVE-ROSETON_345_303</b>				FWD	
Mon 09/11/2017 to Fri 09/29/2017				(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
<b>SPRNBRK_-DUNWODIE_345_W75</b>				FWD	
Fri 09/15/2017 to Sun 09/17/2017				(Import)	
2200	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK_345KV_RNS3</b>				FWD	
Fri 09/15/2017 to Sun 09/17/2017				(Import)	
2200	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 09/18/2017 to Fri 10/13/2017				(Import)	(Export)
0600	Continuous	1600		SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38				TTC with All Lines In Service	190 MW 40 MW
<b>GILBOA_-N.SCTLND_345_GNS-1</b>				FWD	
Mon 09/18/2017 to Fri 10/06/2017				(Import)	
0630	Continuous	1700		CENTRAL EAST - VC	<b>2520 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW
<b>NIAGARA_345_230_AT4</b>				FWD	REV
Mon 09/18/2017 to Tue 09/19/2017				(Import)	(Export)
0700	Continuous	1530		SCH - OH - NY	<b>1750 MW</b> <b>1300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 300 MW
				TTC with All Lines In Service	1750 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/25/2017 to Fri 09/29/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-ROCHESTR\_345\_NR2

Mon 10/02/2017 to Fri 10/06/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

REV

(Import) (Export)

SCH - HQ - NY **0 MW 0 MW**

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## MARCY\_765\_345\_AT1

Sat 10/14/2017 to Sat 10/28/2017

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH **1750 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 3150 MW

## MARCY\_765\_345\_AT2

Sat 10/14/2017 to Sat 10/28/2017

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH **1700 MW**

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/14/2017 to Sat 10/28/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2265 MW**

Impacts Total Transfer Capability 710 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_765\_MSU1

Sat 10/14/2017 to Sat 10/28/2017  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY 475 MW 1000 MW  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_-MARCY\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_765\_MSU1 & ILCTLINT\_MARCY\_SO\_COMP\_I/S

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC 2080 MW  
Impacts Total Transfer Capability 895 MW  
TTC with All Lines In Service 2975 MW

## MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 10/14/2017 to Sat 10/28/2017  
0700 1530

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY 850 MW 0 MW  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## LEEDS\_-HURLYAVE\_345\_301

Mon 10/16/2017 to Fri 11/03/2017  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED 4100 MW  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW

## BROWNFLS-TAYLORVL\_115\_3

Mon 10/30/2017 to Sat 11/11/2017  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 09/01/2016

ARR: 38

FWD REV  
(Import) (Export)  
SCH - HQ\_CEDARS 70 MW 40 MW  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 5100MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017

0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_-FRASANNX\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017

0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC

2500 MW

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

## BROWNFLS-TAYLORVL\_115\_4

Mon 11/13/2017 to Thu 11/30/2017

0600 Continuous 1900

Work scheduled by: NGrid

UPDATEDby NGRID 08/25/2016

ARR: 38

FWD

(Import) (Export)

SCH - HQ\_CEDARS

100 MW 100 MW

Impacts Total Transfer Capability 99 MW 0 MW

TTC with All Lines In Service 199 MW 100 MW

## ILCTLIMIT\_MARCY\_SO\_COMP\_I/S

Fri 11/17/2017 to Sat 02/01/2020

1700 Continuous 0000

Work scheduled by: NYISO

FWD

(Import)

CENTRAL EAST - VC

2740 MW

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 2975 MW

## MARCY\_\_765\_345\_AT2

Mon 12/04/2017 to Fri 12/08/2017

0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

MOSES SOUTH

1700 MW

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 12/11/2017 to Fri 12/15/2017

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 12/18/2017 to Fri 12/22/2017

0700 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA 10/23/2016

FWD

(Import)

MOSES SOUTH

2300 MW

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, February 01, 2017 to Friday , August 03, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_\_\_-ADIRNDCK\_230\_MA2

FWD

Tue 12/26/2017 to Thu 12/28/2017

( Import )

0700 Continuous 1530

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA